



August 6, 2021

Phillips 66
2518 W 10th St
Indianapolis, IN 46222

RE: UST Testing/Inspection Results

Testing Performed:

Elec Line Leak Detector, Product Line Testing

Testing Date: 8/6/2021

Location of Test: Phillips 66
2518 W 10th St
Indianapolis, IN 46222

We have completed the testing and/or inspections for the above location as per your request.

A summary of testing results along with copies of the testing/inspections have been enclosed for your records.

If you should have any questions after your review of the results, please let us know.

Thank you for your continued business.

Sincerely,

Larry A. Gentry
Director of Operations & Business Development

Enclosures



UST TESTING/INSPECTION RESULTS SUMMARY

OWNER NAME: Phillips 66
 OWNER ADDRESS: 2518 W 10th St
 OWNER CITY/STATE/ZIP: Indianapolis, IN 46222

LOCATION NAME: Phillips 66
 LOCATION ADDRESS: 2518 W 10th St
 LOCATION CITY/STATE: Indianapolis, IN 46222

TESTING DATE: 8/6/2021

ANNUAL TESTING/INSPECTIONS

AUTOMATIC TANK GAUGE TEST NOT PERFORMED

TANK NO	PRODUCT	BRAND/MODEL	RESULT

PRODUCT LINE TEST COMPLETED

Product line must be within manufacturer's criteria of +/- .050 GPH.

LINE NO	PRODUCT	RESULT	GPH
#1	REGULAR	PASS	0
#2	PREMIUM	PASS	0

LEAK DETECTOR TEST COMPLETED

PUMP NO	PRODUCT	MAKE	RESULT
	REGULAR	FE PETRO	PASS
	PREMIUM	FE PETRO	PASS

LIQUID SENSOR FUNCTIONALITY TEST NOT PERFORMED

LOCATION	PRODUCT	TYPE	RESULT

UPON REQUEST TESTING/INSPECTIONS

NON-VOLUMETRIC TANK TEST NOT PERFORMED

LOCATION	VOLUME	PRODUCT	RESULT

SHEAR VALVE OPERATION INSPECTION NOT PERFORMED

DISPENSER	PRODUCT	TYPE	RESULT

THREE YEAR TESTS/INSPECTIONS

SPILL BUCKET INTERGRITY TESTING NOT PERFORMED

TANK NO	PRODUCT	CONSTRUCTION	RESULT

HYDROSTATIC SUMP TEST NOT PERFORMED

SUMP ID	MATERIAL	DEPTH	RESULT

OVERFILL EQUIPMENT INSPECTION NOT PERFORMED

TANK	PRODUCT	TYPE	RESULT

OVERFILL ALARM TEST NOT PERFORMED

TANK	PRODUCT	BRAND/MODEL	RESULT

VENT CAP TEST NOT PERFORMED

VALVE ID	MANUFACTURER	MODEL #	RESULT

INTERSTITIAL TEST NOT PERFORMED

PRODUCT	LINE #	READING	RESULT

CATHODIC PROTECTION TEST NOT PERFORMED

	PRODUCT	RESULT	



ELECTRONIC LINE LEAK DETECTOR TEST RESULTS

Certified Presion Tank & Line Testing Monthly Monitoring * Stage - 2 Testing

DATE OF TEST: 8/6/2021

TECHNICIAN SIGNATURE: *Patricia Foley*

LOCATION ADDRESS:
Phillips 66
2518 W 10th St
Indianapolis, IN 46222

TECHNICIAN CERT #: 02-9389

PRODUCT TESTED	MAKE	PASS/FAIL
REGULAR	FEPETRO	PASS
PREMIUM	FEPETRO	PASS

NOTES:

