

PETROLEUM TESTING SERVICES, LLC
PO BOX 146
YORKTOWN, IN 47396
765-749-5540 EMAIL: petroleumtesting@aol.com

SITE: MONROEVILLE 66
ADDRESS: 121 W SOUTH ST
CITY/ST/ZIP: MONROEVILLE, IN 46773
DATE: 6/24/2022 TIME: 2:00P

OVERFILL TEST

	1	2	3	4	5
PRODUCT	UNL	PREM	DSL		
TYPE OF OVERFILL	AUTO	AUTO	AUTO		
TANK SIZE	7896	6016	6016		
TANK DIAMETER	96	96	96		
RISER LENGTH	44	44	44		
TOP OF RISER TO OVERFILL	56	56	56		
OVERFILL FROM TANK BOTTOM	84	84	84		
OVERFILL IS SET AT 95% OR LESS?	YES	YES	YES		
RESULT	PASS	PASS	PASS		

COMMENTS: ball floats removed.

TECHNICIAN: JOHN LANNOM

CERTIFICATION

UC20129333