

Poon, Peter

From: Yahoo Mail <btcwater1@yahoo.com>
Sent: Wednesday, July 3, 2024 10:13 AM
To: Poon, Peter
Subject: Monthly Report of Operations for June 2024
Attachments: doc06000420240703091001.pdf

**** This is an EXTERNAL email. Exercise caution. DO NOT open attachments or click links from unknown senders or unexpected email. ****

Hi Peter,

Below is our MRO for June 2024,

Thanks

Daryl Naville
Manager
BTC Water Co.

----- Forwarded Message -----

From: "btcwaterscan@gmail.com" <btcwaterscan@gmail.com>
To: "btcwater1@yahoo.com" <btcwater1@yahoo.com>
Sent: Wednesday, July 3, 2024 at 10:10:54 AM EDT
Subject:

SENT FROM COPIER
DO NOT REPLY



11110C 17 0.0



IE/LT1 SWTR COMBINED FILTER EFFLUENT TURBIDITY

State Form 53294 (6-07)
 Indiana Department of Environmental Management (IDEM)
 Office of Water Quality - Drinking Water Branch - Compliance Section

INSTRUCTIONS: Please submit completed forms to: IDEM OWQ Drinking Water, Mail Code 66-34, 100 N Senate Ave, Indianapolis, IN 46204-2251

PWSID:	System Name:
IN5210002	BORDEN TRI-COUNTY
Plant Number:	Plant Name:
01	BORDEN WTP

This form must be completed and submitted to IDEM within the first ten (10) days after the end of the monitoring period in which the samples were collected.

Monitoring Period (MM/DD/YYYY) :

06 / 01 / 2024

Please submit completed form to:
 IDEM OWQ - Drinking Water Branch
 100 N Senate Avenue
 Indianapolis, IN 46204-2251

Day	Hours of Operation	Raw Water Turbidity	Record Combined Effluent Turbidity Every Four Hours on a Daily Basis						Daily Max	Number >0.3 NTU
			1st	2nd	3rd	4th	5th	6th		
1	16.3	3.5	0.11	0.09	0.10	0.10	0.10	0.11	0	
2	24.0	2.8	0.13	0.09	0.10	0.11	0.10	0.13	0	
3	15.2	3.2	0.09	0.09	0.11	0.09	0.10	0.11	0	
4	24.0	2.7	0.12	0.11	0.11	0.11	0.11	0.12	0	
5	15.2	3.2	0.10	0.10	0.12	0.13	0.12	0.13	0	
6	24.0	3.6	0.12	0.10	0.11	0.12	0.12	0.12	0	
7	24.0	3.8	0.11	0.12	0.14	0.11	0.09	0.14	0	
8	16.5	4.2	0.16	0.10	0.10	0.09	0.09	0.16	0	
9	15.5	4.0	0.17	0.14	0.14	0.15	0.13	0.17	0	
10	24.0	4.4	0.15	0.12	0.15	0.14	0.15	0.15	0	
11	24.0	3.6	0.26	0.17	0.14	0.17	0.17	0.26	0	
12	24.0	1.9	0.18	0.18	0.17	0.14	0.14	0.18	0	
13	24.0	1.7	0.07	0.08	0.09	0.12	0.07	0.12	0	
14	24.0	1.7	0.09	0.08	0.07	0.08	0.12	0.12	0	
15	24.0	1.6	0.07	0.06	0.08	0.09	0.06	0.10	0	
16	16.5	1.4	0.10	0.11	0.12	0.09	0.10	0.12	0	
17	15.5	1.6	0.12	0.10	0.11	0.16	0.11	0.16	0	
18	24.0	1.5	0.12	0.10	0.09	0.14	0.14	0.14	0	
19	24.0	1.2	0.09	0.09	0.11	0.11	0.12	0.12	0	
20	24.0	1.3	0.10	0.11	0.10	0.08	0.07	0.11	0	
21	24.0	1.1	0.07	0.06	0.08	0.07	0.07	0.10	0	
22	24.0	1.1	0.06	0.07	0.08	0.07	0.07	0.09	0	
23	24.0	0.9	0.06	0.10	0.08	0.07	0.09	0.11	0	
24	24.0	1.8	0.08	0.07	0.08	0.09	0.07	0.09	0	
25	24.0	1.6	0.06	0.07	0.10	0.12	0.12	0.12	0	
26	15.5	1.3	0.10	0.10	0.12	0.11	0.10	0.12	0	
27	24.0	1.6	0.10	0.10	0.10	0.12	0.12	0.12	0	
28	24.0	1.9	0.09	0.09	0.12	0.13	0.12	0.13	0	
29	24.0	1.0	0.10	0.09	0.09	0.13	0.12	0.13	0	
30	24.0	1.0	0.11	0.14	0.13	0.12	0.12	0.14	0	
31										

I hereby certify that all the information submitted herein is true and accurate to the best of my knowledge.

Completed By: Daryl Naville Date: 07/02/24 Reviewed by: Daryl Naville

