



Indiana Department of Environmental Management

RM Record

Description

Incident # 112471

Received By: Frownfelter, Karla

Received Date: 05/17/2024 2:24 pm

Receipt Method: Telephone

Incident Description: Residence at 66 E 1150 N in MILFORD is having sewer backups due to nearby lift station issue; when Doug, who is in charge of lift station & in charge of WWTP in a nearby MHP is called; he will not assist. Complainant has called Milford, but they don't have jurisdiction over this lift station, Doug does & he won't do anything.

Incident Type: Complaint-WW Other
Emergency Response-Other

Occurred Date/Time: 05/17/2024 12:00 am

End Date: 05/21/2024 12:00 am

Regulatory Program: Wastewater

Incident Status: Closed

Closure Method: Emergency Response Complete

Lead Investigator: Peters, Jason

Resolution Desc: IDEM WW inspected. Lift station failure and overflowing. Spoke to owner nd informed him that the station must be pumped and repaired. also explained the overflow is a reportable event. Very difficult to deal with owner. Argumentative. Asked Jason Peters to also reach out.

OSC Peters Deployed and spoke with the repair company. They replaced a relay and get the lift station working again.

Parameter	CAS #	Quantity	Units
-----------	-------	----------	-------

Substances/Impacts: Sewage - Estimated

Media Impacted: Surface Soil

Location

Location Description: 66 E 1150 N
Milford, IN
Kosciusko County

Region Code: Northern Regional Office

County: Kosciusko



Indiana Department of Environmental Management RM Record

Source Entity

Source Type: Non-Agency Interest

Source Entity Name: Waubee Lake Mobile Home Park

Address 1: 427 East 1150 North

Municipality: Milford

County: Kosciusko

State: IN

Zip Code: 46542

Reporter

Reporter Type: Private Citizen

Name: Jerry and Brenda Bethel

Address 1: 371 E Nelson Dr

Municipality: Milford

State: IN

Zip Code: 46542

Reporter Requested: Yes

Telecom: Cellular phone number 1 574-453-6559

Actions

Task	Staff Assigned	Start Date	Due Date	Completed Date	Hours Spent
Enter Initial Complaint Into	Frownfelter, Karla	05/17/2024		05/17/2024	
Provide Acknowledgement	Frownfelter, Karla	05/17/2024		05/17/2024	
Conduct Follow-up	Peters, Jason	05/21/2024		05/21/2024	

Comments: Tried calling Doug Stump at 574-551-1529. His voicemail box was full and not taking anymore messages. I sent him a text messages requesting him to contact me regrading his lift stations.