



PANHANDLE EASTERN PIPE LINE COMPANY, LP
An ENERGY TRANSFER Company

8910 Purdue Rd, Suite 300 | Indianapolis, IN 46268 | (317) 879-3034

July 12, 2024

Indiana Department of Environmental Management
Compliance and Enforcement Branch, Office of Air Quality
100 North Senate Avenue
MC 61-53, IGCN 1003
Indianapolis, IN 46204-2251

**Re: Panhandle Eastern Pipe Line Company
Edgerton Station (OP No. 003-42515-00045)
Quarterly Compliance Monitoring Report: 4/1/2024- 6/30/2024**

Dear Sir/Madam:

Panhandle Eastern Pipe Line Company is submitting the Quarterly Monitoring Report for the Edgerton Station.

No deviations are being reported for this period.

If you have any questions, please contact me at (317) 879-3034.

Sincerely,

Kristin Bollerman

Kristin Bollerman
Senior Environmental Specialist

Attachments
Certified Mail

**INDIANA DEPARTMENT OF ENVIRONMENTAL MANAGEMENT
OFFICE OF AIR COMPLIANCE
COMPLIANCE DATA SECTION**

**PART 70 OPERATING PERMIT
QUARTERLY COMPLIANCE MONITORING REPORT**

Source Name: Panhandle Eastern Pipe Line Company - Edgerton Station
 Source Address: 25419 Pauling Road, Monroeville, IN 46773
 Mailing Address: P. O. Box 4967, Houston, TX 77210-4967
 Part 70 Permit No: T003-42515-00045

Months: April 1 to June 30 Year: 2024

This report is an affirmation that the source has met all the compliance monitoring requirements stated in this permit. This report shall be submitted quarterly. Any deviation from the compliance monitoring requirements and the date(s) of each deviation must be reported. Additional pages may be attached if necessary. This form can be supplemented by attaching the Emergency/Deviation Occurrence Report. If no deviations occurred, please specify in the box marked "No deviations occurred this reporting period".

NO DEVIATIONS OCCURRED THIS REPORTING PERIOD.

THE FOLLOWING DEVIATIONS OCCURRED THE REPORTING PERIOD:

Compliance Monitoring Requirement (e.g. Permit Condition D.1.3)	Number of Deviations	Date of each Deviation

Form Completed By: Kristin Bollerman
 Title/Position: Senior Environmental Specialist
 Date: 7/11/2024
 Phone: (317) 879-3034

Attach a signed certification to complete this report

**INDIANA DEPARTMENT OF ENVIRONMENTAL MANAGEMENT
OFFICE OF AIR MANAGEMENT
COMPLIANCE DATA SECTION**

**PART 70 OPERATING PERMIT
CERTIFICATION**

Source Name: Panhandle Eastern Pipe Line Company – Edgerton Station
Source Address: 25419 Pauling Road, Monroeville, IN 46773
Mailing Address: P. O. Box 4967, Houston, TX 77210-4967
Part 70 Permit No: T003-35526-00045 & T003-36957-00045

This certification shall be included when submitting monitoring, testing reports/results or other documents as required by this permit.

Please check what document is being certified:

- Annual Compliance Certification Letter
- Test Result (specify) _____
- Report (specify) Quarterly Compliance Monitoring Report
- Notification (specify) _____
- Other (specify) _____

I certify that, based on information and belief formed after reasonable inquiry, the statements and information in the document are true, accurate, and complete.

Signature: Stephen Schuman

Printed Name: Stephen D Schuman

Title/Position: Vice President, Eastern Division Operations

Date: 7/12/2024

**INDIANA DEPARTMENT OF ENVIRONMENTAL MANAGEMENT
OFFICE OF AIR QUALITY
COMPLIANCE DATA SECTION**

Part 70 Quarterly Report

Source Name: Panhandle Eastern Pipe Line Company – Edgerton Compressor Station
Source Address: 25419 Paulding Road, Monroeville, IN 46773
Mailing Address: P. O. Box 4967, Houston Texas 77210-4967
Part 70 Permit No.: T 003-42515-00045
Facilities: Engines: 1501 through 1504
Parameters: Hours of operation
Limit: Each RICE is limited to less than 100 hours per twelve (12) consecutive month period with compliance determined at the end of each month.

ENGINE: 1501 YEAR: 2024

Month	Hours of Operation	Hours of Operation	Hours of Operation
	This Month	Previous 11 Months	12 Month Total
April	0	0	0
May	0	0	0
June	0	0	0

- No deviations occurred in this month
 Deviation/s occurred in this month
Deviation has been reported on: _____

Submitted by: Kristin Bollerman
Title/Position: Senior Environmental Specialist
Signature: Kristin Bollerman
Date: 7/11/2024
Phone: 317-879-3034

Attach a signed certification to complete this report.

**INDIANA DEPARTMENT OF ENVIRONMENTAL MANAGEMENT
 OFFICE OF AIR QUALITY
 COMPLIANCE DATA SECTION**

Part 70 Quarterly Report

Source Name: Panhandle Eastern Pipe Line Company – Edgerton Compressor Station
 Source Address: 25419 Paulding Road, Monroeville, IN 46773
 Mailing Address: P. O. Box 4967, Houston Texas 77210-4967
 Part 70 Permit No.: T 003-42515-00045
 Facilities: Engines: 1501 through 1504
 Parameters: Hours of operation
 Limit: Each RICE is limited to less than 100 hours per twelve (12) consecutive month period with compliance determined at the end of each month.

ENGINE: 1502 YEAR: 2024

Month	Hours of Operation	Hours of Operation	Hours of Operation
	This Month	Previous 11 Months	12 Month Total
April	0	0	0
May	0	0	0
June	0	0	0

- No deviations occurred in this month
- Deviation/s occurred in this month
 Deviation has been reported on: _____

Submitted by: Kristin Bollerman
 Title/Position: Senior Environmental Specialist
 Signature: Kristin Bollerman
 Date: 7/11/2024
 Phone: 317-879-3034

Attach a signed certification to complete this report.

**INDIANA DEPARTMENT OF ENVIRONMENTAL MANAGEMENT
OFFICE OF AIR QUALITY
COMPLIANCE DATA SECTION**

Part 70 Quarterly Report

Source Name: Panhandle Eastern Pipe Line Company – Edgerton Compressor Station
Source Address: 25419 Paulding Road, Monroeville, IN 46773
Mailing Address: P. O. Box 4967, Houston Texas 77210-4967
Part 70 Permit No.: T 003-42515-00045
Facilities: Engines: 1501 through 1504
Parameters: Hours of operation
Limit: Each RICE is limited to less than 100 hours per twelve (12) consecutive month period with compliance determined at the end of each month.

ENGINE: 1503 YEAR: 2024

Month	Hours of Operation	Hours of Operation	Hours of Operation
	This Month	Previous 11 Months	12 Month Total
April	0	0	0
May	0	0	0
June	0	0	0

- No deviations occurred in this month
 Deviation/s occurred in this month
Deviation has been reported on: _____

Submitted by: Kristin Bollerman
Title/Position: Senior Environmental Specialist
Signature: Kristin Bollerman
Date: 7/11/2024
Phone: 317-879-3034

Attach a signed certification to complete this report.

**INDIANA DEPARTMENT OF ENVIRONMENTAL MANAGEMENT
 OFFICE OF AIR QUALITY
 COMPLIANCE DATA SECTION**

Part 70 Quarterly Report

Source Name: Panhandle Eastern Pipe Line Company – Edgerton Compressor Station
 Source Address: 25419 Paulding Road, Monroeville, IN 46773
 Mailing Address: P. O. Box 4967, Houston Texas 77210-4967
 Part 70 Permit No.: T 003-42515-00045
 Facilities: Engines: 1501 through 1504
 Parameters: Hours of operation
 Limit: Each RICE is limited to less than 100 hours per twelve (12) consecutive month period with compliance determined at the end of each month.

ENGINE: 1504 YEAR: 2024

Month	Hours of Operation	Hours of Operation	Hours of Operation
	This Month	Previous 11 Months	12 Month Total
April	0	0	0
May	0	0	0
June	0	0	0

- No deviations occurred in this month
- Deviation/s occurred in this month
 Deviation has been reported on: _____

Submitted by: Kristin Bollerman
 Title/Position: Senior Environmental Specialist
 Signature: Kristin Bollerman
 Date: 7/11/2024
 Phone: 317-879-3034

Attach a signed certification to complete this report.