



CONSUMER CONFIDENCE REPORT CERTIFICATION IN DRINKING WATER

State Form 54187 (R / 7-14)
INDIANA DEPARTMENT OF ENVIRONMENTAL MANAGEMENT (IDEM)
OFFICE OF WATER QUALITY – DRINKING WATER BRANCH – COMPLIANCE SECTION

IDEM – DRINKING WATER BRANCH
MC 66-34
100 N. Senate Ave.
Indianapolis, IN 46204-2251
Telephone: 317-234-7435
Fax: 317-234-7436
Email: dwbmgr@idem.in.gov

- INSTRUCTIONS:**
1. Complete Consumer Confidence Report (CCR) Certification form.
 2. Submit the certification form to IDEM by October 1st of reporting year.

CERTIFICATION

System Name: South Coast Conservancy District

PWSID Number: IN5246004

The community water system named above hereby confirms that its consumer confidence report has been distributed to customers (and appropriate notices of availability have been given). Further, the system certifies that the information contained in the report is correct and consistent with the compliance monitoring data previously submitted to primacy agency.

Certified by:

Name Aaron Flowers Signature _____

Title Certified Operator

Telephone number 219-552-1119 Date (month, day, year) 06 / 28 / 24

*** You are not required by EPA rules to report the following information, but you may want to provide it to your state. *Check all items that apply.*

- The consumer confidence report (CCR) was distributed by mail or other direct delivery on:
Date (month, day, year) 06 / 21 / 2024

Specify other delivery methods below:

- Good faith efforts were used to reach non-bill paying consumers. Those efforts included the following methods as recommended by the primacy agency:

- posting the CCR on the Internet at [www._____](#)
- mailing the CCR to postal patrons within the service area (attach ZIP codes served)
- advertising availability of the CCR in news media (attach copy of announcement)
- publication of CCR in local newspaper (attach a copy)
- posting the CCR in public places (attach a list of locations)
- delivering multiple copies to single bill addresses serving several persons such as apartments, businesses, and large private employers
- delivering CCR copies to community organizations (attach a list)

- For systems serving at least 100,000 persons only, CCR was posted on a publicly-accessible Internet site at the address: [www._____](#)

- Delivered CCR to other agencies as required by the primacy agency (attach a list).



IN5246004
South Coast Conservancy District
2023 CONSUMER CONFIDENCE REPORT

Is our water safe?

This brochure is a snapshot of the quality of the drinking water that we provided last year. Included as part of this report are details about where the water that you drink comes from, what it contains, and how it compares to Environmental Protection Agency (EPA) and Indiana standards. We are committed to providing you with all the information that you need to know about the quality of the water that you drink.

Do I need to take special precautions?

Some people may be more vulnerable to contaminants in drinking water than the general population. Immune-compromised people, such as people with cancer undergoing chemotherapy, people who have undergone organ transplant, people with HIV/AIDS, or other kind of immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA has set guidelines with appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants which are available from the Safe Drinking Water Hotline at (800) 426-4791.

Where does our water come from?

The South Coast Conservancy District's water comes from the Town of Westville public drinking water system; therefore, at the end of this report is an excerpt from the Town of Westville Consumer Confidence Report.

Why are there contaminants in my drinking water?

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of these contaminants does not necessarily indicate that the water poses a health risk or that it is not suitable for drinking. More information about contaminants and their potential health effects can be obtained by calling the EPA's Safe Drinking Water Hotline at (800)426-4791.

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals, and in some cases, radioactive material, or can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in the raw, untreated water may include:

- ***Microbial Contaminants***, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- ***Inorganic Contaminants***, such as salts and metals, which can be naturally-occurring, or that result from urban storm water runoff, industrial or domestic wastewater discharges, oil and gas production, and mining or farming operations.
- ***Pesticides and Herbicides***, which may come from a variety of sources, such as agriculture, stormwater runoff, and residential uses.
- ***Organic Chemical Contaminants***, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production operations, and can also result from gas stations, urban stormwater runoff, and septic systems.
- ***Radioactive Contaminants***, which can be naturally-occurring or the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, the EPA prescribes regulations that limit the amount of certain contaminants that may be present in the water provided by public drinking water systems. We are required to treat our water according to EPA's regulations. Moreover, FDA regulations establish limits for contaminants that may be present in bottle water, which must provide the same level of health protection for public health.

Water Quality Data

The table below lists all the contaminants that we detected during the 2023 calendar year. The presence of these contaminants in the water does not necessarily indicate that the water poses a health risk. Unless otherwise indicated, the data presented in this table is from testing done between January and December 31, 2023. The Indiana Department of Environmental Management (IDEM) requires us to monitor for certain contaminants at a frequency less than once per year because the concentration of these contaminants are not expected to vary significantly from one year to another. Some of the data, though representative of the water quality, may however be more than one year old.

Definitions

The following table contains scientific terms and measures, some of which may require explanation. Some of the terms and abbreviations used in this report are as follows:

- **Action Level Goal (ALG)** - The level of a contaminant in a drinking water below which there is no known or expected risk to health. ALGs allow for a margin of safety.
- **Action Level** - The concentration of a contaminant which, if associated, trigger treatment or other requirements which a water system must follow.
- **Avg.** - Regulatory compliance with some MCL's based on running annual average of monthly samples.
- **Maximum Contaminant Level or MCL** - The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.
- **Level 1 Assessment** - A Level 1 Assessment is a study of the water system to identify potential problems and determine (if possible) total coliform bacteria have been found in our water system.
- **Maximum Contaminant Level Goal or MCLG** - The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.
- **Level 2 Assessment** - A level 2 Assessment is a very detailed study of the water system to identify potential problems and determine (if possible), why an E. coli MCL violation has occurred and/or why total coliform bacteria have been found in our water system of multiple occasions.
- **Minimum Residual Disinfectant Level or MRDL** - The highest level of a disinfection allowed in drinking water. There is convincing evidence that neither of a disinfectant is necessary for control of microbial contaminants.
- **Maximum Residual Disinfectant Level Goal or MRDLG** - The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.
- **na** - Either not available or not applicable.
- **Mrem** - Millirems per year (a measure of radiation absorbed by the body).
- **ppb** - Micrograms per liter or parts per billion – or one ounce in 7,350,000 gallons of water.
- **ppm** - Milligrams per liter or parts per million – or one ounce in 7,350 gallons of water.
- **Treatment Technique or TT** - A required process intended to reduce the level of a contaminant in drinking water.

Section I – Contaminants Detected

Inorganic Contaminants										
	Contaminant	Action Level	MCLG	Units	Highest Level Detected	Min	Max	Above AI # Repeats	Violates	Likely Sources
6/23/22	Copper (90 th Percentile)	1.3	13	mg/l	0.15			0	No	Erosion of natural deposits; Leaching from wood preservatives; Corrosion of household plumbing systems.
6/23/22	Lead* (90 th Percentile)	15	0	ug/l	0.8			0	No	Corrosion of household plumbing systems; Erosion of natural deposits.

Inorganic Contaminants										
	Contaminant	MCL	MCLG	Units	Highest Level Detected	Min	Max	Above AI # Repeats	Violates	Likely Sources
8/23/23	Dibromochloro methane	0.1	0	mg/l	0.007	0.0057	0.007		No	
8/24/23	Total Haloacetic Acids (HAA5)	60	None	ug/l	4.6	4	4.6		No	By-product of drinking water chlorination.
8/24/23	Total Trihalomethanes (TTHM)	80	None	ug/l	39	29	39		No	By-product of drinking water chlorination.

Residual Disinfectant										
Date	Contaminant	MCL	MCLG	Units	Result	Min	Max	Above AI # Repeats	Violates	Likely Sources
2023	Chlorine Residual	4 MRDL	4 MRDLG	mg/l	0.55	0.18	1.42		No	Water additive (disinfectant) used to control microbiological organisms

*Special Note on Lead: If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Our system is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to

Violations				
Date	Analyte	Violation Type	Violation Explanation	Violation Response
06/30/2023	Consumer Confidence Rule	CCR Report	Failed to deliver Consumer Confidence Report to the state or consumers on time.	The CCR was distributed to consumers on time but was sent to IDEM when the certification form was sent on 7/31/2023.

Public Involvement Opportunities

If you have any questions about the contents of this report, please contact Mr. Jim Sallee at 219-363-4344. Or you can join us at our regularly scheduled Conservancy District meeting, which is regularly held every third Tuesday at the Purdue Northwest Westville Campus at 2:00 pm

Please Share This Information

Large water volume customers (like apartment complexes, hospitals, schools and/or industries) are encouraged to post extra copies of this report in conspicuous locations or to distribute them to your tenants, residents, patients, students, and/or employees. This "good faith" effort will allow non-billed customers to learn more about the quality of the water that they consume.

The following table is taken from the Town of Westville Consumer Confidence report. Since the South Coast Conservancy District receives its water from the Town of Westville, we have included this information as part of the report.

Town of Westville Table of Contaminants Detected

Section I – Contaminants Detected

Inorganic Contaminants										
	Contaminant	Action Level	MCLG	Units	Highest Level Detected	Min	Max	Above AI # Repeats	Violates	Likely Sources
9/15/22	Copper (90 th Percentile)	1.3	13	mg/l	0.31				No	Erosion of natural deposits; Leaching from wood preservatives; Corrosion of household plumbing systems.
9/15/22	Lead* (90 th Percentile)	15	0	ug/l	0.75				No	Corrosion of household plumbing systems; Erosion of natural deposits.
Inorganic Contaminants										
	Contaminant	MCL	MCLG	Units	Highest Level Detected	Min	Max	Above AI # Repeats	Violates	Likely Sources
12/06/23	Nitrate (measured as Nitrogen)	10	10	mg/l	<0.1	N/D	N/D		No	Result from fertilizer and leaching of septic tanks, sewage; Erosion of natural deposits.
9/21/23	Total Haloacetic Acids (HAA5)	60	None	ug/l	<2	<2	<2		No	By-product of drinking water chlorination.
9/21/23	Total Trihalomethanes (TTHM)	80	None	ug/l	42	42	42		No	By-product of drinking water chlorination.
2023	Fluoride	4.0	4.0	mg/l	0.7	0.1	0.7		No	Erosion of natural deposits. Water additive which promotes strong teeth. Discharge from fertilizer and aluminum factories.
8/25/21	Barium	2	2	mg/l	0.044	.044	0.044		No	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits.

Residual Disinfectant										
Date	Contaminant	MCL	MCLG	Units	Result	Min	Max	Above AI # Repeats	Violates	Likely Sources
2023	Chlorine Residual	4 MRDL	4 MRDLG	mg/l	0.82	0.25	1.45		No	Water additive (disinfectant) used to control microbiological organisms

Radioactive Contaminants								
Contaminant	Collection Date	Highest Level Detected	Range of Levels Detected	MCLG	MCL	Units	Violation	Likely Source of Contamination
Gross alpha excluding radon and uranium	8/22/2018	0.4	0.4-0.4	0	15	pCi/L	No	Erosion of natural deposits.
Uranium	8/22/2018	1.1915	1.1915-1.1915	0	30	ug/l	No	Erosion of natural deposits.

Unregulated Contaminants										
Date	Contaminant	MCL	MCLG	Units	Result	Min	Max.	Above AI # Repeats	Violates	Likely Sources
8/22/18	Sodium	None	None	mg/l	3.1					Erosion of natural deposits. By-product of softener regeneration.

Special Note on Lead: If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Our system is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.gov/safewater/lead>.

Violations				
Date	Analyte	Violation Type	Violation Explanation	Violation Response
02/2023	E.Coli	Monitoring, Routine, Major (RTCR)	Failed to collect routine or replacement coliform samples	Testing was inadvertently missed. Follow up sampling was conducted.
06/30/2023	Consumer Confidence Rule	CCR Report	Failed to deliver Consumer Confidence Report to the state or consumers on time.	The CCR was distributed to consumers on time but was sent to IDEM when the certification form was sent on 7/31/2023.