



**INDIANA DEPARTMENT OF ENVIRONMENTAL MANAGEMENT**

*We Protect Hoosiers and Our Environment.*

100 N. Senate Avenue • Indianapolis, IN 46204

(800) 451-6027 • (317) 232-8603 • [www.idem.IN.gov](http://www.idem.IN.gov)

Eric J. Holcomb

*Governor*

Brian C. Rockensues

*Commissioner*

July 29, 2024

Tank Owner  
Speedway LLC  
500 Speedway Drive  
Enon, OH 45323  
SPWYEnvComplianceMidwest@speedway.com

Property Owner  
Speedway LLC  
500 Speedway Drive  
Enon, OH 45323  
SPWYEnvComplianceMidwest@speedway.com

Tank Operator  
Speedway LLC  
500 Speedway Drive  
Enon, OH 45323  
SPWYEnvComplianceMidwest@speedway.com

Re: **Notice of Deficiency for UST System Closure**  
Speedway 5153  
2150 S Bend Ave  
South Bend, IN 46637  
Facility ID #635

To All Parties:

The Indiana Department of Environmental Management (IDEM) received an Underground Storage Tank Systems Closure Report (Closure Report) form for the facility referenced above on 7/15/2024. The Closure Report can be found on the IDEM Virtual File Cabinet (VFC) at VFC #83669317.

IDEM staff reviewed the information contained in this form and attachments. At this time the Closure Report is INCOMPLETE. The following items need to be addressed:

1. 2202 - Closure - Sample Results - Groundwater sampling data missing or not in tabular format.  
- The rule states that if groundwater is not encountered in the tank pit a boring must be advanced to 30 feet or the occurrence of water, whichever comes first.
2. 2307 - Closure - Miscellaneous - Disposal documentation not provided for product or sludge.
3. 2308 - Closure - Miscellaneous - Disposal documentation not provided for USTs and piping.


Please resubmit the necessary pages of the Closure Report and/or backup resolving the deficiencies identified within forty-five (45) days of receipt of this letter.

Any questions concerning the UST Closure process may be directed to:

Lauren Welch, Environmental Project Manager  
IDEM – Office of Land Quality  
lwelch@idem.in.gov

Failure to submit the required information detailed in this deficiency letter may be a violation of Indiana Code (IC) 13-23-14-2 and the Indiana Administrative code (IAC) 329 IAC 9-2-2 and 329 IAC 9-3-1. Additionally, the submittal of false information, as well as the failure to submit required UST Notification Forms, is subject to a civil penalty of up to \$10,000.

Sincerely,



Lauren Welch  
Environmental Project Manager  
Petroleum Branch  
Office of Land Quality

ecopy: IDEM File

Michael Byrne, Michael.Byrne@7-11.com

Aaron Fix, afix@idem.in.gov

Steven Browning, steve.browning@oneatlas.com

Jenny Roether, jenny.roether@oneatlas.com

Andrew Rice, andrew.rice@7-11.com



Visit [on.IN.gov/survey](https://on.IN.gov/survey) or scan the QR code to provide feedback.  
*We appreciate your input!*

