

MONTHLY REPORT OF OPERATION
WATER TREATMENT PLANT

System Name: LSC Communications

PWSID Number: 2431056

For the Month of: July 2024

IDEM Field Rep.: Sophia J. Andrews

Signed:

Title: Water Treatment Operator

I certify under penalty of law by this signature that this document was prepared by me or under my direction and the information submitted is to the best of my knowledge and belief, true, accurate, and complete. I am also aware that there are significant penalties for submitting false information.

Certification Number: DS220174 / WT230024

PHYSICAL AND CHEMICAL DATA											
Date	Iron (mg/l)		Water Treated	Chemicals Used (Gallons)	Industrial Filters (operate 24 hours/day)		Potable Filters (operate 24 hours/day)		Chlorine Residual (mg/l)	Initials of Tester	Remarks
	Raw	Finished	Gallons	Sodium Hypochlorite (NaOCl)	Run Hours	Gallons per Backwash	Run Hours	Gallons per Backwash	Plant Tap (Free Cl)		
1	3.84	0.09	3,906	0.0	168	66,000			0.01	DK	BW Industrial #1
2	1.79	0.07	3,906	0.0	24				0.01	DK	
3	1.86	0.08	3,359	0.0	48				0.02	DK	
4			3,359	0.0	72						
5			3,359	0.0	96						
6			3,359	0.0	120						
7			3,361	0.0	144						
8	1.66	0.02	3,617	0.0	168	66,000			0.00	DK	BW Industrial #2
9	1.74	0.07	2,506	0.0	24				0.00	DK	
10	1.83	0.07	5,659	0.0	48				0.01	DK	
11	1.69	0.09	7,261	0.0	72				0.01	DK	
12	1.73	0.08	5,158	0.0	96				0.00	DK	
13			5,158	0.0	120						
14			5,158	0.0	144						
15	1.71	0.12	5,652	0.0	168	66,000			0.00	MR	BW Industrial #1
16	1.40	0.08	4,076	0.0	24				0.01	DK	
17	1.70	0.08	5,026	0.0	48				0.01	DK	
18	1.78	0.07	4,369	0.0	72				0.00	DK	
19	3.15	0.06	3,198	0.0	96				0.00	DK	
20			3,234	0.0	120						
21			3,236	0.0	144						
22	1.77	0.03	3,508	0.0	168	66,000			0.02	DK	BW Industrial #2
23	1.84	0.07	5,451	0.0	24				0.00	DK	
24	1.65	0.08	4,214	0.0	48				0.01	DK	
25	1.74	0.09	4,356	0.0	72				0.01	DK	
26	1.80	0.05	2,823	0.0	96				0.00	DK	
27			2,823	0.0	120						
28			2,823	0.0	144						
29	1.56	0.11	3,744	0.0	168	66,000			0.01	DK	BW Industrial #1
30	1.64	0.10	4,044	0.0	24				0.01	DK	
31	1.52	0.12	3,720	0.0	48				0.02	DK	

Monthly Water Treatment	Total Gallons	125,423	DUE BY THE 10TH OF THE MONTH FOLLOWING THE REPORTING PERIOD.	Mail to: Indiana Dept. of Environmental Mgmt. Drinking Water Branch 68-34-2 100 N. Senate Avenue Indianapolis, IN 46204-2251
	Daily Maximum	7,261		
	Daily Minimum	2,508		
	Daily Average	4,057		