

To: Agnew, Dianna[DAgnew@idem.IN.gov]
From: DWBMGR
Sent: Thur 8/15/2024 2:41:11 PM
Subject: FW: Adjusted time for boil water
Received: Thur 8/15/2024 2:41:14 PM

Thank you,

Roger Svendsen

Indiana CMDP Administrator
IDEM Drinking Water Branch
100 N. Senate Ave. MC 66-34
Indianapolis, IN 46204

Phone: 317-234-7455 Fax: 317-234-7455

Routine Drinking Water Test Results submitted to IDEM Drinking Water Branch can be viewed on-line by clicking the link below.
<https://myweb.in.gov/IDEM/DWWW/>

From: Neal McKee <NMckee@cityofanderson.com>
Sent: Thursday, August 15, 2024 10:40 AM
To: DWBMGR <DWBMGR@idem.IN.gov>; Stephanie Cain <scain@madisoncounty.in.gov>
Subject: FW: Adjusted time for boil water

****** This is an EXTERNAL email. Exercise caution. DO NOT open attachments or click links from unknown senders or unexpected email. ******

See below for the extension of the BWA for 8/13/2024. The first Bac-t sample failed and we are resampling today.

Neal L McKee
Director, City of Anderson Water Utility
550 Dale Keith Jones Road
Anderson, IN 46011



Phone: 765-648-6420
Email: nmckee@cityofanderson.com

From: Kade Hoover <khoover@cityofanderson.com>
Sent: Thursday, August 15, 2024 7:40 AM
To: Neal McKee <NMckee@cityofanderson.com>; J.D. Allman <jdallman@cityofanderson.com>; Josh Castor <JCastor@cityofanderson.com>
Subject: Adjusted time for boil water

Neal, we had to adjust the time for this because of the bacteriological.

The Anderson Water System ([5248002](#)) issued a boil water advisory due to a main repair. Affected customers were notified to boil water for drinking, cooking, and/or oral hygiene purposes. Sample analysis is being conducted at the Anderson Water Pollution Control Laboratory, certification# M-48-1.

BWA issued: 08-13-2024

Anderson Water Department - [5248002](#)

Residential Customers affected – 17

Commercial customers affected -0

Affected Area: Romine Rd. between Anderson St. and Moss Island Rd.

Cause - Main Repairs

Result: Water pressure <20 psi for approximately 2 hrs.

BWA Cancellation:08-16-2024 930am

Kade Hoover

Leak Supervisor

City of Anderson Water Utility



Mayor Thomas J. Broderick, Jr.

Phone: 765-648-6420

Email: khoover@cityofanderson.com