

# SANITARY DISTRICT of HAMMOND

5143 COLUMBIA AVENUE  
HAMMOND, INDIANA 46327-1794  
TELEPHONE (219) 853-6412-13-14-88  
FAX (219) 853-6321

Board of Sanitary Commissioners

SAM DIMOPOULOS  
MICHAEL DYE  
MONICA RUBIO  
OWANA MILLER  
MICHAEL HAWKINS, Sr.



THOMAS M. MCDERMOTT, JR.  
Mayor

MILAN A. KRUSZYNSKI  
District Manager

RACHEL MONTES  
Business Manager

JOSEPH P. ALLEGRETTI  
Legal Counsel

October 25, 2024

SENT VIA ELECTRONIC MAIL

Indiana Department of Environmental Management  
Office of Water Quality – Mail Code 65-42  
Compliance Data Section – Pretreatment Group  
100 North Senate Avenue  
Indianapolis, IN 46204-2551

RE: NPDES PERMIT #IN 0023060 – LAKE COUNTY – 3<sup>rd</sup> QUARTER 2024 PRETREATMENT  
COMPLIANCE REPORT

Dear Ms. Armacost:

Enclosed you will find the Report on the Sanitary District of Hammond's Pretreatment Program for the Third Quarter, ending in September 2024. Included in this report is the bimonthly sludge metals.

If further information is needed, or if you have any questions, please feel free to call.

Sincerely,

Jeffrey Massey  
Superintendent of Wastewater Treatment

CC: Board of Sanitary Commissioners

**SANITARY DISTRICT of HAMMOND  
PRETREATMENT DEPARTMENT  
INDUSTRIAL USER QUARTERLY REPORT  
3<sup>rd</sup> QUARTER 2024**

<u>INDUSTRIAL USER</u>	<u>COMPLIANCE</u>	<u>NON-COMPLIANCE</u>
ACS	X	
AMSTED	X	
BUCKEYE TERMINALS, LLC.	X	
BULKMATIC		X (1)
CARGILL	X	
CINTAS	X	
COMMUNITY HOSPITAL	X	
COVANTA	X	
DOVER CHEMICAL	X	
ECO SERVICES (RHODIA)	X	
EXXONMOBIL TANK FARM	X	
HAMMOND FILTRATION PLANT	X	
HAMMOND GROUP (HAMMOND LEAD DIV.)	X	
HUHTAMAKI	X	
JUPITER ALUMINUM	X	
MARATHON OIL – TANK FARM	X (No Discharge)	
MICKEY'S LINEN AND TOWEL SUPPLY	X	
NIAGARA LASALLE HAMMOND	X	
NIPSCO	X	
PEPSI AMERICAS	X	
PLEASANT VIEW DAIRY	X	
PREMCOR	X (No Discharge)	
RESCO	X	
ST. MARGARET HOSPITAL*	X	

NPDES Permit # IN 0023060 – Lake County

SILGAN CONTAINER	X	
UHS		X (2)
UNIFIRST	X	
UNILEVER, H.P.C.	X	
WHITING CLEAN ENERGY	X	
WOLVERINE PIPELINE	X	

**NOTES:**

- 1) **Bulkmatic:** Exceeded permit limitation of 2,800 mg/l for Chlorides on 8/13/24 with a result of 3,405.60 mg/l.
- 2) **UHS:** Failed to submit Permit Application on time. Ongoing

\*ST. Margaret Hospital is in the process of closing.

## Bi-Monthly Sludge Metals

<b>METALS</b>	<b>Aug-2024</b>
Cadmium	0.722
Chromium	51.6
Copper	268
Lead	64.1
Nickel	37.8
Zinc	1390
% TS	16.70

Results are expressed as mg/kg dry weight