
 <p><b>CONSTRUCTION DESIGN RELEASE</b> State Form 41191 (R9/5-98) Report Printed on: October 21, 2024</p> <p>Indiana Department of Homeland Security DIVISION OF FIRE &amp; BUILDING SAFETY PLAN REVIEW DIVISION 402 W. Washington St., Room E245 Indianapolis, IN 46204</p> <p>To: Owner / Architect / Engineer Circle K Midw est</p> <p>4080 W. Jonathon Moore Pike Columbus IN 47201</p> <p>Fax &amp; e-mail: 7659382710, natalie.petit@circlek.com</p>			Project number 449009	Release date 10/21/24
	Construction type *SEE BELOW		Occupancy classification U, REM	
	Scope of release TNK			
	Type of release Standard			
	Project name Circle K 4700121 Resump & Repipe			
	Street address 2105 E King St			
City FRANKLIN		County JOHNSON		

The plans, specifications and application submitted for the above referenced project have been reviewed for compliance with the applicable rules of the Fire Prevention and Building Safety Commission. The project is released for construction subject to, but not necessarily limited to, the conditions listed below. THIS IS NOT A BUILDING PERMIT. All required local permits and licenses must be obtained prior to beginning construction work. All construction work must be in full compliance with all applicable State rules. Any changes in the released plans and/or specifications must be filed with and released by this Office before any work is altered. This release may be suspended or revoked if it is determined to be issued in error, in violation of any rules of the Commission or if it is based on incorrect or insufficient information. This release shall expire by limitation, and become null and void, if the work authorized is not commenced within one (1) year from the above date.

CONDITIONS:

Note :(A1A & A1B): In accordance with the affidavit sworn under penalties of perjury in the application for construction design release the plans and specifications filed in conjunction with this project shall comply with all of the applicable rules and laws of Fire Prevention and Building Safety Commission. Providing false information constitutes an act of perjury, which is a Class D felony punishable by a prison term and a fine up to \$10,000. In accordance with Section 19 of the General Administrative Rules (675 IAC 12-6-19) a complete set of plans and specifications that conform exactly to the design that was released by the office of the state building commissioner shall be maintained on the construction jobsite as well as a copy of the design release.

This release is for the resump and repiping of 2-23,000 GAL existing tanks and 4 existing dispensers.

14W This project was reviewed under the 2014 Indiana Fire Code (675 IAC 22-2.5).

4G0412AE The proposed building, addition, or remodel shall not put the existing building in noncompliance or into further noncompliance in accordance with 675 IAC 12-4-12.

14W5704211 Underground storage of flammable and combustible liquids in tanks shall comply with Section 5704.2.11, IFC (675 IAC 22-2.5).

NOTE: Flammable and combustible liquid storage tanks located underground, either outside or under buildings, shall be in accordance with Section 5704.2.11.2 IFC (675 IAC 22-2.5).

14W23066 The design, fabrication, assembly, testing and inspection of piping, valves, fittings and ancillary equipment for use with flammable or combustible liquids shall be in accordance with Chapter 57 and Sections 2306.6.1 through 2306.6.3 in accordance with Section 2306.6, IFC (675 IAC 22-2.5).

AREL Pursuant to 675 IAC 12-6-21, the issuance of a design release does not relieve the owner from required compliance with all applicable rules of the commission, even if noncompliant conditions appear in the plans and specifications that have been filed with the division. The owner is responsible for correcting any and all areas of noncompliance even if they are discovered subsequent to the issuing of this design release.

ELECTRONICALLY FILE YOUR PROJECT WITH STATE OF INDIANA at <http://www.in.gov/dhs/2650.htm>.

This on-line filing is through a secure site, you can use it to submit your project information, pay the fees and upload your project plans.

*Use Internet Browser to View this report, other browsers are not compatible to view this report*

Please be advised that if an administrative review of this action is desired, a written petition for review must be filed at the above address with the Fire Prevention and Building Safety Commission identifying the matter for which a review is sought no later than eighteen (18) days from the above -stated date, unless the eighteenth day falls on a Saturday, a Sunday, a legal holiday under State statute, or a day in which the Department of Fire and Building Services is closed during normal business hours. In the latter case, the filing deadline will be the first working day thereafter. If you choose to petition, and the before-mentioned procedures are followed, your petition for review will be granted, and an administrative proceeding will be conducted by an administrative law judge of the Fire Prevention and Building Safety Commission. If a petition for review is not filed, this Order will be final, and you must comply with its requirements.

Code review official AARON HOUGH ahough@dhs.in.gov	Indiana State Building Commissioner
Address (name,title of local official,street,city,state and ZIP code) BUILDING COMMISSIONER DAVID PARSLEY BOX 280 FRANKLIN, IN 46131 Fax & e-mail: 3177364035, dparsley@franklin.in.gov	*RELEASED*

