

Poon, Peter

From: Michele Gerke <Michele.Gerke@cityoffortwayne.org>
Sent: Friday, December 6, 2024 10:01 AM
To: DWBMGR; IDEM DWBMRO; Poon, Peter
Cc: Jason Anspach; Brian Robinson; Miranda Sparkman; Andrew Schipper
Subject: IN5202020_01_202411 Reports
Attachments: IN5202020_01_202411 Reports.pdf

EXTERNAL EMAIL: This email was sent from outside your organization. Exercise caution when clicking links, opening attachments or taking further action, before validating its authenticity.

Attached are the November 2024 reports for the City of Fort Wayne, Three Rivers Filtration Plant (PWSID: IN5202020).

If you have any questions or concerns, please feel free to contact either Jason Anspach or Andrew Schipper.

Thank You,

Michele Gerke

Water Quality Supervisor
Three Rivers Filtration Plant
Fort Wayne City Utilities – Drinking Water Plant
1100 Griswold Drive
Ft. Wayne, IN 46805





Indiana Department of Environmental Management
Office of Water Quality- Drinking Water Branch

Monthly reporting form for systems that measure daily Chlorine
Dioxide (with no Chlorine booster station)

PWSID#	5	2	0	2	0	2	0	Facility Name: Three Rivers Filtration Plant	
Submitted by: Jason Anspach								Month	Year
								November	2024

Day	ClO ₂ daily (mg/L) @POE	Does Daily ClO ₂ sample level exceed 0.800 (mg/L) (Y/N)	ClO ₂ Distribution sample first Customer (mg/L)	ClO ₂ Distribution Sample @ Average residence time (mg/L)	ClO ₂ Distribution sample @ maximum residence time (mg/L)
1	0.133	N			
2	0.076	N			
3	0.190	N			
4	0.152	N			
5	0.095	N			
6	0.114	N			
7	0.133	N			
8	0.095	N			
9	0.095	N			
10	0.095	N			
11	0.133	N			
12	0.114	N			
13	0.171	N			
14	0.171	N			
15	0.133	N			
16	0.114	N			
17	0.076	N			
18	0.095	N			
19	0.133	N			
20	0.133	N			
21	0.114	N			
22	0.171	N			
23	0.114	N			
24	0.133	N			
25	0.152	N			
26	0.095	N			
27	0.114	N			
28	0.133	N			
29	0.133	N			
30	0.076	N			
31					



Indiana Department of Environmental Management
Office of Water Quality- Drinking Water Branch

Monthly reporting form for Daily, Monthly and additional Chlorite sampling for systems that use Chlorine Dioxide

PWSID#	5	2	0	2	0	2	0	Facility Name: Three Rivers Filtration Plant	
Submitted by: Jason Anspach								Month	Year
								November	2024

• Has reduced monitoring been granted for monthly monitoring? Yes ___ No ___*

Day	Chlorite daily sample level at (mg/L) @POE	Does Chlorite Daily sample level exceed 1.000 (mg/L) (Y/N)	Distribution	Distribution	Distribution	Routine Chlorite monthly Distribution sample
			Chlorite sample at first Customer (mg/L)	Chlorite sample at average residence time (mg/L)	Chlorite sample at maximum residence time (mg/L)	
1	0.757	N				Sample No. 1 @ first customer 0.790
2	0.755	N				
3	0.751	N				
4	0.750	N				
5	0.743	N				
6	0.754	N				
7	0.743	N				
8	0.744	N				
9	0.762	N				
10	0.783	N				
11	0.773	N				Sample No. 2 @ average residence time Customer 0.750
12	0.771	N				
13	0.704	N				
14	0.637	N				
15	0.612	N				
16	0.619	N				
17	0.627	N				
18	0.632	N				
19	0.636	N				
20	0.652	N				
21	0.616	N				Sample No. 3 @maximum residence time customer 0.670
22	0.638	N				
23	0.652	N				
24	0.669	N				
25	0.652	N				
26	0.631	N				
27	0.625	N				
28	0.656	N				
29	0.645	N				
30	0.655	N				
31						