




DATE	Site Wide Data	Filters	Chlorination		Water Chemistry											Comments	
	System Delivery (MGal)	Wash Water	Total Usage (Lbs)	CL2 Dosage (Lbs/Mgal)	Chlorine-Finished		Chlorine - Dist. (Merom Tank)		pH	Iron		Manganese		Alkalinity	Hardness		
		Wash Water (MGal)			Free Cl (grab) (mg/L)	Total Cl (grab) (mg/L)	Free Cl (grab) (mg/L)	Total Cl (grab) (mg/L)		Finished	Raw (mg/L)	Finished (mg/L)	Raw (mg/L)	Finished (mg/L)	Finished (mg/L)		Finished (mg/L-CaCO3)
1	0.0247	-	0.3	12.10	1.41	1.61	0.96	1.15	-	-	-	-	-	-	-	-	-
2	0.0247	-	0.3	12.10	1.14	-	0.85	-	-	-	-	-	-	-	-	-	-
3	0.0247	-	0.5	20.17	0.73	-	0.90	-	-	-	-	-	-	-	-	-	-
4	0.0366	0.022	0.9	24.56	1.64	1.84	1.04	1.11	7.91	0.13	0.01	0.260	0.066	300	340	-	-
5	0.0265	-	0.6	22.61	1.63	1.88	1.27	1.46	-	-	-	-	-	-	-	-	-
6	0.0181	-	0.2	10.97	1.42	1.61	1.07	1.18	-	-	-	-	-	-	-	-	-
7	0.0328	-	0.2	6.08	1.05	1.33	1.07	1.14	-	-	-	-	-	-	-	-	-
8	0.0221	0.005	0.4	18.03	1.55	1.79	1.37	1.44	-	-	-	-	-	-	-	-	-
9	0.0222	-	0.4	17.96	1.42	-	1.19	-	-	-	-	-	-	-	-	-	-
10	0.0220	-	0.4	18.11	1.24	-	1.16	-	-	-	-	-	-	-	-	-	-
11	0.0221	-	0.4	18.03	1.09	-	1.51	-	-	-	-	-	-	-	-	-	-
12	0.0334	0.008	0.5	14.92	1.61	1.67	1.05	1.15	7.91	2.34	0.01	0.360	0.173	300	350	-	-
13	0.0162	-	0.3	18.49	1.56	1.74	1.30	1.55	-	-	-	-	-	-	-	-	-
14	0.0228	-	0.4	17.52	1.59	1.70	1.13	1.25	-	-	-	-	-	-	-	-	-
15	0.0231	0.005	0.7	30.25	1.67	1.88	0.84	1.02	-	-	-	-	-	-	-	-	-
16	0.0231	-	0.4	18.00	0.65	-	0.95	-	-	-	-	-	-	-	-	-	-
17	0.0230	-	0.3	12.96	1.27	-	0.89	-	-	-	-	-	-	-	-	-	-
18	0.0298	0.005	0.8	26.63	1.58	1.67	1.05	1.10	7.75	1.04	0.02	0.367	0.168	330	350	-	-
19	0.0264	-	0.4	15.11	1.19	1.22	1.25	1.37	-	-	-	-	-	-	-	-	-
20	0.0180	-	0.3	16.58	1.59	1.73	1.25	1.30	-	-	-	-	-	-	-	-	-
21	0.0236	0.005	0.3	12.65	1.22	1.34	1.28	1.46	-	-	-	-	-	-	-	-	-
22	0.0211*	-	0.5	23.60*	1.18	1.42	1.00	1.21	-	-	-	-	-	-	-	-	-
23	0.0211*	-	0.5	23.60*	0.62	-	1.07	-	-	-	-	-	-	-	-	-	-
24	0.0211*	-	0.5	23.60*	0.70	-	0.64	-	-	-	-	-	-	-	-	-	-
25	0.0182*	-	0.1	5.47*	1.49	1.60	1.11	1.23	7.78	0.86	0.01	0.313	0.208	304	334	-	-
26	0.0182*	0.004	0.1	5.47*	1.46	1.50	1.01	1.07	-	-	-	-	-	-	-	-	-
27	0.0318	-	0.1	3.13	1.33	1.44	1.89	1.91	-	-	-	-	-	-	-	-	-
28	0.0299	-	0.3	9.97	0.98	-	1.21	-	-	-	-	-	-	-	-	-	-
29	0.0237*	0.004	0.3	12.58*	1.01	-	1.23	-	-	-	-	-	-	-	-	-	-
30	0.0237*	-	0.3	12.58*	0.91	-	1.21	-	-	-	-	-	-	-	-	-	-
Total	0.7249	0.059	11.7														
Max	0.0366	0.022	0.9	30.25	1.67	1.88	1.89	1.91	7.91	2.34	0.02	0.367	0.208	330	350		
Min	0.0162	0.004	0.1	3.13	0.62	1.22	0.64	1.02	7.75	0.13	0.01	0.260	0.066	300	334		
Avg	0.0242	0.007	0.4	16.13	1.26	1.61	1.13	1.28	7.84	1.09	0.01	0.325	0.154	309	344		

Site Wide Data		Certification	
Phone Number: 8122088253		I certify under penalty of law, by this signature that this document was prepared by me, or under my direction, and the information submitted is to the best of my knowledge and belief, true, accurate and complete. I am also aware that there are significant penalties for submitting false information.	
		Reported by: 	Cert or Reg Number: WT150119

*Calculated value based on an interpolated value