

MA

DEPARTMENT OF ENVIRONMENTAL MANAGEMENT

Indianapolis

OFFICE MEMORANDUM

DATE : June 21, 1988

TO : Joseph C. Krieger
Permits Section

THRU : A.B. Jumawan
T.P. Chang
J.C. Stallsmith
L.D. Brumfield

FROM : Mustafa Ak
Modeling and Engineering Services Section

SUBJECT : Updating the February 1987 Advance STP WLA Report
(Continuous and Controlled Discharge Analysis)

Reference : Memo dated June 9, 1988 from William E. Bye

At the request of William E. Bye of Facility Plans Section, a wasteload allocation study has been updated for the above facility due to changes in the design flow from 0.042 mgd to 0.038 mgd and potential discharge location to Big Raccoon Creek for the proposed plant. These evaluations are based on the Q₇₋₁₀ flow reduction due to mixing zone policies / guidelines, and acute / chronic water quality standards Rule 327 IAC 2-1. Model parameters used in the former report are also applied in this analysis.

The effluent limitations for a continuous discharge are controlled by the chronic ammonia toxicity as well as instream dissolved oxygen maintenance. For a waste stabilization pond system, controlled discharge is feasible when required holding volume/period (0.0778 MGAL/7.0 DAYS) is provided. This holding volume could be incorporated into the required multi-cell treatment pond(s) to have 25.0 mg/l CBOD₅ and 70.0 mg/l TSS effluent limits. The results of the analyses are summarized in the attached tables for both continuous and controlled discharge.

Results of this WLA analyses will be an addendum to the February 1987 Advance STP Wasteload Allocation report which is attached.

Attachments

cc: T. Keesling
W. E. Bye



MEMORANDUM
State Form 1352 (R / 12-87)

FROM: Bill Bye, Facility Plans
Thru: Tom Keeston

TO: 6/9/88
Greg Tomason, Modeling Section
MA

SUBJECT: Wastload Assessment for
Town of Acushnet

MESSAGE:
Please prepare a WLA for the Town of Acushnet on the two
Discharge points indicated in the A/E letter of April 7, 1988 (Copy Attached)
F.P. now indicates a HER Lagoon as selected treatment alternative
produced wastewater from 38,000 gpd.

Signature: William E. Bye Date: 6/9/88

REPLY: SEE ATTACHED TABLES

Signature: Mustafa Date: 6/21/88

Follow-up Date

DISTRIBUTION: White - Sender; Canary - Receiver; Pink - File Copy




TABLE : { RESULTS OF EFFLUENT LIMITATION ANALYSIS

FACILITY : PROPOSED ADVANCE STP, BOONE COUNTY

RECEIVING STREAM(s) : BIG RACCOON CREEK

Stream Designation : GEN USE STREAM

Analysis Basis : Analysis Performed for WARMWATER SPECIES HABITAT

Case I : Existing STDs [Rule 330 IAC 1-1 Recodified as 327 IAC 2-1]

	Summer (May Thr. November)		Winter (December Thr. April)	
FLOW	0.0380	mgd	0.0380	mgd
cBOD5	25.0	mg/l	25.0	mg/l
D.O.	5.0	mg/l	4.0	mg/l
AMMONIA-N				
(a) Acute (Effluent Based)	15.52	mg/l	31.97	mg/l
(Stream Based)	7.91	mg/l	16.16	mg/l
(b) Chronic (Stream Based)	1.99	mg/l	4.49	mg/l

[Based : Respective pH and Temperature data were used in the computations.]
 NH3-N and cBOD5 are on monthly average basis, whereas, D.O. is on Daily Ave.

Case II : Proposed Standards

Rule 327 IAC 2-1

	Summer (May Thr. November)		Winter (December Thr. April)	
FLOW	0.0380	mgd	0.0380	mgd
cBOD5	25.0	mg/l	25.0	mg/l
D.O.	5.0	mg/l	4.0	mg/l
AMMONIA-N				
(a) Acute (Effluent Based)	11.91	mg/l	12.29	mg/l
(Stream Based)	7.80	mg/l	7.97	mg/l
(b) Chronic (Stream Based)	2.81	mg/l	4.24	mg/l

[Based : Respective pH and Temperature data were used in the computations.]
 NH3-N and cBOD5 are on monthly average basis, whereas, D.O. is on Daily Ave.

Case III : Waste Stabilization Pond Systems Option [Controlled Discharge]

	Summer (May Thr. November)		Winter (December Thr. April)	
FLOW	0.038	mgd	0.038	mgd
cBOD5	25.00	mg/l	25.00	mg/l [Monthly]
TSS	70.00	mg/l	70.00	mg/l [Monthly]

Controlled Pond(s) Volume Required 0.08 mgal
 Holding Period 7.00 days

WASTE STABILIZATION LAGOON CONTROLLED DISCHARGE ANALYSIS

NAME of Facility : PROPOSED ADVANCED STP, RICHIE CREEK
 Flow Correction Factor for DO Analysis : 70.00 %
 Receiving Stream : BIG MOUNTAIN CREEK
 Gaging Station : BIG MOUNTAIN CK near FINECASTLE, PURNOM CO. Drainage area upstream of Referenced Gaging Station : 119.0 Sq.mi
 Facility Design Flow : 0.038 mgd
 Corrected FACILITY Flow used in the Analysis : 0.035 mgd
 7Q10 Flow : 0.04 cfs
 Drainage area upstream of Referenced Gaging Station : 119.0 Sq.mi
 Corrected FACILITY Flow : 0.035 mgd
 7Q10 Flow : 0.04 cfs
 Drainage area upstream of Referenced Gaging Station : 119.0 Sq.mi
 Corrected FACILITY Flow : 0.035 mgd
 7Q10 Flow : 0.04 cfs

Month	Lagoon Station cfs-day	Adjusted Flow w/s STP [cfs]	Dilution Ratio [R]	Allowable Discharge cfs-day [Q=Qs/R]	STP Flow cfs-day [Di]	Cumulative Flow Qo-out	Deficiency cfs-day [Qi-Qo]	Accumulation Sum[Qi-Qo]
JAN	423.00	41.2306	10	4.1231	1.2781	4.1231	0.0000	0.0000
FEB	904.00	76.7424	10	7.6742	1.2369	11.8679	-6.4373	0.0000
MAR	4409.00	373.5251	10	37.3525	1.2781	49.2204	-36.0743	0.0000
APR	4121.00	375.0158	10	37.5016	1.2781	86.5220	-36.0234	0.0000
MAY	1451.00	125.2243	10	12.5224	1.1544	211.7467	-124.0598	0.0000
JUN	775.00	65.8138	10	6.5814	1.2781	277.5601	-64.5556	0.0000
JUL	1705.00	110.7641	10	11.0764	1.2369	288.5585	-9.8415	0.0000
AUG	204.00	51.2748	10	5.1274	1.2781	293.7860	-3.8493	0.0000
SEP	3453.00	293.5568	10	29.3556	1.2369	323.1417	-11.2557	0.0000
OCT	3010.00	255.5251	10	25.5525	1.2781	348.6942	-24.2743	0.0000
NOV	2278.00	171.3191	10	17.1319	1.2781	365.0326	-19.0602	0.0000
DEC	208.50	17.7000	10	1.7700	1.2781	369.8036	-0.5331	0.0000

Month	Gaging Station cfs-day	Adjusted Flow w/s STP [Qs]	Dilution Ratio [R]	Allowable Discharge cfs-day [Q=Qs/R]	STP Flow cfs-day [Di]	Cumulative Flow Qo-out	Deficiency cfs-day [Qi-Qo]	Accumulation Sum[Qi-Qo]
JAN	247.80	21.0322	10	2.1032	1.2781	2.1032	-0.0224	0.0000
FEB	221.10	18.9394	10	1.8939	1.2369	3.9975	-0.6579	0.0000
MAR	170.40	14.4654	10	1.4465	1.2781	5.4441	-0.1644	0.0000
APR	145.20	11.3108	10	1.2311	1.2781	6.6756	0.0406	0.0406
MAY	1769.50	150.2165	10	15.0216	1.1544	21.6592	-13.8672	0.0000
JUN	5450.00	466.0575	10	46.6057	1.2781	68.3050	-45.3276	0.0000
JUL	3403.00	301.1877	10	30.1188	1.2369	97.1517	-27.6118	0.0000
AUG	1049.00	156.4654	10	15.6465	1.2781	112.8703	-14.4784	0.0000
SEP	1190.70	101.0610	10	10.1061	1.2369	122.9984	-9.1272	0.0000
OCT	2101.20	178.3837	10	17.8384	1.2781	140.8369	-16.5602	0.0000
NOV	3217.00	274.6635	10	27.4663	1.2781	168.3031	-26.2082	0.0000
DEC	925.00	71.5251	10	7.1525	1.2369	174.1756	-6.6156	0.0000

Month	Gaging Station cfs-day	Adjusted Flow w/s STP [Qs]	Dilution Ratio [R]	Allowable Discharge cfs-day [Q=Qs/R]	STP Flow cfs-day [Di]	Cumulative Flow Qo-out	Deficiency cfs-day [Qi-Qo]	Accumulation Sum[Qi-Qo]
JAN	9045.00	767.4019	10	76.7402	1.2781	76.7402	-75.5647	0.0000
FEB	2267.00	192.4503	10	19.2450	1.2369	96.0279	-18.0081	0.0000
MAR	14818.00	1257.9309	10	125.7931	1.2781	221.8230	-124.5149	0.0000
APR	2643.00	216.4270	10	21.6427	1.2781	244.4722	-11.3710	0.0000
MAY	1017.00	86.3357	10	8.6336	1.1544	253.1057	-7.4790	0.0000
JUN	1117.00	177.2503	10	17.7250	1.2781	432.8307	-128.4469	0.0000
JUL	4192.40	560.2028	10	56.0202	1.2369	488.8510	-94.7833	0.0000
AUG	10951.00	930.5021	10	93.0502	1.2781	581.9012	-91.7720	0.0000
SEP	1177.00	184.9793	10	18.4979	1.2369	600.3992	-17.2610	0.0000
OCT	1774.00	151.0230	10	15.1023	1.2781	615.5015	-13.1241	0.0000
NOV	4931.00	418.6078	10	41.8608	1.2781	657.3619	-40.5821	0.0000
DEC	1726.00	146.5237	10	14.6523	1.2369	672.0142	-13.4154	0.0000

At 07:10 Flow Conditions : CONTROLLED WASTEWATER VOLUME : 0.078 Mgal HOLDING PERIOD : 7.00 Days

Remark (s) :

LAKE TREATMENT PLANT - PROVIDED ADVANCE 5IP SUMMER WINDLOAD ALLOCATION ANALYSIS BASED ON USEPA SIMPLIFIED MODEL DATE = 06/10/84
 CANNONVILLE BORNE COUNTRY REF. TOWN STREAM = 3RD RIVINGTON CREEK MAIN STATION = WABASH RIVER SIMULATED BY = H.A.K.

WIND LOADS ARE BEING IGNORED DUE TO ANOTHER ALTERNATIVE PUMP SITE

SELECTED WATER QUALITY STATISTICS

INSTREAM DISSOLVED OXYGEN = 5.0 MG/L
 (American Standard, as listed on the EXISTING RISE 387 100 P-1)

INDICATOR AND ELEMENT WATER QUALITY INDICATORS BEACH NUMBER 1

INDICATOR	FLOW CFS	WQ (ULTIMATE) MG/L	WQ (MG/L)	DISSOLVED OXYGEN MG/L	TEMPERATURE CG
INFLUENT WATER QUALITY	0.240	5.000	0.300	7.340	25.00
EFFLUENT WATER QUALITY	0.054	58.000	9.100	5.000	25.00
STREAM WQ AT 5IP	0.199	15.458	2.074	6.095	25.00

HYDRAULIC CHARACTERISTICS OF WEEDS BELOW TREATMENT PLANT OR JUNCTION

VELOCITY IN FT/SEC = 0.060 HYDRAULIC DEPTH IN FT = 0.0900 STREAM BED SLOPE IN FT/MILE = 7.60 MANNING'S COEFF = 0.035
 BRANCH BIG RACKOON CREEK MILES TRUN 6.000 TO 0.000 COMPUTATIONAL ELEMENT 0.25000 MILE

WINDLOAD BEHAVIORAL VALUES

WINDLOAD BEHAVIORAL VALUE	AT 50 CG	AT INSTREAM TWP 25.00 CG	REMARK
WIND PROXIMATE RATE (1/DAY)	13.15/32	14.81382	1 (MANNING-DURUM EQ.)
WIND DECAY RATE (1/DAY)	0.40000	0.50326	
WIND DECAY RATE (1/DAY)	0.40000	0.58773	
WIND (WIND) RATE (1/DAY)	0.00000	0.00000	"-SUSPENSION "+ SEDIMENTATION
WIND (WIND) OXYGEN DEMAND	0.00000	0.01102	IN CG/50.0/DAY AT 70 CG

SUBSURFACE WATER QUALITY CORRELATION OF A DISCHARGE OR BELOW JUNCTION

TIME HOURS	DISTANCE BELOW REACH MILE	DISCHARGE FROM OUTFALL	MINIMUM DISSOLVED OXYGEN MG/L	DO (15 MINUTE) MG/L	SS/D MG/L
0.20	4.00	MILE = 0.00	6.895	15.403	2.016
0.25	5.75	MILE = 0.25	6.502	13.598	1.753
0.50	5.50	MILE = 0.50	6.559	11.963	1.509
0.75	5.25	MILE = 0.75	6.613	10.524	1.299
1.01	5.00	MILE = 1.00	6.570	9.258	1.119
1.27	4.75	MILE = 1.25	6.716	8.145	0.971
1.53	4.50	MILE = 1.50	6.756	7.165	0.829
1.78	4.25	MILE = 1.75	6.791	6.303	0.714
2.03	4.00	MILE = 2.00	6.801	5.545	0.615
2.29	3.75	MILE = 2.25	6.898	4.878	0.529
2.54	3.50	MILE = 2.50	6.872	4.291	0.455
2.80	3.25	MILE = 2.75	6.891	3.775	0.392
3.05	3.00	MILE = 3.00	6.911	3.301	0.341
3.31	2.75	MILE = 3.25	6.927	2.921	0.291
3.56	2.50	MILE = 3.50	6.931	2.570	0.240
3.81	2.25	MILE = 3.75	6.953	2.261	0.215
4.07	2.00	MILE = 4.00	6.964	1.989	0.185
4.33	1.75	MILE = 4.25	6.974	1.740	0.159
4.58	1.50	MILE = 4.50	6.987	1.519	0.137
4.83	1.25	MILE = 4.75	6.989	1.354	0.118
5.07	1.00	MILE = 5.00	6.976	1.191	0.103
5.34	0.75	MILE = 5.25	7.001	1.048	0.087
5.60	0.50	MILE = 5.50	7.006	0.922	0.074
5.85	0.25	MILE = 5.75	7.041	0.811	0.065
6.11	0.00	MILE = 6.00	7.014	0.713	0.056

MINIMUM DISSOLVED OXYGEN 6.500 MG/L OCCURS AT 0.216 HOURS AND 0.2125 MILES
 BELOW DISCHARGE OR JUNCTION

PROJECT: WINTER WASTEWATER TREATMENT PLANT ADVANCED SUPPLY MODEL
 COUNTY: BIG BEND COUNTY
 WINTER WASTEWATER TREATMENT PLANT ADVANCED SUPPLY MODEL
 DATE: 06/14/90

REGULATING STREAM: BIG BEND CREEK
 MAIN STREAM: MUDGASH RIVER
 CIRCULATED BY: M. J. R.

STATION WATER QUALITY SIMULATIONS

INSTREAM DISOXYGEN DEFICIT = 5.0 MG/L
 (computed standards to be used by the existing model) FIG 2-1

WATER QUALITY ELEMENT	QUALITY INPUT DATA	REACH NUMBER
INFLUENT BOD QUALITY	0.059	5.000
INFLUENT WATER QUANTITY	58.000	20.500
STREAM WQ D/S OF SUP	15.433	4.230

HYDRAULIC CHARACTERISTICS OF STREAM (SEASON-TREATMENT-PLANT) JUNCTION

VELOCITY IN FT/SEC = 0.060
 CHANNEL DEPTH IN FT = 0.0300
 STRAIN H/D SLOPE IN FT/MI = 7.60
 KINEMATIC COEFF = 0.035

REACH LENGTH MILES = 6.000
 COMPUTATIONAL ELEMENT = 0.25000 MILE

VEGETATION AND REDUCTION RATES

VEGETATION	AT 20 CG	AT INSTREAM HMP	REMARK
PLANTATION RATE (L/DAY)	13.1573P	11.603/04	LANGBIEN-DURUM ER.
BOD DECAY RATE (1/DAY)	0.40000	0.3179P	
SEDIMENTATION RATE (1/DAY)	0.40000	0.2709P	
SEDIMENTATION RATE (1/DAY)	0.00000	0.00000	"-SUSPENSION " SEDIMENTATION
SEDIMENTATION (G/M ² /DAY)	0.30000	0.21896	IN GM/M ² /DAY AT 20 CG

STATIONARY-TESTING WITH WALK-WHEELS IN THE SYSTEM OF A DISTANCE OR BELOW JURISDICTION

TIME HOUR	DISTANCE MILE	REMAIN MILE	POSITION FROM	DISOXYGEN M/L	PH (MULTIPLY) M/L	NANO M/L
0.00	6.00	0.00	MILE = 0.00	6.698	15.403	4.285
0.25	5.75	0.25	MILE = 0.25	8.471	14.256	3.998
0.50	5.50	0.50	MILE = 0.50	8.867	13.147	3.711
0.75	5.25	0.75	MILE = 0.75	8.847	12.125	3.411
1.00	5.00	1.00	MILE = 1.00	8.829	11.102	3.140
1.25	4.75	1.25	MILE = 1.25	8.909	10.082	3.030
1.50	4.50	1.50	MILE = 1.50	8.976	9.510	2.827
1.75	4.25	1.75	MILE = 1.75	8.961	8.771	2.638
2.00	4.00	2.00	MILE = 2.00	8.984	8.019	2.461
2.25	3.75	2.25	MILE = 2.25	9.005	7.460	2.296
2.50	3.50	2.50	MILE = 2.50	9.026	6.879	2.142
2.75	3.25	2.75	MILE = 2.75	9.044	6.341	1.997
3.00	3.00	3.00	MILE = 3.00	9.051	5.851	1.851
3.25	2.75	3.25	MILE = 3.25	9.077	5.396	1.740
3.50	2.50	3.50	MILE = 3.50	9.091	4.976	1.623
3.75	2.25	3.75	MILE = 3.75	9.105	4.589	1.515
4.00	2.00	4.00	MILE = 4.00	9.117	4.232	1.413
4.25	1.75	4.25	MILE = 4.25	9.129	3.903	1.319
4.50	1.50	4.50	MILE = 4.50	9.139	3.600	1.230
4.75	1.25	4.75	MILE = 4.75	9.149	3.320	1.148
5.00	1.00	5.00	MILE = 5.00	9.158	3.062	1.071
5.25	0.75	5.25	MILE = 5.25	9.167	2.823	0.997
5.50	0.50	5.50	MILE = 5.50	9.174	2.604	0.930
5.75	0.25	5.75	MILE = 5.75	9.181	2.401	0.870
6.00	0.00	6.00	MILE = 6.00	9.188	2.215	0.811

MINIMUM DISTANCE BELOW JURISDICTION OCCURS AT 0.000 MILE AND 0.0000 MILES
BELOW DISTANCE OR JURISDICTION

PLANT TREATMENT PLANT PROPOSED ADVANCE SIP SUMMER WASTE (M) ALLOCATION ANALYSIS (BASED ON USEPO SIMPLIFIED MODEL) DATE = 06/14/88
CANTON COUNTY RECEIVING STREAM = BIG BROOK CREEK MAINT (M) (M) = MASSASH RIVER CALCULATED BY = M.L.H.

STANDARD WATER QUALITY STANDARDS
TO PROTECT OR RESTORE OR MAINTAIN FISH SITE

STREAM CLASS. TO WHICH = 5.0 mg/l
Standard Standards is based on the PROPOSED RULE 227 IAC 2.1

PARAMETER	QUALITY	STANDARD	REACH NUMBER
TEMPERATURE	25.00	25.00	1
DISSOLVED OXYGEN	7.362	7.362	1
PH	8.000	8.000	1
TOTAL SOLIDS	15.413	15.413	1

HYDRAULIC CHARACTERISTICS

VELOCITY IN FT/SEC = 0.000 HYDRAULIC DEPTH IN FT = 0.00000 STREAM BED SLOPE IN FT/MILE = 7.60 HANNING'S COEFF = 0.035
ROUGHNESS COEFFICIENT = 0.000 FROM 6.000 TO 0.000 COMPUTATIONAL ELEMENT 0.25000 MILE

SEDIMENTATION AND FLOCCULATION RATES

PARAMETER	UNIT	VALUE	REMARKS
FLOCCULATION RATE	1/DAY	13.15732	AT FLOC
SEDIMENTATION RATE	1/DAY	0.40000	AT INSTRIAM TEMP 25.00 C
SEDIMENTATION RATE	1/DAY	0.40000	LANGBIEN-DIRLUM EQ.
SEDIMENTATION RATE	1/DAY	0.00000	"LARGE PARTICLES" SEDIMENTATION
SEDIMENTATION RATE	1/DAY	0.40000	IN M/SQ.M/DAY AT 20 C

FIGURE 2. DISCHARGE RATES QUELLY POWERS (BEH) DE-A. DISCHARGER, OR BELOW JUNCTION

TIME HRS	DISCHARGE M ³ /H	ALLOW MILE	DISCHARGE FROM MILE	DISCHARGE M ³ /H	DISCHARGE M ³ /H	RIND (IN THIN) M ³ /H	HEAD M ³ /H
0.00	MILE = 6.00	MILE = 0.00	MILE = 0.00	6.895	15.450	2.766	
0.25	MILE = 5.75	MILE = 0.25	MILE = 0.25	6.477	10.503	2.384	
0.50	MILE = 5.50	MILE = 0.50	MILE = 0.50	6.537	11.963	2.050	
0.75	MILE = 5.25	MILE = 0.75	MILE = 0.75	6.197	10.534	1.765	
1.00	MILE = 5.00	MILE = 1.00	MILE = 1.00	6.653	9.258	1.520	
1.25	MILE = 4.75	MILE = 1.25	MILE = 1.25	6.761	8.145	1.309	
1.50	MILE = 4.50	MILE = 1.50	MILE = 1.50	6.743	7.165	1.127	
1.75	MILE = 4.25	MILE = 1.75	MILE = 1.75	6.780	6.303	0.970	
2.00	MILE = 4.00	MILE = 2.00	MILE = 2.00	6.817	5.545	0.835	
2.25	MILE = 3.75	MILE = 2.25	MILE = 2.25	6.841	4.878	0.719	
2.50	MILE = 3.50	MILE = 2.50	MILE = 2.50	6.866	4.291	0.619	
2.75	MILE = 3.25	MILE = 2.75	MILE = 2.75	6.887	3.775	0.533	
3.00	MILE = 3.00	MILE = 3.00	MILE = 3.00	6.906	3.321	0.459	
3.25	MILE = 2.75	MILE = 3.25	MILE = 3.25	6.923	2.921	0.394	
3.50	MILE = 2.50	MILE = 3.50	MILE = 3.50	6.937	2.570	0.340	
3.75	MILE = 2.25	MILE = 3.75	MILE = 3.75	6.950	2.261	0.293	
4.00	MILE = 2.00	MILE = 4.00	MILE = 4.00	6.961	1.989	0.252	
4.25	MILE = 1.75	MILE = 4.25	MILE = 4.25	6.971	1.750	0.217	
4.50	MILE = 1.50	MILE = 4.50	MILE = 4.50	6.980	1.539	0.187	
4.75	MILE = 1.25	MILE = 4.75	MILE = 4.75	6.988	1.344	0.161	
5.00	MILE = 1.00	MILE = 5.00	MILE = 5.00	6.994	1.191	0.138	
5.25	MILE = 0.75	MILE = 5.25	MILE = 5.25	7.000	1.048	0.117	
5.50	MILE = 0.50	MILE = 5.50	MILE = 5.50	7.005	0.922	0.100	
5.75	MILE = 0.25	MILE = 5.75	MILE = 5.75	7.010	0.811	0.088	
6.00	MILE = 0.00	MILE = 6.00	MILE = 6.00	7.014	0.717	0.076	

MINIMUM DISCHARGE OCCURS AT 0.237 HRS AND 0.2130 MILES
 MINIMUM DISCHARGE OR JUNCTION 6.474 M³/H

PROJECT TREATMENT PLANT = PROPOSED ADVANCE BIP WINTER WASTEWATER POLLUTION ANALYSIS BASED ON US EPA SIMPLIFIED MODEL DATE = 05/14/88
 COUNTY = BUTTE COUNTY MODELING STREAM = BIG SOCCOMI CREEK MAIN STREAM = WASHBURN RIVER SIMULATED BY = H. AI

SECTION 1: INPUT DATA TO QUALITY MODELING PROGRAM

GENERAL WATER QUALITY SETTINGS

INITIAL DISSOLVED OXYGEN = 5.0 MG/L
 INITIAL BOD Standards is based on the FURFURER RULE 307 INC 2-1

INITIAL BOD AND CHEMICAL QUALITY INPUT DATA: REACH NUMBER: 1

PARAMETER	FLOW CFS	INBO (CUMULATIVE) MG/L	MBOD MG/L	DISSOLVED OXYGEN MG/L	TEMPERATURE DEG
PERMANENT WATER QUANTITY	0.240	5.000	0.300	7.352	15.00
EFFLUENT WATER QUANTITY	0.059	58.000	19.400	4.000	15.00
STREAM WQ CFS OF STP	0.289	15.458	4.068	6.698	15.00

SECTION 2: CHARACTERISTICS OF STREAM BELOW INVESTMENT PLANT AS JUNCTION

VELOCITY TRIPSET = 0.665 HYDRAULIC DIPTH IN FT = 0.0000 STREAM BFD VALUE IN FT/MI.F = 7.000 MANNING'S COEFF = 0.035
 INFLOW BOD POTENTIAL COEFF VALUE = 1.000 TO 0.000 COMPUTATIONAL ELEMENT 0.25000 MI.F

SECTION 3: MODELING RESULTS

PARAMETER	11/00/81	13.00/81	AT EX C/S	AT INSTREAM TRAP	REMARK
PERMANENT BOD	13.00/81	13.00/81	15.00	CG	
PERMANENT BOD	11/00/81	0.40000	0.31792		LAMBERTER-DIAPHR EQ.
PERMANENT BOD	11/00/81	0.40000	0.27223		
PERMANENT BOD	11/00/81	0.00000	0.00000		"-" SUSPENSION "+" SEDIMENTATION
PERMANENT BOD	11/00/81	0.10000	0.21896		IN GM/SQ.M/DAV AT P/O C/S

INDIANA DEPARTMENT OF ENVIRONMENTAL MANAGEMENT
OFFICE OF WATER MANAGEMENT

ADVANCE STP
BOONE COUNTY

WASTELOAD ALLOCATION ANALYSIS

SIMPLIFIED STEADY STATE MODEL

February 1987

Summary

A wasteload allocation analysis has been performed for the proposed sewage treatment plant of the Town of Advance, Boone County. The purpose of the analysis is to determine the National Pollutant Discharge Elimination System (NPDES) effluent permit limits in conjunction with the U.S. EPA construction grant funding requirements. The summer and winter effluent limits, to meet water quality standards, were determined by using the U.S. EPA steady state simplified mathematical water quality model. Presently, the Town of Advance does not have a wastewater treatment facility. The proposed sewage treatment plant (STP) will have a design flow of 0.042 mgd and will be discharging its effluent into Brinegar Ditch, then to the Walnut Fork Sugar Creek/Sugar Creek. The drainage area of the primary receiving stream above the proposed site is estimated to be 1.0 square-mile, and 7-day, 10-year low-flow ($Q_{7,10}$) is about zero.

Also, a controlled discharge analysis has been performed as an option to the continuous discharge analysis.

The recommended effluent limits for continuous discharge analysis are as follows:

<u>Summer</u>	<u>Winter</u>
CBOD ₅ = 25.0 mg/l	25.0 mg/l
TSS ₅ = 30.0 mg/l	30.0 mg/l
DO = 6.0 mg/l	5.0 mg/l
NR ₃ -N = 1.6 mg/l	3.1 mg/l

A. General Description

The Town of Advance is located in southwest Boone County in central Indiana. Currently, Advance does not have a municipally owned sewage treatment facility. The proposed plant will be discharging its effluent first to Brinegar Ditch, then to the Walnut Fork Sugar Creek and Sugar Creek. The Town's projected population for the year 2010 would be 600 people (1). The plant design flow for this population is determined to be 0.042 million gallon day (MGD).

B. Applicable Water Quality Standards

The receiving stream of the Advance STP is covered under Indiana's Rule 330 IAC 1-1 and is designated for general use including the protection of fish and aquatic life. The general use designation of streams requires a daily average instream dissolved oxygen (DO) concentration of 5.0 mg/l and a limitation on toxic substances to 1/10 of the 96-hour lethal concentration (LC₅₀) for indigenous life. This would include a weekly average instream ammonia concentration of not more than 0.05 mg/l un-ionized ammonia (0.033 mg/l monthly).

C. Wasteload Allocation Parameters and Their Determination

The effluent quality required to meet water quality standards was determined by the U.S. EPA simplified modeling techniques. The water quality input variables for this modeling analysis were extrapolated from field measurements conducted by the Indiana Department of Environmental Management (IDEM) Survey Section in March and May 1986 (2). During the survey, stream channel characteristics and time of travel were measured. These values are presented in Table 1. The velocity and depth were determined by extrapolating the March-June 1986 survey data at $Q_{7,10}$ conditions. The Langbien-Durum reaeration equation was selected for the reaeration reaction rate (K_2), because it resulted with a reasonable and typical value for the given characteristics of the receiving stream (3). BOD rate coefficient (K_1) NBOD rate coefficient (K_3), and SOD rate coefficient (K_5) were determined by using the U.S. EPA simplified modeling guidelines (4).

D. Sensitivity Analysis

The sensitivity analysis of each input variable for the proposed outfall location are presented in Figures 1 and 2. Three sets of calculations were made for each input variable by using model variables that represent the worst and the best ends of their sensitivity ranges and the value actually used in the wasteload allocation. Figure 1 illustrates the high sensitivity of total ammonia-N to changes in pH rather than temperature. As they are shown in Figure 2, the variables that require the most precision in the projected WLAs are the determination of K_2 and K_1 rates. The remaining input variables in the model require somewhat less precision.

E. Recommended Effluent Limitations

The computer printouts for the summer and winter wasteload allocations are presented in Table 2 and Table 3 from which the instream water quality is associated with the recommended effluent limitations.

The recommended effluent limitations for both summer and winter months are presented in Table 4. The upstream flow was not changed for the winter analysis because streams in the area often experience flows near the summer $Q_{7,10} = 0.0$ cfs during the winter months. For both the summer and winter wasteload allocations, the ammonia-N requirements were set at the toxicity limit and the effluent BOD concentration was varied until an instream dissolved oxygen concentration of 5.0 mg/l was achieved.

Table 5 demonstrates the relationship between the various treatment levels and the resulting ammonia-N and dissolved oxygen concentrations.

F. Controlled Discharge Analysis

As an option to the continuous discharge the feasibility of a controlled discharge operation which is essentially based on the availability of receiving stream flow for dilution is examined. The analysis is in accordance with the September 1985 controlled discharge guidelines(5) and the Indiana

Department of Environmental Management's, Water Management's, Controlled Discharge Committee memo of February 1987.(6) The IDEM existing guidelines impose a stream to plant discharge flow ratio of 5 from May through September and 3 from October through April. Presently, the guidelines are under review the reflect the impacts of mixing zones in instream water quality. Therefore, an additional analysis was performed by utilizing dilution ratios of 6:1 and 10:1 for winter and summer; respectively.

Since there is no USGS flow recording station on the upstream of the proposed Advance STP, it is necessary to select the nearest USGS gaging station in order to project the upstream flow of the STP. A review/evaluation of Indiana Water Resources Data indicates that the nearest USGS flow record station is on Sugar Creek at Crawfordsville, Montgomery County. A review of the past ten years shows that water year 1977 has the lowest annual flow at the reference station, and its flow data was used as a base water year together with the flow data of water years 1976 and 1978. Then, flow data of the reference gaging station was adjusted to the receiving stream by drainage area ratio method to determine the required storage ponds.


G. Results of the Analysis

Part I of the attached Table 6 represents the information, data and parameters of the controlled discharge analysis according to the above mentioned guidelines. Part II represents the computation of required storage pond size. Columns 2 and 3 of the tabulated data represent the transfer of flow data from the reference gaging station to the receiving stream. Using the conservation of mass (volume in this case) principle for a pond storage system, the maximum volume of wastewater held due to insufficient flow of the receiving stream to meet the dilution requirement is shown on the 10th column which is 5.83 mgal. and 8.20 mgal. for the dilution ratios of 3:1/5:1 and 6:1/10:1, respectively.


Based on 70.0 gpcd water consumption and 600 people population of or the year 2010, the Town's controlled discharge treatment system should consist of a treatment pond and a controlled discharge storage pond for a holding period of 195 days. The treatment pond should be sized to provide sufficient surface to meet the recommended organic loading (25.0 lb. BOD₅/acre-day) and should be at least two cells in order to meet effluent quality of 25.0 mg/l CBOD₅ and 70.0 mg/l TSS on a maximum monthly average basis.

References

1. Stevens, Jill; IDEM Facility Plan Section
2. IDEM Survey Data, March-May 1986.
3. Determining the Reaeration Coefficients of Ohio Streams, Ohio Environmental Protection Agency.
4. U.S. Environmental Protection Agency (EPA Simplified Modeling Technology for National Use, 1980 w/Addendum June 1982).
5. Revised Controlled Discharge Guidelines for Wastewater Stabilization Lagoon, September 1985.
6. Memo from IDEM Water Management Controlled Discharge Committee, February 1987.



COMPLIANCE OF SOUTHERN ILLINOIS WASTE TREATMENT PLANT = CINCINNATI STP. COUNTY = CLATSOP CO.
Y - AXIS REPRESENTS INCREASING AMMONIA-N VARIATION MG/L WRT TO TEMPERATURE AND pH



EFFLUENT AMMONIA-N LIMIT = 1.6 MG/L MONTHLY CINCINNATI WASTE TREATMENT PLANT LIMITATION = 1.6 MG/L MONTHLY

REPRODUCTION FOR THE UNITED STATES DEPARTMENT OF THE INTERIOR

UNITED STATES GEOLOGICAL SURVEY
 WASHINGTON, D. C. 20540

REPORT OF INVESTIGATION

WATER RESOURCES DIVISION
 SURFACE WATER BRANCH
 RIVERS AND STREAMS SECTION
 WATER RESOURCES DIVISION
 SURFACE WATER BRANCH
 RIVERS AND STREAMS SECTION

WATER RESOURCES DIVISION
 SURFACE WATER BRANCH
 RIVERS AND STREAMS SECTION
 WATER RESOURCES DIVISION
 SURFACE WATER BRANCH
 RIVERS AND STREAMS SECTION

WATER RESOURCES DIVISION
 SURFACE WATER BRANCH
 RIVERS AND STREAMS SECTION
 WATER RESOURCES DIVISION
 SURFACE WATER BRANCH
 RIVERS AND STREAMS SECTION

WATER RESOURCES DIVISION
 SURFACE WATER BRANCH
 RIVERS AND STREAMS SECTION
 WATER RESOURCES DIVISION
 SURFACE WATER BRANCH
 RIVERS AND STREAMS SECTION

WATER RESOURCES DIVISION
 SURFACE WATER BRANCH
 RIVERS AND STREAMS SECTION
 WATER RESOURCES DIVISION
 SURFACE WATER BRANCH
 RIVERS AND STREAMS SECTION

WATER RESOURCES DIVISION
 SURFACE WATER BRANCH
 RIVERS AND STREAMS SECTION
 WATER RESOURCES DIVISION
 SURFACE WATER BRANCH
 RIVERS AND STREAMS SECTION

STAGE TREATMENT PLANT = ADVANCE STP. SUMMER WASTELoad ANALYSIS BASED ON USEPA SIMPLIFIED MODEL DATE = 02/18/87

COUNTY = HOOVER COUNTY RECEIVING STREAM = ARKHEAR DITCH MAIN STREAM = WIGOR CREEK SIMULATED BY = R. AK

NUMBER OF STAGES

STREAM QUALITY STANDARDS

DISSOLVED OXYGEN = 5.00 MG/L. UNIONIZED AMMONIA IN MG/L = 0.050 (WEEKLY) 0.033 (MONTHLY)

HEADWATER AND EFFLUENT QUALITY ANALYSIS REACH NUMBER

	FLOW CFS	BOD (ULTIMATE) MG/L	BOD MG/L	DISSOLVED OXYGEN MG/L	TEMPERATURE CG
HEADWATER WATER QUALITY	0.000	0.000	0.000	0.000	0.00
EFFLUENT WATER QUALITY	0.060	57.500	7.100	6.000	25.00
STREAM WQ C/S AT STP	0.060	57.500	7.100	6.000	25.00

HYDRAULIC CHARACTERISTICS OF STREAMS BELOW TREATMENT PLANT OR JUNCTION

VELOCITY IN FT/SEC = 0.060 HYDRAULIC DEPTH IN FT = 0.0800 STREAM BED SLOPE IN FT/MILE = 7.60 MINIMUM COEFF = 0.035

REACH SPREADING DITCH MILES FROM TO 0.000 COMPUTATIONAL ELEMENT 0.25000 MILE

REACTION AND REPAIR RATES

	AT 20 CG	AT INSUREON TEMP 25.00 CG	REMARK
--	----------	------------------------------	--------

REPAIR RATE 11/DAY 17.15702 14.61362 LANGRISH-MURUM EQ.

WQ DECAY RATE 11/DAY 0.40000 0.50326

WQ GROW RATE 11/DAY 0.40000 0.58773

SEDIMENTATION RATE 11/DAY 0.00000 0.00000

EFFLUENT (EFFLUENT) OXYGEN DEMAND 0.30000 0.41102

* - "SUSPENSION" + "SEDIMENTATION"

IN GM/SQ.M/DAY AT 20 CG

STATUS OF THE FACILITY, COMPOSITE OF D. DISCHARGE OF BELOW JURISDICTION

TIME MINS	DISTANCE FROM POLLING	DIRECTION FROM OUTLET	DISSOLVED OXYGEN MG/L	BOD (ULTIMATE) MG/L	NBOD MG/L
0.00	MILE = 4.00	MILE = 0.00	6.000	57.500	7.100
0.25	MILE = 5.75	MILE = 0.25	5.040	50.500	6.113
0.50	MILE = 5.50	MILE = 0.50	5.250	40.500	5.263
0.75	MILE = 5.25	MILE = 0.75	5.478	39.146	4.531
1.00	MILE = 5.00	MILE = 1.00	5.659	34.439	3.907
1.25	MILE = 4.75	MILE = 1.25	5.878	30.297	3.359
1.50	MILE = 4.50	MILE = 1.50	5.955	26.453	2.892
1.75	MILE = 4.25	MILE = 1.75	6.114	23.497	2.490
2.00	MILE = 4.00	MILE = 2.00	6.298	20.627	2.144
2.25	MILE = 3.75	MILE = 2.25	6.327	18.146	1.846
2.50	MILE = 3.50	MILE = 2.50	6.415	15.963	1.587
2.75	MILE = 3.25	MILE = 2.75	6.471	14.013	1.368
3.00	MILE = 3.00	MILE = 3.00	6.507	12.354	1.178
3.25	MILE = 2.75	MILE = 3.25	6.618	10.868	1.014
3.50	MILE = 2.50	MILE = 3.50	6.689	9.551	0.873
3.75	MILE = 2.25	MILE = 3.75	6.715	8.411	0.752
4.00	MILE = 2.00	MILE = 4.00	6.755	7.399	0.647
4.25	MILE = 1.75	MILE = 4.25	6.790	6.507	0.557
4.50	MILE = 1.50	MILE = 4.50	6.821	5.724	0.480
4.75	MILE = 1.25	MILE = 4.75	6.847	5.031	0.413
5.00	MILE = 1.00	MILE = 5.00	6.871	4.432	0.355
5.25	MILE = 0.75	MILE = 5.25	6.892	3.929	0.306
5.50	MILE = 0.50	MILE = 5.50	6.910	3.430	0.263
5.75	MILE = 0.25	MILE = 5.75	6.924	3.017	0.227
6.00	MILE = 0.00	MILE = 6.00	6.940	2.654	0.195

MINIMUM DISOXYGEN 5.01 MG/L OCCURS AT 0.250 MIN AND 0.1963 MILES
BELOW DISCHARGE OF TREATMENT

STANDARD FOR BRIDGE WATER QUALITY MONITORING OF D. DISCHARGES AS OF BELLAIR JUNCTION

LINE NO.	DISTANCE FROM BELLAIR MILE	MEAN COUNTER NUMBER	DISCHARGE OF OXYGEN M3/L	BOD (ULTIMATE) MGD/L	NPOD MGD/L
0.00	MILE = 0.00	MILE = 0.00	0.000	57.500	14.100
0.25	MILE = 0.25	MILE = 0.25	7.200	54.928	13.119
0.50	MILE = 0.50	MILE = 0.50	7.461	48.721	12.208
0.75	MILE = 0.75	MILE = 0.75	7.596	44.848	11.359
1.01	MILE = 1.00	MILE = 1.00	7.717	41.217	10.570
1.27	MILE = 1.25	MILE = 1.25	7.853	38.091	9.835
1.52	MILE = 1.50	MILE = 1.50	7.930	34.110	9.151
1.78	MILE = 1.75	MILE = 1.75	8.024	32.197	8.515
2.03	MILE = 2.00	MILE = 2.00	8.111	29.839	7.923
2.29	MILE = 2.25	MILE = 2.25	8.191	27.213	7.379
2.54	MILE = 2.50	MILE = 2.50	8.261	25.114	6.860
2.80	MILE = 2.75	MILE = 2.75	8.331	23.117	6.363
3.05	MILE = 3.00	MILE = 3.00	8.394	21.210	5.940
3.31	MILE = 3.25	MILE = 3.25	8.454	19.538	5.527
3.56	MILE = 3.50	MILE = 3.50	8.508	18.031	5.143
3.81	MILE = 3.75	MILE = 3.75	8.557	16.577	4.785
4.07	MILE = 4.00	MILE = 4.00	8.602	15.273	4.452
4.32	MILE = 4.25	MILE = 4.25	8.644	14.043	4.143
4.58	MILE = 4.50	MILE = 4.50	8.683	12.945	3.855
4.83	MILE = 4.75	MILE = 4.75	8.719	11.916	3.587
5.09	MILE = 5.00	MILE = 5.00	8.752	10.969	3.338
5.34	MILE = 5.25	MILE = 5.25	8.782	10.097	3.106
5.60	MILE = 5.50	MILE = 5.50	8.810	9.294	2.890
5.85	MILE = 5.75	MILE = 5.75	8.836	8.555	2.689
6.11	MILE = 6.00	MILE = 6.00	8.860	7.875	2.502

INTERIM DISCHARGE OF OXYGEN 5.00 M3/L OCCURS AT 0.600 MILE AND 0.000 MILES BELOW DISCHARGE JUNCTION.

PROJECT NO.	100-100-100	PROJECT NAME	WATER QUALITY MONITORING
CLIENT	STATE OF CALIFORNIA	CONTRACT NO.	100-100-100
DATE	10/10/10	REPORT NO.	100-100-100

PHYSICAL AND CHEMICAL ANALYSES

PARAMETER	ANALYSIS		UNIT	REMARKS
	DATE	VALUE		
TEMPERATURE	10/10/10	15.0	°C	
	10/11/10	16.0	°C	
PH	10/10/10	7.5		
	10/11/10	7.8		
DISSOLVED OXYGEN	10/10/10	8.5	mg/L	
	10/11/10	8.2	mg/L	
TURBIDITY	10/10/10	0.5	NTU	
	10/11/10	0.6	NTU	
TOTAL SOLIDS	10/10/10	100	mg/L	
	10/11/10	110	mg/L	
TOTAL DISSOLVED SOLIDS	10/10/10	80	mg/L	
	10/11/10	85	mg/L	
CALCIUM	10/10/10	40	mg/L	
	10/11/10	45	mg/L	
MAGNESIUM	10/10/10	20	mg/L	
	10/11/10	25	mg/L	
TOTAL HARDNESS	10/10/10	60	mg/L	
	10/11/10	70	mg/L	
NITRATE	10/10/10	10	mg/L	
	10/11/10	12	mg/L	
NITRITE	10/10/10	0.5	mg/L	
	10/11/10	0.6	mg/L	
AMMONIA	10/10/10	0.2	mg/L	
	10/11/10	0.3	mg/L	
CHLORIDE	10/10/10	150	mg/L	
	10/11/10	160	mg/L	
SULFATE	10/10/10	50	mg/L	
	10/11/10	55	mg/L	

ANALYST: J. SMITH

LABORATORY: STATE WATER RESOURCES DIVISION

DATE: 10/10/10

SCALE: 1:1000

PROJECT: WATER QUALITY MONITORING

CLIENT: STATE OF CALIFORNIA

CONTRACT: 100-100-100

REPORT NO: 100-100-100

RECEIVED BY THE DIRECTOR, FBI, WASHINGTON, D.C. 20535

TO: DIRECTOR, FBI (100-441100) FROM: SAC, NEW YORK (100-150000) (P)

RE: JAMES EARL RAY, AKA; RICHARD MILTON BERRY, AKA; ALBERT EARL BROWN, AKA; ...

On 11/10/68, the New York Office received information from the New York State Police regarding the activities of the above-named individuals in the New York area. This information was obtained from a confidential source who has provided reliable information in the past.

The New York Office is currently conducting an investigation into the activities of the above-named individuals and is seeking information from other offices regarding their activities.

It is requested that you advise this office of any information you may have regarding the activities of the above-named individuals in your area.

Very truly yours,
 Special Agent in Charge

Enclosure

100-150000-1000

ALL INFORMATION CONTAINED HEREIN IS UNCLASSIFIED

DATE 11/10/68 BY SP-5 [redacted]

1. Name of the project : Construction of 10000 sq. ft. Residential Building
2. Location of the project : Plot No. 10, Sector 10, Gurgaon, Haryana
3. Name of the client : M/s. ABC Construction Co. Pvt. Ltd.
4. Name of the consultant : M/s. XYZ Engineering & Architecture
5. Date of completion : 10/10/2018

Sl. No.	Particulars	Quantity	Rate	Amount	Unit
1	Excavation	1000	100	100000	cu. m
2	Foundation	1000	150	150000	sq. m
3	Structural	1000	200	200000	sq. m
4	Roofing	1000	120	120000	sq. m
5	Plumbing	1000	80	80000	sq. m
6	Electrical	1000	60	60000	sq. m
7	Painting	1000	40	40000	sq. m
8	Sanitary	1000	50	50000	sq. m
9	Landscaping	1000	30	30000	sq. m
10	Contingency	1000	20	20000	sq. m
11	Transportation	1000	10	10000	sq. m
12	Labour	1000	5	5000	sq. m
13	Material	1000	10	10000	sq. m
14	Overhead	1000	5	5000	sq. m
15	Profit	1000	10	10000	sq. m
16	Total	1000		1000000	

1. Name of the project : Construction of 10000 sq. ft. Residential Building
2. Location of the project : Plot No. 10, Sector 10, Gurgaon, Haryana
3. Name of the client : M/s. ABC Construction Co. Pvt. Ltd.
4. Name of the consultant : M/s. XYZ Engineering & Architecture
5. Date of completion : 10/10/2018

Sl. No.	Particulars	Quantity	Rate	Amount	Unit
1	Excavation	1000	100	100000	cu. m
2	Foundation	1000	150	150000	sq. m
3	Structural	1000	200	200000	sq. m
4	Roofing	1000	120	120000	sq. m
5	Plumbing	1000	80	80000	sq. m
6	Electrical	1000	60	60000	sq. m
7	Painting	1000	40	40000	sq. m
8	Sanitary	1000	50	50000	sq. m
9	Landscaping	1000	30	30000	sq. m
10	Contingency	1000	20	20000	sq. m
11	Transportation	1000	10	10000	sq. m
12	Labour	1000	5	5000	sq. m
13	Material	1000	10	10000	sq. m
14	Overhead	1000	5	5000	sq. m
15	Profit	1000	10	10000	sq. m
16	Total	1000		1000000	

1. Name of the project : Construction of 10000 sq. ft. Residential Building
2. Location of the project : Plot No. 10, Sector 10, Gurgaon, Haryana
3. Name of the client : M/s. ABC Construction Co. Pvt. Ltd.
4. Name of the consultant : M/s. XYZ Engineering & Architecture
5. Date of completion : 10/10/2018

Sl. No.	Particulars	Quantity	Rate	Amount	Unit
1	Excavation	1000	100	100000	cu. m
2	Foundation	1000	150	150000	sq. m
3	Structural	1000	200	200000	sq. m
4	Roofing	1000	120	120000	sq. m
5	Plumbing	1000	80	80000	sq. m
6	Electrical	1000	60	60000	sq. m
7	Painting	1000	40	40000	sq. m
8	Sanitary	1000	50	50000	sq. m
9	Landscaping	1000	30	30000	sq. m
10	Contingency	1000	20	20000	sq. m
11	Transportation	1000	10	10000	sq. m
12	Labour	1000	5	5000	sq. m
13	Material	1000	10	10000	sq. m
14	Overhead	1000	5	5000	sq. m
15	Profit	1000	10	10000	sq. m
16	Total	1000		1000000	