

MONTHLY REPORT OF OPERATION WATER TREATMENT PLANT

System Name: LSC Communications

PWSID Number: 2431056

For the Month of: December 2024

IDEM Field Rep.: Sophia J. Andrews

Signed: 

Title: Water Treatment Operator

I certify **under penalty of law** by this signature that this document was prepared by me or under my direction and the information submitted is to the best of my knowledge and belief, true, accurate, and complete. I am also aware that there are significant penalties for submitting false information.

Certification Number: DS220174/ WT230024

PHYSICAL AND CHEMICAL DATA											
Date	Iron (mg/l)		Water Treated	Chemicals Used (Gallons)	Industrial Filters (operate 24 hours/day)		Potable Filters (operate 24 hours/day)		Chlorine Residual (mg/l)	Initials of Tester	Remarks WELL 2
	Raw	Finished	Gallons	Sodium Hypochlorite (NaOCl)	Run Hours	Gallons per Backwash	Run Hours	Gallons per Backwash	Plant Tap (Free Cl)		
1			457	0.0	72						
2	2.64	0.20	7,773	0.4	96	66,000			0.01	DK	BW Industrial #1 & #2
3	2.73	0.10	5,905	0.3	24				0.01	DK	
4	2.38	0.13	6,023	0.3	48				0.01	DK	
5	2.61	0.14	3,817	0.2	72	66,000			0.00	DK	BW Industrial #1 & #2
6	2.58	0.16	4,336	0.2	24				0.01	DK	
7			3,587	0.2	48						
8			3,587	0.2	72						
9	2.24	0.13	4,263	0.2	96	66,000			0.01	DK	BW Industrial #1 & #2
10	2.63	0.11	4,168	0.2	24				0.00	DK	
11	2.58	0.12	2,398	0.1	48				0.00	DK	
12	2.61	0.09	2,398	0.1	72	66,000			0.01	DK	BW Industrial #1 & #2
13	2.70	0.10	2,398	0.1	24				0.00	DK	
14			2,409	0.1	48						
15			2,409	0.1	72						
16	1.53	0.12	2,634	0.1	96	66,000			0.01	DK	BW Industrial #1 & #2
17	2.43	0.11	2,829	0.1	24				0.01	DK	
18	2.56	0.08	2,829	0.1	48				0.00	DK	
19	2.63	0.09	2,830	0.1	72	66,000			0.00	DK	BW Industrial #1 & #2
20	2.49	0.10	3,054	0.2	24				0.00	MR	
21			2,842	0.1	48						
22			2,842	0.1	72						
23	2.57	0.11	3,642	0.2	96	66,000			0.02	MR	BW Industrial #1 & #2
24			2,414	0.1	24						HOLIDAY
25			961	0.0	48						HOLIDAY
26	1.68	0.13	1,001	0.1	72	66,000			0.03	DK	BW Industrial #1 & #2
27	2.48	0.10	3,325	0.2	24				0.01	DK	
28			2,839	0.1	48						
29			2,839	0.1	72						
30	2.53	0.11	2,617	0.1	96	66,000			0.01	DK	BW Industrial #1 & #2
31	2.61	0.09	2,831	0.1	24				0.01	DK	

Monthly Water Treatment	Total Gallons	98,257	DUE BY THE 10TH OF THE MONTH FOLLOWING THE REPORTING PERIOD.	Indiana Dept. of Environmental Mgmt. Drinking Water Branch 66-34-2 100 N. Senate Avenue Indianapolis, IN 46204-2251
	Daily Maximum	7,773		
	Daily Minimum	457		
	Daily Average	3,181		