

DEPARTMENT OF ENVIRONMENTAL MANAGEMENT

Indianapolis

OFFICE MEMORANDUM

DATE : May 5, 1988

TO : Joseph C. Krieger
Permits Section

THRU : *G. Senolke fd*
Gus Jumawan

T.P. Chang *TPC*

J.C. Stallsmith *JCS*

FROM : Mustafa Ak *M.A.*
Modeling and Engineering Services Section

SUBJECT : Updating the January 1987 Berne STP WLA Report
(Continuous and Controlled Discharge Analysis)

Reference : Memo dated March 8, 88 from Randy K. Jones.

At the request of Randy K. Jones of Facility Plans Section, a wasteload allocation study has been performed for the above facility due to change in the design flow from 0.6 mgd to 0.75 mgd and proposed discharge location to Wabash River for the existing plant. These evaluations are based on the Q₇₋₁₀ flow reduction due to mixing zone policies / guidelines, and acute / chronic water quality criteria for both existing and proposed water quality standards Rule 327 IAC 2-1. The alternative outfall locations on the respective receiving streams are as follows :

Site	Stream	Q _{7,10} Flow
1	Habegger Ditch / St. Mary River	0.1 cfs
2	Wabash River	5.6 cfs


The effluent limitations for a continuous discharge option for both sites are controlled by the chronic ammonia toxicity as well as instream dissolved oxygen maintenance. For a waste stabilization pond system, Site - 2 is feasible but not Site - 1. If Site - 2 is selected, then required holding volume/period (4.57 MGAL/9.0 DAYS) can/will be incorporated into the treatment pond(s) to have secondary treatment levels. For both continuous and controlled discharge options, the results of the analyses are summarized in the attached Tables.

Results of this WLA analyses will be an addendum to the January 1987 Berne STP Wasteload Allocation report.

CC : Tom Keesling
Randy K. Jones

Attachments

SITE - 1	Tables 1 - 2	Toxic Ammonia-N Analysis.
	Tables 3 - 4	Instream WQ Simulation.
	Table 5	CD Analysis.
SITE - 2	Tables 6 - 7	Toxic Ammonia-N Analysis.
	Tables 8 - 9	Instream WQ Simulation.
	Table 10	CD Analysis.
	Map	Site Locations.



ADAMS COUNTY

DEPARTMENT OF ENVIRONMENTAL MANAGEMENT

INDIANAPOLIS

OFFICE MEMORANDUM

TO:

~~CUS SUMHWAAN~~ 3/8

DATE:

3/8/88

THRU:

Tom Krelling

FROM:

Randy K. Jones

SUBJECT:

Wasteload Allocation for BERNE, IL.

Please review the wasteload allocation for BERNE dated April 10, 1987 for facilitation planning purposes. Does another allocation study need to be done for the new design flow of .75 MGD for Habersham Ditch.

Also request that a wasteload allocation for a design flow of .25 MGD be run for the Wabash River, and controlled discharge for both locations.

RECEIVING STREAM(S) : HERRINGER DITCH/ST. MARY'S RIVER

Receiving Stream : OPEN USE STREAM

Analysis Basis : Analysis Performed for WASTEWATER SPECIES HIGHLIGHT

TREATMENT PLANT DESIGN FLOW : 1.162 cfs
 Headwater @ 7.10 FLOW : 0.10 cfs
 NH3-N Toxic Analysis done at : 50.00 % Dilution

Upstream Ammonia-N Conc. mg/l (Weekly)	0.300 MG/L	0.100 MG/L
UPSTREAM DATA	25.00 C	15.00 C
Temperature	7.80	7.00
pH		

EFFLUENT DATA	Temperature	15.00 C	15.00 C
	pH	7.50	7.50

Season	Standard	un-ionized NH3-N	Instrument #	Effluent Ammonia-N
1. SUMMER	1x 327 IAC 2-1 Acute (1)	0.411 (M)		15.52 Monthly Ave
WINTER		0.411 (W)		31.97 Monthly Ave
2. SUMMER	307 IAC 2-1 Acute (2)	0.210 (D)		11.91 Monthly Ave
WINTER		0.105 (R)		12.29 Monthly Ave
3. SUMMER	Ex 327 IAC 2-1 Chronic (1)	0.041 (M)	1.187 (W)	0.81 Monthly Ave
WINTER		0.041 (W)	2.424 (W)	1.67 Monthly Ave
4. SUMMER	307 IAC 2-1 Chronic (2)	0.036 (M)	1.523 (W)	1.09 Monthly Ave
WINTER		0.026 (M)	2.301 (W)	1.59 Monthly Ave

(D) : 1-hour max. average concentration as Maximum Daily Average.
 (M) : 4-day average concentration as Maximum Monthly Average
 (W) : Weekly Average Concentration as per Existing Rule 327 IAC 2-1.

1. Existing RULE 327 IAC 2-1 Acute Hydraulic Limit. : the 0.5 mg/l un-ionized ammonia criterion is taken to be weekly average ammonia limit at the end of effluent pipe

2. Proposed RULE 327 IAC 2-1 Acute Aquatic Criteria : the 400 Values of the proposed Rule are taken to be monthly average final acute ammonia-N limits at the end of effluent pipe.

3. Existing RULE 327 IAC 2-1 Continuous Criterion Concent. : the 0.05 mg/l un-ionized ammonia criterion is taken to be weekly average instream ammonia limitations.

4. Proposed RULE 327 IAC 2-1 Continuous Criterion Concentration : the 0.05 mg/l Values of the proposed Rule are taken to be monthly average instream ammonia N limitations.

TABLE 2 : RESULTS OF EFFLUENT LIMITATION ANALYSIS

FACILITY : BEPAC, SFP

RECEIVING STREAM(S) : HANSEN DITCH/ST. HARRY'S RIVER

Stream Designation : CUMULATIVE STREAM

Analysis Basis : Analysis Performed for WARMWATER SPECIES HABITAT

Case I : Existing STDs (Rule 330 IAC 1-1 Recodified as 397 IAC 2-1)

	Summer (May Thru. November)		Winter (December Thru. April)	
FLOW	0.7500 mgd	0.7500 mgd		
TSS	10.00 mg/l	20.00 mg/l		
D.O.	6.0 mg/l	5.0 mg/l		
Phosphorus	1 mg/l or 80 % Removal			

AMMONIA-N

(a) Acute (Effluent Based)	15.52 mg/l	31.97 mg/l
(Stream Based)	7.76 mg/l	16.16 mg/l
(b) Chronic (Stream Based)	0.8174 mg/l *	1.6770 mg/l *
(Treatability Limits)	1.5000 mg/l	3.0000 mg/l

(Based : Respective pH and Temperature data were used in the computations. NH3-N and CBOD5 are on monthly average basis, whereas, D.O. is on Daily Ave.)

Case II : Proposed Standards

Rule 327 IAC 2-1

	Summer (May Thru. November)		Winter (December Thru. April)	
FLOW	0.7500 mgd	0.7500 mgd		
TSS	10.00 mg/l	20.00 mg/l		
D.O.	6.0 mg/l	5.0 mg/l		
Phosphorus	1 mg/l or 80 % Removal			

AMMONIA-N

(a) Acute (Effluent Based)	11.91 mg/l	12.24 mg/l
(Stream Based)	7.80 mg/l	7.97 mg/l
(b) Chronic (Stream Based)	1.0792 mg/l *	1.5918 mg/l *
(Treatability Limits)	1.5000 mg/l	3.0000 mg/l

(Based : Respective pH and Temperature data were used in the computations. NH3-N and CBOD5 are on monthly average basis, whereas, D.O. is on Daily Ave.)

Case III : Waste Stabilization Pond Systems Option (Controlled Discharge)

	Summer (May Thru. November)		Winter (December Thru. April)	
FLOW	0.7500 mgd	0.7500 mgd		
TSS	25.00 mg/l	25.00 mg/l		
	70.00 mg/l	70.00 mg/l		
Controlled Pond(s) Volume Required	369.50 mgal			
Retaining Period	704.00 days			

WASTE STABILIZATION POND SYSTEM IS NOT FEASIBLE FOR THE EXISTING DISCHARGE LOCATION.

DEPARTMENT OF ENVIRONMENTAL MANAGEMENT
WATER MANAGEMENT

SEWER TREATMENT PLANT = BERNE STP SUMMER WASTELOAD ALLOCATION ANALYSIS BASED ON USEPA SIMPLIFIED MODEL DATE = 05/02/88
 COUNTY = ADAMS COUNTY RECEIVING STREAM = HABEGGER DITCH RIVER STREAM = ST. MARY'S RIVER SIMILAR TO BY = N.A.H

EXISTING DISCHARGE LOCATION HAS BEEN ANALYSED

STREAM QUALITY STANDARDS

INSTREAM DISSOLVED OXYGEN = 5.0 MG/L In-limited nitrogen is based on acute or chronic Criteria as per RULE 327 (M) 2-1

HEADWATER AND EFFLUENT WATER QUALITY TRENDS REACH NUMBER 1

	FLOW CFS	BOD (ULTIMATE) MG/L	NBOD MG/L	DISSOLVED OXYGEN MG/L	TEMPERATURE CG
11-MONTH WATER QUALITY	0.100	2.300	0.300	7.362	25.00
17-MONTH WATER QUALITY	1.162	20.000	6.900	6.000	25.00
STREAM NO. 1/3 OF STP	1.262	21.360	6.377	6.107	25.00

HYDRAULIC CHARACTERISTICS OF SIBS BELOW TREATMENT PLANT OR JUNCTION

VELOCITY IN FT/SEC = 0.240 HYDRAULIC DEPTH IN FT = 0.4000 STREAM BED SLOPE IN FT/MILE = 3.80 MANNING'S COEFF = 0.035
 REACH HABEGGER DITCH MILES FROM TO 0.000 COMPUTATIONAL ELEMENT 0.25000 MILE

REACTION AND REGENERATION RATES

	AT 20 CG	AT INSTREAM TEMP 25.00 CG	REMARK
REGENERATION RATE	6.10867	6.96782	LONGITUDINAL DEPTH EN.
BOD DECAY RATE	0.40000	0.50326	
NBOD DECAY RATE	0.40000	0.51873	
SEDIMENTATION RATE	0.00000	0.00000	" SUSPENSION " SEDIMENTATION
SEDIMENT (BENTHIC) OXYGEN DEMAND	0.90000	1.23307	1M CM/ML/DAY AT 20 CG

STRIKESHELL TRENCH WATER QUALITY PROVISION ON R. DISCHARGE OR BELOW JUNCTION

TIME DAYS	DISTANCE BELOW TRENCH	DISTANCE BELOW DISCHARGE	DISTANCE BELOW JUNCTION	DISSOLVED OXYGEN MG/L	BOD (5 DAYS) MG/L	MLD (5 DAYS) MG/L	MLD MG/L
0.00	0.00	0.00	0.00	6.107	21.360	4.377	4.377
0.06	0.06	0.06	0.06	5.598	20.686	4.143	4.143
0.12	0.12	0.12	0.12	5.295	20.034	3.917	3.917
0.19	0.19	0.19	0.19	5.123	19.403	3.700	3.700
0.25	0.25	0.25	0.25	5.036	18.791	3.490	3.490
0.31	0.31	0.31	0.31	5.002	18.198	3.289	3.289
0.38	0.38	0.38	0.38	5.001	17.625	3.094	3.094
0.44	0.44	0.44	0.44	5.020	17.069	2.907	2.907
0.50	0.50	0.50	0.50	5.053	16.531	2.727	2.727
0.57	0.57	0.57	0.57	5.092	16.009	2.554	2.554
0.63	0.63	0.63	0.63	5.136	15.505	2.386	2.386
0.70	0.70	0.70	0.70	5.182	15.016	2.225	2.225
0.76	0.76	0.76	0.76	5.232	14.542	2.070	2.070
0.82	0.82	0.82	0.82	5.284	14.084	1.921	1.921
0.89	0.89	0.89	0.89	5.338	13.640	1.777	1.777
0.95	0.95	0.95	0.95	5.397	13.210	1.638	1.638
1.01	1.01	1.01	1.01	5.411	12.793	1.504	1.504
1.08	1.08	1.08	1.08	5.453	12.390	1.376	1.376
1.14	1.14	1.14	1.14	5.495	11.999	1.252	1.252
1.20	1.20	1.20	1.20	5.535	11.621	1.132	1.132
1.27	1.27	1.27	1.27	5.574	11.255	1.017	1.017
1.33	1.33	1.33	1.33	5.612	10.900	0.906	0.906
1.40	1.40	1.40	1.40	5.649	10.556	0.800	0.800
1.46	1.46	1.46	1.46	5.684	10.223	0.697	0.697
1.52	1.52	1.52	1.52	5.718	9.901	0.598	0.598

MINIMUM DISSOLVED OXYGEN 4.998 MG/L OCCURS AT 0.351 DOW AND 1.3804 MILES
BELOW DISCHARGE OR JUNCTION

DEPARTMENT OF ENVIRONMENTAL MANAGEMENT
WATER POLLUTION

SEWAGE TREATMENT PLANT : BERNE STP WASTEWATER TREATMENT FACILITY NAMED IN REPORT: BERNE STP DATE : 05/07/88
 COUNTY : DADE COUNTY RECEIVING STREAM : HADDEGER DITCH MAIN STREAM : ST. MARY'S RIVER SIMULATED BY : M. ORK

DISCHARGE LOCATION HAS BEEN ANALYZED

SERIAL WATER QUALITY STANDARDS

UPSTREAM DISSOLVED OXYGEN = 5.0 MG/L Un-ionized NH₃-N is based on limits on Chronic Criteria as per RLLF 3P? Unit: 1.1

LOADING AND EFFLUENT QUALITY INPUT DATA REACH NUMBER 1

PARAMETER	FLOW CFS	BOD (ULTIMATE) MG/L	NH ₃ -N MG/L	TEMPERATURE CG
HEADWATER WATER QUALITY	0.100	2.300	0.300	15.00
EFFLUENT WATER QUALITY	1.162	46.000	13.700	15.00
STREAM WQ DYS OF STP	1.162	42.538	12.638	15.00

HYDRAULIC CHARACTERISTICS OF STREAM ULTIMATE RESIDENT LOAD AT JUNCTION

VELOCITY IN FT/SEC = 0.240 HYDRAULIC DEPTH IN FT = 0.4000 STREAM BED SLOPE IN FT/MILE = 3.80 Manning's Coefficient = 0.035
 REACH HADDEGER DITCH MILES FROM 6.000 TO 0.000 COMPUTATIONAL ELEMENT 0.25000 MILE

REACTION AND REGRESSION RATES

PARAMETER	UNIT	AT 20 DS	AT 100 DS	REMARK
REMOVAL RATE	1/DAY	6.18867	5.49664	LANGRISH-DUMYON EQ.
DELAY RATE	1/DAY	0.40000	0.31792	
REACTOR DECAY RATE	1/DAY	0.40000	0.27223	
SEDIMENTATION RATE	1/DAY	0.00000	0.00000	"- SUSPENSION "+ SEDIMENTATION
EFFLUENT CONCENTRATION OXYGEN DEFICIT		0.90000	0.65689	IN GM/SEC/M/DAY AT 20 DS

STANDARDIZED WATER QUALITY COMPLIANCE LA 0 FISHKILLER OR FLOW JUNCTION

TIME HRS	DISTANCE DOWN MILE	REFLOW FROM DITCH	DISCHARGE FROM DITCH	DISCHARGE OXYGEN MG/L	SD (U.L. MILE)	SD (M.G./L)
0.00	MILE = 0.00	MILE = 0.00	MILE = 0.00	5.187	42.538	12.678
0.04	MILE = 0.25	MILE = 0.25	MILE = 0.25	5.428	41.686	12.421
0.12	MILE = 0.50	MILE = 0.50	MILE = 0.50	5.615	40.851	12.208
0.19	MILE = 0.75	MILE = 0.75	MILE = 0.75	5.764	40.032	11.998
0.25	MILE = 1.00	MILE = 1.00	MILE = 1.00	5.886	39.270	11.792
0.31	MILE = 1.25	MILE = 1.25	MILE = 1.25	5.989	38.494	11.589
0.38	MILE = 1.50	MILE = 1.50	MILE = 1.50	6.078	37.674	11.390
0.44	MILE = 1.75	MILE = 1.75	MILE = 1.75	6.156	36.919	11.194
0.50	MILE = 2.00	MILE = 2.00	MILE = 2.00	6.227	36.179	11.002
0.57	MILE = 2.25	MILE = 2.25	MILE = 2.25	6.292	35.455	10.813
0.63	MILE = 2.50	MILE = 2.50	MILE = 2.50	6.353	34.744	10.627
0.70	MILE = 2.75	MILE = 2.75	MILE = 2.75	6.410	34.040	10.445
0.76	MILE = 3.00	MILE = 3.00	MILE = 3.00	6.465	33.346	10.265
0.82	MILE = 3.25	MILE = 3.25	MILE = 3.25	6.518	32.677	10.089
0.89	MILE = 3.50	MILE = 3.50	MILE = 3.50	6.569	32.042	9.915
0.95	MILE = 3.75	MILE = 3.75	MILE = 3.75	6.619	31.400	9.745
1.01	MILE = 4.00	MILE = 4.00	MILE = 4.00	6.667	30.771	9.578
1.08	MILE = 4.25	MILE = 4.25	MILE = 4.25	6.714	30.155	9.413
1.14	MILE = 4.50	MILE = 4.50	MILE = 4.50	6.760	29.551	9.251
1.20	MILE = 4.75	MILE = 4.75	MILE = 4.75	6.805	28.959	9.092
1.27	MILE = 5.00	MILE = 5.00	MILE = 5.00	6.849	28.378	8.936
1.33	MILE = 5.25	MILE = 5.25	MILE = 5.25	6.892	27.810	8.783
1.40	MILE = 5.50	MILE = 5.50	MILE = 5.50	6.934	27.254	8.632
1.46	MILE = 5.75	MILE = 5.75	MILE = 5.75	6.976	26.707	8.484
1.52	MILE = 6.00	MILE = 6.00	MILE = 6.00	7.016	26.172	8.338

MINIMUM DITCH OXYGEN 5.187 MG/L OCCURS AT 0.000 DAY AND 0.000 MILES
 REFLOW DISCHARGE OR JUNCTION

WATER MANAGEMENT
 MAINTENANCE AND FINANCIAL SERVICES

AMNH VRT : 41.0K

TABLE : 5

WASTEWATER STABILIZATION LAGOONS CONTROLLED DISCHARGE ANALYSIS

DATE : 04/27/88

Name of Facility : BERNE STP, ADAMS COUNTY,

Flow Correction Factor for ID Analysis : 20.00 %

Receiving Stream : HAREKNER DILLIPLINE CREEK

Gaging Station : WABASH RIVER @ LINDEN GROVE, ADAMS COUNTY. Drainage area upstream of Receiving Station : 453.0 Sq.mi

Facility Design Flow : 0.750 mgd

Flow used in the Analysis : 0.500 mgd

Drainage area upstream of STP : 4.0 Sq.mi

Drainage area upstream of Receiving Station : 453.0 Sq.mi

1.162E cfs

0.8137 cfs

7/10 Flow : 0.10 cfs

Corrected Flow Ratio : 0.12

Month	Gaging Station	Adjusted Flow u/s STP [Qs]	Dilution Ratio [R]	Allowable Discharge cfs-day [QD=Qs/R]	STP Flow cfs-day [Qs]	Cumulative Flow Qo-out	Deficiency cfs-day [Qi-QD]	Accumulation Sum[Qi-QD]
OCT	2526.00	31.1346	10	3.1134	25.2262	3.1134	22.1127	22.1127
NOV	1796.00	15.8587	10	1.5858	24.4125	4.6993	22.8266	44.9394
DEC	14420.00	127.3289	10	12.7328	25.2262	17.4322	12.4933	57.4327
JAN	261341.00	250.7516	10	25.0751	25.2262	42.4573	0.2010	57.6338
FEB	47790.00	439.6467	10	43.9646	22.7850	86.4720	21.1776	36.4541
MAR	32984.00	202.9492	10	20.2949	25.2262	106.7169	4.9313	41.3855
APR	2153.00	19.0110	10	1.9011	24.4125	108.6181	22.5113	63.8968
MAY	1567.00	13.8366	10	1.3836	25.2262	110.0017	21.8425	87.7394
JUN	5133.00	45.3245	10	4.5324	24.4125	114.5342	19.8800	107.6195
JUL	2106.00	18.5960	10	1.8596	25.2262	116.3930	21.3666	130.9861
AUG	694.00	6.1280	10	0.6128	25.2262	117.0066	24.6134	155.5996
SEP	344.00	3.2534	10	0.3253	24.4125	117.3310	24.0871	179.6867

Month	Gaging Station	Adjusted Flow u/s STP [Qs]	Dilution Ratio [R]	Allowable Discharge cfs-day [QD=Qs/R]	STP Flow cfs-day [Qs]	Cumulative Flow Qo-out	Deficiency cfs-day [Qi-QD]	Accumulation Sum[Qi-QD]
OCT	471.60	4.1642	10	0.4164	25.2262	0.4164	24.8098	204.4945
NOV	337.30	2.7283	10	0.2728	24.4125	0.7142	24.1146	228.6112
DEC	286.90	2.5331	10	0.2533	25.2262	0.9675	24.9729	251.5141
JAN	192.00	1.6953	10	0.1695	25.2262	1.1371	25.0567	276.5404
FEB	47029.00	106.2163	10	10.6216	22.7850	11.7587	12.1633	290.8042
MAR	17277.00	152.5562	10	15.2556	25.2262	27.0143	9.9706	300.7740
APR	6231.00	55.0194	10	5.5019	24.4125	32.5163	18.9105	319.6847
MAY	3822.00	33.7483	10	3.3748	25.2262	35.8912	21.8514	341.5362
JUN	594.00	5.2410	10	0.5241	24.4125	36.4157	23.8879	365.4247
JUL	966.10	8.5304	10	0.8530	25.2262	37.2687	24.3731	389.7979
AUG	764.80	6.7532	10	0.6753	25.2262	37.9441	24.5509	414.3488
SEP	259.130	2.2898	10	0.2289	24.4125	40.2339	22.1226	436.4714

Month	Gaging Station	Adjusted Flow u/s STP [Qs]	Dilution Ratio [R]	Allowable Discharge cfs-day [QD=Qs/R]	STP Flow cfs-day [Qs]	Cumulative Flow Qo-out	Deficiency cfs-day [Qi-QD]	Accumulation Sum[Qi-QD]
OCT	2145.00	19.9403	10	1.9940	25.2262	1.9940	23.3322	459.8037
NOV	1174.00	10.3841	10	1.0384	24.4125	2.9324	23.3740	483.1777
DEC	35504.00	313.5011	10	31.3501	25.2262	34.3925	-6.1238	477.0539
JAN	5628.00	49.6953	10	4.9695	25.2262	39.3520	20.2567	497.3104
FEB	2408.00	21.2626	10	2.1262	22.7850	41.4783	20.6587	517.9691
MAR	74308.00	656.1412	10	65.6141	25.2262	106.9924	-40.3678	477.5815
APR	34167.00	334.1456	10	33.4145	24.4125	140.4070	-9.0020	468.5794
MAY	12678.00	112.1336	10	11.2133	25.2262	151.6194	14.0138	482.5933
JUN	2332.00	20.5916	10	2.0591	24.4125	153.6785	22.3523	504.9464
JUL	6278.00	55.6114	10	5.5611	25.2262	159.2397	19.6651	524.6117
AUG	1284.00	11.3377	10	1.1337	25.2262	160.3735	24.0924	548.7042
SEP	462.70	4.0956	10	0.4095	24.4125	160.7820	24.0039	572.7081

*** MAXIMUM ACCUMULATION : 572.70 cfs-day
 Remark (s) : EXISTING DISCHARGE LIMITATION HAS BEEN ANALYZED.
 HOLDING PERIOD : 201.78 Days ***

RECEIVING STREAM(S) : WARASH RIVER
Stream Designation : WUP USE STRICH

Analysis Basis : Analysis Performed For Warmwater Species Habitat

TREATMENT PLANT DESIGN FLOW : 1.162 cfs
Maximum 127,10 FLOW : 5.60 cfs
NH3-N Toxic Analytic dose at : 50.00 % Dilution

	Summer	Winter
Upstream Ammonia-N Conc. mg/l (Weekly)	0.300 MDA	0.300 MDA
Temperature	25.00 C	15.00 C
pH	7.50	7.80

EFFLUENT DATA	Temperature	15.00 C	15.00 C
	pH	7.50	7.50

Season	Standard	un-ionized NH3-N	Instream NH3-N	Effluent Ammonia-N
1. SUMMER	Ex 1/7 IAC 2-1 Acute (1)	0.411 (M)		15.52 Monthly Ave
WINTER		0.411 (M)		31.97 Monthly Ave
2. SUMMER	327 IAC 2-1 Acute (2)	0.210 (D)	*	11.91 Monthly Ave
WINTER		0.105 (D)	*	12.09 Monthly Ave
3. SUMMER	Ex 1/7 IAC 2-1 Chronic (1)	0.041 (M)	1.107 (M)	2.21 Monthly Ave
WINTER		0.041 (M)	2.484 (M)	5.02 Monthly Ave
4. SUMMER	1/7 IAC 2-1 Chronic (2)	0.036 (M)	1.593 (M)	3.13 Monthly Ave
WINTER		0.026 (M)	2.301 (M)	4.74 Monthly Ave

(D) : 1-hour max. average concentration as Maximum Daily Average.
 (M) : 4-day average concentration as Maximum Monthly Average.
 (W) : Weekly Average Concentration as per Existing Rule 327 IAC P.1.

- Existing RULE 327 IAC 2-1 Acute Aquatic Crit. : the 0.5 mg/l un-ionized ammonia criterion is taken to be weekly average ammonia limit at the end of effluent pipe
- Proposed Rule 327 IAC 2-1 Acute Aquatic Criteria : the AOC Values of the proposed Rule are taken to be monthly average final acute ammonia-N limits at the end of effluent pipe.
- Existing RULE 327 IAC 2-1 Continuous Criterion Concen. : the 0.05 mg/l un-ionized ammonia criterion is taken to be weekly average instream ammonia limitations.
- Proposed Rule 327 IAC 2-1 Continuous Criterion Concentration : the CCC Values of the proposed Rule are taken to be monthly average instream ammonia N limitations.

TABLE 7 RESULTS OF EFFLUENT LIMITATION ANALYSIS

FACILITY : RFRNE STP

RECEIVING STREAM(S) : WASHNET RIVER

Stream Destination : GEN USE STREAM

Analysis Basis : Analysis Performed for WARMWATER SPECIFIC LIMITS

Case I : Existing STDs (Rule 330) (Recodified as 327 IAC 2-1)

	Summer		Winter	
	(May thr. November)	(December thr. April)	(May thr. November)	(December thr. April)
FLOW	0.7500 mgd	0.7500 mgd	0.7500 mgd	0.7500 mgd
CBOD5	25.00 mg/l	25.00 mg/l	25.00 mg/l	25.00 mg/l
D.O.	5.0 mg/l	4.0 mg/l	4.0 mg/l	4.0 mg/l
Phosphorus	1 mg/l or 80 % Removal			
AMMONIA-N	(a) Acute (Effluent Based)	15.52 mg/l	31.97 mg/l	31.97 mg/l
	(Stream Based)	7.91 mg/l	16.16 mg/l	16.16 mg/l
(b) Chronic (Stream Based)	4.21 mg/l	5.02 mg/l	5.02 mg/l	5.02 mg/l

(Based : Respective pH and Temperature data were used in the computations.)
 NH3-N and CBOD5 are on monthly average basis, whereas, D.O. is on Daily Ave.

Case II : Proposed Standards Rule 327 IAC 2-1

	Summer		Winter	
	(May thr. November)	(December thr. April)	(May thr. November)	(December thr. April)
FLOW	0.7500 mgd	0.7500 mgd	0.7500 mgd	0.7500 mgd
CBOD5	25.00 mg/l	25.00 mg/l	25.00 mg/l	25.00 mg/l
D.O.	5.0 mg/l	4.0 mg/l	4.0 mg/l	4.0 mg/l
Phosphorus	1 mg/l or 80 % Removal			
AMMONIA-N	(a) Acute (Effluent Based)	11.91 mg/l	12.29 mg/l	12.29 mg/l
	(Stream Based)	7.80 mg/l	7.97 mg/l	7.97 mg/l
(b) Chronic (Stream Based)	3.13 mg/l	4.74 mg/l	4.74 mg/l	4.74 mg/l

(Based : Respective pH and Temperature data were used in the computations.)
 NH3-N and CBOD5 are on monthly average basis, whereas, D.O. is on Daily Ave.

Case III : Waste Stabilization Pond System Option (Controlled Discharge)

	Summer		Winter	
	(May thr. November)	(December thr. April)	(May thr. November)	(December thr. April)
FLOW	0.750 mgd	0.750 mgd	0.750 mgd	0.750 mgd
CBOD5	25.00 mg/l	25.00 mg/l	25.00 mg/l	25.00 mg/l
D.O.	70.00 mg/l	70.00 mg/l	70.00 mg/l	70.00 mg/l
Controlled Ponds	Volume Required 4.57 mgal		4.57 mgal	
	Holding Period 9.00 days		9.00 days	

WASTE STABILIZATION POND SYSTEM IS TO BE USED WHEN EFFLUENT IS DISCHARGE
 DIRECTLY TO WASHNET RIVER.

5. SIMULATED...INSTRUMENT...QUALITY...DOMESTIC...WATER...DISCHARGE...CR. BELOW JUNCTION

TIME (HOUR)	DISTANCE BELOW DISCHARGE FROM JUNCTION MILE	DISSOLVED OXYGEN (MG/L)	TURBIDITY (NTU)	PH (MILLI)	TEMP (DEGREE C)
0.00	MILE = 6.00	6.755	11.784	PH = 7.00	2.706
0.02	MILE = 5.75	6.751	11.601	MILE = 0.25	2.756
0.06	MILE = 5.50	6.571	11.417	MILE = 0.50	2.607
0.09	MILE = 5.25	6.413	11.235	MILE = 0.75	2.518
0.12	MILE = 5.00	6.275	11.057	MILE = 1.00	2.511
0.15	MILE = 4.75	6.155	10.881	MILE = 1.25	2.464
0.19	MILE = 4.50	6.041	10.704	MILE = 1.50	2.419
0.22	MILE = 4.25	5.961	10.538	MILE = 1.75	2.374
0.25	MILE = 4.00	5.883	10.371	MILE = 2.00	2.330
0.29	MILE = 3.75	5.817	10.206	MILE = 2.25	2.287
0.31	MILE = 3.50	5.761	10.044	MILE = 2.50	2.244
0.35	MILE = 3.25	5.714	9.880	MILE = 2.75	2.203
0.38	MILE = 3.00	5.674	9.727	MILE = 3.00	2.162
0.41	MILE = 2.75	5.642	9.572	MILE = 3.25	2.121
0.44	MILE = 2.50	5.617	9.419	MILE = 3.50	2.083
0.47	MILE = 2.25	5.597	9.271	MILE = 3.75	2.044
0.50	MILE = 2.00	5.582	9.123	MILE = 4.00	2.006
0.54	MILE = 1.75	5.571	8.970	MILE = 4.25	1.969
0.57	MILE = 1.50	5.564	8.816	MILE = 4.50	1.932
0.60	MILE = 1.25	5.561	8.675	MILE = 4.75	1.897
0.63	MILE = 1.00	5.561	8.537	MILE = 5.00	1.861
0.66	MILE = 0.75	5.563	8.401	MILE = 5.25	1.827
0.70	MILE = 0.50	5.568	8.267	MILE = 5.50	1.793
0.73	MILE = 0.25	5.575	8.136	MILE = 5.75	1.760
0.76	MILE = 0.00	5.584	8.006	MILE = 6.00	1.727

MINIMUM DISSOLVED OXYGEN 5.561 MG/L OCCURS AT 0.622 MILE FROM DISCHARGE IN JUNCTION

DEPARTMENT OF ENVIRONMENTAL MANAGEMENT
WATER MANAGEMENT

SEWAGE TREATMENT PLANT :: ULARNE STP WINTER WASTEWATER ALLOCATION AND YIELDS BASED ON USEPA SIMPLIFIED MODEL DATE = 04/29/88
COUNTY = ADAMS COUNTY RECEIVING STREAM = WABASH RIVER MAIN STREAM = WABASH RIVER SIMULATED BY = H.AK

EFFLUENT DISCHARGE POINT WHILE BE CHANGED TO WABASH RIVER

STREAM WATER QUALITY STANDARDS

INSURE MIN DISSOLVED OXYGEN = 5.0 MG/L Un-simulated NH3-N is based on Acute or Chronic Criteria as per RULE 327 THU 2-1

GROUNDWATER SOLUBLE WATER QUALITY IMPROVEMENT BEACH NUMBER 1

	FLOW CFS	BOD (KINETIC) MG/L	PHOS MG/L	DISSOLVED OXYGEN MG/L	TEMPERATURE CG
INFLUENT WATER QUALITY	6.600	2.300	0.300	7.360	15.00
EFFLUENT WATER QUALITY	1.162	57.500	21.700	9.000	15.00
STREAM WQ D/S OF STP	6.762	11.789	3.978	6.784	15.00

HYDRAULIC CHARACTERISTICS OF STREAM BELOW TREATMENT PLANT OR JUNCTION

VELOCITY IN FT/SEC = 0.480 HYDRAULIC DEPTH IN FT = 1.1500 STREAM BED SLOPE IN FT/MILE = 3.80 MANNING'S COEFF = 0.035
FROM WABASH RIVER MILES FROM TO 0.000 COMPUTATIONAL ELEMENT 0.25000 MILE

RETENTION AND DECOMPOSITION RATES

	AT 20 CG	AT 15 CG	REMARK
REGENERATION RATE [1/DAY]	3.03835	1.69540	LAMBERT MINION EQ.
BOD DECAY RATE [1/DAY]	0.40000	0.31792	
NOD DECAY RATE [1/DAY]	0.10000	0.27793	
SEDIMENTATION RATE [1/DAY]	0.00000	0.00000	"SUSPENSION" SEDIMENTATION
SEDIMENT BENTHIC OXYGEN DEMAND	0.90000	0.65689	IN GR/SQ.M/DAY AT 20 CG

SCHEDULED UNDESIRABLE WATER QUALITY STANDARDS (REQD. DE. B. DISCHARGE) IN KILLAM JUNCTION

TIME DAYS	DISTANCE FROM RECEIVER MILE	DISCHARGE FROM DITCH	DISSOLVED OXYGEN MG/L	REQD. (MILLI) RATE MG/L	MG/D MG/L
0.00	MILE = 6.00	MILE = 0.00	6.784	11.709	3.978
0.03	MILE = 5.75	MILE = 0.25	6.498	11.670	3.944
0.06	MILE = 5.50	MILE = 0.50	6.208	11.582	3.910
0.09	MILE = 5.25	MILE = 0.75	6.005	11.476	3.876
0.12	MILE = 5.00	MILE = 1.00	5.818	11.351	3.843
0.15	MILE = 4.75	MILE = 1.25	5.648	11.207	3.810
0.19	MILE = 4.50	MILE = 1.50	5.494	11.054	3.777
0.22	MILE = 4.25	MILE = 1.75	5.344	10.882	3.744
0.25	MILE = 4.00	MILE = 2.00	5.204	10.872	3.712
0.28	MILE = 3.75	MILE = 2.25	5.074	10.762	3.680
0.31	MILE = 3.50	MILE = 2.50	4.953	10.654	3.648
0.35	MILE = 3.25	MILE = 2.75	4.841	10.547	3.617
0.38	MILE = 3.00	MILE = 3.00	4.734	10.441	3.585
0.41	MILE = 2.75	MILE = 3.25	4.638	10.335	3.554
0.44	MILE = 2.50	MILE = 3.50	4.550	10.231	3.524
0.47	MILE = 2.25	MILE = 3.75	4.467	10.128	3.494
0.50	MILE = 2.00	MILE = 4.00	4.390	10.026	3.463
0.54	MILE = 1.75	MILE = 4.25	4.317	9.925	3.433
0.57	MILE = 1.50	MILE = 4.50	4.248	9.825	3.404
0.60	MILE = 1.25	MILE = 4.75	4.184	9.727	3.374
0.63	MILE = 1.00	MILE = 5.00	4.124	9.629	3.345
0.66	MILE = 0.75	MILE = 5.25	4.068	9.532	3.316
0.70	MILE = 0.50	MILE = 5.50	4.016	9.436	3.288
0.73	MILE = 0.25	MILE = 5.75	3.968	9.341	3.259
0.76	MILE = 0.00	MILE = 6.00	3.924	9.247	3.231

MINIMUM DISSOLVED OXYGEN 6.784 MG/L OCCURS AT 0.000 DAY AND 0.0000 MILES
BELOW DISCHARGE OF FUNCTION

NAME OF FACILITY : HERME STP, ADAMS COUNTY
 FLOW CONNECTION FACTOR FOR CD ANALYSIS : 70.00 %
 RECEIVING STREAM : WABASH RIVER
 GAGING STATION : WABASH RIVER @ LIMN URINE, ADAMS COUNTY
 DRAINAGE AREA UPSTREAM OF STP'S OUTFALL LOCATION : 428.0 SQ.MI
 DRAINAGE AREA UPSTREAM OF REFERENCED GAGING STATION : 453.0 SQ.MI
 CORRECTED FACILITY FLOW USED IN THE ANALYSIS : 0.525 MGD
 FACILITY DESIGN FLOW : 0.750 MGD
 1.1475 CFS
 0.8137 CFS
 7.0110 CFS
 5.60 CFS
 6.88

NAME OF FACILITY : HERME STP, ADAMS COUNTY
 FLOW CONNECTION FACTOR FOR CD ANALYSIS : 70.00 %
 RECEIVING STREAM : WABASH RIVER
 GAGING STATION : WABASH RIVER @ LIMN URINE, ADAMS COUNTY
 DRAINAGE AREA UPSTREAM OF STP'S OUTFALL LOCATION : 428.0 SQ.MI
 DRAINAGE AREA UPSTREAM OF REFERENCED GAGING STATION : 453.0 SQ.MI
 CORRECTED FACILITY FLOW USED IN THE ANALYSIS : 0.525 MGD
 FACILITY DESIGN FLOW : 0.750 MGD
 1.1475 CFS
 0.8137 CFS
 7.0110 CFS
 5.60 CFS
 6.88

MONTH	GAGING STATION	ADJUSTED FLOW (Qs)	DILUTION RATIO (R)	ALLOWABLE DISCHARGE (Q0=Qs/R)	STP FLOW (Qi)	CUMULATIVE FLOW (Qi-Q0)	DEFICIENCY	ACCUMULATION
OCT	471.60	445.5735	10	44.5573	25.2262	44.5573	-19.3311	0.0000
NOV	337.10	318.6817	10	31.8685	24.4125	74.4258	-7.4560	0.0000
DEC	246.90	271.0666	10	27.1066	25.2262	103.5325	-1.8804	0.0000
JAN	191.00	181.1079	10	18.1103	25.2262	121.6717	7.0858	7.0858
FEB	12029.40	11365.5258	10	1136.5525	22.7950	1258.2255	-1113.7675	0.0000
MAR	1727.00	1632.3523	10	163.2352	25.2262	148.1025	-1607.1260	0.0000
APR	6731.00	5887.125	10	588.7125	24.4125	3479.2904	-564.3000	0.0000
MAY	3022.00	7611.0728	10	761.1072	25.2262	3840.3977	-335.8810	0.0000
JUN	594.00	561.5115	10	56.1218	24.4125	3096.5195	-31.7093	0.0000
JUL	966.10	919.7932	10	91.2783	25.2262	3987.7978	-66.0520	0.0000
AUG	764.80	744.5924	10	74.2592	25.2262	4060.0571	-47.0319	0.0000
SEP	2593.30	2450.1811	10	245.0181	24.4125	4305.0753	-220.6056	0.0000

MONTH	GAGING STATION	ADJUSTED FLOW (Qs)	DILUTION RATIO (R)	ALLOWABLE DISCHARGE (Q0=Qs/R)	STP FLOW (Qi)	CUMULATIVE FLOW (Qi-Q0)	DEFICIENCY	ACCUMULATION
OCT	471.60	445.5735	10	44.5573	25.2262	44.5573	-19.3311	0.0000
NOV	337.10	318.6817	10	31.8685	24.4125	74.4258	-7.4560	0.0000
DEC	246.90	271.0666	10	27.1066	25.2262	103.5325	-1.8804	0.0000
JAN	191.00	181.1079	10	18.1103	25.2262	121.6717	7.0858	7.0858
FEB	12029.40	11365.5258	10	1136.5525	22.7950	1258.2255	-1113.7675	0.0000
MAR	1727.00	1632.3523	10	163.2352	25.2262	148.1025	-1607.1260	0.0000
APR	6731.00	5887.125	10	588.7125	24.4125	3479.2904	-564.3000	0.0000
MAY	3022.00	7611.0728	10	761.1072	25.2262	3840.3977	-335.8810	0.0000
JUN	594.00	561.5115	10	56.1218	24.4125	3096.5195	-31.7093	0.0000
JUL	966.10	919.7932	10	91.2783	25.2262	3987.7978	-66.0520	0.0000
AUG	764.80	744.5924	10	74.2592	25.2262	4060.0571	-47.0319	0.0000
SEP	2593.30	2450.1811	10	245.0181	24.4125	4305.0753	-220.6056	0.0000

MONTH	GAGING STATION	ADJUSTED FLOW (Qs)	DILUTION RATIO (R)	ALLOWABLE DISCHARGE (Q0=Qs/R)	STP FLOW (Qi)	CUMULATIVE FLOW (Qi-Q0)	DEFICIENCY	ACCUMULATION
OCT	471.60	445.5735	10	44.5573	25.2262	44.5573	-19.3311	0.0000
NOV	337.10	318.6817	10	31.8685	24.4125	74.4258	-7.4560	0.0000
DEC	246.90	271.0666	10	27.1066	25.2262	103.5325	-1.8804	0.0000
JAN	191.00	181.1079	10	18.1103	25.2262	121.6717	7.0858	7.0858
FEB	12029.40	11365.5258	10	1136.5525	22.7950	1258.2255	-1113.7675	0.0000
MAR	1727.00	1632.3523	10	163.2352	25.2262	148.1025	-1607.1260	0.0000
APR	6731.00	5887.125	10	588.7125	24.4125	3479.2904	-564.3000	0.0000
MAY	3022.00	7611.0728	10	761.1072	25.2262	3840.3977	-335.8810	0.0000
JUN	594.00	561.5115	10	56.1218	24.4125	3096.5195	-31.7093	0.0000
JUL	966.10	919.7932	10	91.2783	25.2262	3987.7978	-66.0520	0.0000
AUG	764.80	744.5924	10	74.2592	25.2262	4060.0571	-47.0319	0.0000
SEP	2593.30	2450.1811	10	245.0181	24.4125	4305.0753	-220.6056	0.0000

MONTH	GAGING STATION	ADJUSTED FLOW (Qs)	DILUTION RATIO (R)	ALLOWABLE DISCHARGE (Q0=Qs/R)	STP FLOW (Qi)	CUMULATIVE FLOW (Qi-Q0)	DEFICIENCY	ACCUMULATION
OCT	471.60	445.5735	10	44.5573	25.2262	44.5573	-19.3311	0.0000
NOV	337.10	318.6817	10	31.8685	24.4125	74.4258	-7.4560	0.0000
DEC	246.90	271.0666	10	27.1066	25.2262	103.5325	-1.8804	0.0000
JAN	191.00	181.1079	10	18.1103	25.2262	121.6717	7.0858	7.0858
FEB	12029.40	11365.5258	10	1136.5525	22.7950	1258.2255	-1113.7675	0.0000
MAR	1727.00	1632.3523	10	163.2352	25.2262	148.1025	-1607.1260	0.0000
APR	6731.00	5887.125	10	588.7125	24.4125	3479.2904	-564.3000	0.0000
MAY	3022.00	7611.0728	10	761.1072	25.2262	3840.3977	-335.8810	0.0000
JUN	594.00	561.5115	10	56.1218	24.4125	3096.5195	-31.7093	0.0000
JUL	966.10	919.7932	10	91.2783	25.2262	3987.7978	-66.0520	0.0000
AUG	764.80	744.5924	10	74.2592	25.2262	4060.0571	-47.0319	0.0000
SEP	2593.30	2450.1811	10	245.0181	24.4125	4305.0753	-220.6056	0.0000

MONTH	GAGING STATION	ADJUSTED FLOW (Qs)	DILUTION RATIO (R)	ALLOWABLE DISCHARGE (Q0=Qs/R)	STP FLOW (Qi)	CUMULATIVE FLOW (Qi-Q0)	DEFICIENCY	ACCUMULATION
OCT	471.60	445.5735	10	44.5573	25.2262	44.5573	-19.3311	0.0000
NOV	337.10	318.6817	10	31.8685	24.4125	74.4258	-7.4560	0.0000
DEC	246.90	271.0666	10	27.1066	25.2262	103.5325	-1.8804	0.0000
JAN	191.00	181.1079	10	18.1103	25.2262	121.6717	7.0858	7.0858
FEB	12029.40	11365.5258	10	1136.5525	22.7950	1258.2255	-1113.7675	0.0000
MAR	1727.00	1632.3523	10	163.2352	25.2262	148.1025	-1607.1260	0.0000
APR	6731.00	5887.125	10	588.7125	24.4125	3479.2904	-564.3000	0.0000
MAY	3022.00	7611.0728	10	761.1072	25.2262	3840.3977	-335.8810	0.0000
JUN	594.00	561.5115	10	56.1218	24.4125	3096.5195	-31.7093	0.0000
JUL	966.10	919.7932	10	91.2783	25.2262	3987.7978	-66.0520	0.0000
AUG	764.80	744.5924	10	74.2592	25.2262	4060.0571	-47.0319	0.0000
SEP	2593.30	2450.1811	10	245.0181	24.4125	4305.0753	-220.6056	0.0000

*** OVERFLOW ***
 Remark (s) : EFFLUENT WILL BE DIRECTLY DISCHARGED TO WABASH RIVER
 Maximum ACCUMULATION : 7.08 cfs-day
 CONTROLLED WASTEWATER VOLUME : 4.5715 Mgal
 HML DURING PERIOD : 8.70 Day
 111 MPM