



INDIANA DEPARTMENT OF ENVIRONMENTAL MANAGEMENT

100 N. Senate Avenue • Indianapolis, IN 46204
(800) 451-6027 • (317) 232-8603 • Fax (317) 233-6647 • www.idem.IN.gov

Mike Braun
Governor

Clint Woods
Commissioner

February 18, 2025

VIA ELECTRONIC MAIL

Mr. Steve Reinbrecht, Member
Simplified Developments, LLC.
304 E. State Road 68
Haubstadt, Indiana 47639

Dear Mr. Reinbrecht:

Re: 327 IAC 3 Construction
Permit Application
Sanitary Sewer
Darlington Villas
Permit Approval No. 25713
Jamestown, Indiana
Boone County

The application, plans and specifications, and supporting documents for the above-referenced project have been reviewed and processed in accordance with rules adopted under 327 IAC 3. Enclosed is the Construction Permit (Approval No. 25713), which applies to the construction of the above-referenced proposed sanitary sewer system to be located approximately 1,030 feet north of the intersection of Darlington Road and Columbia Street in Jamestown, Indiana.

Please review the enclosed permit carefully and become familiar with its terms and conditions. In addition, it is imperative that the applicant, consulting architect/engineer (A/E), inspector, and contractor are aware of these terms, conditions, and reporting and testing requirements.

It should be noted that any person affected or aggrieved by the agency's decision in authorizing the construction of the above-referenced facility may, within fifteen (15) days from date of mailing, appeal this permit by filing a request with the Office of Administrative Law Proceedings for an adjudicatory hearing in accordance with IC 4-21.5-3-7 and IC 13-15-6. The procedure for appeal is outlined in more detail in Part III of the attached construction permit.

Plans and specifications were prepared by Morley Engineering, certified by Mr. James E. Morley, P.E., and submitted for review on November 25, 2024.

Visit on.IN.gov/survey or scan the QR code to provide feedback.

We appreciate your input!



Any questions concerning this permit may be addressed to Rob Pardue, of our staff, at (317) 234-1022 or RPardue@idem.IN.gov.

Sincerely,

A handwritten signature in black ink that reads "Kevin D. Czerniakowski". The signature is written in a cursive style with a distinct loop at the end of the last name.

Kevin D. Czerniakowski, P.E.
Section Chief
Facility Construction and
Engineering Support Section
Office of Water Quality

Project No. M-26586

Enclosures

cc: Boone County Health Department

Jamestown Wastewater Treatment Plant

Mr. James E. Morley, P.E. – Morley Engineering

INDIANA DEPARTMENT OF ENVIRONMENTAL MANAGEMENT
AUTHORIZATION FOR CONSTRUCTION OF
SANITARY SEWER SYSTEM
UNDER 327 IAC 3

DECISION OF APPROVAL

Simplified Developments, LLC., in accordance with the provisions of IC 13-15 and 327 IAC 3 is hereby issued a permit to construct the sanitary sewer system to be located approximately 1,030 feet north of the intersection of Darlington Road and Columbia Street in Jamestown, Indiana. The permittee is required to comply with requirements set forth in Parts I, II and III hereof. The permit is effective pursuant to IC 4-21.5-3-4(d). If a petition for review and a petition for stay of effectiveness are filed pursuant to IC 13-15-6, an Environmental Law Judge may be appointed for an adjudicatory hearing. The force and effect of any contested permit provision may be stayed at that time.

NOTICE OF EXPIRATION DATE

Authorization to initiate construction of this sanitary sewer system shall expire at midnight one year from the date of issuance of this construction permit. In order to receive authorization to initiate construction beyond this date, the permittee shall submit such information and forms as required by the Indiana Department of Environmental Management. It is requested that this information be submitted sixty (60) days prior to the expiration date to initiate construction. This permit shall be valid for a period of five (5) years from the date below for full construction completion.

Issued on February 18, 2025, for the Indiana Department of Environmental Management.



Kevin D. Czerniakowski, P.E.
Section Chief
Facility Construction and
Engineering Support Section
Office of Water Quality

SANITARY SEWER SYSTEM DESCRIPTION

The proposed project will consist of the construction of approximately 8,415 feet of 8-inch diameter PVC (ASTM D3034 SDR-35) sanitary sewer in the referenced project location. The proposed sewer will provide service for 199 single-family homes with an average design flow of 61,690 GPD. The proposed sewer will be connected to an existing 8-inch diameter VCP sanitary sewer at an existing manhole, located on the north side of Ash Street approximately 10 feet north and 440 feet west of the intersection of Darlington Road in Jamestown, Indiana.

Inspection during construction and maintenance of the new sanitary sewer will be provided by the Jamestown Municipal Sewer. Wastewater treatment will be provided by the City of Jamestown Wastewater Treatment Plant.

CONDITIONS AND LIMITATIONS TO THE AUTHORIZATION FOR
CONSTRUCTION OF SANITARY SEWERS

During the period beginning on the effective date of this permit and extending until the expiration date, the permittee is authorized to construct the above-described sanitary sewer system. Such construction shall conform to all provisions of State Rule 327 IAC 3 and the following specific provisions:

PART I

SPECIFIC CONDITIONS AND LIMITATIONS TO THE CONSTRUCTION PERMIT

Unless specific authorization is otherwise provided under the permit, the permittee shall comply with the following conditions:

1. Any local permits required for this project, along with easement acquisition, shall be obtained before construction is initiated.
2. If pollution or nuisance conditions are created, immediate corrective action will be taken by the permittee.
3. The separation of sanitary sewers from water mains and drinking water wells must comply with 327 IAC 3-6-9.
4. All gravity sewer pipe must be leak tested using either a hydrostatic test or air test in accordance with 327 IAC 3-6-19(d). If using a hydrostatic test, the rate of exfiltration or infiltration shall not exceed 200 gallons per inch of pipe diameter per linear mile per day. Air test shall be as prescribed.

5. The results of the gravity sewer leakage test on the completed sewer shall be submitted to this office within three months of completion of construction.
6. Deflection tests must be performed on all flexible* pipe after the final backfill has been in place at least 30 days. No pipe shall exceed a vertical deflection of 5%. Deflection test results shall be submitted with the infiltration/exfiltration test results. (*The following are considered nonflexible pipes: vitrified clay pipe, concrete pipe, ductile iron pipe, cast iron pipe, asbestos cement pipe.)
7. Manholes shall be air tested in accordance with ASTM C1244, Standard Test Method for Concrete Sewer Manholes by the Negative Air Pressure (Vacuum) Test. The manhole test results shall be submitted with the gravity sewer leakage test results.

Failure to submit test results within the allotted time period or failure to meet guidelines as set forth in the above conditions could be subject to enforcement proceedings as provided by 327 IAC 3-5-3.

PART II

GENERAL CONDITIONS

1. No significant or material changes in the scope of the plans or construction of this project shall be made unless the following provisions are met:
 - a. Request for permit modification is made 60 days in advance of the proposed significant or material changes in the scope of the plans or construction;
 - b. Submit a detailed statement of such proposed changes;
 - c. Submit revised plans and specifications including a revised design summary; and
 - d. Obtain a revised construction permit from this agency.
2. This permit may be modified, suspended, or revoked for cause including, but not limited to the following:
 - a. Violation of any term or conditions of this permit:
 - b. Obtaining this permit by misrepresentation or failure to disclose fully all relevant facts.
3. Nothing herein shall be construed as guaranteeing that the proposed sanitary sewer system shall meet standards, limitations or requirements of this or any other agency of state or federal government, as this agency has no direct control over the actual construction and/or operation of the proposed project.

PART III

NOTICE OF RIGHT TO ADMINISTRATIVE REVIEW

Anyone wishing to challenge this construction permit must do so by filing a Petition for Administrative Review with the Office of Administrative Law Proceedings (OALP) and serving a copy of the petition upon IDEM. The requirements for filing a Petition for Administrative Review are found in IC 4-21.5-3-7, IC 13-15-6-1 and 315 IAC 1-3-2. A summary of the requirements of these laws is provided below.

A Petition for Administrative Review must be filed with the Office of Administrative Law Proceedings (OALP) within fifteen (15) days of the issuance of this notice (eighteen (18) days if notice was received by U.S. Mail), and a copy must be served upon IDEM. Addresses are:

Director
Office of Administrative Law Proceedings
Indiana Government Center North
Room 802
100 North Senate Avenue
Indianapolis, Indiana 46204

Commissioner
Indiana Department of Environmental
Management
Indiana Government Center North
Room 1301
100 North Senate Avenue
Indianapolis, Indiana 46204

The petition must contain the following information:

1. The name, address and telephone number of each petitioner.
2. A description of each petitioner's interest in the permit.
3. A statement of facts demonstrating that each petitioner is:
 - a. a person to whom the order is directed;
 - b. aggrieved or adversely affected by the permit; or
 - c. entitled to administrative review under any law.
4. The reasons for the request for administrative review.
5. The particular legal issues proposed for review.
6. The alleged environmental concerns or technical deficiencies of the permit.
7. The permit terms and conditions that the petitioner believes would be appropriate and would comply with the law.
8. The identity of any persons represented by the petitioner.
9. The identity of the person against whom administrative review is sought.
10. A copy of the permit that is the basis of the petition.
11. A statement identifying petitioner's attorney or other representative, if any.

Failure to meet the requirements of the law with respect to a Petition for Administrative Review may result in a waiver of the Petitioner's right to seek administrative review of the permit. Examples are:

1. Failure to file a Petition by the applicable deadline;
2. Failure to serve a copy of the Petition upon IDEM when it is filed; or
3. Failure to include the information required by law.

If Petitioner seeks to have a permit stayed during the administrative review, he or she may need to file a Petition for a Stay of Effectiveness. The specific requirements for such a Petition can be found in 315 IAC 1-3-2 and 315 IAC 1-3-2.1.

Pursuant to IC 4-21.5-3-17, OALP will provide all parties with notice of any pre-hearing conferences, preliminary hearings, hearings, stays, or orders disposing of the review of this action. Those who are entitled to notice under IC 4-21.5-3-5(b) and would like to obtain notices of any pre-hearing conferences, preliminary hearings, hearings, stays, or orders disposing of the review of this action without intervening in the proceeding must submit a written request to OALP at the address above.

More information on the review process is available at the website for the Office of Administrative Law Proceedings at <http://www.in.gov/oalp>.

M-26586**APPLICATION FOR SANITARY SEWER
CONSTRUCTION PERMIT PER 327 IAC 3**

State Form 53159 (R8 / 6-22)

Indiana Department of Environmental Management
Office of Water Quality
Facility Construction and Engineering Support Section,
Mail Code 65-42FC
100 North Senate Avenue, Room N1255
Indianapolis, IN 46204-2251

| APPLICANT | | APPLICANT'S ENGINEER OR LAND SURVEYOR | |
|--|--|---|--|
| Name <input checked="" type="checkbox"/> Mr. or <input type="checkbox"/> Ms. Steve Reinbrecht, Member | | Name <input checked="" type="checkbox"/> Mr. or <input type="checkbox"/> Ms. James E. Morley | |
| Name of Organization Simplified Developments, LLC | | Name of Company Morley | |
| Address (number and street, city, state, and ZIP) 304 E SR 68, Haubstadt, IN 47639 | | Address (number and street, city, state, and ZIP) 4800 Rosebud Ln., Newburgh, IN 47630 | |
| Telephone Number (812) 615-0137 | | Telephone Number (812) 464-9585 | |
| E-Mail Address steve@eliteconstructionservices.com | | E-Mail Address jim@morleycorp.com | |
| NAME AND LOCATION OF PROPOSED FACILITY | | PROJECT DESCRIPTION | |
| Name Darlington Villas | | Describe the scope and/or purpose of this project The sanitary sewer main extension will begin at an existing manhole on the north side of Ash Street approximately 440 feet west of the intersection formed by Darlington Road and Ash Street and extend throughout Darlington Villas, a 199-lot single family home, residential subdivision in Boone County. | |
| Location or Project Boundaries The project is located approximately 1,030 feet north of the intersection formed by Darlington Road and Columbia Street. | | | |
| City or Town Jamestown | | | |
| County Boone | | | |
| SOURCE OF FUNDING | | | |
| <input type="checkbox"/> IFA's Wastewater State Revolving Fund Loan Program | | <input type="checkbox"/> Local Funds | |
| <input type="checkbox"/> OCRA's Community Development Block Grant | | <input checked="" type="checkbox"/> Private Funds | |
| <input type="checkbox"/> USDA's Rural Development Loan and Grant Assistance | | <input type="checkbox"/> Other: | |
| CERTIFICATION AND SIGNATURE | | | |
| I swear or affirm, under penalty of perjury as specified by IC 35-44.1-2-1 and other penalties specified by IC 13-30-10 and IC 13-15-7-1(3), that the statements and representations in this application are true, accurate, and complete. | | | |
| Printed Name of Person Signing Steve Reinbrecht | | | |
| Title Member | | | |
| Signature of Applicant <i>Steve Reinbrecht</i> | | Date Signed (month / day / year) 10 / 11 / 2024 | |

*(Please refer to IC 13-30-10 for penalties of submission of false information.)*Paid Online
\$100.00

IDEM - Water Quality

November 25, 2024

Received

COLLECTION SYSTEM DESIGN SUMMARY

Design Flow – Refer to 327 IAC 3-6-11 for Design Flow Rate Requirements

| Description of Units Served | Design Flow Per Unit | Number of Units | Unit Design Flow |
|-------------------------------------|----------------------|-------------------------|--------------------|
| <i>Example: Single family homes</i> | <i>310 gpd/unit</i> | <i>30</i> | <i>9,300 gpd</i> |
| Single family homes | 310 (gpd/unit) | 199 | 61,690 gpd |
| | (gpd/unit) | | gpd |
| | (gpd/unit) | | gpd |
| | (gpd/unit) | | gpd |
| | (gpd/unit) | | gpd |
| Average Design Flow | | | 61,690 gpd |
| Peaking factor | 4 | Peak Design flow | |
| | | | 246,760 gpd |

Gravity Sewer Pipe Applicable Not Applicable

| Length | Diameter | Material | ASTM or AWWA Standard | SDR or DR | Pressure Class (psi) | Installation Method |
|--------------------------|---------------|------------|-----------------------|---------------|----------------------|---------------------|
| <i>Example: 1,525 ft</i> | <i>8-inch</i> | <i>PVC</i> | <i>ASTM D3034</i> | <i>SDR-35</i> | <i>N/A</i> | <i>Open Cut</i> |
| 8,415 ft | 8 in | PVC | ASTM D3034 | SDR-35 | N/A | Open Cut |
| ft | in | | | | | |
| ft | in | | | | | |
| ft | in | | | | | |
| ft | in | | | | | |

Force Main Pipe and Low Pressure Sewer Applicable Not Applicable

| Length | Diameter | Material | ASTM or AWWA Standard | SDR or DR | Pressure Class (psi) | Installation Method |
|--------------------------|---------------|------------|-----------------------|---------------|----------------------|---------------------|
| <i>Example: 1,525 ft</i> | <i>8-inch</i> | <i>PVC</i> | <i>ASTM D2241</i> | <i>SDR-21</i> | <i>200 psi</i> | <i>Open Cut</i> |
| ft | in | | | | | |
| ft | in | | | | | |
| ft | in | | | | | |
| ft | in | | | | | |
| ft | in | | | | | |

Connection Location(s)

Example: The proposed sanitary sewer shall connect to an existing 8-inch sewer located approximately 10 ft north and 10 ft west of the intersection of Main Street and Park Avenue and to an existing lift station located approximately 20 ft southeast of the intersection of Oak Lane and Maple Drive.

The proposed sanitary sewer shall connect to an existing 8-inch sewer located approximately 10 ft north and 440 ft west of the intersection of Darlington Road and Ash Street.

Inspection / Maintenance

Inspection during construction will be provided by Jamestown Municipal Sewer

Maintenance after completion will be provided by Jamestown Municipal Sewer

Wastewater Treatment

Wastewater treatment will be provided by Jamestown WWTP


Lift Station Applicable Not Applicable

1. Location:

| |
|---|
| 2. Type of pump (example: submersible, dry pit): |
| 3. Number of pumps: |
| 4. Constant or variable speed: |
| 5. Design pump rate (gpm) and TDH (ft): |
| 6. Operating volume of the wet well (gal): |
| 7. Average detention time in the wet well (min): |
| 8. Type of standby power/pump provisions: |
| 9. Type of alarm: |
| 10. Additional information: |

| | |
|--|--|
| Low Pressure Sewer Grinder Pump Station | <input type="checkbox"/> Applicable <input checked="" type="checkbox"/> Not Applicable |
| 1. Number of stations: simplex duplex triplex | |
| 2. Number of residential connections per simplex station (two maximum): | |
| 3. Design pump rate (gpm) at maximum TDH (ft): | |
| 4. Type of alarm: | |
| 5. Privately or utility owned and maintained: | |
| 6. Additional information: | |

| | |
|--|--|
| Vacuum Pump Station | <input type="checkbox"/> Applicable <input checked="" type="checkbox"/> Not Applicable |
| 1. Location: | |
| 2. Total volume of vacuum tank (gal): | |
| 3. Operating volume of the vacuum tank (gal): | |
| 4. Number and size (HP) of vacuum pumps: | |
| 5. Number and type of sewage pumps: | |
| 6. Constant or variable speed: | |
| 7. Design pump rate (gpm) and TDH (ft): | |
| 8. Type of standby power/pump provisions: | |
| 9. Type of alarm: | |
| 10. Additional information: | |

| | |
|---|--|
| Certification Seal, Signature, and Date | |
| Printed Name of Engineer or Land Surveyor James E. Morley | |
| Signature  | Date Signed (month / day / year) 10 / 11 / 2024 |



A factor of four (4) is prescribed by 327 IAC 3-6-11. However, an alternative peaking factor may be justified by other means (327 IAC 3-6-32) or as provided by Ten State Standards 11.243: **Peaking Factor = $(18 + \sqrt{P}) / (4 + \sqrt{P})$** , where P = population in thousands.

Provide pump and system curves and design calculations for TDH. If connecting to an existing force main, provide upstream lift station pump curves and describe how the proposed flow will affect the lift station performance during simultaneous operation.

For small diameter low-pressure sanitary sewer systems, provide a spreadsheet that includes the maximum expected simultaneous operation of the proposed grinder pumps, maximum expected flow (gpm) and fluid velocity (ft/sec), static head and accumulated friction loss, and expected accumulated total dynamic head (TDH).

The average detention time in the wet well (cycle time between pump on/off settings) should be between 5 and 30 minutes. The cycle time may be calculated from the following equation: **Cycle Time = $(V / (D - Q)) + (V / Q)$** , where D = discharge flowrate out of the wet well (design pump rate) in gpm, Q = inflow rate into wet well (average design flow) in gpm, and V = operating volume of wet well (between pump on/off settings) in gallons.

CAPACITY CERTIFICATION

This form must be filled-out in its entirety with no alterations.

| |
|--|
| Name of Applicant: Simplified Developments, LLC |
| Name of Applicant Representative: Steve Reinbrecht, Member |
| Name of Project: Darlington Villas |

CERTIFICATION

I, Joshua Hawkins, representing the Jamestown Municipal Sewer, in my capacity as Superintendent of Utilities have the authority to act on behalf of the Jamestown Municipal Sewer

(Name of individual) (Name of municipality or utility) (Title) (Name of municipality or utility)

certify that I have reviewed and understand the requirements of 327 IAC 3 and that the sanitary collection system proposed, with the submission of this application, plans and specifications, meets all requirements of 327 IAC 3. I certify that the daily flow generated in the area that will be collected by the project system will not cause overflowing or bypassing in the collection system other than NPDES authorized discharge points and that there is sufficient capacity in the receiving water pollution treatment/control facility to treat the additional daily flow and remain in compliance with applicable NPDES permit effluent limitations. I certify that the proposed average flow will not result in hydraulic or organic overload. I certify that the proposed collection system does not include new combined sewers or a combined sewer extension to existing combined sewers. I certify that the ability for this collection system to comply with 327 IAC 3 is not contingent on water pollution/control facility construction that has not been completed and put into operation. I certify that the project meets all local rules or laws, regulations and ordinances. The information submitted is true, accurate, and complete, to the best of my knowledge and belief. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment.

| | |
|--|---|
| Average Design Flow (<i>gallons per day</i>) | 61,690 |
| Peak Design Flow (<i>gallons per day</i>) | 246,760 |
| Owner of Receiving Collection System | Jamestown Municipal Sewer |
| Name of Wastewater Treatment Plant | Jamestown WWTP |
| Mailing Address of Certifying Representative <small>(number and street, city, state, and ZIP code)</small> | E-mail Address of Certifying Representative |
| 421 E Main, PO Box 165, Jamestown IN, 46147 | jhawks@townofjamestown.in.gov |
| I am certifying for the <input checked="" type="checkbox"/> Collection System <input checked="" type="checkbox"/> Treatment Facility | |
| Signature <i>Josh Hawkins</i> | Date Signed (<i>month / day / year</i>) 11 / 06 / 2024 |

(Please refer to IC 13-30-10 for penalties of submission of false information.)

CERTIFICATION OF REGISTERED PROFESSIONAL ENGINEER OR LAND SURVEYOR


This form must be filled-out in its entirety with no alterations.

| |
|--|
| Name of Applicant: Simplified Developments, LLC |
| Name of Applicant Representative: Steve Reinbrecht, Member |
| Name of Project: Darlington Villas |

CERTIFICATION

I, James E. Morley, representing the project applicant, in my capacity as a
(Name of Individual)
 registered professional Engineer, No. 10100250
(Engineer or Land Surveyor) *(Indiana registration number)*

certify the following under penalty of law: The design of this project has been performed under my direction or supervision to assure conformance with 327 IAC 3 and the plans and specifications require the construction of said project to be performed in conformance with 327 IAC 3-6. The peak daily flow rates, in accordance with 327 IAC 3-6-11 generated from within the specific area that will be collected by the proposed collection system that is the subject of the application, plans, and specifications (when functioning as designed and properly installed), will not cause overflowing or bypassing in the same specific area serviced by the proposed collection system other than from NPDES authorized discharge points. The proposed collection system does not include new combined sewers (serving new areas) or a combined sewer extension to existing combined sewers. The sewer at the point of connection is physically in existence and operational. Based upon information provided by the owner of the Wastewater System, the ability for this collection system to comply with 327 IAC 3 is not contingent on downstream water pollution/control facility construction that has not been completed and put into operation. The design of the proposed project meets applicable local rules or laws, regulations and ordinances. The information submitted is true, accurate, and complete, to the best of my knowledge and belief. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment.

| | |
|---|---|
| Average Design Flow (<i>gallons per day</i>) | 61,690 |
| Peak Design Flow (<i>gallons per day</i>) | 246,760 |
| Owner of Receiving Collection System | Jamestown Municipal Water |
| Name of Wastewater Treatment Plant | Jamestown WWTP |
| Signature  | Date Signed (<i>month / day / year</i>) 10 / 11 / 24 |

(Please refer to IC 13-30-10 for penalties of submission of false information.)

IDENTIFICATION OF POTENTIALLY AFFECTED PERSONS

Please list any and all persons whom you have reason to believe have a substantial or proprietary interest in this matter, or could otherwise be considered to be potentially affected under law. Failure to notify a person who is later determined to be potentially affected could result in voiding IDEM's decision on procedural grounds. To ensure conformance with Administrative Orders and Procedures Act (AOPA) and to avoid reversal of a decision, please list all such parties. The letter on the opposite side of this form will further explain the requirements under the AOPA. Attach additional names and addresses on a separate sheet of paper, as needed.

| | |
|--------------------------------------|----------|
| Name SEE ATTACHED SHEET | |
| Address (<i>number and street</i>) | |
| City | |
| State | ZIP Code |

| | |
|--------------------------------------|----------|
| Name | |
| Address (<i>number and street</i>) | |
| City | |
| State | ZIP Code |

| | |
|--------------------------------------|----------|
| Name | |
| Address (<i>number and street</i>) | |
| City | |
| State | ZIP Code |


| | |
|--------------------------------------|----------|
| Name | |
| Address (<i>number and street</i>) | |
| City | |
| State | ZIP Code |

| | |
|--------------------------------------|----------|
| Name | |
| Address (<i>number and street</i>) | |
| City | |
| State | ZIP Code |

| | |
|--------------------------------------|----------|
| Name | |
| Address (<i>number and street</i>) | |
| City | |
| State | ZIP Code |

CERTIFICATION

I certify that to the best of my knowledge I have listed all potentially affected parties, as defined by IC 4-21.5-3-5.

| | |
|--|---|
| Proposed Facility Name Darlington Villas | City Jamestown |
| Printed Name of Person Signing James E. Morley | County Vanderburgh |
| Signature  | Date Signed (<i>month / day / year</i>) 10 / 11 / 24 |

65-42FC
BROSHAR GARY L
6370 SOUTH DARLINGTON ROAD
JAMESTOWN, IN 46147

65-42FC
TW DEVELOPMENT LLC
10719 ROSS ROAD
JAMESTOWN, IN 46147

65-42FC
SLONE JOSEPH B TRUSTEE OF
THE
698 N DARLINGTON ST
JAMESTOWN, IN 46147

65-42FC
HILDRED RITA D
237 W COLUMBIA ST
JAMESTOWN, IN 46147-9079

65-42FC
HOSKINS KEVIN D & D
ELIZABETH
416 W COLUMBIA ST
JAMESTOWN, IN 46147

65-42FC
GREENE REALTY, LLC
PO BOX 309
ROACHDALE, IN 46172

65-42FC
WATTS MARY JO
538 N DARLINGTON ST
JAMESTOWN, IN 46147

65-42FC
HOSKINS KEVIN & ELIZABETH
416 W COLUMBIA ST
JAMESTOWN, IN 46147

65-42FC
BOWDEN DARRELL & CAROL
604 S UNION ST
WESTFIELD, IN 46074

65-42FC
SMITH RODNEY D & SUSAN I
630 N DARLINGTON ST
JAMESTOWN, IN 46147

65-42FC
HOSKINS MICKEY L & RHONDA R
7034 S DARLINGTON RD
JAMESTOWN, IN 46147-9139

65-42FC
WEEMS KENNETH & ROSEMARIE
690 N DARLINGTON ST
JAMESTOWN, IN 46147

65-42FC
MCDONALD KOREY C
527 N DARLINGTON ST
JAMESTOWN, IN 46147

65-42FC
REID JACK L
9422 W 440 N
WAYNETOWN, IN 47990

65-42FC
LITELL NICHOLAS & ELIZABETH
417 WEST COLUMBIA ST
JAMESTOWN, IN 46147

65-42FC
RAWLINGS KRISTY
330 WASH ST
JAMESTOWN, IN 46147

65-42FC
PARRINELLO CODY M & CINDY D
532 N DARLINGTON ST
JAMESTOWN, IN 46147

65-42FC
PURDUE PARKER R
434 WASH ST
JAMESTOWN, IN 46147

65-42FC
LUMMIS JOHN DAVID & DIANA
SUSO
610 N DARLINGTON ST
JAMESTOWN, IN 46147

65-42FC
KRAMER THERESA
640 N DARLINGTON ST
JAMESTOWN, IN 46147

65-42FC
PURDY JEFFREY L & KIMBERLY A
6500 S. DARLINGTON RD
JAMESTOWN, IN 46147

65-42FC
COOK VIRLIN MICHAEL & TAMMY
LY
680 N DARLINGTON ST
JAMESTOWN, IN 46147

65-42FC
BRENNAN JAMIE RUTH ETAL
606 N DARLINGTON ST
JAMESTOWN, IN 46147

65-42FC
SHIRK PHILIP THOMAS &
KATHERIN
333 W COLUMBIA ST
JAMESTOWN, IN 46147

65-42FC
BRENNAN JAMIE RUTH ETAL
606 N DARLINGTON ST
JAMESTOWN, IN 46147

65-42FC
COOPER JOAN & BILLY J
650 N DARLINGTON ST
JAMESTOWN, IN 46147

65-42FC
HOLLINGSWORTH BLAKE L &
ANNEMA
448 WASH ST
JAMESTOWN, IN 46147

65-42FC
RUSSELL SHANE A & ANGELA J
414 WASH ST
JAMESTOWN, IN 46147-9072

65-42FC
BARINGER STEPHEN D
7620 S 1100 W
JAMESTOWN, IN 46147

65-42FC
RINER JOHN R & KATHRYN J
9885 W 200 S
JAMESTOWN, IN 46147



IDEM

Indiana Department of Environmental Management

PURCHASE RECEIPT

IDEM

100 N Senate Avenue
Indianapolis IN 46204
(317)234-3099
billing@idem.IN.gov
OTC Local Ref ID: 126601078
11/25/2024 01:18 PM

If you have any questions, please email us at billing@idem.IN.gov.

This acknowledges receipt of your payment. Thank you.

Status: **APPROVED**
Customer Name: Cody Simpson
Type: Visa
Credit Card Number: **** * 4961

| | Items | Quantity | TPE Order ID | Total Amount |
|--|-------|----------|--------------|--------------|
| Wastewater Treatment Plant Construction Permit | | 1 | 190512788 | \$100.00 |
| Company Name: Morley | | | | |
| Facility Name: Sanitary Sewer/Darlington Villas | | | | |
| Total remitted to the IDEM | | | | \$100.00 |
| INGov total amount charged | | | | \$102.46 |