



Astbury Water Technology, Inc.
Thomas B. Astbury, Vice President – Business Development

November 10, 2025

IN0063967
Montgomery Co.

Via Electronic Mail

Mr. Jason Palin
Wastewater Field Inspector
Indiana Department of Environmental Management
japalin@idem.in.gov
wwViolationResponse@idem.in.gov

Dear Mr. Palin:

SUBJECT: Inspection Summary/ Noncompliance Letter
Nucor Road WWTP Montgomery County RSD
NPDES Permit No. IN0063967
Crawfordsville, Montgomery County

The purpose of this letter is to respond to the referenced Inspection Summary Letter dated November 5, 2025 from Indiana Department of Environmental Management (IDEM) regarding an inspection performed November 4 at the Nucor Road Wastewater Treatment Plant (Nucor Road WWTP). This letter is being written on behalf of Montgomery County Regional Sewer District (MCRSD) by contract operations firm Astbury Water Technology, Inc. (Astbury).

1. The Flow Measurement area of the evaluation generated an “unsatisfactory” rating because the effluent flow meter, despite repeated corrective action, continues to malfunction.
 - a. A proposal to replace the effluent flow meter was previously approved by the MCRSD Board. This equipment should arrive at Astbury’s Indianapolis office this week and be installed no later than the following week.

All parties are committed to maintaining full compliance with the NPDES permit. Please don’t hesitate to contact me with any questions regarding this response letter (via email at tastbury@astburygroup.com, or via mobile phone at 317-828-1534).

Headquarters Office/Lab
5940 West Raymond Street
Indianapolis, Indiana 46241
Office: 317-328-7153 x111
Cell: 317-828-1534
tastbury@astburygroup.com
AstburyWater.com

Northwest Office/Lab
South Haven Sewer Works
305 West 700 North
Valparaiso, Indiana 46385
Office: 219-364-8375

North Central Service Center
2557 East US 30
Warsaw, Indiana 46580

Southern Office/Lab
2500 Lincoln Drive, Suite A
Clarksville, Indiana 47129
Office: 812-282-8481



Best regards,

A handwritten signature in black ink, appearing to read "T. B. Astbury", with a horizontal line extending from the end of the signature.

Thomas B. Astbury

CC: MCRSD Board
BCS Management
Stuart Bookwalter, Operator of Record – Astbury