



# INDIANA DEPARTMENT OF ENVIRONMENTAL MANAGEMENT

*We Protect Hoosiers and Our Environment.*

100 N. Senate Avenue • Indianapolis, IN 46204  
(800) 451-6027 • (317) 232-8603 • [www.idem.IN.gov](http://www.idem.IN.gov)

Eric J. Holcomb  
Governor

Bruno Pigott  
Commissioner

Re: Actions for Reopening a Public Water Supply  
After a Long Shut Down  
**IN2270017 Harts Celebration Center**

Below is a list of IDEM recommendations and requirements for a Public Water Supply system before reopening after being closed for a period of time due to the COVID-19 pandemic. Studies show that water will become stagnant after seven to nine days of standing still. *If you have any questions please contact your IDEM Field Inspector Dale Pershing at (317) 694-2754.*

### Recommended actions:

- Visually inspect system components to be sure all components are intact
- Flush building piping systems thoroughly
- Check if well and pump are operating correctly
- See if all valves, gauges and controls are working properly
- Ensure system is fully pressurized (at least 20 psi) and not leaking
- Make sure all treatment equipment is operating correctly (*if applicable*)
- Inspect/change inline filters, regenerate softeners, chlorine residual, etc. for any treatment that applies
- Make sure storage tanks are sealed, not leaking, and in working order
- Collect a special purpose total coliform sample from the farthest point in the distribution system. Submit the results of the sample to IDEM.
- Optionally chlorinate the well and distribution system

### Required action:

- **Collect a routine total coliform sample within seven (7) days of returning to normal operations. Submit the results to IDEM.**
- Your estimated reopen date is June 2020. Please notify the IDEM Compliance Section at [dwbmgr@idem.in.gov](mailto:dwbmgr@idem.in.gov) **if that date changes**, so we can adjust your requirements accordingly.

Sincerely,

Drinking Water Branch  
Office of Water Quality  
IDEM  
[DWBmgr@idem.in.gov](mailto:DWBmgr@idem.in.gov)

cc: Dale Pershing, Field Inspector



A State that Works



# Guidance for Flushing Public Water Systems

Office of Water Quality – Drinking Water Branch

(317) 232-8603 • (800) 451-6027

[www.idem.IN.gov](http://www.idem.IN.gov)

100 N. Senate Ave., Indianapolis, IN 46204

This document is designed to help public water systems prepare their systems for safe use once they reopen buildings that may have been temporarily closed or used less frequently due to the COVID-19 pandemic. It is imperative that operators adhere to the flushing instructions below to ensure their indoor plumbing is receiving fresh water and not stagnant water. The flushing instructions apply to:

- Community water systems such as municipal water supplies, subdivisions, or mobile home parks
- Non-transient non-community water systems such as schools, daycares or factories
- Transient water systems such as churches, restaurants/bars or campgrounds

## Issues Caused by Stagnant Water

When water is not used over an extended period, it will become stagnant. Stagnant or standing water can cause conditions that increase the risk for growth and spread of *Legionella* and other harmful biofilm-associated bacteria. When water is stagnant, hot water temperatures can decrease to the *Legionella* growth range (77–108°F, 25–42°C). Stagnant water can also lead to low or undetectable levels of disinfectants such as chlorine and could also cause corrosion issues. It is critical to ensure water systems are safe to use after a prolonged shutdown to minimize the risk of Legionnaires' and other diseases associated with stagnant water.

## How to Remove Stagnant Water

Since stagnant water is a potential health risk and can impact water quality, it is necessary to systematically flush the plumbing. In general, flushing involves opening taps and other fixtures and letting water run to remove any stagnant water within plumbing and fixtures. To protect the health and safety of consumers, IDEM recommends that you carefully read and adhere to the following instructions, which provide a systematic approach for conducting a complete flush.

NOTE: Some buildings have water treatment systems and those treatment devices need to be cleaned, flushed, and maintained as part of the start-up process. After flushing, water filters need to be replaced. If there is a point-of-entry water treatment system such as a water softener or filter, please refer to the instruction manual for information on how to replace the filter.

## Flushing Instructions

**Please complete these steps in the order set out below. Finish each step completely before moving on to the next step. During the initial flushing, it is a good idea to wear protective respiratory equipment. Discoloration and a lingering odor may occur during flushing; these issues are expected and are not a health issue.**

### 1. Flush ALL cold water taps for at least 5 minutes.

Begin the cold water flushing procedure. Open ALL cold-water fixtures and run them for at least 5 minutes. Shut the water off after 5 minutes. Flush each toilet at least one time. This step includes the water in your refrigerator water dispenser.

Flushing should begin at the water service entrance and proceed through the building to the end points of the plumbing system in the building(s). Depending on flow and pressure, you may need to increase the flushing time to ensure all stagnant water has been flushed.

## 2. Flush ALL hot water taps for 15 minutes.

Once the cold water lines have been flushed, begin the hot water flushing procedure. Open ALL hot water taps in your bathroom(s) including lavatory (sink) fixtures, hot water bath fixtures, and any other hot water fixtures such as kitchens, wet bars, etc. Run these hot water fixtures for at least 15 minutes. Shut the water off after 15 minutes. Depending on the size of the hot water tank, you may need to flush longer to ensure the water in the tank has drained and fresh water has refilled the tank. These steps should be effective at removing contaminants from the water heater. However, for information on draining and cleaning the water heater, please consult the manufacturer.

## 3. Flush ALL remaining appliances and faucets for 5 minutes.

Open any remaining fixtures such as hose bibs, external faucets, or fixtures not used for drinking for at least 5 minutes to finish the plumbing system flushing. Take additional steps to remove water from other appliances including:

- Ice Makers
- Dishwashers
- Washing Machines
- Humidifiers
- CPAP Machines
- Oral, Medical, or Health Care Devices
- Baby Formula
- Water Filters
- Water Softeners
- Filters (point of use and whole house)

Remove ice from the ice maker bin and discard 2 additional batches of ice. Run empty dishwasher and washing machine once on rinse cycle.

## 4. Perform periodic ongoing flushes.

Periodic flushing is important to maintain water quality. Full-building, periodic flushes proceed the same as the initial flush except water tanks do not need to be drained and hot water flushing times are the same as cold water flushing times.

If you have chlorinated water, it is a good idea to measure chlorine residual during periodic flushes.

**For additional COVID-19 response information that is more detailed, please visit:**

<https://engineering.purdue.edu/PlumbingSafety/project>

### Other Resources

- [Guidance for Building Water Systems](#) (Centers for Disease Control and Prevention)
- [Return to Service Guidance](#) (American Water Works Association)

## Tobias, Anthony

---

**From:** Roger Hart <rogerdhart@gmail.com>  
**Sent:** Friday, April 24, 2020 8:52 AM  
**To:** Tobias, Anthony  
**Subject:** Re: 2270017 Harts Celebration Center

**Follow Up Flag:** Follow up  
**Flag Status:** Flagged

\*\*\*\* This is an EXTERNAL email. Exercise caution. DO NOT open attachments or click links from unknown senders or unexpected email. \*\*\*\*

---

I am requesting a waiver for April and May 2020 and to be put back on 1/4ly testing Starting in June. We have had nothing at the center(We are an event center where people come to be together.) Since Feb because of the virus shutdown. We have absolutely no income to cover \$1000's of of monthly bills.(utility's,insurance,property taxes,maintenance on building and property and mortgage payments.. Roger Hart, you may call me at 765-669-2747 if you have any questions.

On Wed, Apr 22, 2020 at 3:54 PM Tobias, Anthony <[ATobias@idem.in.gov](mailto:ATobias@idem.in.gov)> wrote:

Roger,

Please email me a reply requesting a waiver for April sampling that includes the specific date of closure, expectation of reopening, and reason for closure. We will review and grant your waiver as long as the criteria is met to do so.

Thank you,

### **Coping with COVID-19:**

- **Indiana State Dept. of Health (ISDH) COVID-19 Call Center:** Call 877-826-0011 (open 24/7)
- **Anthem NurseLine:** Call 800-337-4770 or visit the Anthem NurseLine online for a FREE symptom screening. Available to anyone with an Anthem health plan (this includes State of IN employees)
- **Anthem Employee Assistance Program (EAP):** Available to ALL state employees and adults in household regardless of health plan participation. Call 800-223-7723 or visit [anthemeap.com](http://anthemeap.com) (enter State of Indiana) for crisis counseling, help finding child/elder care, legal/financial consultation and much more.

**Anthony Tobias**

*Compliance Section*

*IDEM-OWQ, Drinking Water Branch*

*100 North Senate Avenue (66-34)*

*Indianapolis, IN 46204*

[atobias@idem.in.gov](mailto:atobias@idem.in.gov)

*Tel. No. (317)234-7445*

*Fax No. (317)234-7436*

**IDEM values your feedback.**

**Please take two minutes and complete this brief survey.**

