

Lakeview Campground

## JUN - 8 2020 em Start-up Requirements

Date (month, day, year)

State Form 55927 (R279-16)

This checklist must be completed as you start up your system. It will aid in preventing contamination from entering your water system and will help you identify problems with your system. You must complete the following tasks (if applicable), check completion of each task, and mail, fax, or e-mail a signed copy with a copy of the special purpose sample result to the IDEM Drinking Water Branch. Make and keep a copy for your records.

PWSID

Review Sampling Requirements	DYOINY='?
Review sampling schedule available at <a href="myweb.in.gov/IDEM/DWW/">myweb.in.gov/IDEM/DWW/</a> or you can call 1(800) 451-6027 ext. 47430	<b>√</b> Yes
Make arrangements for sample collection analysis with a certified lab (including SSLAP)	✓ Yes
Review your site sampling plan and make sure it is up to date	Yes
W/ell(s)	Doine?
Well cap is tight and secure	Yes
Pump house is locked and secure	Yes n/a
Well casing is structurally sound and there is no visible damage	✓ Yes
Vent screen is in place and downturned	Yes n/a
Rodents and insects are kept out of any enclosure around the well (e.g. keep area mowed)	Yes
The source or well sample tap* does not leak and flows freely when opened *This is typically a spigot, hose bib, or sample tap located after the well but before the storage tank or any water treatment device	Yes
Contaminant sources such as chemicals, livestock, and fuel are kept at least 100 feet from the well	Yes
Check for evidence of flooding or standing water near the well	Yes
Tireatiment Equipment	Done?
All components are operating properly and free of corrosion or damage	Yes n/a
ANSI- or NSF-approved water treatment chemicals are on hand	Yes n/a
Storage Tank(s)	Doine?
All valves, gauges, and controls are working properly	Yes n/a

System Name	PWSID		Date (month, day, year)
Siensigie Tanki(s)) Gionalipiuleid			Dioxine?
Pressure is being maintained and the pump is cy (once the system is pressurized)	cling normally		Yes
Tanks are sealed, <b>not</b> leaking, and in working or	der		Yes
For a non-pressurized tank, the vent screen is in	place and downt	urned	√ Yes n/a
Dietifferitent Syratem			[Drayare?]
All accessible lines and equipment are free of co	rrosion, damage,	or leaks	Yes
All valves open and close freely			Yes n/a
Outdoor spigots or yard hydrants have vacuum b	reakers or backflo	ow preventers	✓ Yes n/a
All testable backflow preventers have been tested the last twelve (12) months.	by a certified ba	ckflow tester in	Yes n/a
Avoilivatie aintol Pressaulificae			Done?
Well and pump are operating correctly		•	Yes
System is fully pressurized (at least 20 psi) and no	ot leaking		✓ Yes
Water treatment equipment is operating correctly			Yes V n/a
Distinfered amo Flush System			Doug?
System was disinfected			Yes No
System was flushed			<b>∨</b> Yes
Collected a satisfactory special purpose total coliforin the distribution system. Submit results of sample	orm sample from t e to IDEM.	farthest point	4 - 22 - 2025  Date Collected
Keep a copy of this checklist and submit the origin	al to IDEM.		✓ Yes
Daile system opens for this sessons 5.24.20			
Comments (Attach an additional sheet if more spa	ce is needed.)		
I certify, <i>under penalty of law,</i> that this document was me, and that any deficiencies found during this seaso	s prepared by onal start-up		c, or e-mail

inspection have, to the best of my knowledge and belief, been corrected.

Roberta Berns

6.3.2020

Date (month, day, year)

Indiana Department of **Environmental Management** 100 N. Senate Ave IGCN 1255 Indianapolis, IN 46204 Fax: 317-234-7462 Email: CapCert@idem.in.gov