



**MONTHLY REPORT OF OPERATION
OF WATER TREATMENT PLANT**
State Form 34609 (R 7 / 9-06)

INDIANA DEPARTMENT OF
ENVIRONMENTAL MANAGEMENT

System Name Versailles Water Works PWSID Number 5269006.000

For the Month of May IDEM Field Rep. Angie Willoughby

Signed Tony Franklin Title Superintendent

I certify, *under penalty of law*, by this signature that this document was prepared by me, or under my direction, and the information submitted is to the best of my knowledge and belief, true, accurate and complete. *I am also aware that there are significant penalties for submitting false information.*

Certification Number DS140210

PHYSICAL AND CHEMICAL DATA *

Date	Water Treated 1000 Gallons	Chlorine Residual D.S.		pH Finished	Hardness		Iron		Remarks
		Free	Total		Raw	Finished	Raw	Finished	
1	0.165	0.9	0.8	7.85					
2	0.165	1.0	1.0	8.45					
3	0.164	0.9	1.0	8.12					
4	0.157	0.9	1.0	8.24					
5	0.164	0.8	1.0	8.36					
6	0.099	0.8	0.9	8.12					
7	0.212	0.9	0.9	7.96					
8	0.262	1.0	1.1	7.66					
9	0.218	1.1	1.1	7.90					
10	0.191	1.1	1.0	7.81					
11	0.194	1.0	1.0	7.83					
12	0.175	1.0	1.0	7.90					
13	0.181	0.8	0.9	7.95					
14	0.162	1.0	1.0	7.77					
15	0.160	0.9	1.2	7.84					
16	0.187	0.7	0.9	7.73					
17	0.163	1.0	1.1	7.85					
18	0.188	0.9	1.0	7.79					
19	0.185	0.8	0.9	7.74					
20	0.177	0.8	0.8	7.86					
21	0.202	0.8	0.9	7.71					
22	0.167	1.0	1.1	7.51					
23	0.165	1.0	1.1	7.54					
24	0.183	1.0	1.1	7.54					
25	0.178	1.0	1.0	7.63					
26	0.162	0.9	1.0	7.73					Monthly Water Treatment
27	0.211	1.0	1.0	7.94					Total Gallons 5.467
28	0.149	1.0	1.0	8.13					Max. Day 0.262
29	0.152	1.1	1.3	7.76					Min. Day 0.099
30	0.171	1.1	1.2	7.62					Avg. Daily 0.176
31	0.157	1.2	1.1	7.75					

* All parameters are to be expressed in mg/l except ph and turbidity

