

From: [Steven Dyke](#)
To: [IDEM WWViolationresponse](#)
Cc: [Dryden, Andrew](#)
Subject: Palmyra Municipal WWTP IN0039403 6-12-23 CEI, Harrison Co.
Date: Monday, June 24, 2024 2:03:20 PM
Attachments: [Outlook-vtovztcx.png](#)

**** This is an EXTERNAL email. Exercise caution. DO NOT open attachments or click links from unknown senders or unexpected email. ****

To whom it may concern,

Over the past couple months, we have tried to put the blower system on a timer to conserve energy usage. With the many fluxuations in the final results, we have taken the blower system off of the timers and they are back on a continuous run cycle. Everything is back in proper order as of June 24. I have also went back and corrected the NetDMRs that had the wrong number of exceedances. If there is anything else that needs to be completed please feel free to reach out.

Thank you,

Stephen Dyke
System Manager
930-968-1137
sdyke@astburygroup.com

