



MONTHLY REPORT OF OPERATION WATER TREATMENT PLANT

State Form 34609 (R11 / 1-17)

INDIANA DEPARTMENT OF
ENVIRONMENTAL MANAGEMENT

System Name Kingman Water PWSID Number IN5223004

For the Month of May Year 2024 IDEM Field Rep. John Summerlin

Signed *Michael...* Title Operator

I certify *under penalty of law*, by this signature that this document was prepared by me, or under my direction, and the information submitted is to the best of my knowledge and belief, true, accurate, and complete. I am also aware that there are significant penalties for submitting false information.

Certification Number WT031109

PHYSICAL AND CHEMICAL DATA *

Date	Turbidity		Alkalinity		pH		Hardness		Iron		Manganese		Phosphate	Fluoride
	Raw	Finished	Raw	Finished	Raw	Finished	Raw	Finished	Raw	Finished	Raw	Finished	Finished	Finished
1					7.5	7.0			.8	.0				
2					7.5	7.0			1.2	.0				
3					7.5	7.0			1.0	.0				
4														
5														
6					7.5	7.0			.6	.1				
7					7.5	7.0			1.2	.0				
8					7.5	7.0			.7	.0				
9					7.5	7.0			1.1	.0				
10					7.5	7.0			.5	.0				
11														
12														
13					7.5	7.0			.9	.0				
14					7.5	7.0			.8	.0				
15					7.5	7.0			.7	.0				
16					7.5	7.0			.8	.0				
17					7.5	7.0			.9	.0				
18														
19														
20					7.5	7.0			.7	.0				
21					7.5	7.0			.6	.0				
22					7.5	7.0			1.2	.0				
23					7.5	7.0			.6	.0				
24					7.5	7.0			.6	.1				
25														
26														
27					7.5	7.0			.6	.0				
28					7.5	7.0			.7	.0				
29					7.5	7.0			.6	.0				
30					7.5	7.0			.7	.0				
31					7.5	7.0			1.9	.0				

* All parameters are to be expressed in mg/l except pH and turbidity.

DUE BY THE 10TH OF THE MONTH FOLLOWING THE REPORTING PERIOD.

Date	Water Treated 1000 gallons	Chemicals Used – Pounds								Filters		Chlorine Residual				Remarks	
		Salt	Alum	Lime	Soda Ash	Carbon	Chlorine	Fluoride	Phos- phate	Filter Run (hours)	Gallons per wash x 1000	Plant Tap		D. S.			
												Free	Total	Free	Total		
1	28					1.6			6	6	.5	1.7	.1	2.1			
2	39					2.2			9	4	.2	1.4	.1	1.3			
3	50					3.2			11	6	.7	1.5	.1	1.0			
4	59					3.8			15		.3	1.2	.1	1.1			
5	60					3.4			13		.7	2.1	.1	.9			
6	38					2.4			8	10	1.3	4.7	.1	3.5			
7	45					3.2			12		1.0	3.6	.1	.7			
8	45					2.6			10	6	.3	1.9	.1	1.5			
9	47					2.8			12	4	.1	.8	.1	.7			
10	36					2.0			8	6	.2	.7	.1	.9			
11	32					2.0			7		.4	.8	.1	1.1			
12	35					2.2			8		.3	1.0	.1	.6			
13	30					1.8			7	6	.9	3.6	.1	.9			
14	45					2.4			11	4	.9	.9	.1	.8			
15	35					4.0			.8	6	.2	1.7	.1	1.6			
16	23					3.8			6	4	1.5	6.2	.1	1.8			
17	51					7.2			11	6	1.8	5.0	.1	1.2			
18	49					6.0			11		1.8	5.5	.1	2.0			
19	30					4.8			8		2.3	5.5	.1	1.6			
20	44					5.6			10	10	1.4	6.2	.1	3.8			
21	68					10.0			16		.9	5.1	.1	3.8	Monthly Water Treatment		
22	58					7.4			15	10	.6	3.1	.1	3.1	Total Gallons	1,345,000	
23	50					7.2			11		.4	3.4	.1	3.4	Max. Day	72,000	
24	68					8.6			16	10	.2	4.3	.1	2.9	Min. Day	22,000	
25	38					5.0			8		.8	3.8	.1	1.2	Avg. Daily	43,000	
26	37					7.8			6		.5	2.9	.1	1.8	E-Mail To: DWBMRO@idem.in.gov		
27	22					3.0			4	10	.2	1.5	.1	1.1			
28	38					5.8			9		.2	6.4	.1	2.9	Mail To: Indiana Department of Environmental Management Drinking Water Branch 100 N. Senate Ave. Room N1201 Indianapolis, IN 46204-2237		
29	32					4.8			8	6	.9	5.0	.1	4.3			
30	41					6.4			10	4	.9	5.0	.1	4.9			
31	72					7.8			17	6	1.5	7.5	.1	5.2			