



**MONTHLY REPORT OF OPERATION
WATER TREATMENT PLANT**

State Form 34609 (R11 / 1-17)

INDIANA DEPARTMENT OF
ENVIRONMENTAL MANAGEMENT

System Name Fillmore Water PWSID Number IN5267012

For the Month of May Year 2024 IDEM Field Rep. John Summerlin

Signed [Signature] Title Operator

I certify *under penalty of law*, by this signature that this document was prepared by me, or under my direction, and the information submitted is to the best of my knowledge and belief, true, accurate, and complete. I am also aware that there are significant penalties for submitting false information.

Certification Number DS220062

PHYSICAL AND CHEMICAL DATA *

Date	Turbidity		Alkalinity		pH		Hardness		Iron		Manganese		Phosphate	Fluoride
	Raw	Finished	Raw	Finished	Raw	Finished	Raw	Finished	Raw	Finished	Raw	Finished	Finished	Finished
1														
2														
3														
4														
5														
6														
7														
8														
9														
10														
11														
12														
13														
14														
15														
16														
17														
18														
19														
20														
21														
22														
23														
24														
25														
26														
27														
28														
29														
30														
31														

* All parameters are to be expressed in mg/l except pH and turbidity.

DUE BY THE 10TH OF THE MONTH FOLLOWING THE REPORTING PERIOD.

Date	Water Treated 1000 gallons	Chemicals Used – Pounds								Filters		Chlorine Residual				Remarks	
		Salt	Alum	Lime	Soda Ash	Carbon	Chlorine	Fluoride	Phosphate	Filter Run (hours)	Gallons per wash x 1000	Plant Tap		D. S.			
												Free	Total	Free	Total		
1	35											.89	.91	.79	.80		
2	32											.81	.85	.76	.74		
3	43											.90	.91	.79	.77		
4	31											.88	.87	.76	.77		
5	13											.89	.85	.77	.73		
6	54											.83	.91	.76	.79		
7	34											.80	.94	.79	.80		
8	33											.85	.90	.77	.79		
9	31											.87	.92	.77	.80		
10	30											.80	1.0	.79	.83		
11	32											.80	1.01	.75	.81		
12	34											.67	.80	.70	.77		
13	36											.77	.90	.74	.81		
14	42											.81	.94	.80	.83		
15	60											.81	.94	.82	.86		
16	140											1.07	1.12	.79	.80		
17	10											1.05	1.17	.77	.81		
18	37											1.09	1.29	.79	.80		
19	31											1.05	1.10	.81	.86		
20	38											1.00	1.07	.77	.81		
21	34											1.01	1.05	.79	.84	Monthly Water Treatment	
22	31											.76	1.01	.77	.82	Total Gallons	1,100,000
23	18											.79	.89	.74	.77	Max. Day	140,000
24	32											.72	1.09	.76	.81	Min. Day	10,000
25	29											1.03	1.07	.76	.79	Avg. Daily	36,000
26	27											1.01	1.09	.76	.77	E-Mail To: DWBMRO@idem.in.gov	
27	31											.99	1.12	.72	.80		
28	25											1.03	1.15	.74	.79	Mail To: Indiana Department of Environmental Management Drinking Water Branch 100 N. Senate Ave. Room N1201 Indianapolis, IN 46204-2237	
29	18											.65	.71	.56	.62		
30	34											.63	.68	.52	.59		
31	30											.37	.51	.49	.53		