

INDIANA DEPARTMENT OF ENVIRONMENTAL MANAGEMENT

We Protect Hoosiers and Our Environment.

100 N. Senate Avenue • Indianapolis, IN 46204

(800) 451-6027 • (317) 232-8603 • www.idem.IN.gov

Eric J. Holcomb

Brian C. Rockensuess

June 27, 2024

Tank Owner S & S Gas LLC 12833 Columa Bay Fort Wayne, IN 46845 salehsalih16@gmail.com

Property Owner S & S Gas LLC 12833 Columa Bay Fort Wayne, IN 46845 salehsalih16@gmail.com

Re: Notice of Deficiency for UST Notification

Oxford Express 1416 Oxford St Fort Wayne, IN 468063679 Facility ID #40041

To All Parties:

The Indiana Department of Environmental Management (IDEM) received a notification for the facility referenced above on 6/22/2023. The form can be found on the IDEM Virtual File Cabinet (VFC) at http://vfc.idem.in.gov under VFC #83634093, 83540142, 83512079.

IDEM staff reviewed the information contained in this form and additional information is required. The following items need to be addressed:

- 1. 1803 Other Other tank/compartment deficiency
- No leak detectors elected for pressurized piping.

Please resubmit the necessary pages of the notification form and/or backup resolving the deficiencies identified within fourteen (14) days of receipt of this letter.

Any questions concerning the UST Notification process may be directed to:

Rita Browne, Senior Environmental Manager IDEM - Office of Land Quality rbrowne@idem.in.gov

Failure to submit the required information detailed in this deficiency letter is a violation of Indiana Code (IC) 13-23-14-2 and the Indiana Administrative code (IAC) 329 IAC 9-2-2 and 40 CFR 280.34. Please note, IDEM has incorporated the majority of the federal underground storage tank regulations of 40 Code Fed. Reg. (CFR) Part 280 via 329 Ind. Admin. Code (IAC) 9-1-1. All CFR citations refer to the regulation as incorporated. Additionally, the submittal of false information on UST Notification Forms, as well as the failure to submit required UST Notification Forms, is subject to a \$10,000 penalty.

Sincerely,

Rita Browne

Senior Environmental Manager

Petroleum Branch

Office of Land Quality

Lita Browne

ecopy: IDEM File

Chris Dunifon, chrisdunifon@gmail.com



