

Jeremy Beckner, Superintendent
I.D.E.M. Field Rep. Sara Benkert

Certification WT3# 062535 Signed _____

6/3/2024

I certify under penalty of law by this signature that this document was prepared by me or under my direction and the information submitted is to the best of my knowledge and belief, true, accurate, and complete.

Date	Thousand Gallons Treated	Chemicals Used				Gallons Per Wash X 1000	All Test Results in mg/l except pH													
		Gallons Fluoride	Pounds Chlorine	Pounds Phosphate	Pounds Ammonia		Iron		Chlorine Plant		Chlorine D.S.		Manganese			pH				
							Raw	Finished	Mono	Total	Mono	Total	Raw	Finished	Filter	Flouride	Phosphate	Raw	Finished	
1	281	0	15	4.6	2.5	0	0.30	0.01	1.65	2.71	2.67	3.34	0.059	0.031	0.039	0.64	0.21	7.5	7.5	
2	243	0	14	4.2	1.8	0	0.03	0.02	2.79	2.56	1.90	2.15	0.046	0.028	0.044	0.78	0.29	7.7	7.5	
3	235	0	13	4.2	2.3	20	0.26	0.01	2.27	2.35	2.01	2.80	0.198	0.020	0.031	0.53	0.31	7.6	7.6	
4	237	0	14	4.2	2.0	0	0.07	0.02	2.43	2.56	1.22	1.98	0.081	0.040	0.020	0.69	0.43	7.6	7.5	
5	245	0	13	4.2	2.0	0	0.36	0.01	2.67	2.96	2.00	2.58	0.216	0.030	0.031	0.58	0.37	7.5	7.6	
6	360	0	20	6.3	3.5	0	0.06	0.02	2.36	2.46	2.60	2.10	0.101	0.050	0.047	0.54	0.30	7.8	7.5	
7	358	0	20	6.3	2.8	0	0.27	0.02	2.56	2.68	2.11	2.62	0.228	0.007	0.017	0.65	0.24	7.7	7.5	
8	271	0	16	5.0	2.5	20	0.04	0.01	2.39	2.52	2.33	2.43	0.115	0.019	0.091	0.94	0.31	7.7	7.5	
9	245	0	13	4.2	2.0	0	0.17	0.02	2.27	2.35	2.42	1.78	0.215	0.015	0.021	0.95	0.26	7.6	7.5	
10	243	0	14	4.2	2.3	0	0.13	0.01	2.42	2.82	2.36	2.98	0.090	0.030	0.031	0.73	0.27	7.7	7.5	
11	256	0	14	4.2	2.0	0	0.25	0.03	2.21	2.33	2.00	1.92	0.224	0.014	0.023	0.56	0.33	7.6	7.5	
12	243	0	13	5.0	2.5	0	0.44	0.07	2.15	2.42	2.02	1.81	0.088	0.021	0.023	0.97	0.12	7.6	7.5	
13	282	0	16	4.6	2.5	20	0.05	0.01	2.43	1.95	2.07	1.71	0.225	0.010	0.055	0.36	0.29	7.6	7.5	
14	258	0	14	4.2	2.5	0	0.11	0.03	3.08	3.06	2.32	3.20	0.086	0.031	0.031	0.58	0.19	7.4	7.5	
15	268	0	15	5.0	2.3	0	0.05	0.01	2.32	2.26	2.16	2.20	0.260	0.022	0.050	0.97	0.25	7.6	7.5	
16	250	0	14	4.6	2.3	0	0.04	0.02	2.32	2.41	2.46	2.86	0.086	0.029	0.025	0.74	0.20	7.7	7.5	
17	264	0	15	4.2	2.3	20	0.67	0.02	2.28	2.72	2.34	2.92	0.216	0.040	0.038	0.71	0.09	7.6	7.5	
18	265	0	16	4.6	2.3	0	0.28	0.07	2.46	2.59	1.91	2.18	0.100	0.032	0.040	0.49	0.27	7.7	7.5	
19	271	0	14	4.6	2.5	0	0.38	0.04	2.49	2.36	1.71	2.02	0.241	0.020	0.018	0.97	0.25	7.6	7.5	
20	313	0	18	5.0	2.5	0	0.07	0.02	2.46	2.80	2.14	2.16	0.085	0.025	0.027	0.73	0.20	7.7	7.5	
21	288	0	17	5.5	2.5	0	0.25	0.01	2.72	2.59	2.11	2.47	0.234	0.025	0.027	0.70	0.26	7.6	7.5	
22	315	0	17	5.0	2.5	20	0.05	0.01	2.86	2.91	1.78	1.72	0.091	0.025	0.012	0.42	0.20	7.7	7.5	
23	268	0	15	5.0	2.3	0	0.19	0.02	2.71	2.96	1.24	1.93	0.122	0.008	0.010	0.58	0.13	7.7	7.5	
24	266	0	15	4.6	2.3	0	0.09	0.03	1.73	1.69	2.63	2.20	0.089	0.003	0.009	0.46	0.29	7.7	7.5	
25	264	0	15	4.6	2.3	0	0.48	0.03	2.27	2.31	2.48	2.20	0.197	0.040	0.033	0.72	0.08	7.8	7.6	
26	230	0	13	3.8	1.8	0	0.14	0.03	2.42	2.54	2.59	2.20	0.098	0.033	0.050	0.66	0.29	7.7	7.5	
27	235	0	12	4.2	2.3	20	0.15	0.02	2.77	2.82	2.25	2.86	0.210	0.026	0.038	0.51	0.17	7.6	7.5	
28	268	0	16	5.0	2.3	0	0.24	0.02	2.53	2.94	2.13	1.93	0.095	0.026	0.023	0.65	0.22	7.7	7.5	
29	265	0	15	4.2	2.0	0	0.33	0.02	2.51	2.57	2.55	2.37	0.235	0.035	0.036	0.69	0.28	7.5	7.5	
30	320	0	18	5.9	3.0	20	0.07	0.01	2.40	2.96	2.34	1.97	0.083	0.019	0.015	0.86	0.17	7.7	7.5	
31	304			6.3	2.8	0	0.06	0.02	2.58	2.53	1.78	1.63	0.208	0.050	0.057	0.70	0.16	7.7	7.5	
Totals	8,107	0.0	454.0	141.5	70.0	140.0						Mail To: IDEM Drinking Water Branch 66-34 100 N. Senate Ave. Room N 1255 Indianapolis, IN 46204-2222								
Max.	360	0.0	20.0	6.3	3.5															
Min.	230	0.0	12.0	3.8	1.8															
Avg.	270	0.0	15.1	4.7	2.3															