



INDIANA DEPARTMENT OF ENVIRONMENTAL MANAGEMENT

We Protect Hoosiers and Our Environment.

100 N. Senate Avenue • Indianapolis, IN 46204
(800) 451-6027 • (317) 232-8603 • www.idem.IN.gov

Eric J. Holcomb
Governor

Brian C. Rockensuess
Commissioner

May 20, 2024

Via Email to: Becker.wahbeh@bwigroup.com

Becker Wahbeh, Plant Manager
BWI Indiana, Inc.
989 Opportunity Parkway
Greenfield, Indiana 46

Dear Mr. Wahbeh:

Re: Noncompliance Letter
Permit No. INP000686
BWI – Hancock Co.

Staff of the Indiana Department of Environmental Management (IDEM), Office of Water Quality, has reviewed the compliance status of the above cited facility for the period of January 2022 through March 24, 2024. This review revealed violations of the facility's permit, as follows:

Part I. A. of the permit sets forth the final effluent limitations and monitoring applicable to the discharge from outfall 001A.

Specifically, the submitted Discharge Monitoring Report(s) (DMRs) indicate your facility exceeded its limits for the following:

- Oil and Grease - March and November 2022; December 2023; and March 2024.
- Zinc - June 2022.

Within 30 days of receipt of this letter, a compliance plan describing any corrective measures which will be taken to assure compliance in the future, must be submitted to this office. Failure to respond to this letter may result in a referral to the Office of Water Quality's Enforcement Section.

Your response to this letter must also include the date by which you expect to return to compliance with your permit limits.

Part II. (A)(1) of your permit requires you to comply with all terms and conditions thereof. You are hereby required, pursuant to IC 13-1412-1 and IC 13-14-2-7 to immediately take all necessary measures to comply with the terms and conditions of your NPDES/IWP permit, specifically those items identified above as violations.

Thank you for your attention to this matter. If you have any questions, please contact Greg Glover at (317) 232-8630, or (800) 451-6027, ext.2-8630. You may also write to him at the above address; or his e-mail address, gglover@idem.IN.gov. Please direct your formal response to him at the previously mentioned addresses, or via e-mail to wwViolationResponse@idem.in.gov.

Sincerely



Gary Starks, Chief
Compliance Data Section
Office of Water Quality

Cc: Andy Schmidt, Inspector