



Town of Edinburgh

Wastewater

701 W. River Road
PO Box 65
Edinburgh, IN 46124
Phone: 812-526-3530

June/26/2024

Danzer

206 Holland street,Edinburgh,In 46124

Attention: Mr. Randy Dorton

This is a notice of **Significant Noncompliance**

At the time of our inspection on May 14,2024 IDEM inspector noted that the effluent appeared to have a noticeable brownish tint, he was told this tint has always been the color of our discharge except when the veneer mills was on shut down.

Part 1.A.2 of our permit prohibits the Discharge from any sources specified within this permit from causing receiving waters, including the mixing zone,to contain substances, materials ,floating debris oil, or scum ;[1] that will settle to form putrescent or otherwise objectionable deposits ;[2]that are in amounts sufficient to be unsightly or deleterious ;[3] **that produce color** ,visible oil sheen,oder,or other condition in such degree as to create a nuisance.

We are getting a passthrough of tannins effecting the color of our discharge.

Within 30 days of receipt of this letter I would like a written detailed response documenting a plan of action to correct this issue

Robert Jessie

Edinburgh WWTP Superintendent

o.812-526-3530 c.812-341-1702 rjessie@edinburgh.in.us

Ryan Piercefield

Town Board President

Office of Water Quality – Mail code 65-42
Compliance Data Section
100 North Senate Avenue, Room N1255
Indianapolis, IN 46204-2251

cc: Pam Grams, IDEM
Gary Starks, IDEM
Jeff Simpson, President, Town Council, Town of Edinburgh
Dan Cartwright, Town Manager, Town of Edinburgh