



INDIANA DEPARTMENT OF ENVIRONMENTAL MANAGEMENT

We Protect Hoosiers and Our Environment.

100 N. Senate Avenue • Indianapolis, IN 46204

(800) 451-6027 • (317) 232-8603 • www.idem.IN.gov

Eric J. Holcomb
Governor

Brian C. Rockensuess
Commissioner

June 28, 2024

Tank Owner
City of Columbus
123 Washington St
Columbus, IN 47201
bryanburton@columbus.in.gov

Property Owner
City of Columbus
123 Washington St
Columbus, IN 47201
bryanburton@columbus.in.gov

Tank Operator
City of Columbus
123 Washington St
Columbus, IN 47201
bryanburton@columbus.in.gov

Re: **Notice of Deficiency for UST Notification**

City Garage
2250 Kreutzer Dr
Columbus, IN 47201
Facility ID #16844

To All Parties:

The Indiana Department of Environmental Management (IDEM) received a notification for the facility referenced above on 8/4/2023. The form can be found on the IDEM Virtual File Cabinet (VFC) at <http://vfc.idem.in.gov> under VFC #83605575, 83526202.

IDEM staff reviewed the information contained in this form and additional information is required. The following items need to be addressed:

1. 1503 - Underground Piping Release Detection - The owner and/or operator did not provide an appropriate release detection method for piping installed before 9/2/2009.

2. 1803 - Other - Other tank/compartiment deficiency
- Historic records support 12K USTs had Enviroflex piping between 1/22/2001 to 5/28/2009. Accurate install date for OPW piping is needed.

Please resubmit the necessary pages of the notification form and/or backup resolving the deficiencies identified within fourteen (14) days of receipt of this letter.

Any questions concerning the UST Notification process may be directed to:

Jeff Turley, Senior Environmental Manager
IDEM - Office of Land Quality
jturley@idem.in.gov

Failure to submit the required information detailed in this deficiency letter is a violation of Indiana Code (IC) 13-23-14-2 and the Indiana Administrative code (IAC) 329 IAC 9-2-2 and 40 CFR 280.34. Please note, IDEM has incorporated the majority of the federal underground storage tank regulations of 40 Code Fed. Reg. (CFR) Part 280 via 329 Ind. Admin. Code (IAC) 9-1-1. All CFR citations refer to the regulation as incorporated. Additionally, the submittal of false information on UST Notification Forms, as well as the failure to submit required UST Notification Forms, is subject to a \$10,000 penalty.

Sincerely,



Jeff Turley
Senior Environmental Manager
Petroleum Branch
Office of Land Quality

ecopy: IDEM File

Bryan Burton, bryanburton@columbus.in.gov

