

Kocher, Jean

To: Kocher, Jean
Subject: FW: WS 12601 - INDIANA AMERICAN WATER SHELBYVILLE - AMENDMENT - PWSID# 5273002
Attachments: 12601 Indiana American Water Shelbyville AMENDMENT.pdf

From: Andy Ewald <aewald@midwesterneng.com>
Sent: Monday, February 26, 2024 2:25 PM
To: Kocher, Jean <JKocher@idem.IN.gov>; Steve Bender <sbender@midwesterneng.com>; Jonny Norris <Jonny.Norris@amwater.com>; Jared.Burnett@amwater.com; Nikolaou, Artemis <ANikolao@idem.IN.gov>; Chappell, Carolyn C <CCHAPPEL@idem.IN.gov>; TERNIEDEN, LUCIO <LTERNIED@idem.IN.gov>; MELVIN, LIZ <LMELVIN@idem.IN.gov>; JONES, STACY <SJONES@idem.IN.gov>; Sullivan, Judy <JASulliv@idem.IN.gov>; Prater, Matthew <MPrater@idem.IN.gov>
Subject: FW: WS 12601 - INDIANA AMERICAN WATER SHELBYVILLE - AMENDMENT - PWSID# 5273002

**** This is an EXTERNAL email. Exercise caution. DO NOT open attachments or click links from unknown senders or unexpected email. ****

Jean,

The attached Permit Amendment was received. Answers to your questions below are answered in RED. To clarify, construction began on July 27, 2023 as noted in the original permit. This amendment simply clarifies the addition of Hypo-Clean additive to the bulk sodium hypochlorite by the supplier during the delivery process, and does not change the construction schedule.

Thanks,

Andy Ewald
Senior Project Designer
Office: 812.295.2800 / 317.334.0262
Direct: 317.966.6637
www.midwesterneng.com

Midwestern Engineers, Inc.


From: Steve Bender <sbender@midwesterneng.com>
Sent: Monday, February 26, 2024 1:41 PM
To: Andy Ewald <aewald@midwesterneng.com>
Subject: FW: WS 12601 INDIANA AMERICAN WATER SHELBYVILLE AMENDMENT PWSID# 5273002

From: Kocher, Jean <JKocher@idem.IN.gov>
Sent: Monday, February 26, 2024 12:30 PM
To: Steve Bender <sbender@midwesterneng.com>; jonny.norris@amwater.com; Jared M Burnett <Jared.Burnett@amwater.com>
Cc: Nikolaou, Artemis <ANikolao@idem.IN.gov>; Chappell, Carolyn C <CCHAPPEL@idem.IN.gov>; TERNIEDEN, LUCIO <LTERNIED@idem.IN.gov>; MELVIN, LIZ <LMELVIN@idem.IN.gov>; JONES, STACY <SJONES@idem.IN.gov>; Sullivan, Judy

<JASulliv@idem.IN.gov>; Prater, Matthew <MPrater@idem.IN.gov>

Subject: WS 12601 INDIANA AMERICAN WATER SHELBYVILLE AMENDMENT PWSID# 5273002

You don't often get email from jkocher@idem.in.gov. [Learn why this is important](#)

Please see the attached amendment approval for construction permit WS 12601 INDIANA AMERICAN WATER SHELBYVILLE.

Please reply to this email notifying us that you did indeed receive it. We are also sending this email as a reminder that you must notify us at least 10 days in advance of construction beginning, pursuant to Condition #1 of the permit. We are accepting notifications for construction via email at dwpermits@idem.in.gov. The information you are required to provide for compliance with Condition #1 is below. You may satisfy both requests by "replying to all" to this email, stating you did receive the permit and providing the start of construction information below:

1. Permit # WS-12601
2. PWSID# 5273002
3. Location of construction; Blue River Water Treatment Plant, 250 S. 550 West, Shelbyville, IN 46176
4. Description of construction; Convert disinfection chemical from gaseous Chlorine to liquid Sodium Hypochlorite
5. Construction start date; July 27, 2023
6. Anticipated duration of construction; and, Substantial completion was achieved on February 13, 2024
7. Name and Phone # of permittee or permittee's representative who will be present during construction. Jonny Norris, 317-885-2408

Please note that failure to follow this condition or any other condition of the permit shall be grounds for revocation of the permit. If you have any questions on the conditions included in the permit, please contact the permit review engineer listed at the end of the permit