



**UNDERGROUND STORAGE
TANK INSPECTION REPORT**

INDIANA DEPARTMENT OF
ENVIRONMENTAL MANAGEMENT

UST FAC ID: **40079**

Inspector's Name:	Tristan Voge
Date:	June 17, 2024
Time In:	11:40
Time Out:	12:15
Inspection Type:	Initial

FACILITY NAME / LOCATION

FACILITY NAME Friendly Market		FACILITY ADDRESS (number and street) 3607 Cheryl Lane		
ADDRESS (line 2)	CITY Lafayette	STATE IN	ZIP CODE 47905	COUNTY Tippecanoe

UST OWNER

UST Owner Name (If in Individual Capacity) Mann Brothers Holdings LLC				BUSINESS ID (From the Secretary of State) 2014040300723
PREFIX Mr.	FIRST NAME Karamjeet	MI S	LAST NAME Mann	SUFFIX
TELEPHONE NUMBER (765) 398-1260	EMAIL ADDRESS zidjattdi@yahoo.com			

UST OPERATOR


UST Operator Name (If in Individual Capacity) Veterans Petroleum Inc				BUSINESS ID (From the Secretary of State) 201908091339420
PREFIX Mr.	FIRST NAME Gurdev	MI	LAST NAME Singh	SUFFIX
TELEPHONE NUMBER (765) 398-1260	EMAIL ADDRESS			

PROPERTY OWNER

UST Property Owner Name (If in Individual Capacity) Mann Brothers Holdings LLC				BUSINESS ID (From the Secretary of State) 2014040300723
PREFIX Mr.	FIRST NAME Karamjeet	MI S	LAST NAME Mann	SUFFIX
TELEPHONE NUMBER (765) 398-1260	EMAIL ADDRESS zidjattdi@yahoo.com			

COMPLIANCE ELEMENTS

All USTs properly registered and up-to-date notification form on file	<input type="checkbox"/> YES	<input checked="" type="checkbox"/> NO	<input type="checkbox"/> UNK
An updated notification form is needed with the correct UST material and design indicated.			
O/O is in compliance with reporting & record keeping requirements	<input type="checkbox"/> YES	<input checked="" type="checkbox"/> NO	<input type="checkbox"/> UNK
The owner and/or operator did not respond to IDEM's records request dated 05/06/2024.			
O/O is in compliance with release reporting or investigation	<input type="checkbox"/> YES	<input type="checkbox"/> NO	<input checked="" type="checkbox"/> N/A
O/O is in compliance with all UST closure requirements	<input type="checkbox"/> YES	<input type="checkbox"/> NO	<input checked="" type="checkbox"/> N/A
O/O has met all financial responsibility requirements	<input checked="" type="checkbox"/> YES	<input type="checkbox"/> NO	<input type="checkbox"/> N/A
40 CFR 280, Subpart A installation requirements (partially excluded) met	<input type="checkbox"/> YES	<input type="checkbox"/> NO	<input checked="" type="checkbox"/> N/A
40 CFR 280, Subpart B installation and upgrade requirements met	<input type="checkbox"/> YES	<input checked="" type="checkbox"/> NO	<input type="checkbox"/> UNK
The DSL and PREM spill buckets were over half filled with fluid and would not function in a spill.			
40 CFR 280, Subpart C spill/overflow control requirements met	<input checked="" type="checkbox"/> YES	<input type="checkbox"/> NO	<input type="checkbox"/> N/A
40 CFR 280, Subpart C compatibility requirements met	<input checked="" type="checkbox"/> YES	<input type="checkbox"/> NO	<input type="checkbox"/> N/A
40 CFR 280, Subpart C O&M and testing requirements met	<input type="checkbox"/> YES	<input checked="" type="checkbox"/> NO	<input type="checkbox"/> UNK
Periodic spill and overflow equipment test reports and annual walkthroughs was not provided.			
40 CFR 280, Subpart D release detection requirements met	<input type="checkbox"/> YES	<input checked="" type="checkbox"/> NO	<input type="checkbox"/> UNK
Twelve (12) months of UST INT RD, ATG/probes/sensors/LLD test reports were not provided.			
40 CFR 280, Subpart J operator training requirements met	<input type="checkbox"/> YES	<input checked="" type="checkbox"/> NO	<input type="checkbox"/> UNK
A, B and C operator certificates were not provided.			



N Rickover Cir

S Rickover Cir

Dillon Dr

Remington Dr

Runyon Dr

Bridgewater Cir

Ciburum Rd

IFCU Way

IFCU Way

Cheryln Ln

Oil Changers
(QuickLube)

McDonald's
Fast Food • \$

Amis Lafayette
350 South

Builder Dr

7 Brew
Cat 7 Brew
Full Menu

Veterans Memorial Pkwy S

Coinstar

Raymond Dr

Kyra Blvd

Kyra Dr

Foxfire at Valley
Lakes Apartments

Sweet Valley Ln

Nicholas Dr

Deerfoot Trails
Family Dental
Temporarily closed

Monster Mini
Golf Lafayette

O'Reilly Auto Parts
Auto parts store

Verizon
Cellphone store


KFC

Promenade Pkwy

Crumbl - Lafayette
Takeout • Delivery

Promenade Self Storage

Regal Valley



Builder Dr

Builder Dr

Builder Dr

B

Cheryl Ln

Cheryl Ln

Cheryl Ln

Cheryl Ln

bp



350

Veterans Memorial Pkwy S

The Was
(Quick

2847





Now Serving
Fresh
Nuts












































2 stop engine no smoking

BP diesel

S 2227
Gallons 6.364

PLEASE PREPAY

ACCEPT DEBIT

87 89 93

300 miles farther

Invoice







4 stop engine no smoking



ultimate
You can get up to 300 miles farther
with our ultimate blend. (with 50% bioethanol)
Compare to regular fuel.

\$ 26.00
Gallons 74.30

WARNING
PLEASE PREPARE
ACCEPT DEBIT



regular 87
silver 89
ultimate 93









6 stop engine no smoking



Gallons 10.00 9.58

WARNING
No smoking, no open flames, no sparks, no fire, no smoking, no open flames, no sparks, no fire.




regular 87
silver 89
Ultimate 93









FM BP
3607 CHERYL LANE
LAFAYETTE IN
47909

JUN 17, 2024 11:44

SYSTEM STATUS REPORT

L 8:FUEL ALARM

INVENTORY REPORT

T 1:UNLEADED
VOLUME = 2729 GALS
ULLAGE = 8971 GALS
90% ULLAGE = 7711 GALS
TC VOLUME = 2714 GALS
HEIGHT = 26.26 INCHES
WATER VOL = 0 GALS
WATER = 0.00 INCHES
TEMP = 67.9 DEG F

T 2:PREMIUM
VOLUME = 1184 GALS
ULLAGE = 2816 GALS
90% ULLAGE = 2416 GALS
TC VOLUME = 1175 GALS
HEIGHT = 30.71 INCHES
WATER VOL = 0 GALS
WATER = 0.00 INCHES
TEMP = 69.3 DEG F

T 3:DIESEL
VOLUME = 2780 GALS
ULLAGE = 920 GALS
90% ULLAGE = 550 GALS
TC VOLUME = 2767 GALS
HEIGHT = 62.72 INCHES
WATER VOL = 0 GALS
WATER = 0.00 INCHES
TEMP = 69.8 DEG F

***** END *****

FM BP
3607 CHERYL LANE
LAFAYETTE IN
47909

JUN 17, 2024 11:44

LIQUID STATUS

JUN 17, 2024 11:44

L 1:UNLD SUMP
SENSOR NORMAL

***** END *****

FM BP
3607 CHERYL LANE
LAFAYETTE IN
47909

JUN 17, 2024 11:44

LIQUID STATUS

JUN 17, 2024 11:44

L 2:PREM SUMP
SENSOR NORMAL

***** END *****

FM BP
3607 CHERYL LANE
LAFAYETTE IN
47909

JUN 17, 2024 11:44

LIQUID STATUS

JUN 17, 2024 11:44

L 3:DIESEL SUMP
SENSOR NORMAL

***** END *****

FM BP
3607 CHERYL LANE
LAFAYETTE IN
47909

JUN 17, 2024 11:44

LIQUID STATUS

JUN 17, 2024 11:44

L 6:DBL INT
SENSOR NORMAL

***** END *****

FM BP
3607 CHERYL LANE
LAFAYETTE IN
47909

JUN 17, 2024 11:44

LIQUID STATUS

JUN 17, 2024 11:44

L 8:REG INT
FUEL ALARM

***** END *****

FM BP
3607 CHERYL LANE
LAFAYETTE IN
47909

JUN 17, 2024 11:44

TANK LEAK TEST HISTORY

T 1:UNLEADED

LAST GROSS TEST PASSED:

NO TEST PASSED

LAST ANNUAL TEST PASSED:

NO TEST PASSED

FULLEST ANNUAL TEST PASS

NO TEST PASSED

LAST PERIODIC TEST PASS:

NO TEST PASSED

FULLEST PERIODIC TEST

PASSED EACH MONTH:

***** END *****

FM BP
3607 CHERYL LANE
LAFAYETTE IN
47909

JUN 17, 2024 11:44

TANK LEAK TEST HISTORY

T 2:PREMIUM

LAST GROSS TEST PASSED:

NO TEST PASSED

LAST ANNUAL TEST PASSED:

NO TEST PASSED

FULLEST ANNUAL TEST PASS

NO TEST PASSED

LAST PERIODIC TEST PASS:

NO TEST PASSED

FULLEST PERIODIC TEST

PASSED EACH MONTH:

***** END *****

ALARM HISTORY REPORT

----- SENSOR ALARM

L 8:REG INT
ANNULAR SPACE
FUEL ALARM
SEP 29, 2023 12:17

FUEL ALARM
SEP 29, 2023 12:09

FUEL ALARM
SEP 29, 2023 11:56

***** END *****

FM BP
3607 CHERYL LANE
LAFAYETTE IN
47909

JUN 17, 2024 11:44

TANK LEAK TEST HISTORY

T 3:DIESEL

LAST GROSS TEST PASSED:

NO TEST PASSED

LAST ANNUAL TEST PASSED:

NO TEST PASSED

FULLEST ANNUAL TEST PASS

NO TEST PASSED

LAST PERIODIC TEST PASS:

NO TEST PASSED

FULLEST PERIODIC TEST

PASSED EACH MONTH:

***** END *****

FM BP
3607 CHERYL LANE
LAFAYETTE IN
47909

JUN 17, 2024 11:45

TANK LEAK TEST HISTORY

T 4:KEROSENE

LAST GROSS TEST PASSED:

NO TEST PASSED

LAST ANNUAL TEST PASSED:

NO TEST PASSED

FULLEST ANNUAL TEST PASS

NO TEST PASSED

LAST PERIODIC TEST PASS:

NO TEST PASSED

FULLEST PERIODIC TEST

PASSED EACH MONTH:

***** END *****

FM BP
3607 CHERYL LANE
LAFAYETTE IN
47909

MAY 21. 2024 15:34

LIQUID STATUS

MAY 21. 2024 15:34

L 1: UNLD SUMP
SENSOR NORMAL

L 2: PREM SUMP
SENSOR NORMAL

L 3: DIESEL SUMP
SENSOR NORMAL

L 6: DSL INT
FUEL ALARM

L 8: REG INT
FUEL ALARM

* * * * * END * * * * *

FM BP
3607 CHERYL LANE
LAFAYETTE IN

Tanks Data
Facility I.D. (FID) # 40079
City Name BP
Address 3607 Cheryl Ln
Operator on Duty Name

Operator Training cu

Is Registration current with correct

Release Detection Me

Make and Model

Does it have paper

Is it in Alarm mod

Interstitial Monitoring Sensor

Necessary Monthly Print

Spill Buckets Clean and free from w
the Spill Bucket in good condition as

Is Fill pipe cap tight and fill pipe free

Are Sumps Clean and free from water

Are UDCs clean and free from water

NOTE: ALL LIQUID/DEBRIS O

DAYS WALK THROU

er
tion 05/21/24
erson
pection AKSHIT

No OperatorNot

Form
 No OperatorNot

CIM 350 SIR

No OperatorNot

No OperatorNot

No OperatorNot

No OperatorNot

No OperatorNot

No OperatorNot

No OperatorNot

No OperatorNot

nts (UDC)

No OperatorNot

CORDING TO EXISTING RU
ERTIFIED CONTRACTOR.

LIQUID STATUS

APR 22, 2024 16:59

L 1:UNLD SUMP
SENSOR NORMAL

L 2:PREM SUMP
SENSOR NORMAL

L 3:DIESEL SUMP
SENSOR NORMAL

L 6:DSL INT
FUEL ALARM

L 8:REG INT
FUEL ALARM

* * * * * END * * * * *

* * * * * END * * * * *

FM BP
3607 CHERYL LANE
LAFAYETTE IN
47909

MAR 30. 2024 17:48

LIQUID STATUS

MAR 30. 2024 17:48

L 1:UNLD SUMP
SENSOR NORMAL

L 2:PREM SUMP
SENSOR NORMAL

L 3:DIESEL SUMP
SENSOR NORMAL

L 6:DSL I/T
SENSOR NORMAL

L 8:REG INT
FUEL ALARM

--- END * * * * *

Vehicle Data

Vehicle ID. (FID) # 400

Vehicle Name Cheryl

Address 3607

Operator on Duty Name _____

Operator Tr _____

Is Registration current _____

Release _____

M _____

D _____

FM BP

WALK THROUGH INSPECTION

Operator Name _____

Operator _____

Form _____

on _____

ALIM _____

TLS _____

No _____

No _____

No _____

No _____

No _____

Yes _____

Yes _____

Yes _____

Spill Buckets _____

Yes _____

Yes _____

47909

FEB 29. 2024 14:28

LIQUID STATUS

FEB 29. 2024 14:28

L 1:UNLD SUMP
SENSOR NORMAL

L 2:PREM SUMP
SENSOR NORMAL

L 3:DIESEL SUMP
SENSOR NORMAL

L 6:DSL INT
SENSOR NORMAL

L 8:REG INT
FUEL ALARM

* * * * * END * * * * *

30 DAYS WALK THROUGH

Contact Number
Contact email

Date of Inspection
Name of the Person
Conducting Inspection

Operator Training
 Yes
 No

7909

Notified	<input type="radio"/> Yes	<input type="radio"/> No
Notified	<input checked="" type="radio"/> Yes	<input type="radio"/> No
Notified	<input checked="" type="radio"/> Yes	<input type="radio"/> No
Notified	<input type="radio"/> Yes	<input type="radio"/> No
Notified	<input type="radio"/> Yes	<input type="radio"/> No
Notified	<input checked="" type="radio"/> Yes	<input type="radio"/> No
Notified	<input type="radio"/> Yes	<input type="radio"/> No

THROUGH INSPECTION

1/31/24

Josh Rider

Operator Notified Yes

Operator Notified Yes

SIR IC

350 Operator Notified Yes

Operator Notified Yes

Operator Notified Yes

Operator Notified Yes

FM BP
3607 CHERYL LANE
LAFAYETTE IN
47909

JAN 31, 2024 13:50

LIQUID STATUS

JAN 31, 2024 13:50

L 1:UNLD SUMP
SENSOR NORMAL

L 2:PREM SUMP
SENSOR NORMAL

L 3:DIESEL SUMP
SENSOR NORMAL

L 6:DSL INT
SENSOR NORMAL

L 8:REG INT
FUEL ALARM

* * * * * END * * * * *

30 DAYS WALK THROUGH

47909

Contact Number
Contact email

Date of Inspection
Name of the Person
Conducting Inspection

Operator Training Yes No
Notification Yes No

DEC 28, 2023 13:00
LIQUID STATUS
- - - - -
DEC 28, 2023 13:00

L 1:UNLD SUMP
SENSOR NORMAL

L 2:PREM SUMP
SENSOR NORMAL

L 3:DIESEL SUMP
SENSOR NORMAL

L 6:DSL INT
FUEL ALARM

L 8:REG INT
FUEL ALARM

* * * * * END * * * * *

Operator Notified	<input checked="" type="radio"/> Yes	<input type="radio"/> No
Operator Notified	<input checked="" type="radio"/> Yes	<input type="radio"/> No
Operator Notified	<input type="radio"/> Yes	<input type="radio"/> No
Operator Notified	<input type="radio"/> Yes	<input type="radio"/> No
Operator Notified	<input checked="" type="radio"/> Yes	<input type="radio"/> No
Operator Notified	<input type="radio"/> Yes	<input type="radio"/> No
Operator Notified	<input type="radio"/> Yes	<input type="radio"/> No
Operator Notified	<input type="radio"/> Yes	<input type="radio"/> No

FM BP
3607 CHERYL LANE
LAFAYETTE IN
47909

JAN 17. 2023 13:38

CSLD TEST RESULTS

JAN 17. 2023 13:38

T 1:UNLEADED
PROBE SERIAL NUM 104689

0.2 GAL/HR TEST
PER: JAN 17. 2023 PASS

T 2:PREMIUM
PROBE SERIAL NUM 386611

0.2 GAL/HR TEST
PER: JAN 17. 2023 PASS

T 3:DIESEL
PROBE SERIAL NUM 070428

0.2 GAL/HR TEST
PER: JAN 17. 2023 PASS

***** END *****

FM BP
3607 CHERYL LANE
LAFAYETTE IN
47909

JAN 17. 2023 13:39

LIQUID STATUS

JAN 17. 2023 13:39

L 1:UNLD SUMP
SENSOR NORMAL

L 2:PREM SUMP
SENSOR NORMAL

L 3:DIESEL SUMP
SENSOR NORMAL

L 6:PREM INT
SENSOR NORMAL

L 8:RUL INT
SENSOR NORMAL

***** END *****

FM BP
3607 CHERYL LANE
LAFAYETTE IN

FM BP
3607 CHERYL LANE
LAFAYETTE IN
47909

FEB 16. 2023 13:10

CSLD TEST RESULTS

FEB 16. 2023 13:10

T 1:UNLEADED
PROBE SERIAL NUM 104689

0.2 GAL/HR TEST
PER: FEB 16. 2023 PASS

T 2:PREMIUM
PROBE SERIAL NUM 386611

0.2 GAL/HR TEST
PER: FEB 16. 2023 PASS

T 3:DIESEL
PROBE SERIAL NUM 070428

0.2 GAL/HR TEST
PER: FEB 16. 2023 PASS

* * * * * END * * * * *

FM BP
3607 CHERYL LANE
LAFAYETTE IN
47909

FEB 16. 2023 13:10

LIQUID STATUS

FEB 16. 2023 13:10

L 1:UNLD SUMP
SENSOR NORMAL

L 2:PREM SUMP
SENSOR NORMAL

L 3:DIESEL SUMP
SENSOR NORMAL

L 6:PREM INT
SENSOR NORMAL

L 8:RUL INT
SENSOR NORMAL

* * * * * END * * * * *

FM BP
3607 CHERYL LANE
LAFAYETTE IN
47909

FEB 16. 2023 13:10

LEAK TEST REPORT

T 1:UNLEADED
PROBE SERIAL NUM 104689

TEST STARTING TIME:
MAR 4. 2021 19:54

TEST LENGTH = 2.0 HRS
STRT VOLUME = 5156.9 GAL

LEAK TEST RESULTS
0.20 GAL/HR TEST FAIL

* * * * * END * * * * *

FM BP
3607 CHERYL LANE
LAFAYETTE IN
47909

MAR 16. 2023 12:56

CSLD TEST RESULTS

MAR 16. 2023 12:56

T 1:UNLEADED
PROBE SERIAL NUM 104689

0.2 GAL/HR TEST
PER: MAR 16. 2023 PASS

T 2:PREMIUM
PROBE SERIAL NUM 386611

0.2 GAL/HR TEST
PER: MAR 16. 2023 PASS

T 3:DIESEL
PROBE SERIAL NUM 070428

0.2 GAL/HR TEST
PER: MAR 16. 2023 PASS

***** END *****

FM BP
3607 CHERYL LANE
LAFAYETTE IN
47909

MAR 16. 2023 12:57

LIGUID STATUS

MAR 16. 2023 12:57

L 1:UNLD SUMP
SENSOR NORMAL

L 2:PREM SUMP
SENSOR NORMAL

L 3:DIESEL SUMP
SENSOR NORMAL

L 6:PREM INT
SENSOR NORMAL

L 8:RUL INT
SENSOR NORMAL

***** END *****

FM BP
3607 CHERYL LANE
LAFAYETTE IN

FM BP
3607 CHERYL LANE
LAFAYETTE IN
47909

APR 18. 2023 12:54

CSLD TEST RESULTS

APR 18. 2023 12:54

T 1:UNLEADED
PROBE SERIAL NUM 104689

0.2 GAL/HR TEST
PER: APR 18. 2023 PASS

T 2:PREMIUM
PROBE SERIAL NUM 386611

0.2 GAL/HR TEST
PER: APR 18. 2023 PASS

T 3:DIESEL
PROBE SERIAL NUM 070428

0.2 GAL/HR TEST
PER: APR 18. 2023 PASS

* * * * * END * * * * *

FM BP
3607 CHERYL LANE
LAFAYETTE IN
47909

APR 18. 2023 12:54

LIQUID STATUS

APR 18. 2023 12:54

L 1:UNLD SUMP
SENSOR NORMAL

L 2:PREM SUMP
SENSOR NORMAL

L 3:DIESEL SUMP
SENSOR NORMAL

L 6:PREM INT
SENSOR NORMAL

L 8:RUL INT
SENSOR NORMAL

* * * * * END * * * * *

FM BP
3607 CHERYL LANE
LAFAYETTE IN

FM BP
3607 CHERYL LANE
LAFAYETTE IN
47909

MAY 22. 2023 13:25

CSLD TEST RESULTS

MAY 22. 2023 13:25

T 1:UNLEADED
PROBE SERIAL NUM 104689

0.2 GAL/HR TEST
PER: MAY 22. 2023 PASS

T 2:PREMIUM
PROBE SERIAL NUM 386611

0.2 GAL/HR TEST
PER: MAY 22. 2023 PASS

T 3:DIESEL
PROBE SERIAL NUM 070428

0.2 GAL/HR TEST
PER: MAY 22. 2023 PASS

***** END *****

FM BP
3607 CHERYL LANE
LAFAYETTE IN
47909

MAY 22. 2023 13:25

LIQUID STATUS

MAY 22. 2023 13:25

L 1:UNLD SUMP
SENSOR NORMAL

L 2:PREM SUMP
SENSOR NORMAL

L 3:DIESEL SUMP
SENSOR NORMAL

L 6:PREM INT
SENSOR NORMAL

L 8:RUL INT
SENSOR NORMAL

***** END *****

FM BP
3607 CHERYL LANE
LAFAYETTE IN
47909

MAY 22. 2023 13:25

LEAK TEST REPORT

T 1:UNLEADED
PROBE SERIAL NUM 104689

TEST STARTING TIME:
MAR 4. 2021 19:54

TEST LENGTH = 2.0 HRS
STRT VOLUME = 5156.9 GAL

LEAK TEST RESULTS
0.20 GAL/HR TEST FAIL

***** END *****

FM BP
3607 CHERYL LANE
LAFAYETTE IN
47909

JUN 23, 2023 12:13

CSLD TEST RESULTS

JUN 23, 2023 12:13

T 1:UNLEADED
PROBE SERIAL NUM 104689

0.2 GAL/HR TEST
PER: JUN 23, 2023 PASS

T 2:PREMIUM
PROBE SERIAL NUM 386611

0.2 GAL/HR TEST
PER: JUN 23, 2023 PASS

T 3:DIESEL
PROBE SERIAL NUM 070428

0.2 GAL/HR TEST
PER: JUN 23, 2023 PASS

***** END *****

FM BP
3607 CHERYL LANE
LAFAYETTE IN
47909

JUN 23, 2023 12:13

LIQUID STATUS

JUN 23, 2023 12:13

L 1:UNLD SUMP
SENSOR NORMAL

L 2:PREM SUMP
SENSOR NORMAL

L 3:DIESEL SUMP
SENSOR NORMAL

L 6:PREM INT
SENSOR NORMAL

L 8:RUL INT
SENSOR NORMAL

***** END *****

FM BP
3607 CHERYL LANE
LAFAYETTE IN

FM BP
3607 CHERYL LANE
LAFAYETTE IN
47909

JUN 30, 2011 13:25

LIQUID STATUS

JUN 30, 2011 13:25

L 1:UNLD SUMP
SENSOR NORMAL

L 2:PREM SUMP
SENSOR NORMAL

L 3:DIESEL SUMP
SENSOR NORMAL

L 6:
SENSOR NORMAL

L 8:
SENSOR NORMAL

* * * * * END * * * * *

FM BP
3607 CHERYL LANE
LAFAYETTE IN
47909

JUN 30, 2011 13:25

LEAK TEST REPORT

T 1:UNLEADED
PROBE SERIAL NUM 104689

NO TEST DATA AVAILABLE

* * * * * END * * * * *

FM BP
3607 CHERYL LANE
LAFAYETTE IN
47909

JUN 30, 2011 13:25

LEAK TEST REPORT

T 2:PREMIUM
PROBE SERIAL NUM 386611

NO TEST DATA AVAILABLE

* * * * * END * * * * *

FM BP
3607 CHERYL LANE
LAFAYETTE IN
47909

JUN 30, 2011 13:25

LEAK TEST REPORT

T 3:DIESEL
PROBE SERIAL NUM 070428

NO TEST DATA AVAILABLE

* * * * * END * * * * *

FM BP
3607 CHERYL LANE
LAFAYETTE IN
47909

SEP 29, 2023 12:49

LIQUID STATUS

SEP 29, 2023 12:49

L 1:UNLD SUMP
SENSOR NORMAL

L 2:PREM SUMP
SENSOR NORMAL

L 3:DIESEL SUMP
SENSOR NORMAL

L 6:DSL INT
FUEL ALARM

L 8:REG INT
FUEL ALARM

* * * * * END * * * * *

FM BP
3607 CHERYL LANE
LAFAYETTE IN
47909

SEP 29, 2023 12:49

LEAK TEST REPORT

T 1:UNLEADED
PROBE SERIAL NUM 104689

NO TEST DATA AVAILABLE

* * * * * END * * * * *

FM BP
3607 CHERYL LANE
LAFAYETTE IN
47909

SEP 29, 2023 12:49

LEAK TEST REPORT

T 2:PREMIUM
PROBE SERIAL NUM 386611

NO TEST DATA AVAILABLE

* * * * * END * * * * *

FM BP
3607 CHERYL LANE
LAFAYETTE IN
47909

SEP 29, 2023 12:49

LEAK TEST REPORT

T 3:DIESEL
PROBE SERIAL NUM 070428

NO TEST DATA AVAILABLE

* * * * * END * * * * *

FM BP
3607 CHERYL LANE
LAFAYETTE IN
47909

OCT 30. 2023 13:08

LIQUID STATUS

OCT 30. 2023 13:08

L 1:UNLD SUMP
SENSOR NORMAL

L 2:PREM SUMP
SENSOR NORMAL

L 3:DIESEL SUMP
SENSOR NORMAL

L 6:DEL INT
FUEL ALARM

L 8:REG INT
FUEL ALARM

* * * * * END * * * * *

FM BP
3607 CHERYL LANE
LAFAYETTE IN
47909

OCT 30. 2023 13:08

LEAK TEST REPORT

T 1:UNLEADED
PROBE SERIAL NUM 104689

NO TEST DATA AVAILABLE

* * * * * END * * * * *

FM BP
3607 CHERYL LANE
LAFAYETTE IN
47909

OCT 30. 2023 13:08

LEAK TEST REPORT

T 2:PREMIUM
PROBE SERIAL NUM 386611

NO TEST DATA AVAILABLE

* * * * * END * * * * *

FM BP
3607 CHERYL LANE
LAFAYETTE IN
47909

OCT 30. 2023 13:08

LEAK TEST REPORT

T 3:DIESEL
PROBE SERIAL NUM 070428

NO TEST DATA AVAILABLE

* * * * * END * * * * *

FM BP
3607 CHERYL LANE
LAFAYETTE IN
47909

NOV 29, 2023 13:14

LIQUID STATUS

NOV 29, 2023 13:14

L 1:UNLD SUMP
SENSOR NORMAL

L 2:PREM SUMP
SENSOR NORMAL

L 3:DIESEL SUMP
SENSOR NORMAL

L 6:DSL INT
FUEL ALARM

L 8:REG INT
FUEL ALARM

***** END *****

FM BP
3607 CHERYL LANE
LAFAYETTE IN
47909

NOV 29, 2023 13:14

LEAK TEST REPORT

T 1:UNLEADED
PROBE SERIAL NUM 104689

NO TEST DATA AVAILABLE

***** END *****

FM BP
3607 CHERYL LANE
LAFAYETTE IN
47909

NOV 29, 2023 13:14

LEAK TEST REPORT

T 2:PREMIUM
PROBE SERIAL NUM 386611

NO TEST DATA AVAILABLE

***** END *****

FM BP
3607 CHERYL LANE
LAFAYETTE IN
47909

NOV 29, 2023 13:14

LEAK TEST REPORT

T 3:DIESEL
PROBE SERIAL NUM 070428

NO TEST DATA AVAILABLE

***** END *****

FM BP
3607 CHERYL LANE
LAFAYETTE IN
47909

DEC 28. 2023 13:00

LIQUID STATUS

DEC 28. 2023 13:00

L 1:UNLD SUMP
SENSOR NORMAL

L 2:FREM SUMP
SENSOR NORMAL

L 3:DIESEL SUMP
SENSOR NORMAL

L 6:DSL INT
FUEL ALARM

L 8:REG INT
FUEL ALARM

* * * * * END * * * * *

FM BP
3607 CHERYL LANE
LAFAYETTE IN
47909

DEC 28. 2023 13:00

LEAK TEST REPORT

T 1:UNLEADED
PROBE SERIAL NUM 104689

NO TEST DATA AVAILABLE

* * * * * END * * * * *

FM BP
3607 CHERYL LANE
LAFAYETTE IN
47909

DEC 28. 2023 13:00

LEAK TEST REPORT

T 2:PREMIUM
PROBE SERIAL NUM 386611

NO TEST DATA AVAILABLE

* * * * * END * * * * *

FM BP
3607 CHERYL LANE
LAFAYETTE IN
47909

DEC 28. 2023 13:00

LEAK TEST REPORT

T 3:DIESEL
PROBE SERIAL NUM 070428

NO TEST DATA AVAILABLE

* * * * * END * * * * *

FM BP
3607 CHERYL LANE
LAFAYETTE IN
47909

JAN 31, 2024 13:50

LIQUID STATUS

JAN 31, 2024 13:50

L 1:UNLD SUMP
SENSOR NORMAL

L 2:PREM SUMP
SENSOR NORMAL

L 3:DIESEL SUMP
SENSOR NORMAL

L 6:DSL INT
SENSOR NORMAL

L 8:REG INT
FUEL ALARM

* * * * * END * * * * *

FM BP
3607 CHERYL LANE
LAFAYETTE IN
47909

JAN 31, 2024 13:50

LEAK TEST REPORT

T 1:UNLEADED
PROBE SERIAL NUM 104689

NO TEST DATA AVAILABLE

* * * * * END * * * * *

FM BP
3607 CHERYL LANE
LAFAYETTE IN
47909

JAN 31, 2024 13:50

LEAK TEST REPORT

T 2:PREMIUM
PROBE SERIAL NUM 386611

NO TEST DATA AVAILABLE

* * * * * END * * * * *

FM BP
3607 CHERYL LANE
LAFAYETTE IN
47909

JAN 31, 2024 13:50

LEAK TEST REPORT

T 3:DIESEL
PROBE SERIAL NUM 070428

NO TEST DATA AVAILABLE

FM BP
3607 CHERYL LANE
LAFAYETTE IN
47909

FEB 29, 2024 14:28

LIQUID STATUS

FEB 29, 2024 14:28

L 1:UNLD SUMP
SENSOR NORMAL

L 2:PREM SUMP
SENSOR NORMAL

L 3:DIESEL SUMP
SENSOR NORMAL

L 6:DCL INT
SENSOR NORMAL

L 8:PEG INT
FUEL ALARM

* * * * * END * * * * *

FM BP
3607 CHERYL LANE
LAFAYETTE IN
47909

FEB 29, 2024 14:28

LEAK TEST REPORT

T 1:UNLEADED
PROBE SERIAL NUM 104689

NO TEST DATA AVAILABLE

* * * * * END * * * * *

FM BP
3607 CHERYL LANE
LAFAYETTE IN
47909

FEB 29, 2024 14:28

LEAK TEST REPORT

T 2:PREMIUM
PROBE SERIAL NUM 386611

NO TEST DATA AVAILABLE

* * * * * END * * * * *

FM BP
3607 CHERYL LANE
LAFAYETTE IN
47909

FEB 29, 2024 14:28

LEAK TEST REPORT

T 3:DIESEL
PROBE SERIAL NUM 070428

NO TEST DATA AVAILABLE

* * * * * END * * * * *

FM BP
3607 CHERYL LANE
LAFAYETTE IN
47909

MAR 30. 2024 17:48

LEAK TEST REPORT

T 1:UNLEADED
PROBE SERIAL NUM 104609

NO TEST DATA AVAILABLE

***** END *****

FM BP
3607 CHERYL LANE
LAFAYETTE IN
47909

MAR 30. 2024 17:48

LIQUID STATUS

MAR 30. 2024 17:48

L 1:UNLD SUMP
SENSOR NORMAL

L 2:PREM SUMP
SENSOR NORMAL

L 3:DIESEL SUMP
SENSOR NORMAL

L 6:DSL INT
SENSOR NORMAL

L 8:REG INT
FUEL ALARM

***** END *****

FM BP
3607 CHERYL LANE
LAFAYETTE IN
47909

MAR 30. 2024 17:48

LEAK TEST REPORT

T 2:PREMIUM
PROBE SERIAL NUM 386611

NO TEST DATA AVAILABLE

***** END *****

FM BP
3607 CHERYL LANE
LAFAYETTE IN
47909


MAR 30. 2024 17:48

LEAK TEST REPORT

T 3:DIESEL
PROBE SERIAL NUM 070428

NO TEST DATA AVAILABLE

***** END *****



30 DAYS WALK THROUGH INSPECTION

UST Facility I.D.(FID) # <u>40079</u>	Contact Number
Facility Name <u>BP</u>	Contact email
Address <u>3607 Cheryl Ln, Lafayette, IN</u>	Date of Inspection <u>05/21/24</u>
Operator on Duty Name <u>47909</u>	Name of the Person Conducting Inspection <u>AKSHIT SAHARAN</u>

Operator Training				
Operator Training current	<input type="radio"/> Yes <input type="radio"/> No	Operator Notified	<input type="radio"/> Yes <input type="radio"/> No	
Registration/Notification Form				
Is Registration current with correct owner, operator etc.	<input type="radio"/> Yes <input type="radio"/> No	Operator Notified	<input type="radio"/> Yes <input type="radio"/> No	
Release Detection				
Release Detection Method	<input checked="" type="radio"/> PATG <input type="radio"/> CIM <input type="radio"/> BIR <input type="radio"/> IC <input type="radio"/> Other			
Make and Model	<u>VR T25 350</u>			
Does it have paper?	<input checked="" type="radio"/> Yes <input type="radio"/> No	Operator Notified	<input type="radio"/> Yes <input type="radio"/> No	
Is it in Alarm mode?	<input checked="" type="radio"/> Yes <input type="radio"/> No	Operator Notified	<input checked="" type="radio"/> Yes <input type="radio"/> No	
Interstitial Monitoring Sensor Status Normal	<input checked="" type="radio"/> Yes <input type="radio"/> No	Operator Notified	<input type="radio"/> Yes <input type="radio"/> No	
Necessary Monthly Printout Taken	<input type="radio"/> Yes <input type="radio"/> No	Operator Notified	<input type="radio"/> Yes <input type="radio"/> No	
Spill Buckets				
Are Spill Buckets Clean and free from water, debris, product etc?	<input type="radio"/> Yes <input checked="" type="radio"/> No	Operator Notified	<input checked="" type="radio"/> Yes <input type="radio"/> No	
Are the Spill Bucket in good condition and free of damage/cracks	<input type="radio"/> Yes <input type="radio"/> No	Operator Notified	<input type="radio"/> Yes <input type="radio"/> No	
Fill Ports				
Is Fill pipe cap tight and fill pipe free from any obstruction?	<input checked="" type="radio"/> Yes <input type="radio"/> No	Operator Notified	<input type="radio"/> Yes <input type="radio"/> No	
Piping/STP Sumps				
Are Sumps Clean and free from water, debris, product etc?	<input checked="" type="radio"/> Yes <input type="radio"/> No	Operator Notified	<input type="radio"/> Yes <input type="radio"/> No	
Under Dispenser Containments (UDC)				
Are UDCs clean and free from water, debris, product etc?	<input type="radio"/> Yes <input checked="" type="radio"/> No	Operator Notified	<input checked="" type="radio"/> Yes <input type="radio"/> No	

NOTE: ALL LIQUID/DEBRIS OR WASTE MUST BE DISPOSED OFF ACCORDING TO EXISTING RULES AND REGULATIONS FOLLOWING PROPER PROCEDURE BY A CERTIFIED CONTRACTOR.

Operator on Duty Name	Signature	Date
317-645-0215	tanksdata@gmail.com	www.tanksdata.com



30 DAYS WALK THROUGH INSPECTION

UST Facility I.D. (FID) # 40079	Contact Number
Facility Name BP	Contact email
Address 3607 Cheryl Ln Lafayette	Date of Inspection 04/22/24
Operator on Duty Name 47909	Name of the Person Conducting Inspection Shubhan

Operator Training		
Operator Training current	<input type="radio"/> Yes <input type="radio"/> No	Operator Notified <input type="radio"/> Yes <input type="radio"/> No
Registration/Notification Form		
Is Registration current with correct owner, operator etc.	<input type="radio"/> Yes <input type="radio"/> No	Operator Notified <input type="radio"/> Yes <input type="radio"/> No
Release Detection		
Release Detection Method	<input type="radio"/> ATG <input checked="" type="radio"/> CIM	<input type="radio"/> SIR <input type="radio"/> IC <input type="radio"/> Other
Make and Model	VR TL S-350	
Does it have paper?	<input checked="" type="radio"/> Yes <input type="radio"/> No	Operator Notified <input type="radio"/> Yes <input type="radio"/> No
Is it in Alarm mode?	<input checked="" type="radio"/> Yes <input type="radio"/> No	Operator Notified <input checked="" type="radio"/> Yes <input type="radio"/> No
Interstitial Monitoring Sensor Status Normal	<input type="radio"/> Yes <input checked="" type="radio"/> No	Operator Notified <input checked="" type="radio"/> Yes <input type="radio"/> No
Necessary Monthly Printout Taken	<input checked="" type="radio"/> Yes <input type="radio"/> No	Operator Notified <input type="radio"/> Yes <input type="radio"/> No
Spill Buckets		
Are Spill Buckets Clean and free from water, debris, product etc?	<input type="radio"/> Yes <input checked="" type="radio"/> No	Operator Notified <input checked="" type="radio"/> Yes <input type="radio"/> No
Are the Spill Bucket in good condition and free of damage/cracks	<input checked="" type="radio"/> Yes <input type="radio"/> No	Operator Notified <input type="radio"/> Yes <input type="radio"/> No
Fill Parts		
Is Fill pipe cap tight and fill pipe free from any obstruction?	<input type="radio"/> Yes <input type="radio"/> No	Operator Notified <input type="radio"/> Yes <input type="radio"/> No
Piping/STP Sumps		
Are Sumps Clean and free from water, debris, product etc?	<input type="radio"/> Yes <input type="radio"/> No	Operator Notified <input type="radio"/> Yes <input type="radio"/> No
Under Dispenser Containments (UDC)		
Are UDCs clean and free from water, debris, product etc?	<input type="radio"/> Yes <input type="radio"/> No	Operator Notified <input type="radio"/> Yes <input type="radio"/> No

NOTE: ALL LIQUID/DEBRIS OR WASTE MUST BE DISPOSED OFF ACCORDING TO EXISTING RULES AND REGULATIONS FOLLOWING PROPER PROCEDURE BY A CERTIFIED CONTRACTOR.

Operator on Duty Name	Signature	Date
317-645-0215	tanksdata@gmail.com	www.tanksdata.com



30 DAYS WALK THROUGH INSPECTION

UST Facility I.D.(FID) #	40079	Contact Number	
Facility Name	B.P.	Contact email	
Address	3607 Cheryl Ln, Lafayette, LA	Date of Inspection	3/30/24
Operator on Duty Name	DN 47955	Name of the Person Conducting Inspection	VIRENDRA

Operator Training				
Operator Training current	<input type="radio"/> Yes	<input type="radio"/> No	Operator Notified	<input type="radio"/> Yes <input type="radio"/> No
Registration/Notification Form				
Is Registration current with correct owner, operator etc.	<input type="radio"/> Yes	<input type="radio"/> No	Operator Notified	<input type="radio"/> Yes <input type="radio"/> No
Release Detection				
Release Detection Method	<input checked="" type="radio"/> ATG	<input checked="" type="radio"/> CIM	<input type="radio"/> SIR	<input type="radio"/> IC <input type="radio"/> Other
Make and Model	VR TLS 3SD			
Does it have paper?	<input checked="" type="radio"/> Yes	<input type="radio"/> No	Operator Notified	<input type="radio"/> Yes <input type="radio"/> No
Is it in Alarm mode?	<input checked="" type="radio"/> Yes	<input type="radio"/> No	Operator Notified	<input type="radio"/> Yes <input type="radio"/> No
Interstitial Monitoring Sensor Status Normal	<input type="radio"/> Yes	<input checked="" type="radio"/> No	Operator Notified	<input type="radio"/> Yes <input type="radio"/> No
Necessary Monthly Printout Taken	<input checked="" type="radio"/> Yes	<input type="radio"/> No	Operator Notified	<input type="radio"/> Yes <input type="radio"/> No
Spill Buckets				
Are Spill Buckets Clean and free from water, debris, product etc?	<input type="radio"/> Yes	<input checked="" type="radio"/> No	Operator Notified	<input checked="" type="radio"/> Yes <input type="radio"/> No
Are the Spill Bucket in good condition and free of damage/cracks	<input checked="" type="radio"/> Yes	<input type="radio"/> No	Operator Notified	<input type="radio"/> Yes <input type="radio"/> No
Fill Ports				
Is Fill pipe cap tight and fill pipe free from any obstruction?	<input checked="" type="radio"/> Yes	<input type="radio"/> No	Operator Notified	<input type="radio"/> Yes <input type="radio"/> No
Piping/STP Sumps				
Are Sumps Clean and free from water, debris, product etc?	<input type="radio"/> Yes	<input checked="" type="radio"/> No	Operator Notified	<input checked="" type="radio"/> Yes <input type="radio"/> No
Under Dispenser Containments (UDC)				
Are UDCs clean and free from water, debris, product etc?	<input type="radio"/> Yes	<input checked="" type="radio"/> No	Operator Notified	<input checked="" type="radio"/> Yes <input type="radio"/> No

NOTE: ALL LIQUID/DEBRIS OR WASTE MUST BE DISPOSED OFF ACCORDING TO EXISTING RULES AND REGULATIONS FOLLOWING PROPER PROCEDURE BY A CERTIFIED CONTRACTOR.

Operator on Duty Name	Signature	Date
317-645-0215	tanksdata@gmail.com	www.tanksdata.com



30 DAYS WALK THROUGH INSPECTION

UST Facility I.D.(FID) # 40079	Contact Number
Facility Name BP	Contact email
Address 3607 Cheryl Ln Lafayette 47909	Date of Inspection 2/29/24
Operator on Duty Name	Name of the Person Conducting Inspection Josh Rider

Operator Training

Operator Training current Yes No OperatorNotified Yes No

Registration/Notification Form

Is Registration current with correct owner, operator etc. Yes No OperatorNotified Yes No

Release Detection

Release Detection Method ATG CIM SIR IC Other

Make and Model **VR TL S-350**

Does it have paper? Yes No OperatorNotified Yes No

Is it in Alarm mode? Yes No OperatorNotified Yes No

Interstitial Monitoring Sensor Status Normal Yes No OperatorNotified Yes No

Necessary Monthly Printout Taken Yes No OperatorNotified Yes No

Spill Buckets *minimal*

Are Spill Buckets Clean and free from water, debris, product etc? Yes No OperatorNotified Yes No

Are the Spill Bucket in good condition and free of damage/cracks Yes No OperatorNotified Yes No

Fill Ports

Is Fill pipe cap tight and fill pipe free from any obstruction? Yes No OperatorNotified Yes No

Piping/STP Sumps

Are Sumps Clean and free from water, debris, product etc? Yes No OperatorNotified Yes No

Under Dispenser Containments (UDC)

Are UDCs clean and free from water, debris, product etc? Yes No OperatorNotified Yes No

NOTE: ALL LIQUID/DEBRIS OR WASTE MUST BE DISPOSED OFF ACCORDING TO EXISTING RULES AND REGULATIONS FOLLOWING PROPER PROCEDURE BY A CERTIFIED CONTRACTOR.

Operator on Duty Name

317-645-0215

Signature

tanksdata@gmail.com

Date

www.tanksdata.com



30 DAYS WALK THROUGH INSPECTION

UST Facility I.D. (FID) # 40079	Contact Number
Facility Name BP	Contact email
Address 3607 Cheryl Ln Lafayette 47909	Date of Inspection 1/31/24
Operator on Duty Name	Name of the Person Conducting Inspection Josh Rider

Operator Training				
Operator Training current	<input type="radio"/> Yes	<input type="radio"/> No	Operator Notified	<input type="radio"/> Yes <input type="radio"/> No
Registration/Notification Form				
Is Registration current with correct owner, operator etc.	<input type="radio"/> Yes	<input type="radio"/> No	Operator Notified	<input type="radio"/> Yes <input type="radio"/> No
Release Detection				
Release Detection Method	<input checked="" type="radio"/> ATG	<input type="radio"/> CIM	<input type="radio"/> SIR	<input type="radio"/> IC <input type="radio"/> Other
Make and Model	VR	TLS-350		
Does it have paper?	<input checked="" type="radio"/> Yes	<input type="radio"/> No	Operator Notified	<input type="radio"/> Yes <input type="radio"/> No
Is it in Alarm mode?	<input checked="" type="radio"/> Yes	<input type="radio"/> No	Operator Notified	<input checked="" type="radio"/> Yes <input type="radio"/> No
Interstitial Monitoring Sensor Status Normal	<input type="radio"/> Yes	<input type="radio"/> No	Operator Notified	<input type="radio"/> Yes <input type="radio"/> No
Necessary Monthly Printout Taken	<input checked="" type="radio"/> Yes	<input type="radio"/> No	Operator Notified	<input type="radio"/> Yes <input type="radio"/> No
Spill Buckets				
Are Spill Buckets Clean and free from water, debris, product etc?	<input type="radio"/> Yes	<input checked="" type="radio"/> No <i>minimal</i>	Operator Notified	<input checked="" type="radio"/> Yes <input type="radio"/> No
Are the Spill Bucket in good condition and free of damage/cracks	<input checked="" type="radio"/> Yes	<input type="radio"/> No	Operator Notified	<input type="radio"/> Yes <input type="radio"/> No
Fill Ports				
Is Fill pipe cap tight and fill pipe free from any obstruction?	<input checked="" type="radio"/> Yes	<input type="radio"/> No	Operator Notified	<input type="radio"/> Yes <input type="radio"/> No
Piping/STP Sumps				
Are Sumps Clean and free from water, debris, product etc?	<input type="radio"/> Yes	<input checked="" type="radio"/> No	Operator Notified	<input checked="" type="radio"/> Yes <input type="radio"/> No
Under Dispenser Containments (UDC)				
Are UDCs clean and free from water, debris, product etc?	<input type="radio"/> Yes	<input checked="" type="radio"/> No	Operator Notified	<input checked="" type="radio"/> Yes <input type="radio"/> No

NOTE: ALL LIQUID/DEBRIS OR WASTE MUST BE DISPOSED OFF ACCORDING TO EXISTING RULES AND REGULATIONS FOLLOWING PROPER PROCEDURE BY A CERTIFIED CONTRACTOR.

Operator on Duty Name	Signature	Date
317-645-0215	tanksdata@gmail.com	www.tanksdata.com



30 DAYS WALK THROUGH INSPECTION

UST Facility I.D.(FID) # 40079	Contact Number
Facility Name BP	Contact email
Address 3607 Cheryl Ln Lafayette 47909	Date of Inspection 12/28/23
Operator on Duty Name	Name of the Person Conducting Inspection Josh Rider

Operator Training

Operator Training current	<input type="radio"/> Yes	<input type="radio"/> No	Operator Notified	<input type="radio"/> Yes	<input type="radio"/> No
---------------------------	---------------------------	--------------------------	-------------------	---------------------------	--------------------------

Registration/Notification Form

Is Registration current with correct owner, operator etc.	<input type="radio"/> Yes	<input type="radio"/> No	Operator Notified	<input type="radio"/> Yes	<input type="radio"/> No
---	---------------------------	--------------------------	-------------------	---------------------------	--------------------------

Release Detection

Release Detection Method	<input checked="" type="radio"/> ATG	<input checked="" type="radio"/> CIM	<input type="radio"/> SIR	<input type="radio"/> IC	<input type="radio"/> Other
Make and Model	VR	TLS-350			
Does it have paper?	<input checked="" type="radio"/> Yes	<input type="radio"/> No	Operator Notified	<input type="radio"/> Yes	<input type="radio"/> No
Is it in Alarm mode?	<input checked="" type="radio"/> Yes	<input type="radio"/> No	Operator Notified	<input checked="" type="radio"/> Yes	<input type="radio"/> No
Interstitial Monitoring Sensor Status Normal	<input type="radio"/> Yes	<input checked="" type="radio"/> No	Operator Notified	<input checked="" type="radio"/> Yes	<input type="radio"/> No
Necessary Monthly Printout Taken	<input checked="" type="radio"/> Yes	<input type="radio"/> No	Operator Notified	<input type="radio"/> Yes	<input type="radio"/> No

Spill Buckets

Are Spill Buckets Clean and free from water, debris, product etc?	<input type="radio"/> Yes	<input checked="" type="radio"/> No <i>minimal</i>	Operator Notified	<input checked="" type="radio"/> Yes	<input type="radio"/> No
Are the Spill Bucket in good condition and free of damage/cracks	<input checked="" type="radio"/> Yes	<input type="radio"/> No	Operator Notified	<input type="radio"/> Yes	<input type="radio"/> No

Fill Ports

Is Fill pipe cap tight and fill pipe free from any obstruction?	<input checked="" type="radio"/> Yes	<input type="radio"/> No	Operator Notified	<input type="radio"/> Yes	<input type="radio"/> No
---	--------------------------------------	--------------------------	-------------------	---------------------------	--------------------------

Piping/STP Sumps

Are Sumps Clean and free from water, debris, product etc?	<input type="radio"/> Yes	<input checked="" type="radio"/> No	Operator Notified	<input checked="" type="radio"/> Yes	<input type="radio"/> No
---	---------------------------	-------------------------------------	-------------------	--------------------------------------	--------------------------

Under Dispenser Containments (UDC)

Are UDCs clean and free from water, debris, product etc?	<input type="radio"/> Yes	<input checked="" type="radio"/> No	Operator Notified	<input checked="" type="radio"/> Yes	<input type="radio"/> No
--	---------------------------	-------------------------------------	-------------------	--------------------------------------	--------------------------

NOTE: ALL LIQUID/DEBRIS OR WASTE MUST BE DISPOSED OFF ACCORDING TO EXISTING RULES AND REGULATIONS FOLLOWING PROPER PROCEDURE BY A CERTIFIED CONTRACTOR.

Operator on Duty Name	Signature	Date
317-645-0215	tanksdata@gmail.com	www.tanksdata.com



30 DAYS WALK THROUGH INSPECTION

FM BP
3607 CHERYL LANE
LAFAYETTE IN
47909

NOV 29, 2023 13:14

LIQUID STATUS
NOV 29, 2023 13:14

UST Facility I.D.(FID) # 40079	Contact Number
Facility Name BP	Contact email
Address 3607 Cheryl Ln Lafayette 47909	Date of Inspection 11/29/23
Operator on Duty Name	Name of the Person Conducting Inspection Josh Rider

L 1:UNLD SUMP
SENSOR NORMAL

L 2:PREM SUMP
SENSOR NORMAL

L 3:DIESEL SUMP
SENSOR NORMAL

L 6:DSL INT
FUEL ALARM

L 8:REG INT
FUEL ALARM

***** END *****

FM BP
3607 CHERYL LANE
LAFAYETTE IN
47909

NOV 29, 2023 13:14

LEAK TEST REPORT

T 1:UNLEADED
PROBE SERIAL

Operator Training		Operator Notified		<input type="radio"/> Yes	<input type="radio"/> No
Operator Training current	<input type="radio"/> Yes <input type="radio"/> No				
Registration/Notification Form		Operator Notified		<input type="radio"/> Yes	<input type="radio"/> No
Is Registration current with correct owner, operator etc.	<input type="radio"/> Yes <input type="radio"/> No				
Release Detection					
Release Detection Method	<input checked="" type="radio"/> ATG <input checked="" type="radio"/> CIM <input type="radio"/> SIR <input type="radio"/> IC <input type="radio"/> Other				
Make and Model	<input checked="" type="radio"/> VR <input checked="" type="radio"/> TLS-350				
Does it have paper?	<input checked="" type="radio"/> Yes <input type="radio"/> No	Operator Notified		<input type="radio"/> Yes	<input type="radio"/> No
Is it in Alarm mode?	<input checked="" type="radio"/> Yes <input type="radio"/> No	Operator Notified		<input checked="" type="radio"/> Yes	<input type="radio"/> No
Interstitial Monitoring Sensor Status Normal	<input type="radio"/> Yes <input checked="" type="radio"/> No	Operator Notified		<input checked="" type="radio"/> Yes	<input type="radio"/> No
Necessary Monthly Printout Taken	<input checked="" type="radio"/> Yes <input type="radio"/> No	Operator Notified		<input type="radio"/> Yes	<input type="radio"/> No
Spill Buckets					
Are Spill Buckets Clean and free from water, debris, product etc?	<input type="radio"/> Yes <input checked="" type="radio"/> No	Operator Notified		<input checked="" type="radio"/> Yes	<input type="radio"/> No
Are the Spill Bucket in good condition and free of damage/cracks	<input checked="" type="radio"/> Yes <input type="radio"/> No	Operator Notified		<input type="radio"/> Yes	<input type="radio"/> No
Fill Ports					
Is Fill pipe cap tight and fill pipe free from any obstruction?	<input checked="" type="radio"/> Yes <input type="radio"/> No	Operator Notified		<input type="radio"/> Yes	<input type="radio"/> No
Piping/STP Sumps					
Are Sumps Clean and free from water, debris, product etc?	<input type="radio"/> Yes <input checked="" type="radio"/> No	Operator Notified		<input checked="" type="radio"/> Yes	<input type="radio"/> No
Under Dispenser Containments (UDC)					
Are UDCs clean and free from water, debris, product etc?	<input type="radio"/> Yes <input checked="" type="radio"/> No	Operator Notified		<input checked="" type="radio"/> Yes	<input type="radio"/> No

NOTE: ALL LIQUID/DEBRIS OR WASTE MUST BE DISPOSED OFF ACCORDING TO EXISTING RULES AND REGULATIONS FOLLOWING PROPER PROCEDURE BY A CERTIFIED CONTRACTOR.

Operator on Duty Name	Signature	Date
317-645-0215	tanksdata@gmail.com	www.tanksdata.com

20220516

Tanks Data		30 DAYS WALK THROUGH INSPECTION		
UST Facility I.D. (FID) #	40079	Contact Number		
Facility Name	BP	Contact email		
Address	3607 Cheryl Ln Lafayette 47909	Date of Inspection	10/30/23	
Operator on Duty Name		Name of the Person Conducting Inspection	Josh Rider	
Operator Training				
Operator Training current	<input type="radio"/> Yes <input type="radio"/> No	Operator Notified	<input type="radio"/> Yes <input type="radio"/> No	
Registration/Notification Form				
Is Registration current with correct owner, operator etc.	<input type="radio"/> Yes <input type="radio"/> No	Operator Notified	<input type="radio"/> Yes <input type="radio"/> No	
Release Detection				
Release Detection Method	<input checked="" type="radio"/> ATG <input checked="" type="radio"/> CIM <input type="radio"/> SIR <input type="radio"/> IC <input type="radio"/> Other			
Make and Model	VR TLS-350			
Does it have paper?	<input checked="" type="radio"/> Yes <input type="radio"/> No	Operator Notified	<input type="radio"/> Yes <input type="radio"/> No	
Is it in Alarm mode?	<input checked="" type="radio"/> Yes <input type="radio"/> No	Operator Notified	<input checked="" type="radio"/> Yes <input type="radio"/> No	
Interstitial Monitoring Sensor Status Normal	<input type="radio"/> Yes <input checked="" type="radio"/> No	Operator Notified	<input checked="" type="radio"/> Yes <input type="radio"/> No	
Necessary Monthly Printout Taken	<input checked="" type="radio"/> Yes <input type="radio"/> No	Operator Notified	<input type="radio"/> Yes <input type="radio"/> No	
Spill Buckets				
Are Spill Buckets Clean and free from water, debris, product etc?	<input type="radio"/> Yes <input checked="" type="radio"/> No	Operator Notified	<input checked="" type="radio"/> Yes <input type="radio"/> No	
Are the Spill Bucket in good condition and free of damage/cracks	<input checked="" type="radio"/> Yes <input type="radio"/> No	Operator Notified	<input type="radio"/> Yes <input type="radio"/> No	
Fill Ports				
Is Fill pipe cap tight and fill pipe free from any obstruction?	<input checked="" type="radio"/> Yes <input type="radio"/> No	Operator Notified	<input type="radio"/> Yes <input type="radio"/> No	
Piping/STP Sumps				
Are Sumps Clean and free from water, debris, product etc?	<input type="radio"/> Yes <input checked="" type="radio"/> No	Operator Notified	<input checked="" type="radio"/> Yes <input type="radio"/> No	
Under Dispenser Containments (UDC)				
Are UDCs clean and free from water, debris, product etc?	<input type="radio"/> Yes <input checked="" type="radio"/> No	Operator Notified	<input checked="" type="radio"/> Yes <input type="radio"/> No	
<i>NOTE: ALL LIQUID/DEBRIS OR WASTE MUST BE DISPOSED OFF ACCORDING TO EXISTING RULES AND REGULATIONS FOLLOWING PROPER PROCEDURE BY A CERTIFIED CONTRACTOR.</i>				
Operator on Duty Name	Signature	Date		
317-645-0215	tanksdata@gmail.com	www.tanksdata.com		

FM BP
3607 CHERYL LANE
LAFAYETTE IN
47909

OCT 30. 2023 13:08

LIQUID STATUS
OCT 30. 2023 13:08

L 1: UNLD SUMP
SENSOR NORMAL

L 2: PREM SUMP
SENSOR NORMAL

L 3: DIESEL SUMP
SENSOR NORMAL

L 6: DSL INT
FUEL ALARM

L 8: REG INT
FUEL ALARM

***** END *****

FM BP
3607 CHERYL LANE
LAFAYETTE IN
47909

OCT 30. 2023 13:08

LEAK TEST REPORT

T 1: UNLEADED
PROBE SERIAL NUM



30 DAYS WALK THROUGH INSPECTION

UST Facility I.D.(FID) # **40079**
 Facility Name **BP**
 Address **3607 Cheryl Ln Lafayette 47909**
 Operator on Duty Name

Contact Number
 Contact email
 Date of Inspection **9/29/23**
 Name of the Person Conducting Inspection **Josh Rider**

FM BP
 3607 CHERYL LANE
 LAFAYETTE IN
 47909

SEP 29, 2023 12:49
 LIQUID STATUS
 SEP 29, 2023 12:49

Operator Training
 Operator Training current Yes No OperatorNotified Yes No

Registration/Notification Form
 Is Registration current with correct owner, operator etc. Yes No OperatorNotified Yes No

Release Detection
 Release Detection Method ATG CIM SIR IC Other
 Make and Model **VR TLS-350**
 Does it have paper? Yes No OperatorNotified Yes No
 Is it in Alarm mode? Yes No OperatorNotified Yes No
 Interstitial Monitoring Sensor Status Normal Yes No OperatorNotified Yes No
 Necessary Monthly Printout Taken Yes No OperatorNotified Yes No

L 1:UNLD SUMP
 SENSOR NORMAL
 L 2:PREM SUMP
 SENSOR NORMAL
 L 3:DIESEL SUMP
 SENSOR NORMAL
 L 6:DSL INT
 FUEL ALARM
 L 8:REG INT
 FUEL ALARM

Spill Buckets
 Are Spill Buckets Clean and free from water, debris, product etc? Yes No ^{minimal} OperatorNotified Yes No
 Are the Spill Bucket in good condition and free of damage/cracks Yes No OperatorNotified Yes No

Fill Ports
 Is Fill pipe cap tight and fill pipe free from any obstruction? Yes No OperatorNotified Yes No

Piping/STP Sumps
 Are Sumps Clean and free from water, debris, product etc? Yes No OperatorNotified Yes No

Under Dispenser Containments (UDC)
 Are UDCs clean and free from water, debris, product etc? Yes No OperatorNotified Yes No

***** END *****

NOTE: ALL LIQUID/DEBRIS OR WASTE MUST BE DISPOSED OFF ACCORDING TO EXISTING RULES AND REGULATIONS FOLLOWING PROPER PROCEDURE BY A CERTIFIED CONTRACTOR.

Operator on Duty Name **317-645-0215** tanksdata@gmail.com Signature _____ Date _____
 www.tanksdata.com 20220516

FM BP
 3607 CHERYL LANE
 LAFAYETTE IN
 47909

SEP 29, 2023 12:49
 LEAK TEST REPORT
 T 1:UNLEADED
 PROBE SERIAL NUM



30 DAYS WALK THROUGH INSPECTIO

UST Facility I.D. (FID) #	40079	Contact Number	
Facility Name	BP	Contact email	
Address	3607 Cheryl Ln Lafayette 47909	Date of Inspection	8/31/23
Operator on Duty Name		Name of the Person Conducting Inspection	Josh Rider

FM BP
3607 CHERYL LANE
LAFAYETTE IN
47909

JUN 30. 2011 13:25

LIQUID STATUS

JUN 30. 2011 13:25

Operator Training				
Operator Training current	<input type="radio"/> Yes	<input type="radio"/> No	Operator Notified	<input type="radio"/> Yes <input type="radio"/> No
Registration/Notification Form				
Is Registration current with correct owner, operator etc.	<input type="radio"/> Yes	<input type="radio"/> No	Operator Notified	<input type="radio"/> Yes <input type="radio"/> No
Release Detection				
Release Detection Method	<input checked="" type="radio"/> ATG	<input checked="" type="radio"/> IIM	<input type="radio"/> SIR	<input type="radio"/> IC
Make and Model	VR	TL5-350		
Does it have paper?	<input checked="" type="radio"/> Yes	<input type="radio"/> No	Operator Notified	<input type="radio"/> Yes <input type="radio"/> No
Is it in Alarm mode?	<input type="radio"/> Yes	<input checked="" type="radio"/> No	Operator Notified	<input type="radio"/> Yes <input type="radio"/> No
Interstitial Monitoring Sensor Status Normal	<input checked="" type="radio"/> Yes	<input type="radio"/> No	Operator Notified	<input type="radio"/> Yes <input type="radio"/> No
Necessary Monthly Printout Taken	<input checked="" type="radio"/> Yes	<input type="radio"/> No	Operator Notified	<input type="radio"/> Yes <input type="radio"/> No
Spill Buckets				
Are Spill Buckets Clean and free from water, debris, product etc?	<input type="radio"/> Yes	<input checked="" type="radio"/> No	Operator Notified	<input checked="" type="radio"/> Yes <input type="radio"/> No
Are the Spill Bucket in good condition and free of damage/cracks	<input checked="" type="radio"/> Yes	<input type="radio"/> No	Operator Notified	<input type="radio"/> Yes <input type="radio"/> No
Fill Ports				
Is Fill pipe cap tight and fill pipe free from any obstruction?	<input checked="" type="radio"/> Yes	<input type="radio"/> No	Operator Notified	<input type="radio"/> Yes <input type="radio"/> No
Piping/STP Sumps				
Are Sumps Clean and free from water, debris, product etc?	<input type="radio"/> Yes	<input checked="" type="radio"/> No	Operator Notified	<input checked="" type="radio"/> Yes <input type="radio"/> No
Under Dispenser Containments (UDC)				
Are UDCs clean and free from water, debris, product etc?	<input type="radio"/> Yes	<input checked="" type="radio"/> No	Operator Notified	<input checked="" type="radio"/> Yes <input type="radio"/> No

L 1: UNLD SUMP
SENSOR NORMAL

L 2: PREM SUMP
SENSOR NORMAL

L 3: DIESEL SUMP
SENSOR NORMAL

L 6:
SENSOR NORMAL

L 8:
SENSOR NORMAL

***** END *****

NOTE: ALL LIQUID/DEBRIS OR WASTE MUST BE DISPOSED OFF ACCORDING TO EXISTING RULES AND REGULATIONS FOLLOWING PROPER PROCEDURE BY A CERTIFIED CONTRACTOR.

Operator on Duty Name	Signature	Date
317-645-0215	tanksdata@gmail.com	www.tanksdata.com

FM BP
3607 CHERYL LANE
LAFAYETTE IN
47909

JUN 30. 2011 13:25

LEAK TEST REPORT

T 1: UNLEADED
PROBE SERIAL NUM 104689

Tanks Data		30 DAYS WALK THROUGH INSPECTION	
UST Facility I.D. (FID) #	40079	Contact Number	
Facility Name	BP	Contact email	
Address	3607 Cheryl Ln Lafayette 47909	Date of Inspection	7/31/23
Operator on Duty Name		Name of the Person Conducting Inspection	Josh Rider
Operator Training			
Operator Training current	<input type="radio"/> Yes <input type="radio"/> No	Operator Notified	<input type="radio"/> Yes <input type="radio"/> No
Registration/Notification Form			
Is Registration current with correct owner, operator etc.	<input type="radio"/> Yes <input type="radio"/> No	Operator Notified	<input type="radio"/> Yes <input type="radio"/> No
Release Detection			
Release Detection Method	<input checked="" type="radio"/> ATG <input checked="" type="radio"/> CIM <input type="radio"/> SIR <input type="radio"/> IC <input type="radio"/> Other		
Make and Model	VR TLS-350		
Does it have paper?	<input checked="" type="radio"/> Yes <input type="radio"/> No	Operator Notified	<input type="radio"/> Yes <input type="radio"/> No
Is it in Alarm mode?	<input type="radio"/> Yes <input checked="" type="radio"/> No	Operator Notified	<input type="radio"/> Yes <input type="radio"/> No
Interstitial Monitoring Sensor Status Normal	<input checked="" type="radio"/> Yes <input type="radio"/> No	Operator Notified	<input type="radio"/> Yes <input type="radio"/> No
Necessary Monthly Printout Taken	<input checked="" type="radio"/> Yes <input type="radio"/> No	Operator Notified	<input type="radio"/> Yes <input type="radio"/> No
Spill Buckets			
Are Spill Buckets Clean and free from water, debris, product etc?	<input type="radio"/> Yes <input checked="" type="radio"/> No	Operator Notified	<input checked="" type="radio"/> Yes <input type="radio"/> No
Are the Spill Bucket in good condition and free of damage/cracks	<input checked="" type="radio"/> Yes <input type="radio"/> No	Operator Notified	<input type="radio"/> Yes <input type="radio"/> No
Fill Ports			
Is Fill pipe cap tight and fill pipe free from any obstruction?	<input checked="" type="radio"/> Yes <input type="radio"/> No	Operator Notified	<input type="radio"/> Yes <input type="radio"/> No
Piping/STP Sumps			
Are Sumps Clean and free from water, debris, product etc?	<input type="radio"/> Yes <input checked="" type="radio"/> No	Operator Notified	<input checked="" type="radio"/> Yes <input type="radio"/> No
Under Dispenser Containments (UDC)			
Are UDCs clean and free from water, debris, product etc?	<input type="radio"/> Yes <input checked="" type="radio"/> No	Operator Notified	<input checked="" type="radio"/> Yes <input type="radio"/> No
<i>NOTE: ALL LIQUID/DEBRIS OR WASTE MUST BE DISPOSED OFF ACCORDING TO EXISTING RULES AND REGULATIONS FOLLOWING PROPER PROCEDURE BY A CERTIFIED CONTRACTOR.</i>			
Operator on Duty Name	Signature	Date	
317-645-0215	tanksdata@gmail.com	www.tanksdata.com	

FM BP
 3607 CHERYL LANE
 LAFAYETTE IN
 47909
 MAY 30, 2011 12:46
 LIQUID STATUS
 MAY 30, 2011 12:46
 L 1: UNLD SUMP
 SENSOR NORMAL
 L 2: PREM SUMP
 SENSOR NORMAL
 L 3: DIESEL SUMP
 SENSOR NORMAL
 L 6:
 SENSOR NORMAL
 L 8:
 SENSOR NORMAL
 ***** END *****
 FM BP
 3607 CHERYL
 LAFAYETTE
 47909
 MAY 30
 LEAK T
 T 1: U
 PROPE



30 DAYS WALK THROUGH INSPECTION

UST Facility I.D. (FID) # 40079	Contact Number
Facility Name BP	Contact email
Address 3607 Cheryl Ln Lafayette 47909	Date of Inspection 6/23/23
Operator on Duty Name	Name of the Person Conducting Inspection Josh Rider

Operator Training					
Operator Training current	<input type="radio"/> Yes	<input type="radio"/> No	Operator Notified	<input type="radio"/> Yes	<input type="radio"/> No
Registration/Notification Form					
Is Registration current with correct owner, operator etc.	<input type="radio"/> Yes	<input type="radio"/> No	Operator Notified	<input type="radio"/> Yes	<input type="radio"/> No
Release Detection					
Release Detection Method	<input checked="" type="radio"/> ATG	<input checked="" type="radio"/> CIM	<input type="radio"/> SIR	<input type="radio"/> IC	<input type="radio"/> Other
Make and Model	VR	TLS-350			
Does it have paper?	<input checked="" type="radio"/> Yes	<input type="radio"/> No	Operator Notified	<input type="radio"/> Yes	<input type="radio"/> No
Is it in Alarm mode?	<input type="radio"/> Yes	<input checked="" type="radio"/> No	Operator Notified	<input type="radio"/> Yes	<input type="radio"/> No
Interstitial Monitoring Sensor Status Normal	<input checked="" type="radio"/> Yes	<input type="radio"/> No	Operator Notified	<input type="radio"/> Yes	<input type="radio"/> No
Necessary Monthly Printout Taken	<input checked="" type="radio"/> Yes	<input type="radio"/> No	Operator Notified	<input type="radio"/> Yes	<input type="radio"/> No
Spill Buckets					
Are Spill Buckets Clean and free from water, debris, product etc?	<input type="radio"/> Yes	<input checked="" type="radio"/> No	Operator Notified	<input checked="" type="radio"/> Yes	<input type="radio"/> No
Are the Spill Bucket in good condition and free of damage/cracks	<input checked="" type="radio"/> Yes	<input type="radio"/> No	Operator Notified	<input type="radio"/> Yes	<input type="radio"/> No
Fill Ports					
Is Fill pipe cap tight and fill pipe free from any obstruction?	<input checked="" type="radio"/> Yes	<input type="radio"/> No	Operator Notified	<input type="radio"/> Yes	<input type="radio"/> No
Piping/STP Sumps					
Are Sumps Clean and free from water, debris, product etc?	<input type="radio"/> Yes	<input checked="" type="radio"/> No	Operator Notified	<input checked="" type="radio"/> Yes	<input type="radio"/> No
Under Dispenser Containments (UDC)					
Are UDCs clean and free from water, debris, product etc?	<input type="radio"/> Yes	<input checked="" type="radio"/> No	Operator Notified	<input checked="" type="radio"/> Yes	<input type="radio"/> No

NOTE: ALL LIQUID/DEBRIS OR WASTE MUST BE DISPOSED OFF ACCORDING TO EXISTING RULES AND REGULATIONS FOLLOWING PROPER PROCEDURE BY A CERTIFIED CONTRACTOR.

Operator on Duty Name	Signature	Date
317-645-0215	tanksdata@gmail.com	www.tanksdata.com

FM BP
3607 CHERYL LANE
LAFAYETTE IN
47909

JUN 23, 2023 12:13
CSLD TEST RESULTS
JUN 23, 2023 12:13

T 1: UNLEADED
PROBE SERIAL NUM 104689
0.2 GAL/HR TEST
PER: JUN 23, 2023 PASS

T 2: PREMIUM
PROBE SERIAL NUM 386611
0.2 GAL/HR TEST
PER: JUN 23, 2023 PASS

T 3: DIESEL
PROBE SERIAL NUM 07042
0.2 GAL/HR TEST
PER: JUN 23, 2023 PASS

***** END *****