

**To:** Agnew, Dianna[DAgnew@idem.IN.gov]  
**From:** DWBMGR  
**Sent:** Wed 6/12/2024 1:20:39 PM  
**Subject:** FW: Boil Advisory  
**Received:** Wed 6/12/2024 1:20:43 PM

Thank you,

***Roger Svendsen***

Indiana CMDP Administrator  
IDEM Drinking Water Branch  
100 N. Senate Ave. MC 66-34  
Indianapolis, IN 46204

Phone: 317-234-7455 Fax: 317-234-7455

**Routine** Drinking Water Test Results submitted to IDEM Drinking Water Branch can be viewed on-line by clicking the link below:  
<https://myweb.in.gov/IDEM/DWW/>

---

**From:** Neal McKee <NMckee@cityofanderson.com>  
**Sent:** Wednesday, June 12, 2024 9:20 AM  
**To:** DWBMGR <DWBMGR@idem.IN.gov>; 'Stephanie Cain' <scain@MadisonCounty.IN.Gov>  
**Subject:** FW: Boil Advisory

**\*\*\*\* This is an EXTERNAL email. Exercise caution. DO NOT open attachments or click links from unknown senders or unexpected email. \*\*\*\***

See below for the BWA issued by the city of Anderson.

Neal L McKee  
Director, City of Anderson Water Utility  
550 Dale Keith Jones Road  
Anderson, IN 46011



Phone: 765-648-6420  
Email: [nmckee@cityofanderson.com](mailto:nmckee@cityofanderson.com)

---

**From:** Jake Ockomon <[jockomon@cityofanderson.com](mailto:jockomon@cityofanderson.com)>  
**Sent:** Monday, June 10, 2024 3:53 PM  
**To:** Neal McKee <[NMckee@cityofanderson.com](mailto:NMckee@cityofanderson.com)>; J.D. Allman <[jdallman@cityofanderson.com](mailto:jdallman@cityofanderson.com)>; Donald Ferguson <[dferguson@cityofanderson.com](mailto:dferguson@cityofanderson.com)>; Josh Castor <[JCastor@cityofanderson.com](mailto:JCastor@cityofanderson.com)>  
**Subject:** Fwd: Boil Advisory

The Anderson Water System ([5248002](https://www.andersonin.gov/5248002)) issued a boil water advisory due to a main repair. Affected customers were notified to boil water for drinking, cooking, and/or oral hygiene purposes. Sample analysis is

being conducted at the Anderson Water Pollution Control Laboratory, certification# M-48-1.

BWA issued: 06/10/24

Anderson Water Department - [5248002](#)

Residential Customers affected – 16

Commercial customers affected -

Affected Area: 2534-3045 West Cross Street

Cause - Main Repairs

Result: Water pressure <20 psi for approximately 2 hrs

BWA Cancellation:06/11/24 5:00 PM