

**To:** Agnew, Dianna[DAgnew@idem.IN.gov]  
**From:** DWBMGR  
**Sent:** Wed 6/12/2024 10:11:13 AM  
**Subject:** FW: Muncie (PWSID#5218012) 6/11/2024  
**Received:** Wed 6/12/2024 10:11:15 AM

Thank you,

**Roger Svendsen**

Indiana CMDP Administrator  
IDEM Drinking Water Branch  
100 N. Senate Ave. MC 66-34  
Indianapolis, IN 46204

Phone: 317-234-7455 Fax: 317-234-7455

**Routine** Drinking Water Test Results submitted to IDEM Drinking Water Branch can be viewed on-line by clicking the link below:  
<https://myweb.in.gov/IDEM/DWW/>

---

**From:** William C McCormick <William.McCormick@amwater.com>

**Sent:** Tuesday, June 11, 2024 2:48 PM

**To:** Chappell, Carolyn C <CCHAPPEL@idem.IN.gov>; Wade M Amos <Wade.Amos@amwater.com>; Christina L Gosnell <Christina.Gosnell@amwater.com>; Delaware Co - Jammie Bane <jbane@co.delaware.in.us>; twhite@co.delaware.in.us; DWBMGR <DWBMGR@idem.IN.gov>; James H Henderson <James.Henderson@amwater.com>; Daniel E Allen <Daniel.Allen@amwater.com>; Chris L Daniel <Chris.Daniel@amwater.com>; Joel Reuter <Joel.Reuter@amwater.com>; Anthony Cravens <Anthony.Cravens@amwater.com>

**Subject:** Muncie (PWSID#5218012) 6/11/2024

\*\*\*\* This is an EXTERNAL email. Exercise caution. DO NOT open attachments or click links from unknown senders or unexpected email. \*\*\*\*

---

Boil water advisory issued June 11th, 2024 @ 12:00 PM  
SYSTEM: INDIANA - AMERICAN WATER COMPANY - Muncie  
PWSID: 5218012  
Residential Customers Affected: 26  
Restaurants Affected: 0  
Commercial Customers Affected (no food service): 0  
Area Affected: W Elsie from N Linden to N Virginia: N Virginia from W Dunn to W Haines  
Cause: Service Replacement  
Result: Water pressure less than 20 psi for approximately 20 Min  
BWA Cancellation: June 12th, 2024 @ 12:20 PM

Will McCormick  
Operations Superintendent  
Indiana American Water  
1420 S Burlington Dr  
Muncie IN 47304

Office – 765-881-7053  
Cell – 765-730-4626  
e-mail [William.McCormick@amwater.com](mailto:William.McCormick@amwater.com)

This email and any files transmitted with it are confidential and intended solely for the use of the individual or entity to whom they are addressed. If you have received this email in error, please notify the sender. Please note that any views or opinions presented in this email are solely those of the author and do not necessarily

represent those of American Water Works Company Inc. or its affiliates. The recipient should check this email and any attachments for the presence of viruses. American Water accepts no liability for any damage caused by any virus transmitted by this email. American Water Works Company Inc., 1 Water St. Camden, NJ. 08102  
[www.amwater.com](http://www.amwater.com)