

To: Agnew, Dianna[DAgnew@idem.IN.gov]
From: DWBMGR
Sent: Wed 6/12/2024 10:11:12 AM
Subject: FW: Boil Water Advisory
Received: Wed 6/12/2024 10:11:15 AM

Thank you,

Roger Svendsen

Indiana CMDP Administrator
IDEM Drinking Water Branch
100 N. Senate Ave. MC 66-34
Indianapolis, IN 46204

Phone: 317-234-7455 Fax: 317-234-7455

Routine Drinking Water Test Results submitted to IDEM Drinking Water Branch can be viewed on-line by clicking the link below:
<https://myweb.in.gov/IDEM/DWW/>

From: Tyler W Nevill <Tyler.Nevill@amwater.com>

Sent: Tuesday, June 11, 2024 3:01 PM

To: Christina L Gosnell <Christina.Gosnell@amwater.com>; Wade M Amos <Wade.Amos@amwater.com>; David A Baker <D.Baker@amwater.com>; Doug Foli <Doug.Foli@amwater.com>; Kimberly A Brown <Kimberly.Brown@amwater.com>; DWBMGR <DWBMGR@idem.IN.gov>; Joni Wise <joni.wise@vigocounty.in.gov>

Subject: Boil Water Advisory

****** This is an EXTERNAL email. Exercise caution. DO NOT open attachments or click links from unknown senders or unexpected email. ******

The Terre Haute system (PWSID 5284012) issued a boil water advisory due to installing a new hydrant. The affected customers were notified to boil water for drinking, cooking and/or oral hygiene purposes. Sample analyses were underway at the Terre Haute laboratory M-84-01 using either Colilert-18 or Colilert media.

BWA issued: 6/11/24 @ 1000

Indiana American Water - Terre Haute – PWSID 5284012

Residential customers affected: 19

Commercial customers affected: 0

Area affected: On S Gilchrist St including S Ravine St

Reason: Installing new hydrant

Result: Pressure below 20 psi

BWA Cancellation: 6/12/24 @ 1200 or unless otherwise notified

Tyler Nevill

Supervisor – Water Quality and Environmental Compliance

Indiana American Water Company, Inc.

Western Indiana Operations

51 Locust St.

Terre Haute, IN 47807

C: 812-208-8253

Tyler.Nevill@amwater.com

This email and any files transmitted with it are confidential and intended solely for the use of the individual or entity to whom they are addressed. If you have received this email in error, please notify the sender. Please note that any views or opinions presented in this email are solely those of the author and do not necessarily represent those of American Water Works Company Inc. or its affiliates. The recipient should check this email and any attachments for the presence of viruses. American Water accepts no liability for any damage caused

by any virus transmitted by this email. American Water Works Company Inc., 1 Water St. Camden, NJ. 08102
www.amwater.com