

**To:** Agnew, Dianna[DAgnew@idem.IN.gov]  
**From:** DWBMGR  
**Sent:** Tue 6/11/2024 2:58:10 PM  
**Subject:** FW: Boil Water Advisory  
**Received:** Tue 6/11/2024 2:58:13 PM

Thank you,

***Roger Svendsen***

Indiana CMDP Administrator  
IDEM Drinking Water Branch  
100 N. Senate Ave. MC 66-34  
Indianapolis, IN 46204

Phone: 317-234-7455 Fax: 317-234-7455

**Routine** Drinking Water Test Results submitted to IDEM Drinking Water Branch can be viewed on-line by clicking the link below:  
<https://myweb.in.gov/IDEM/DWW/>

---

**From:** Tyler W Nevill <Tyler.Nevill@amwater.com>  
**Sent:** Tuesday, June 11, 2024 10:12 AM  
**To:** Christina L Gosnell <Christina.Gosnell@amwater.com>; Wade M Amos <Wade.Amos@amwater.com>; David A Baker <D.Baker@amwater.com>; Doug Foli <Doug.Foli@amwater.com>; Kimberly A Brown <Kimberly.Brown@amwater.com>; DWBMGR <DWBMGR@idem.IN.gov>; healthadministrator <healthadministrator@sullivancounty.in.gov>  
**Subject:** Boil Water Advisory

**\*\*\*\* This is an EXTERNAL email. Exercise caution. DO NOT open attachments or click links from unknown senders or unexpected email. \*\*\*\***

The Sullivan system (PWSID 5277009) issued a boil water advisory due to a main break. The affected customers were notified to boil water for drinking, cooking and/or oral hygiene purposes. Sample analyses were underway at the Terre Haute laboratory M-84-01 using either Colilert-18 or Colilert media.

BWA issued: 6/10/24 @ 1330  
Indiana American Water – Sullivan – PWSID 5277009  
Residential Customers affected: 34  
Commercial customers affected: 1  
Area affected: On Marion St, including S State St north to East Harris St  
Reason: Main Break  
Result: water pressure < 20psi  
**BWA cancellation: 6/11/24 @ 1530 or unless otherwise notified**

**Tyler Nevill**  
Supervisor – Water Quality and Environmental Compliance  
**Indiana American Water Company, Inc.**  
Western Indiana Operations  
51 Locust St.  
Terre Haute, IN 47807  
C: 812-208-8253  
[Tyler.Nevill@amwater.com](mailto:Tyler.Nevill@amwater.com)

This email and any files transmitted with it are confidential and intended solely for the use of the individual or entity to whom they are addressed. If you have received this email in error, please notify the sender. Please note that any views or opinions presented in this email are solely those of the author and do not necessarily

represent those of American Water Works Company Inc. or its affiliates. The recipient should check this email and any attachments for the presence of viruses. American Water accepts no liability for any damage caused by any virus transmitted by this email. American Water Works Company Inc., 1 Water St. Camden, NJ. 08102  
[www.amwater.com](http://www.amwater.com)