To: Agnew, Dianna[DAgnew@idem.IN.gov]

From: DWBMGR

Sent: Tue 6/11/2024 1:42:26 PM

Subject: FW: Outage Notification Over 8 Hours - IN5249004 Citizens Water Indianapolis - 5236 N. Arlington Avenue, Indianapolis

Received: Tue 6/11/2024 1:42:31 PM

Thank you,

Roger Svendsen

Indiana CMDP Administrator IDEM Drinking Water Branch 100 N. Senate Ave. MC 66-34 Indianapolis, IN 46204

Phone: 317-234-7455 Fax: 317-234-7455

Routine Drinking Water Test Results submitted to IDEM Drinking Water Branch can be viewed on-line by clicking the link below:

https://myweb.in.gov/IDEM/DWW/

From: Carlson, Cheryl <CCarlson@citizensenergygroup.com>

Sent: Tuesday, June 11, 2024 9:40 AM

To: DWBMGR <DWBMGR@idem.IN.gov>; Decastro, Sandra <SDECASTR@idem.IN.gov>; TERNIEDEN, LUCIO

<LTERNIED@idem.IN.gov>

Cc: Davenport, Kelly <KDavenport@citizensenergygroup.com>; Maxwell, Kari <KMaxwell@citizensenergygroup.com>

Subject: RE: Outage Notification Over 8 Hours - IN5249004 Citizens Water Indianapolis - 5236 N. Arlington Avenue, Indianapolis

**** This is an EXTERNAL email. Exercise caution. DO NOT open attachments or click links from unknown senders or unexpected email. ****

The sample was negative.

From: Carlson, Cheryl < CCarlson@citizensenergygroup.com >

Sent: Friday, June 7, 2024 11:05 AM

To: dwbmgr@idem.IN.gov; Decastro, Sandra SDECASTR@idem.IN.gov; TERNIEDEN, LUCIO letrnied@idem.in.gov>
Cc: Davenport, Kelly KDavenport@citizensenergygroup.com; Maxwell, Kari KDavenport@citizensenergygroup.com>

Subject: Outage Notification Over 8 Hours - IN5249004 Citizens Water Indianapolis - 5236 N. Arlington Avenue, Indianapolis

All,

A main repair at approximately 5236 N. Arlington Avenue, Indianapolis, resulted in an outage greater than 8 hours. The outage was within the Indianapolis system (IN5249004). The outage began on Thursday, June 6, 2024, at 10:50 a.m. and lasted until Friday, June 7, 2024, at 12:57 a.m.

Approximately 12 services were impacted by the outage. At the time of sample collection, chlorine was 1.75 mg/L and turbidity was 0.36 NTU. Sampling already occurred this morning.

If you have any questions or need additional information, please let me know.

Thank you.

Cheryl

Cheryl Carlson

Manager, Environmental Compliance 2020 N. Meridian Street

Indianapolis, IN 46202

O:(317)429-3569 | C:(317)213-2044

ccarlson@citizensenergygroup.com

