

To: Agnew, Dianna[DAgnew@idem.IN.gov]
From: DWBMGR
Sent: Mon 6/10/2024 10:12:39 AM
Subject: FW: Muncie (PWSID#5218012) 6/7/2024
Received: Mon 6/10/2024 10:12:42 AM

Thank you,

Roger Svendsen

Indiana CMDP Administrator
IDEM Drinking Water Branch
100 N. Senate Ave. MC 66-34
Indianapolis, IN 46204

Phone: 317-234-7455 Fax: 317-234-7455

Routine Drinking Water Test Results submitted to IDEM Drinking Water Branch can be viewed on-line by clicking the link below:
<https://myweb.in.gov/IDEM/DWW/>

From: William C McCormick <William.McCormick@amwater.com>

Sent: Friday, June 7, 2024 5:43 PM

To: Chappell, Carolyn C <CCHAPPEL@idem.IN.gov>; Anthony Cravens <Anthony.Cravens@amwater.com>; Wade M Amos <Wade.Amos@amwater.com>; Christina L Gosnell <Christina.Gosnell@amwater.com>; Delaware Co - Jammie Bane <jbane@co.delaware.in.us>; twhite@co.delaware.in.us; DWBMGR <DWBMGR@idem.IN.gov>; James H Henderson <James.Henderson@amwater.com>; Daniel E Allen <Daniel.Allen@amwater.com>; Chris L Daniel <Chris.Daniel@amwater.com>; Joel Reuter <Joel.Reuter@amwater.com>

Subject: Muncie (PWSID#5218012) 6/7/2024

****** This is an EXTERNAL email. Exercise caution. DO NOT open attachments or click links from unknown senders or unexpected email. ******

Boil water advisory issued June 7th, 2024 @ 11:30 AM
SYSTEM: INDIANA - AMERICAN WATER COMPANY - Muncie
PWSID: 5218012
Residential Customers Affected: 12
Restaurants Affected: 0
Commercial Customers Affected: 0
Area Affected: E Butler from N Macedonia to N Wolfe
Cause: Main Break
Result: Water pressure less than 20 psi for approximately 5 Hrs 45 Min
BWA Cancellation: June 8th, 2024 @ 5:15 PM

Will McCormick
Operations Superintendent
Indiana American Water
1420 S Burlington Dr
Muncie IN 47304

Office – 765-881-7053
Cell – 765-730-4626
e-mail William.McCormick@amwater.com

This email and any files transmitted with it are confidential and intended solely for the use of the individual or entity to whom they are addressed. If you have received this email in error, please notify the sender. Please note that any views or opinions presented in this email are solely those of the author and do not necessarily

represent those of American Water Works Company Inc. or its affiliates. The recipient should check this email and any attachments for the presence of viruses. American Water accepts no liability for any damage caused by any virus transmitted by this email. American Water Works Company Inc., 1 Water St. Camden, NJ. 08102
www.amwater.com