

To: Agnew, Dianna[DAgnew@idem.IN.gov]
From: DWBMGR
Sent: Fri 6/7/2024 3:06:29 PM
Subject: FW: Outage Notification Over 8 Hours - IN5249004 Citizens Water Indianapolis - 5236 N. Arlington Avenue, Indianapolis
Received: Fri 6/7/2024 3:06:32 PM

Thank you,

Roger Svendsen

Indiana CMDP Administrator
IDEM Drinking Water Branch
100 N. Senate Ave. MC 66-34
Indianapolis, IN 46204

Phone: 317-234-7455 Fax: 317-234-7455

Routine Drinking Water Test Results submitted to IDEM Drinking Water Branch can be viewed on-line by clicking the link below:
<https://myweb.in.gov/IDEM/DWWW/>

From: Carlson, Cheryl <CCarlson@citizensenergygroup.com>
Sent: Friday, June 7, 2024 11:05 AM
To: DWBMGR <DWBMGR@idem.IN.gov>; Decastro, Sandra <SDECASTR@idem.IN.gov>; TERNIEDEN, LUCIO <LTERNIED@idem.IN.gov>
Cc: Davenport, Kelly <KDavenport@citizensenergygroup.com>; Maxwell, Kari <KMaxwell@citizensenergygroup.com>
Subject: Outage Notification Over 8 Hours - IN5249004 Citizens Water Indianapolis - 5236 N. Arlington Avenue, Indianapolis

****** This is an EXTERNAL email. Exercise caution. DO NOT open attachments or click links from unknown senders or unexpected email. ******

All,

A main repair at approximately 5236 N. Arlington Avenue, Indianapolis, resulted in an outage greater than 8 hours. The outage was within the Indianapolis system (IN5249004). The outage began on Thursday, June 6, 2024, at 10:50 a.m. and lasted until Friday, June 7, 2024, at 12:57 a.m.

Approximately 12 services were impacted by the outage. At the time of sample collection, chlorine was 1.75 mg/L and turbidity was 0.36 NTU. Sampling already occurred this morning.

If you have any questions or need additional information, please let me know.

Thank you.

Cheryl

Cheryl Carlson
Manager, Environmental Compliance
2020 N. Meridian Street
Indianapolis, IN 46202

O:(317)429-3569 | C:(317)213-2044

ccarlson@citizensenergygroup.com



