

# MONTHLY REPORT OF OPERATION WATER TREATMENT PLANT

Report for Town of Campbellsburg In  
poe 2 south plant

for the Month of Mar-24

IDEM Field Rep. E Book

Signed Ch B...

Title Superintendent

Public Water Supply ID No. 5288001

Certification Number 57892

I certify, under penalty of law, by this signature that this document was prepared by me, or under my direction, and the information submitted is to the best of my knowledge and belief, true, accurate and complete. **I am also aware that there are significant penalties for submitting false information.**

### PHYSICAL AND CHEMICAL DATA \*

Date	Turbidity		Alkalinity		pH		Hardness		Iron		Manganese		Phos.	Fluoride	
	Raw	Finished	Raw	Finished	Raw	Finished	Raw	Finished	Raw	Finish	Raw	Finished	Finished	Finished	
1															
2															
3															
4															
5										0.01	0.005	0.01	0.005		
6															
7															
8															
9															
10															
11															
12										0.01	0.005	0.01	0.007		
13															
14															
15															
16															
17															
18															
19										0.01	0.006	0.01	0.008		
20															
21															
22															
23															
24															
25															
26										0.01	0.005	0.01	0.008		
27															
28															
29															
30															
31															
<b>Ave.</b>							#DIV/0!	#DIV/0!			0.010	0.005	0.0	0.0	

\* All parameters are expressed in mg/l, except pH and turbidity

1754

March

Date	Water Treated 1000 gallons	Chemicals Used – Pounds								Filters		Chlorine Residual				Remarks	
		Salt	Alum	Lime	Soda Ash	Carbon	Chlorine	Fluoride	Phosphate	Filter Run (hours)	Gallons per wash x 1000	Plant Tap		D. S.			
												Free	Total	Free	Total		
1	49								.32			1.65	1.71	1.55	1.64		
2	63								.36			1.56	1.65	1.50	1.59		
3	53								.32			1.60	1.67	1.44	1.51		
4	62								.36	3.5		1.51	1.58	1.40	1.48		
5	59								.21			1.49	1.54	1.42	1.51		
6	55								.26			1.49	1.57	1.47	1.55		
7	62								.21	3.5		1.45	1.57	1.50	1.60		
8	53								.23			1.38	1.45	1.60	1.64		
9	52								.25			1.45	1.50	1.51	1.60		
10	66								.25			1.48	1.55	1.45	1.51		
11	60								.32	3.5		1.31	1.38	1.44	1.53		
12	56								.31			1.50	1.58	1.47	1.55		
13	64								.36			1.65	1.71	1.59	1.66		
14	68								.31	3.5		1.67	1.75	1.57	1.64		
15	46								.36			1.50	1.57	1.49	1.54		
16	59								.31			1.53	1.59	1.42	1.50		
17	56								.36			1.47	1.53	1.38	1.44		
18	52								.32	3.5		1.55	1.59	1.50	1.38		
19	62								.36			1.45	1.50	1.32	1.40		
20	62								.31			1.43	1.50	1.30	1.36		
21	51								.31	3.5		1.45	1.49	1.35	1.42	Monthly Water Treatment	
22	54								.32			1.36	1.41	1.38	1.46	Total Gallons	1,754
23	53								.21			1.39	1.47	1.33	1.44	Max. Day	68
24	59								.29			1.29	1.36	1.34	1.46	Min. Day	46
25	56								.26	3.5		1.30	1.37	1.34	1.47	Avg. Daily	57
26	55								.21			1.28	1.33	1.29	1.36	E-Mail To: DWBMRO@idem.in.gov	
27	57								.21			1.25	1.31	1.33	1.40	Mail To: Indiana Department of Environmental Management	
28	51								.26	3.5		1.33	1.40	1.30	1.26	Drinking Water Branch 100 N. Senate Ave. Room N1201 Indianapolis, IN 46204-2237	
29	54								.21			1.36	1.42	1.39	1.44		
30	57								.26			1.31	1.39	1.40	1.46		
31	49								.23			1.31	1.37	1.44	1.50		