



# Indiana Department of Environmental Management

## Emergency Response Incident Report

### Description

Incident # 113059

**Incident Description:** Recharging puddle in yard Hendricks County

**Incident Type:** Emergency Response-Other

**Occurred Date/Time:** 06/22/2024 12:00 am

**Regulatory Program:** Emergency Response

**Incident Priority:** 3-Low

**Incident Status:** Closed

**Closure Method:** Emergency Response Complete

**Lead Investigator:** Mcbeth, Kevin

**Resolution Desc:** FIELD RESPONSE.

OSC Patterson requested pictures from homeowner but not received. Puddle in grass has persisted for a month and a half. Grass is growing in the puddle, OSC Patterson notified wastewater utility and Jason Palin. WW Hendricks County Regional Sewer headed out to check their line.

6/24/2024- Correspondence follow up with Hendricks County Regional Sewer, no answer to weekend check. They will look into it.

06/25/2024- Follow up with Hendricks County Regional Sewer, advised not a wastewater issues. They advised it is a water leak and advised homeowner to contact Citizens. OSC McBeth conducted field response, soil in area was saturated with water, contained a bio-sheen. Area appeared to be a water leak, and referred homeowner to contact Citizens.

No further action needed from IDEM ER at this time.

### Location

**Location Description:** 5610 Noble Drive  
Indianapolis  
Hendricks County

**County:** Hendricks

**Latitude DD:** 39.8462

**Longitude DD:** -86.3459

**Method:** Interpolation-Map

**System:** Lat.\Long - Decimal Degrees

**Datum:** NAD83

**Collected By:** IDEM Staff



# Indiana Department of Environmental Management Emergency Response Incident Report

## Source Entity

**Source Type:** Agency Interest

## Reporter

**Received By:** Patterson, Fawn

**Received Date/Time:** 06/24/2024 10:14:47 am

**Receipt Method:** Emergency Response Hotline

**Reporter Type:** Private Citizen

**Name:** Kwasi Clark

**Address 1:** 5610 Noble Dr.

**Municipality:** Indianapolis

**State:** IN

**Telecom:** Cellular phone number 1 901-361-6743

## Actions

Task	Staff Assigned	Start Date	Due Date	Completed Date	Hours Spent
Lead ER Staff	Mcbeth, Kevin			06/24/2024	
Comments: Received incident notification from OSC Patterson.					
Complete Emergency Response	Mcbeth, Kevin			06/25/2024	

Comments: Contacted Hendricks County Regional Sewer for check on possible wastewater leak. They advised it was not wastewater but a water leak and advised the homeowner to notify Citizens. OSC McBeth conducted a field response. Soil was saturated with water and visible sheen was biological. Advised homeowner to contact water utility company for a possible water leak. No further action needed from IDEM ER at this time.

Perform Initial Field Response	Mcbeth, Kevin			06/25/2024	
--------------------------------	---------------	--	--	------------	--

Comments: Performed field response. Soil in on the property line was heavily saturated and visible water pooling. Sheen observed on top of soil was biological, grass displayed heavy growth in the saturated area. Staining to sidewalk appeared to show a chronic issue of water leaking. No signs of oil and other pollutants, believed to be a water leak and advised homeowner to contact Citizens.