



**MONTHLY REPORT OF OPERATION  
WATER TREATMENT PLANT**



**Astbury Water Technology**  
Northeast Regional Office  
601 West 400 North  
Angola, IN 46703

System Name: **Laville JR. & SR. High School**

PWSID Number: **2710815**

For the Month of: **June** Year: **2024** Printed Name/Title: **Daniel Ringer - Operator**

Signed: **Daniel Ringer** Certification Number: **100207**

I certify **under penalty of law**, by this signature that this document was prepared by me, or under my direction, and the information submitted is to the best of my knowledge and belief, true, accurate, and complete. **I am also aware that there are significant penalties for submitting false information.**

IDEM Field Rep.: \_\_\_\_\_

Date	Meter Reading	Water Treated x1000 gallons	Chemicals Used				Chlorine Residual			
			Chlorine		Phosphate		Plant Tap		D.S.	
			INCHES USED	Gallon Used	INCHES USED	Gallon Used	FREE	TOTAL	FREE	TOTAL
1										
2										
3		6.2		0.5		0.36	2.45	1.76	0.30	0.24
4		3.1		0.4		0.24	1.86	1.32	0.18	0.20
5		3.3		0.1		0.15	2.19	2.22	0.08	0.18
6		4.8		0.4		0.29	1.24	1.36	0.04	0.15
7							1.96	2.09	0.19	0.24
8										
9		17.2		1.7		.36				
10		3.5		0.4		0.07	1.99	2.04	0.18	0.24
11		5.2		0.5		0.32	1.24	1.45	0.10	0.18
12		5.0		0.5		0.3	2.24	2.38	0.20	0.22
13		17.4		0.2		1.51	1.95	2.08	0.14	0.18
14							1.14	1.88	0.08	0.12
15										
16		53.9		4.6		1.81				
17		18.7		1.7		1.7	0.76	0.82	0.05	0.19
18		23.4		0.0		1.44	0.94	2.20	0.08	0.24
19		26.3		1.9		0.18	0.72	1.29	0.18	0.22
20		17.8		1.8		1.51	0.74	1.08	0.20	0.24
21							0.92	1.24	0.32	0.36
22										
23		68.1		3.4		0.21				
24		26.4		1.9		1.57	0.72	0.84	0.08	0.14
25		21.3		1.9		1.56	0.88	0.94	0.14	0.20
26		7.1		0.6		0.39	0.97	1.04	0.16	0.22
27		19.4		0.6		0.6	1.52	2.13	0.20	0.24
28							3.20	2.20	0.89	0.94
29										
30		49.0		4.5		10.08				
31										

MONTHLY WATER TREATMENT	
Total Gallons	397.10
Max. Day	68.10
Min. Day	3.10
Average Daily	19.86

Email To:  
[DWBMRO@idem.in.gov](mailto:DWBMRO@idem.in.gov)

Mail To:  
**IDEM Drinking Water Branch**  
100 N. Senate Ave. Room N1201  
Indianapolis, IN 46204-2237

