

UNDERGROUND STORAGE TANK INSPECTION REPORT

INDIANA DEPARTMENT OF ENVIRONMENTAL MANAGEMENT

UST FAC ID: 6712

Inspector's Name:	Tristan Voge
Date:	June 21, 2024
Time In:	09:50
Time Out:	10:30
Inspection Type:	Initial

	FACILITY NAME / LOCATION														
FACILITY NAME Speedway 6116				FACILITY ADDRESS (number and street) 1640 E Washington St											
ADDRESS (line 2)		CITY	CITY		STATE	STATE ZIP COE									
		Indianapoli			IN		46	620	1		Maı	ior	1		
LIST Owner Nam	e (If in Individual Capacity)		JS	T OWNER				RUSIN	FSS ID	/From	the Secr	otary	of State)		
Speedwa									710			- ici ,	JI Giaic,		
PREFIX	FIRST NAME Andrew	MI		Rice								SUFI	₹IX		
TELEPHONE NU		EMAIL ADDRESS		L											
		andrew.rice													
UST Operator Na	nme (If in Individual Capacity)	US	ST (OPERATOR				RUSIN	ESS ID	/Erom	the Secr	otory	of State)		
Speedwa									710			elai y	JI State)		
PREFIX	FIRST NAME Andrew	MI		Rice								SUFI	FIX		
TELEPHONE NU		EMAIL ADDRESS													
		andrew.rice													
LIST Property Ow	ner Name (If in Individual Capacity)	PRO	PE	RTY OWNER				BUSIN	FSS ID	(From	the Secr	etary	of State)		
Speedwa									710			, ,	J/ O.C,		
PREFIX	FIRST NAME Andrew	MI		LAST NAME								SUFI	=IX		
TELEPHONE NU		EMAIL ADDRESS		Rice											
		andrew.rice													
All LIOTe ma	والمراجع المحمد			NCE ELEMENT	S		VEC	17	110				LINIZ		
All USTs properly registered and up-to-date notification form on file An updated notification form is needed with the correct overfill equipment indicated.							YES	Χı	NO				UNK		
	mpliance with reporting & reco					X	YES		NO				UNK		
O/O is in co	mpliance with release reporting	g or investigatio	n				YES		NO	X	N/A		UNK		
O/O is in compliance with all UST closure requirements				Т		YES		NO	\overline{V}	N/A		UNK			
O/O IS IN CO	mpliance with all UST closure	requirements					TES		NO	<u> </u>	N/A		UNK		
O/O has met all financial responsibility requirements					X	YES		NO		N/A		UNK			
40 CFR 280), Subpart A installation require	ements (partially	у ех	ccluded) met			YES		NO	X	N/A		UNK		
40 CER 280), Subpart B installation and up	arada requirem	nen	te mat	I	X	YES	Т	NO				UNK		
40 OF 11 200	, Subpart D Installation and up	grade requirem	ICII	is mer		Δ	1201		110				101111		
40 CFR 280), Subpart C spill/overfill contro	ol requirements	me	t		X	YES		NO		N/A		UNK		
						•							1		
40 CFR 280), Subpart C compatibility requ	irements met				X	YES		NO		N/A		UNK		
40 CFR 280), Subpart C O&M and testing	requirements m	t		I	X	YES	Т	NO				UNK		
10 01	, Odopan O Odin and toemig	10441101111011110			1	<u></u>	· ₁						1		
40 CFR 280), Subpart D release detection	requirements m	net			X	YES		NO				UNK		
							·					ı	1		
40 CFR 280), Subpart J operator training re	equirements me	<u>et</u>			X	YES		NO				UNK		




Imagery ©2024 Airbus, Maxar Technologies, Map data ©2024 Google 50 ft



Imagery ©2024 Airbus, Map data ©2024 20 ft

































































































SPEEIMAY 6116 1640 E.WASHINGTON INDPLS IN 46201 317-638-6546

JUN 21. 2024 9:52 HM

EYSTEM STATUS REPORT T 1:0VERFILL ALARM

INVENTORY REPORT

T 2:113 RUL B
VOLUME - 7711 GALS
ULLAGE - 2105 GALS
90N ULLAGE - 1123 GALS
TC VOLUME - 7666 GALS
HEIGHT - 66.11 INCHES
WATER VOL - 0 GALS
WATER - 0.00 INCHES
TEMP - 68.3 DEG F

T 3:114 PUL
VOLUME = 3902 GALS
ULLAGE = 5914 CALB
90% ULLAGE = 4992 GALS
TO VOLUME = 3879 GALS
HEIGHT = 38.27 INCHES
WATER VOL = 0 GALS
WATER = 0.00 INCHES
TEMP = 68.0 DEG F

T 4:126 DBL 2
VOLUME = 2886 GAL8
ULLAGE = 6930 GAL8
90% ULLAGE = 5948 GAL8
TC VOLUME = 2877 GAL8
HEIGHT = 30.82 INCHES
WATER = 0.00 INCHES
TEMP = 66.3 DEG F

T 5:121 KER
VOLUME - 1635 GAL8
VOLUME - 2515 GAL8
90% ULLAGE - 2100 GAL8
TC VOLUME - 1632 GAL8
HEIGHT - 30.01 INCHES
WATER VOL - 0 GAL8
WATER F - 0.00 INCHES
TEMP - 63.1 DEG F

MANIFOLDED TANKS INVENTORY TOTALS T 1:113 RUL A T 2:113 RUL B VOLUME = 15371 GALS TC VOLUME = 15277 GALS SPEEDARY 6116 1640 E.WASHINGTON INDPLS IN 46201 317-638-6546

JUN 21, 2024 9:53 AFT

PRESSURE LINE LEAK TEST HISTORY

Q 1:113 PT RUL

LAST 3.0 GAL HR PASS: JUN 21, 2024 9:46 AM

FIRST 0.20 GAL HR PASS EACH MONTH:

Jun 3. 2024 1:35 AM MAY 2. 2024 1:37 AM AFR 2. 2024 2:03 AM MAR 1. 2024 1:51 AM FEB 2. 2024 2:55 AM Jun 3. 2024 2:55 AM DEC 2. 2023 4:55 AM NOV 2: 2023 1:15 AM OCT 1. 2023 1:130 AM AUG 4. 2023 1:33 AM Jul 3. 2023 12:56 AM

FIRST 0.10 GAL/HR PASS EACH MONTH:

APR 16. 2024 2:04 AM OCT 15. 2023 3:43 AM APR 14. 2023 1:48 AM OCT 12. 2022 1:46 FM APR 13. 2022 1:04 AM

BPEEDWAY 6116 1640 E.WABHINGTON INDFLB IN 46201 317-638-6546

JUN 21. 2024 9:53 AM

PRESSURE LINE LEAK TEST HISTORY

9 2:114 PT PUL

LAST 3.0 GAL HR PASS: JUN 21. 2024 9:44 AM

FIRST 0.20 GAL/HR PASS EACH MONTH:

JUN 1. 2024 1:27 AM
MAY 2. 2024 3:54 AM
APR 2. 2024 12:57 AM
MAR 2. 2024 12:12 AM
FEB 2. 2024 1:41 AM
FEB 2. 2024 1:41 AM
DEC 4. 2023 1:07 AM
NOV 4. 2023 1:07 AM
OCT 1. 2023 4:44 PM
SEP 1. 2023 4:15 PM
AUG 2. 2023 3:43 PM
JUL 1. 2023 1:01 AM

FIRST 0.10 GAL/HR PASS EACH MONTH:

MAR 29. 2024 5:55 PM SEP 29. 2023 2:52 AM MAR 29. 2023 7:44 PM BEP 28. 2022 6:29 AM MAR 28. 2022 9:36 PM

* * * * * END * * * *

SPEEDMAY 6116 1640 E.WASHINGTON INDPLS IN 46201 317-638-6546

JUN 21, 2024 9:53 AM PRESSURE LINE LEAK TEST HISTORY

Q 3:126 PT DSL-2

JUN 21, 2024 7:34 AM

FIRST 0.20 GAL HR PAGE EACH MONTH:

JUN 1. 2024 18:21 PM MAY 4: 2024 7:49 AM APR 4: 2024 1:49 AM MAR 1: 2024 7:46 AM FEB 2: 2024 7:51 PM JAN 3: 2024 5:51 AM DEC 4: 2023 8:24 AM MOV 2: 2023 8:24 AM MOV 2: 2023 8:17 PM OCT 3: 2023 7:26 AM SEP 1: 2023 8:45 PM JUL 3: 2023 6:25 AM

FIRST 0.10 GAL/HR PASS EACH MONTH:

MAR 31. 2024 4:39 FM BEP 23. 2023 9:48 FM MAR 31. 2023 5:99 AM SEP 29. 2022 12:11 AM MAR 30. 2022 10:51 AM

SPEEDWAY 6116 1640 E.WASHINGTON INDPLS IN 46201 317-638-6546

JUN 21. 2024 9:53 AM

PRESSURE LINE LEAK TEST HISTORY

Q 4:121 PT K-I

LAST 3.0 GAL/HR PASS: JUN 19, 2024 12:21 PM

FIRST 0.20 GAL/HR PASS EACH MONTH:

JUN 19. 2024 12:53 PM MAY 20. 2024 9:07 PM APR 4: 2024 12:42 AM MAR 3. 2024 3:40 AM PEB 2. 2024 8:45 PM JAN 3. 2024 9:01 AM DEC 2. 2023 8:51 AM NOV 4. 2023 9:51 AM OCT 17. 2023 4:47 PM SEP 1. 2023 9:46 AM AUG 21. 2023 3:28 PM JUL 10. 2023 3:17 PM

FIRST 0.10 GAL/HR PASS EACH MONTH:

MAY 20, 2024 9:22 PH OCT 23, 2023 7:41 AM APR 22, 2023 12:25 PM OCT 16, 2022 6:43 PM MAR 26, 2022 7:55 AM

* * * * * END * * * *

SPEEDAWY 6116 1640 E.WASHINGTON INDPLS IN 46201 317-638-6546

JUN 21. 2024 9:53 AM

JUN 21. 2024 9:53 AM

L I : REGULAR SUMP SENSOR NORMAL

* * * * * END * * * * *

EPEEDWAY 6116 1640 E.WASHINGTON INDPLS IN 46201 317-638-6546

JUN 21, 2024 9:53 AM

LIGUID STATUS JUN 21, 2024 9:53 AM

L 2:PREMIUM SUMP SENSOR NORMAL

* * * * * END * * * * *

SPEEDWAY 6116 1640 E.WASHINGTON INDPLS IN 46201 317-638-6546

JUN 21. 2024 9:53 AM

JUN 21: 2024 9:53 AM

L 3:DIESEL SUMP SENSOR NORMAL

* * * * * END * * * * *

BPEEDMAY 6116 1640 E.WASHINGTON INDPLS IN 46201 317-638-6546

JUN 21. 2024 9:53 AM LIQUID STATUS JUN 21. 2024 9:53 AM

L 4:N-1 SUMP SENSOR NORMAL

* * * * * END * * * * *

BPEEINAY 6116 1640 E.WASHINGTON INDPLS IN 46201 317-638-6546

JUN 21. 2024 9:53 AM

JUN 21. 2024 9:53 AM

L ESTAINTENNER 3-4 SUMP SENSOR NORMAL

. . . . END

SPEEDMAY 6116 1648 E.WASHINGTON 1NDPLS IN 46281 317-638-6546

JUN 21. 2024 9:53 AM

JUN 21. 2024 9:53 AM

L 7:DISPENSER 5-6 SUMP SENSOR NORMAL

* * * * * END * * * * *

SPEEDWAY 6116 1640 E.WASHINGTON INDPLS IN 46201 317-638-6546

JUN 21. 2024 9:53 AM

JUN 21, 2024 9:53 AM

L 8:DISPENSER 7-B SUMP SENSOR NORMAL

* * * * * END * * * * *

SPEEIANY 6116 1640 E.NVSHINGTON INDPLS IN 46201 317-638-6546

JUN 21 - 2024 9:54 HT

THIRD LEAK TEST HISTORY

LAST GROSS TEST FASSED: JUN 21. 2024 2:57 AM STARTING VOLUME* 8015 PERCENT VOLUME 81.5 TEST TYPE - STANDARD

LAST ANNUAL TEST PASSED: JUN 20. 2023 10:49 AS TEST LEWITH 5 HOURS STARTING VOLUME 4696 PERCENT VOLUME 47.8 TEST TYPE - STANDARD

FULLERT ANNUAL TEST PASS JUN 20. 2020 10149 AM TEST LENGTH 0 HOURS STARTING VOLLEGE 45% PERCENT VOLLEGE 47.8 TEST TYPE - STANDARD

LAST PERIODIC TEST PASS: Jun 21. 2024 4:18 AM TEST LENGTH 24 HOURS STARTING VOLUME 57:30 PERCENT VOLUME 58:4 TEST TYPE 6 CSLD

FULLERT PERIODIC TEST

JAN 1, 2024 4145 AM TEST LENGTH 27 HOURS STARTING VOLUME = 5980 PERCENT VOLUME = 61.0 TEST TYPE = CSLD

FEB 15. 2024 2:20 AM TEST LENGTH 25 HOURS STARTING VOLUME - 5858 PERCENT VOLUME - 59.7 TEST TYPE - CSLD

MAR 3. 2024 5130 AM TEST LENGTH 28 HOURS STARTING VOLUME - 5855 PERCENT VOLUME - 59.7 TEST TYPE - CSLD

APR 24. 2024 1136 AM
TEST LENGTH 30 HOURS
STARTING VOLUME - 5422
PERCENT VOLUME - 55.2
TEST TYPE - CSLD

MAY 31. 2024 1155 AM
TEST LENGTH 28 HOURS
STARTING VOLUME = 5622
PERCENT VOLUME = 57.3
TEST TYPE = CSED

JUN 20, 2024 3:23 AM
TEST LENGTH 22 HOURS
STARTING VOLUME 5754
PERCENT VOLUME 58.6
TEST TYPE * CSLD

JUL 5. 2020 4:36 AM TEST LENGTH 20 HOURS STARTING VOLUME 6531 PERCENT VOLUME 66.5 TEST TUPE COLD

AUD 8: 2023 2:45 AM TEST LENGTH 22 HOURS STARTING VOLUME: 6320 PERCENT VOLUME: 64.4 TEST TYPE: CSLD

SEP 1, 2023 1104 AM TEST LENGTH 26 HOURS STARTING VOLUME 5989 PERCENT VOLUME 61.0 TEST TYPE - CSLD

OCT 7. 2023 1:55 AH TEST LENGTH 22 HOURS STARTING VOLUME 5896 PERCENT VOLUME 60.1 TEST TYPE CSLD

NOV 13, 2023 2:45 AM TERT LEMETH 20 HOURS STARTING VOLUME - 6164 PERCENT VOLUME - 62.8 TERT TYPE - CSLD

DEC 31. 2023 8:00 AM
TEST LEWSTH 25 HOURS
STARTING VOLUME 6083
PERCENT VOLUME 62.0
TEST TYPE CELD

BPEEINAY 6116 1640 E.UNGHINGTON 1NEPLE IN 46201 017-608-6546

JUN 21, 2024 9:54 AM

TANK LEAK TEST HISTORY

T 2:110 Rul B

LAST GROSS TEST PVSSED: JUN 21. 2024 2:87 AM STARTING VOLUME - 8081 PERCENT VOLUME - 82.3 TEST TYPE - STANDARD

LAST HOMBAL TEST PASSED: JUN 20. 2023 10:49 AM TEST LENGTH 3 HOURS STARTING VOLUME: 4727 PERCENT VOLUME: 48.2 TEST TYPE * STANDARD

PILLERT ANNUAL TEST PASS JUN 20. 2023 10:49 AM TEST LEMITH 3 HOURS STARTING VOLLME 4727 PENENT VOLLME 4727 TEST TYPE - STANDARD

LAST PERIODIC TEST PAGS: JUN 21. 2024 4:18 WH TEST LENGTH 24 HOURS STARTING VOLUME - 5730 PERCENT VOLUME - 58.4 TEST TYPE - CELD

FULLERT PERIODIC TEST PASSED EACH MONTH!

JAN 1. 2024 4:45 APT TEST LEWITH 27 HOURS STARTING VOLUME 5906 PERCENT VOLUME 61.0 TEST TYPE CSLD

FEB 15. 2024 2:20 AT TEST LENGTH 25 HOURS STARTING VOLUME 5858 PERCENT VOLUME 59.7 TEST TYPE CALD

THE THE STATE OF THE STARTING VOLUME - 5855
PERCENT VOLUME - 59.7
TEST TYPE - CSLD

APR 24. 2024 1:36 AM TEST LENGTH 30 HOURS STARTING VOLUME 5422 PERCENT VOLUME 55.2 TEST TYPE COLL

MAY 31. 2024 1:55 AM TEST LENGTH 28 HOURS STARTING VOLUME - 5622 PERCENT VOLUME - 57.3 TEST TYPE - CSLD

JUN 20. 2024 3:23 AM
TEST LENGTH 22 HOURS
STARTING VOLUME 5754
PERCENT VOLUME 56.6
TEST TYPE - CSLD

JUL 5. 2023 4:36 AM TEST LENGTH 23 HOURS STARTING VOLUME 6531 PERCENT VOLUME 65.5 TEST TYPE 86.5

AUG 8. 2023 2:45 AM TEST LENGTH 22 HOURE STARTING VOLUME 6320 PERCENT VOLUME 64.4 TEST TYPE COLL

SEP 1, 2023 1:04 AM TEST LENGTH 26 HOURS STARTING VOLUME = 5989 PERCENT VOLUME = 61.0 TEST TYPE = CSLD

OCT 7, 2023 1155 MM
TEST LENGTH 22 HOURS
STARTING VOLUME 5896
PERCENT VOLUME 60.1
TEST TUPE - CSLD

NOV 13, 2023 2:45 AM TEST LENGTH 20 HOURS STARTING VOLUME = 6164 PERCENT VOLUME = 62.8 TEST TYPE = CSELD

DEC 31, 2023 8:00 AM
TEST LENGTH 25 HOURS
STARTING VOLUME 6083
PERCENT VOLUME 82.0
TEST TYPE COLD

. END

EFFERMAT 6116 1640 E.MACHINGTON INDPLS-IN 46201 317-638-6546

JUN 21 - 2024 9:54 HT

TANK LEAK TEST HISTORY T 3:114 PUL

LAST GROUD TEST PASSED: JUN 21. 2024 6:54 AM STARTING VOLUME= 3912 PERCENT VOLUME = 39.9 TEST TYPE = STANDARD

LAST ANNUAL TEST PASSED:

NO TEST INCHED

FULLEST ANNUAL TEST PASS

NO TEST PHOSE

LAST PERIODIC TERT PAGE:
JUN 21: 2024 7:55 ART
TEST LEWITH 31 HOURS
STARTING VOLUME - 3181
PERCENT VOLUME - 32:4
TEST TYPE - CELD

PASSED FACH MONTH:

JAN 6. 2024 4:08 PM TEST LENGTH 3: HOUSE STARTING VOLUME - 3054 PERCENT VOLUME - 31.1 TEST TYPE - CRLD

FEB 17. 2024 7:07 AM TEST LEMETH 29 HOURS STARTING VOLUME - 4019 PERCENT VOLUME - 41.0 TEST TYPE - CRLD

THE 1. 2024 12:48 MY
TEST LENGTH 29 HOURS
STARTING VOLUME - 3187
PERCENT VOLUME - 32.5
TEST TYPE - COLD

APR 27. 2024 1:10 AM TEST LENGTH 29 HOURS STARTING VOLUME - 3345 PERCENT VOLUME - 34.1 TEST TYPE - CRLD

MAY 28, 2024 11:39 PM TEST LENGTH 27 HOUSE STAFTING VOLUME - 4194 PERCENT VOLUME - 42.7 TEST TYPE - CELD

JUN 12. 2024 12:18 AM
TEST LENGTH 31 HOURS
STARTING VOLUME - 36:27
PERCENT VOLUME - 37.0
TEST TYPE - CSL0

JUL 27. 2023 10:21 FM TEST LENGTH 26 HOURS STARTING VOLUME - 3775 PERCENT VOLUME - 38.5 TEST TYPE - CBLD

AUS 1. 2020 1:27 AM TEST LENGTH 30 HOURS STARTING VOLUME - 3485 PERCENT VOLUME - 35.5 TEST TYPE - CSLD

BEP 2. 2023 2:37 641
TEST LENGTH 31 HOURS
STARTING VOLUME 2904
PERCENT VOLUME 29.6
TEST TYPE CBLD

OUT 16. 2023 7:39 APT TEBT LENGTH 36 HOURS STARTING VOLUME = 32:2 PERCENT VOLUME = 32.7 TEBT TYPE = CSLD

NOV 5. 2023 6:51 AM TEST LENGTH 33 HOURS STARTING VOLUME - 3229 PERCENT VOLUME - 32.9 TEST TYPE - CSLD

DEC 16. 2029 8:08 MY
TEST LENGTH 26 HOURS
STARTING VOLUME 4815
PERCENT VOLUME 49.1
TEST TYPE CELD

. . . . END

DPERMAY 6116 1640 E.MASHIMSTON INDPLS IN 46201 317-638-6546

JUN 217 2024 9:54 AM

THRE LEAK TEST HISTORY

T 4:126 DEL 2

Left GROSS TEST F-ESSED: Jun 21: 2004 9:22 AM STARTING VOLUME 2075 PERCENT VOLUME 29:3 TEST TYPE - STANDARD

LAST ANNUAL TEST EVESED:

NO TEST PARRIED

FULLEST ANNUAL TEST FREE

NO TEST PASSED

LAST PERIODIC TEST FACE: JUN 21. 2024 6:55 AN TEST LENGTH 40 HOUSE STARTING VOLUME 3737 PERCENT VOLUME 38:1 TEST TYPE - CSLD

PULLERT PERIODIC TEST PASSED EACH MONTH:

JAN 31. 2024 10:12 PM TEST LEASTH 29 HOUSE ETARTING VOLUME - 5450 PERCENT VOLUME - 57.6 TEST TYPE - CSLD

FEE 5. 2024 12:30 AFT TEST LENGTH 39 HOURS STARTING VOLUME 7652 PERCENT VOLUME 76:3 TEST TYPE * CSLD

MAR 21. 2024 1:54 AM TEST LENGTH 33 HOURS STARTING VOLUME - 3837 PERCENT VOLUME - 39.1 TEST TYPE - CSLD

APR 25. 2024 1129 PM TEST LENGTH 36 HOUSE STARTING VOLUME - 5635 PERCENT VOLUME - 57.4 TEST TYPE - CBLD

MAY 1: 2024 2:40 AM TEST LEMOTH 39 HOUSE STARTING VOLUME - 5251 PERCENT VOLUME - 53.5 TEST TYPE - CSLD

JUN 19. 2024 11:20 AM TEST LENGTH 44 HOURS STARTING VOLUME - 4149 PERCENT VOLUME - 42.0 TEST TYPE - CBLD

JUL 31. 2023 5:46 AM
TENT LEWITH 54 HOURS
STARTING VOLUME - 34.2
PERCENT VOLUME - 34.2
TENT TYPE - CSLD

AUG 5. 2023 10:15 AM TEST LENGTH 36 HOURS STARTING VOLUME 3779 PERCENT VOLUME 36.5 TEST TYPE CSLD

SEP 15, 2023 7:35 PM TEST LENGTH 34 HOURS STARTING VOLUME - 4455 PERCENT VOLUME - 45.4 TEST TYPE * CSLD

OCT 29. 2023 8:47 AM
TEST LENGTH 38 HOURS
STARTING VOLUME - 49.3
TEST TYPE - CSLD

TEST LENGTH 48 HOURS
BTARTING VOLUME 4414
PERCENT VOLUME 45.0
TEST TYPE CSILD

DEC 15. 2023 1:31 AM TEST LENGTH 33 HOURS STARTING VOLUME - 8538 PERCENT VOLUME - 86.9 TEST TYPE - CSLD

* * * * * DO * * * * *

EPERTANY 6116 1540 E ANGEMINITON INSPER IN 463GI 317-638-6546

200 21 - 1024 9154 Wt.

TANK LEAK TEST HISTORY

5:121 KER

LAST GROSS TEST PHOSED: JUN 21. 2024 9:03 AM STARTING VOLUME: 1632 PERCENT VOLUME: 1632 TEST TYPE - STANDARD

LAST HOWARD TEST PROBED:

NO TENT IVESTED

FILLEST ANNUAL TEST INCS

NO TEST PHENED

LAST PERIODIC TEST PAGE: JUN 21. 2024 7104 AM TEST LEWITH SE MOUSE STARTING VOLLES | 632 PERCENT VOLLES | 39.3 TEST TYPE - COLD

PULLEST PERIODIC TEST

JAN 27. 2024 7:08 PM TEST LEWITH 40 HOURS STARTING VOLUME: 2469 PERCENT VOLUME: 59.5 TEST TUPE: CSLD

FEE 2. 2024 1132 FM TEST LEMITH 49 HOURS STARTING VOLUME - 2467 PERCENT VOLUME - 59.9 TEST TYPE + CSLD

MAR 1. 2024 12148 AM TEST LENGTH 51 HOURS STAKTING VOLUME - 2104 PERCENT VOLUME - 50.7 TEST TYPE - CSLD

APR 1. 2024 12:21 APT TEST LENGTH 53 HOURS STARTING VOLLME 1765 PERCENT VOLLME 42.6 TEST TYPE - CSLD

MAY 1, 2024 2:29 AM TEST LENGTH 92 HOURS STARTING VOLUME 1636 FROENT VOLUME 29.4 TEST TYPE CSLD

JUN 1-2024 1:57 APT TEST LENGTH 80 HOURS STARTING VOLUME * 1632 PERCENT VOLUME * 09.3 TEST TYPE * CSLD

JUL 1. 2023 1:33 AM TEST LENGTH 81 HOURE STANTING VOLUME * 1592 PERCENT VOLUME * 38.4 TEST TYPE * CSLD

AUD 1. 2023 12:47 AM TEST LENGTH 90 HOURS STARTING VOLUME 1581 PERCENT VOLUME 38.1 TEST TYPE - CSLD

SEP 1, 2023 9:52 PM TEST LENGTH 92 HOURS STARTING VOLUME - 1580 PERCENT VOLUME - 38.1 TEST TYPE - CSLD

OCT 1. 2023 5121 AM TEST LENGTH 91 HOURS STARTING VOLUME: 1569 PERCENT VOLUME: 37.8 TEST TYPE - CSLD

NOV 1. 2023 8142 AM TEST LENGTH 61 HOURS STARTING VOLUME 1465 PERCENT VOLUME 35.3 TEST TYPE CSLD

DEC 16. 2023 2:37 AM TEST LENGTH 43 HOURS STARTING VOLUME 2063 PERCENT VOLUME 49:7 TEST TYPE - CSLD

* * * * * END * * * * *

TENT TYPE - COLD

Speedway LLC.

	Speedway LLC.								
Store# 6116		Tank Comp	liance Report		Facility ID# 006712				
1640 E Washington S	t INDIANAPOLIS, IN			Last 12 Mor	nths - Reported 06/07/2024				
- Kerosene -									
Tank# 5 - Senso	r# 5								
RD Method - CSLD									
06/07/2024 Pass	05/08/2024 Pass	04/08/2024 Pass	03/09/2024 Pass	02/08/2024 Pass	01/09/2024 Pass				
12/10/2023 Pass	11/10/2023 Pass	10/11/2023 Pass	09/11/2023 Pass	08/12/2023 Pass	07/13/2023 Pass				
06/13/2023 Pass	05/14/2023 Pass								
- Regular -									
Tank# 6 - Senso	r# 1								
RD Method - CSLD									
06/07/2024 Pass	05/08/2024 Pass	04/08/2024 Pass	03/09/2024 Pass	02/08/2024 Pass	01/09/2024 Pass				
12/10/2023 Pass	11/10/2023 Pass	10/11/2023 Pass	09/11/2023 Pass	08/12/2023 Pass	07/13/2023 Pass				
06/21/2023 Pass	05/22/2023 Pass								
- Regular -									
Tank# 7 - Sensor	r# 2								
RD Method - CSLD									
06/07/2024 Pass	05/08/2024 Pass	04/08/2024 Pass	03/09/2024 Pass	02/08/2024 Pass	01/09/2024 Pass				
12/10/2023 Pass	11/10/2023 Pass	10/11/2023 Pass	09/11/2023 Pass	08/12/2023 Pass	07/13/2023 Pass				
06/28/2023 Pass	06/20/2023 Pass	05/21/2023 Pass							
- Premium -									
Tank# 8 - Sensor	r# 3								
RD Method - CSLD	· · -								
06/07/2024 Pass	05/08/2024 Pass	04/08/2024 Pass	03/09/2024 Pass	02/08/2024 Pass	01/09/2024 Pass				
12/10/2023 Pass	11/10/2023 Pass	10/11/2023 Pass	09/11/2023 Pass	08/12/2023 Pass	07/13/2023 Pass				
06/13/2023 Pass	05/14/2023 Pass	. 3, 1 1/2020 1 000	23/11/2020 1 400	37,12,2020 . 400	5., 10,2020 F doo				
10 3,2020 . 000	25/ 1 1/2020 1 000								

- Diesel -

Tank# 9 - Sensor# 4

05/08/2024 Pass

11/10/2023 Pass

05/14/2023 Pass

04/08/2024 Pass

10/11/2023 Pass

03/09/2024 Pass

09/11/2023 Pass

02/08/2024 Pass

08/12/2023 Pass

01/09/2024 Pass

07/13/2023 Pass

RD Method - CSLD 06/07/2024 Pass

12/10/2023 Pass

06/13/2023 Pass

Speedway LLC.
0.2 GPH Line Compliance Report

Store# 6116 1640 E Washington St INDIANAPOLIS, IN

06/23/2023 Pass

05/24/2023 Pass

Last 12 Months - Reported 06/07/2024

Facility ID# 006712

TO TO L Washington	SCHADIANA OLIO, HA			Edot 12 IVIO	Title Troported Corottizes
- Kerosene -					
Tank# 5 - Senso	or# 4				
RD Method - ELLD					
05/26/2024 Pass	05/20/2024 Pass	04/20/2024 Pass	03/23/2024 Pass	02/24/2024 Pass	01/25/2024 Pass
12/26/2023 Pass	11/26/2023 Pass	10/27/2023 Pass	09/27/2023 Pass	09/01/2023 Pass	08/21/2023 Pass
07/31/2023 Pass	07/10/2023 Pass	06/11/2023 Pass	05/15/2023 Pass		
- Regular -					
Tank# 7 - Senso	or# 1				
RD Method - ELLD					
06/07/2024 Pass	05/10/2024 Pass	04/10/2024 Pass	03/13/2024 Pass	02/12/2024 Pass	01/14/2024 Pass
12/18/2023 Pass	11/20/2023 Pass	10/21/2023 Pass	09/23/2023 Pass	08/24/2023 Pass	07/27/2023 Pass
06/27/2023 Pass	05/28/2023 Pass				
- Premium -					
Tank# 8 - Senso	or# 2				
RD Method - ELLD					
06/03/2024 Pass	05/04/2024 Pass	04/04/2024 Pass	03/05/2024 Pass	02/04/2024 Pass	01/05/2024 Pass
12/06/2023 Pass	11/06/2023 Pass	10/07/2023 Pass	09/07/2023 Pass	08/08/2023 Pass	07/09/2023 Pass
06/09/2023 Pass	05/10/2023 Pass				
- Diesel -					
Tank# 9 - Senso	or# 3				
RD Method - ELLD					
06/05/2024 Pass	05/06/2024 Pass	04/06/2024 Pass	03/09/2024 Pass	02/09/2024 Pass	01/11/2024 Pass
12/12/2023 Pass	11/12/2023 Pass	10/15/2023 Pass	09/17/2023 Pass	08/20/2023 Pass	07/23/2023 Pass

Speedway LLC.
0.1 GPH Line Compliance Report

Store# 6116 1640 E Washington St INDIANAPOLIS, IN

Last 12 Months - Reported 06/07/2024

Facility ID# 006712

- Kerosene -

Tank# 5 - Sensor# 4

RD Method - ELLD

05/20/2024 Pass 10/23/2023 Pass 04/22/2023 Pass

- Regular -

Tank# 7 - Sensor# 1

RD Method - ELLD

04/16/2024 Pass 10/15/2023 Pass 04/14/2023 Pass

- Premium -

Tank# 8 - Sensor# 2

RD Method - ELLD

- Diesel -

Tank# 9 - Sensor# 3

RD Method - ELLD

03/31/2024 Pass 09/29/2023 Pass 09/29/2022 Pass

Speedway LLC.
Sump Sensor Compliance Report

Store# 6116 1640 E Washington St INDIANAPOLIS, IN

12/10/2023 Normal

06/13/2023 Normal

11/10/2023 Normal

05/14/2023 Normal

Last 12 Months - Reported 06/07/2024

Facility ID# 006712

	· · · · · · · · · · · · · · · · · · ·				<u> </u>
- Regular -					
Tank# 6 - Senso	r# 1				
STP Sump Sensor					
06/07/2024 Normal	05/08/2024 Normal	04/08/2024 Normal	03/09/2024 Normal	02/14/2024 Normal	01/15/2024 Normal
12/16/2023 Normal	11/16/2023 Normal	10/17/2023 Normal	09/17/2023 Normal	08/18/2023 Normal	07/19/2023 Normal
06/19/2023 Normal	05/20/2023 Normal				
- Premium -					
Tank# 8 - Senso	r# 2				
STP Sump Sensor					
06/07/2024 Normal	05/08/2024 Normal	04/08/2024 Normal	03/09/2024 Normal	02/08/2024 Normal	01/09/2024 Normal
12/10/2023 Normal	11/10/2023 Normal	10/11/2023 Normal	09/11/2023 Normal	08/12/2023 Normal	07/13/2023 Normal
06/13/2023 Normal	05/14/2023 Normal				
- Diesel -					
Tank# 9 - Senso	r# 3				
STP Sump Sensor					
06/07/2024 Normal	05/08/2024 Normal	04/08/2024 Normal	03/09/2024 Normal	02/08/2024 Normal	01/09/2024 Normal
12/10/2023 Normal	11/10/2023 Normal	10/11/2023 Normal	09/11/2023 Normal	08/12/2023 Normal	07/13/2023 Normal
06/13/2023 Normal	05/14/2023 Normal				
- Kerosene -					
Tank# 5 - Senso	r# 4				
STP Sump Sensor					
06/07/2024 Normal	05/08/2024 Normal	04/08/2024 Normal	03/09/2024 Normal	02/08/2024 Normal	01/09/2024 Normal

09/11/2023 Normal

08/12/2023 Normal

07/13/2023 Normal

10/11/2023 Normal

	Speedway LLC.
Store# 6116	Dispenser Sensor Compliand

06/07/2024 Normal

12/10/2023 Normal

06/13/2023 Normal

05/08/2024 Normal

11/10/2023 Normal

05/14/2023 Normal

penser Sensor Compliance Report Facility ID# 006712

Last 12 Months - Reported 06/07/2024

1640 E Washington St	INDIANAPOLIS, IN			Last 12 Mont	hs - Reported 06/07/202
DISPENSER 1-2 S	SUMP				
Sensor# 5					
Dispenser Sump Senso	or				
06/07/2024 Normal	05/08/2024 Normal	04/08/2024 Normal	03/09/2024 Normal	02/08/2024 Normal	01/09/2024 Normal
12/10/2023 Normal	11/10/2023 Normal	10/11/2023 Normal	09/11/2023 Normal	08/12/2023 Normal	07/13/2023 Normal
06/13/2023 Normal	05/14/2023 Normal				
DISPENSER 3-4 S	SUMP				
Sensor# 6					
Dispenser Sump Senso	or				
06/07/2024 Normal	05/08/2024 Normal	04/08/2024 Normal	03/09/2024 Normal	02/08/2024 Normal	01/09/2024 Normal
12/10/2023 Normal	11/10/2023 Normal	10/11/2023 Normal	09/11/2023 Normal	08/12/2023 Normal	07/13/2023 Normal
06/13/2023 Normal	05/14/2023 Normal				
DISPENSER 5-6 S	SUMP				
Sensor# 7					
Dispenser Sump Senso	or				
06/07/2024 Normal	05/08/2024 Normal	04/08/2024 Normal	03/09/2024 Normal	02/08/2024 Normal	01/09/2024 Normal
12/10/2023 Normal	11/10/2023 Normal	10/11/2023 Normal	09/11/2023 Normal	08/12/2023 Normal	07/13/2023 Normal
06/13/2023 Normal	05/14/2023 Normal				
DISPENSER 7-8 S	SUMP				
Sensor# 8					
Dispenser Sump Senso	or				

03/09/2024 Normal

09/11/2023 Normal

02/08/2024 Normal

08/12/2023 Normal

01/09/2024 Normal

07/13/2023 Normal

04/08/2024 Normal

10/11/2023 Normal



UST OVERFILL EQUIPMENT INSPECTION AUTOMATIC SHUTOFF DEVICE AND BALL FLOAT VALVE									
Facility Name: SSA 6116			Owner: Speedway,LLC						
Address: 1640 E Washing	Address: 1640 E Washington								
City, State, Zip Code: Indianapolis,	, IN		City, State, Zip (Code: Enon,OH					
Facility I.D. #:			Phone #:						
Testing Company: US Tank Alliand		Phone #: (440)	238-7705	Date: 9/21/23					
This data sheet is for inspecting au	tomatic shutoff d	evices and ball flo	at valves. See PE	I/RP1200, Section	n 7 for inspection	n procedures.			
Product Grade	KER								
Tank Number	5								
Tank Volume, gallons	4150								
Tank Diameter, inches	72								
Overfill Prevention Device Brand	OPW								
Туре	■ Automatic Shutoff Device □ Ball Float Valve	☐ Automatic Shutoff Device ☐ Ball Float Valve							
AUTOMATIC SHUTOFF DEVICE IN	SPECTION								
1. Drop tube removed from tank?	■ Yes □ No	☐ Yes ☐ No	☐ Yes ☐ No	☐ Yes ☐ No	☐Yes ☐No	☐ Yes ☐ No			
Drop tube and float mechanisms are free of debris?	■ Yes □ No	□Yes □No	□ Yes □ No	□ Yes □ No	□Yes □No	□Yes □No			
3. Float moves freely without binding and poppet moves into flow path?	■Yes □No	□Yes □No	□Yes □No	□ Yes □ No	□Yes □No	□Yes □No			
4. Bypass valve in the drop tube is open and free of blockage (if present)?	☐ Yes ☐ No ■ Not Present	☐ Yes ☐ No ☐ Not Present	☐ Yes ☐ No ☐ Not Present	☐ Yes ☐ No ☐ Not Present	☐ Yes ☐ No ☐ Not Present	☐ Yes ☐ No ☐ Not Present			
5. Flapper is adjusted to shut off flow at 95% capacity?*	■ Yes □ No	□Yes □No	□Yes □No	□ Yes □ No	□Yes □No	□Yes □No			
A "No" to any item in Lines 1-5 ind	icates a test failu	ıre.							
BALL FLOAT VALVE INSPECTION									
1. Tank top fittings are vaportight and leak-free?	☐ Yes ☐ No	□ Yes □ No	□ Yes □ No	□ Yes □ No	□ Yes □ No	□Yes □No			
2 Ball float cage free of debris?	□ Yes □ No	□Yes □No							
3. Ball is free of holes and cracks and moves freely in cage?	□ Yes □ No	□Yes □No							
4. Vent hole in pipe is open and near top of tank?	□ Yes □ No	□Yes □No							
5. Ball float pipe is proper length to restrict flow at 90% capacity?**	□ Yes □ No	□Yes □No	□Yes □No	□Yes □No	□Yes □No	□ Yes □ No			
A "No" to any item in Lines 1-5 ind	icates a test failu	ıre.							
Test Results	■ Pass □ Fail		□ Pass □ Fail	□ Pass □ Fail	☐ Pass ☐ Fail	□ Pass □ Fail			
* Use manufacturer's suggested ** Use manufacturer's suggested		_							
	anks for ball flo present in any								



OVERFILL ALARM OPERATION INSPECTION

This procedure is to determine whether the high level See PEI/RP1200, Section 7.3 for the inspection probottom of the tank when in place.				
Tank Number				
Product Stored				
Tank Level Monitor Brand and Model				
1. Tank Volume, gallons				
2. Tank Diameter, inches				
3. Does the overfill alarm activate in the test mode at the console?	□ Yes □ No	□Yes □No	□Yes □No	□ Yes □ No
4. When activated, can the overfill alarm be heard or seen while delivering to the tank?	□ Yes □ No	□ Yes □ No	□Yes □No	□ Yes □ No
5. After removing the probe from the tank, has it been inspected and any damaged or missing parts replaced?	□Yes □No	□Yes □No	□ Yes □ No	□Yes □No
6. Float moves freely on the stem without binding?	□ Yes □ No	□ Yes □ No	□Yes □No	□ Yes □ No
7. Does moving product level float up the stem trigger alarm?	□ Yes □ No	□ Yes □ No	□Yes □No	□ Yes □ No
8. Inch level from bottom of stem when 90% alarm is triggered.				
9. Tank volume at inch level in Line 8.				
10. Calculate (Line 9 / Line 1) x 100				
11. Is Line 10 less than 90%?	□Yes □No	□Yes □No	□ Yes □ No	□ Yes □ No
12. Does the fuel float level on the console agree with the gauge stick reading?	□ Yes □ No	□ Yes □ No	□Yes □No	□ Yes No
13. Does the overfill alarm activate at any product level above 90% tank capacity?	□ Yes □ No	□ Yes □ No	□Yes □No	□ Yes □ No
If any answers in Lines 3, 4, 5, 6, 7 or 11 are "No",	or Line 13 is "Yes",	the system has faile	d the test.	
Test Results	☐ Pass ☐ Fail	☐ Pass ☐ Fail	□ Pass □ Fail	☐ Pass ☐ Fail
Comments: No external overfill. IN Cert# UC111521 PEI Certified				

Tester's Name Justin Stout Tester's Signature

Date	9-21-2023
Site Name/number	SSA 6116
City/State	Indianapolis, IN

update 3/24/23 KP

Overfill Equipment Check Worksheet (Drop Tubes 95%)

			N WUINSIIC					
Tank number (from ATG)	5							
Product	KER							
Drop tube Make/Model	OPW							
Actual Tank Capacity	4150							
			PW 7150					
Upper Tube Length (D)	63.5							
Distance from the inlet tube flange to the bottom of cut (W)	119.25							
Distance from the inlet tube flange to the								
top of of cut (U)	119.25							
Distance from inlet tube flange to bottom of tank (B)	124.25							
Note: If a tank bottom protector is present (OPW 6111 & 61TP add 0.6")								
Using tank chart 100% volume (Y)		п	II.	"	п	11	п	
Subtact (B)-(D)-2" = (X)	58.75							
Convert (X) to gallons	3680	gals	gals	gals	gals	gals	gals	gals
(Y) tank capacity in gallons	4150							
Shut off percent (X)÷(Y)x100	88							
Inches off bottom (Top of cut to bottom of tank) more than 6" call in	5							
and the second s		EMCO V	VHEATON A1	100				
A (bottom of tank to top of fill adapter)								
subtract B (top of drop tube to top of fill adapter)								
Subtract A - B =								
subtract 4.50" (equals C)								
compare C to tank chart	gals	gals	gals	gals	gals	gals	gals	gals
using tank chart multiply total tank capacity by 95%	gals	gals	gals	gals	gals	gals	gals	gals
using tank chart convert 95% gals to inches		li li	U U	ı,	II.	II.	п	n gana
Shut off percent C ÷ total capacity								
Inches off bottom (Top of cut to bottom of tank) more than 6" call in								

OVER for Franklin Fueling (EBW) & Ball Floats

Product								
Drop tube Make/Model								
Actual Tank Capacity								
	FRA	NKLIN FUELII	NG Defender	Series (EBW)				
A (drop tube seal surface to the bottom of								
tank)								
Z (subtact upper drop tube flange to the								
edge of the upper tube adapter) Subtract A - Z =								
subtract 4.50" (equals final shutoff								
colume height)								
equals (final shutoff volume height)								
Locate final shutoff volume on tank chart								
divide by actual tank capacity								
multiply by 100 (equals final shutoff								
volume percentage)								
Inches off bottom (Top of cut to bottom of tank) more than 6" call in								
Tarila namela na Afranca ATC)								
Tank number (from ATG)								
Product								
Actual tank capacity off tank chart								
(Gallons)								
Calculate 90% of actual tank capacity	x .90	x .90	x .90	x .90	x .90	x .90	x .90	x .90
90% tank capacity (gallons)								
(A) Actual tank diameter (inches) on tank								
chart								
(B) 90% volume inch reading on tank chart								
(C) Calculated -top of tank to ball float shut								
off Subtract (B) from (A)								
(D) Field measurement -top of tank to ball float shut off								
Is field measurement (D) same or greater								
than calculated (C)? Y=Pass, N=Fail								

Tank number (from ATG)

Printed: 06/07/2024

Work Order# 001106712136 (T00002546358)

Technicians

WO Assigned: (006H) Vogel, John 502-803-5686 (Manager: Gray 317-416-0855)

Store Assigned: (00J7) Wilmoth, Larry 765-516-5192

Work Order Date: 06/13/2023 13:46

Priority: Emergency Status: Released (Open/Sent to Tech) (REL)

Activity Type: Problem / Breakdown / Repair (130) Order Type: Recurring Maintenance

Expense Class: Equipment Expense Type: Equipment

Function Location 3: Ust Equipment Function Location 4: Tanks

Work Order Description

KER fill adapter is seized and the drop tube measured in tank at 98%. Please make sure adapter and drop tube can be removed and drop tube is set no higher than 95% and no more than 6" off bottom of tank.

Verified: 08/15/2023 11:33 By: derek

Notes/Comment:			
Vendor: Rcm Corp			

Printed: 06/07/2024

Store# 6116 / 43768

Work Order# 001106712136 (T00002546358)

Invoice 31012 Rcm Corp

Date: 08/15/2023 Vendor#: 907601

Invoice Amount: \$725.95 AFE#: NONE

Gross Amount NonTax: \$725.95 **Total Tax:** \$.00 1099 Reportable: \$365.96

Work Description: Remove seized K-1 fill adapter. Replace K-1 drop tube (used).

Capital Assets

There are NO Capital Assets listed for this work order.

Parts Parts

Name/ID Description Count Cost Total K-1 fill adapter 1 \$359.99 \$359.99

(%) Tax:

Total:

Labor

Personnel Rate **Notes** Hours Total Man 6 \$57.50 \$345.00

(%) Tax:

Total:

Travel

Units Rate Total Type **Notes** Mileage 32 \$.66 \$20.96

(%) Tax:

Total:

Sub-Contractor

There are NO Sub-Contractor listed for this work order.

Equipment Rental

There are NO Equipment Rental listed for this work order.

Grand Total

Technician Total: \$.00 **Vendor Invoice Total:** \$725.95 **Grand Total:** \$725.95



UST OVERFILL EQUIPMENT INSPECTION AUTOMATIC SHUTOFF DEVICE AND BALL FLOAT VALVE								
Facility Name: SSA 6116 Owner: Speedway,LLC								
Address: 1640 E Washing	ton		Address: 600 S	peedway Dr				
City, State, Zip Code: Indianapolis,	, IN 46201		City, State, Zip C	Code: Enon,OH				
Facility I.D. #:			Phone #:					
Testing Company: US Tank Alliand	се		Phone #: (440)	238-7705	Date: 6/13/23			
This data sheet is for inspecting aut	tomatic shutoff d	evices and ball flo	at valves. See PE	I/RP1200, Sectio	n 7 for inspection	n procedures.		
Product Grade	RUL A	RUL B	PUL	DSL	KER			
Tank Number	1	2	3	4	5			
Tank Volume, gallons	9816	9816	9816	9816	4150			
Tank Diameter, inches	92	92	92	92	72			
Overfill Prevention Device Brand	OPW	OPW	OPW	OPW	OPW			
Туре	■ Automatic Shutoff Device □ Ball Float	☐ Automatic Shutoff Device ☐ Ball Float						
AUTOMATIO CULITORE DEVICE II	Valve	Valve	Valve	Valve	Valve	Valve		
AUTOMATIC SHUTOFF DEVICE IN	Yes No	■ Yes □ No	■ Yes □ No	■ Yes □ No	☐ Yes ■ No	☐ Yes ☐ No		
 Drop tube removed from tank? Drop tube and float mecha- 	■ res Lino	■ res Linu	■ res Linu	Tes LING	Li tes INU	Li tes Li No		
nisms are free of debris?	■ Yes □ No	☐ Yes ■ No	☐ Yes ☐ No					
3. Float moves freely without binding and poppet moves into flow path?	■ Yes □ No	□ Yes ■ No	□ Yes □ No					
4. Bypass valve in the drop tube is open and free of blockage (if present)?	☐ Yes ☐ No ■ Not Present	☐ Yes ☐ No ☐ Not Present						
5. Flapper is adjusted to shut off flow at 95% capacity?*	■ Yes □ No	☐ Yes ■ No	□ Yes □ No					
A "No" to any item in Lines 1-5 ind	icates a test failu	ıre.						
BALL FLOAT VALVE INSPECTION								
1. Tank top fittings are vapor- tight and leak-free?	□Yes □No	□Yes □No	□ Yes □ No	□Yes □No	□ Yes □ No	□ Yes □ No		
2 Ball float cage free of debris?	□Yes □No	□Yes □No	□ Yes □ No	□Yes □No	□Yes □No	□ Yes □ No		
3. Ball is free of holes and cracks and moves freely in cage?	□Yes □No	□Yes □No	□ Yes □ No	□Yes □No	□ Yes □ No	□ Yes □ No		
4. Vent hole in pipe is open and near top of tank?	□Yes □No	□Yes □No	□ Yes □ No	□Yes □No	□ Yes □ No	□ Yes □ No		
5. Ball float pipe is proper length to restrict flow at 90% capacity?**	□Yes □No	□Yes □No	□ Yes □ No					
A "No" to any item in Lines 1-5 ind	icates a test failu	ıre.						
Test Results	■ Pass □ Fail	□ Pass ■ Fail	□ Pass □ Fail					
* Use manufacturer's suggested ** Use manufacturer's suggested		_				-		
** Use manufacturer's suggested procedure for determining if flow restriction device will restrict flow at 90% capacity. Comments: No ball floats present in any tank								



OVERFILL ALARM OPERATION INSPECTION

This procedure is to determine whether the high level alarm is operational and will trigger when the tank is no more than 90% full. See PEI/RP1200, Section 7.3 for the inspection procedure. This procedure is applicable to tank level monitor stems that touch the bottom of the tank when in place.						
Tank Number						
Product Stored						
Tank Level Monitor Brand and Model						
1. Tank Volume, gallons						
2. Tank Diameter, inches						
3. Does the overfill alarm activate in the test mode at the console?	□ Yes □ No	□ Yes □ No	□Yes □No	□ Yes □ No		
4. When activated, can the overfill alarm be heard or seen while delivering to the tank?	□ Yes □ No	□ Yes □ No	□Yes □No	□ Yes □ No		
5. After removing the probe from the tank, has it been inspected and any damaged or missing parts replaced?	□Yes □No	□Yes □No	□Yes □No	□Yes □No		
6. Float moves freely on the stem without binding?	□ Yes □ No					
7. Does moving product level float up the stem trigger alarm?	□ Yes □ No	□ Yes □ No	□Yes □No	□ Yes □ No		
8. Inch level from bottom of stem when 90% alarm is triggered.						
9. Tank volume at inch level in Line 8.						
10. Calculate (Line 9 / Line 1) x 100						
11. Is Line 10 less than 90%?	□ Yes □ No	□ Yes □ No	□Yes □No	□ Yes □ No		
12. Does the fuel float level on the console agree with the gauge stick reading?	□ Yes □ No	□ Yes □ No	□Yes □No	□ Yes No		
13. Does the overfill alarm activate at any product level above 90% tank capacity?	□ Yes □ No	□ Yes □ No	□Yes □No	□ Yes □ No		
If any answers in Lines 3, 4, 5, 6, 7 or 11 are "No",						
Test Results	□ Pass □ Fail	☐ Pass ☐ Fail	□ Pass □ Fail	□ Pass □ Fail		
Comments: No external overfill. IN Cert# UC111521 PEI Certified						

Tester's Name Justin Stout Tester's Signature Just 815

Date 6-13-2023

Site Name/number SSA 6116

City/State Indianapolis, IN

update 3/24/23 KP

Overfill Equipment Check Worksheet (Drop Tubes 95%)

Tank number (from ATG)	1	2	3	4	5			
Product	RUL A	RUL B	PUL	DSL	KER			
Drop tube Make/Model	OPW	OPW	OPW	OPW	OPW			
Actual Tank Capacity	9816	9816	9816	9816	4150			
		(OPW 7150					
Upper Tube Length (D)	60	60.25	60	58.75	54			
Distance from the inlet tube flange to the								
bottom of cut (W)	137	134.75	135.5	135	123.25			
Distance from the inlet tube flange to the								
top of of cut (U)	137	134.75	135.5	135	123.25			
Distance from inlet tube flange to bottom								
of tank (B)	142	140.25	140.75	140	124.25			
Note: If a tank bottom protector is present (OPW 6111 & 61TP add 0.6")								
Using tank chart 100% volume (Y)	11	11	11	11	11	11	11	11
Subtact (B)-(D)-2" = (X)	80	78	78.75	79.25	68.25			
Convert (X) to gallons	9192	9013	9082	9127	4092	gals	gals	gals
(Y) tank capacity in gallons	9816	9816	9816	9816	4150			
Shut off percent (X)÷(Y)x100	94	92	92	93	98			
Inches off bottom (Top of cut to bottom of								
tank) more than 6" call in	5		5.25		1			
		EMCO \	WHEATON A1	.100	1			
A (bottom of tank to top of fill adapter)								
subtract B (top of drop tube to top of fill adapter)								
Subtract A - B =								
subtract 4.50" (equals C)								
compare C to tank chart	gals	gals	gals	gals	gals	gals	gals	gals
using tank chart multiply total tank						_	-	_
capacity by 95%	gals	gals	gals	gals	gals	gals	gals	gals
using tank chart convert 95% gals to inches	11	11	11	11	11	11	ı	II
Shut off percent C ÷ total capacity								
Inches off bottom (Top of cut to bottom of tank) more than 6" call in								
comy more than or can in		1	<u> </u>	<u> </u>				

OVER for Franklin Fueling (EBW) & Ball Floats



Product								
Drop tube Make/Model								
Actual Tank Capacity								
	FR.A	NKLIN FUELII	NG Defender	Series (EBW)				
A (drop tube seal surface to the bottom of tank)								
Z (subtact upper drop tube flange to the edge of the upper tube adapter)								
Subtract A - Z =								
subtract 4.50" (equals final shutoff colume height)								
equals (final shutoff volume height)								
Locate final shutoff volume on tank chart								
divide by actual tank capacity								
multiply by 100 (equals final shutoff								
volume percentage) Inches off bottom (Top of cut to bottom of tank) more than 6" call in								
0	verfill Equi	pment Che	ck Worksh	eet (Ball Flo	oats 90%)			
Tank number (from ATG)								
Product								
Actual tank capacity off tank chart (Gallons)								
Calculate 90% of actual tank capacity	x .90	x .90	x .90	x .90	x .90	x .90	x .90	x .90
90% tank capacity (gallons)								
(A) Actual tank diameter (inches) on tank							· 	
chart								
(B) 90% volume inch reading on tank chart								
(C) Calculated -top of tank to ball float shut off Subtract (B) from (A)			_					
(D) Field measurement -top of tank to ball float shut off								
Is field measurement (D) same or greater								

Tank number (from ATG)

than calculated (C)? Y=Pass, N=Fail

Printed: 06/07/2024



Technicians

WO Assigned: (005C) Spegal, Justin 317-385-5930 (Manager: Kleinen 937-206-1887)

Store Assigned: (00J7) Wilmoth, Larry 765-516-5192

Work Order Date: 02/21/2023 17:30

Priority: Emergency Status: Closed in Accounting (CLSD)

Activity Type: Problem / Breakdown / Repair (130) Order Type: Recurring Maintenance

Expense Class: Equipment Expense Type: Equipment

Function Location 3: Ust Equipment Function Location 4: Tanks

AFE: 174565

Work Order Description

The RUL-2 & PUL-3 fill adapters are seized so unable to pull the drop tube and check if the overfill device is functioning properly. The RUL-1 vapor adapter is seized so unable to check for a ball float. The RUL-2 & the PUL-3 drop tubes are seized so unable to remove them for testing. The RUL-1 drop tube is 14" off the bottom of the tank, the RUL-2 is 15.5", the PUL-3 is 12.5", DSL-4 is 19" and the KER-5 is 8.5". The DSL-4 drop tube is set for 97.7% shut off. The RUL-2, PUL-3 fill adapters need to be fixed so they are removable to access the drop tube and please make sure the drop tube can be removed for testing as well. The RUL-1 vapor adapter needs to be fixed so it is removable and check the riser for a ball float and remove if present. The RUL-2 & PUL-3 drop tubes need to be fixed so they are removable for testing. The RUL-1, RUL-2, PUL-3 need to be fixed so they are no more than 6" off the bottom of the tank. The DSL-4 drop tube needs to be fixed so it is set for no more than 95% shut off.

Verified: 03/02/2023 15:30 By: Justin

Vendor: Rcm Corp	
Notes/Comment:	

Printed: 06/07/2024

Store# 6116 / 43768

Work Order# 001106497966 (T00002357320)

Invoice 30626 **Rcm Corp**

Date: 03/02/2023 Vendor#: 907601

Invoice Amount: \$7,300.00 AFE#: 174565

Gross Amount NonTax: \$7,300.00 **Total Tax:** \$.00 1099 Reportable: \$7,300.00

Work Description: AS PER QUOTE: Remove seized fill adapters and seized vapor adapter. Replace 4 drop tubes, 2 fill caps. Raise up 2 fill risers. Parts

used: 2 fill adapters, 1 vapor adapter, 4 71SO-400C drop tubes, 2 fill caps, 2 riser rings

Capital Assets

There are NO Capital Assets listed for this work order.

Parts

There are NO Parts listed for this work order.

Labor

Personnel **Notes Hours** Rate **Total** \$7,300.00 AS PER QUOTE 1 \$7,300.00

> (%) Tax: Total:

Travel

There are NO Travel listed for this work order.

Sub-Contractor

There are NO Sub-Contractor listed for this work order.

Equipment Rental

There are NO Equipment Rental listed for this work order.

Grand Total

Technician Total: \$.00 **Vendor Invoice Total:** \$7,300.00 **Grand Total:** \$7,300.00



UST OVERFILL EQUIPMENT INSPECTION AUTOMATIC SHUTOFF DEVICE AND BALL FLOAT VALVE						
Facility Name: Speedway #6110	3		Owner: Speed	dway,LLC		
Address: 1640 E Washing	ton		Address: 600 S	peedway Dr		
City, State, Zip Code: Indianapolis	IN		City, State, Zip (Code: Enon,OH		
Facility I.D. #:			Phone #:			
Testing Company: US Tank Alliand	e		Phone #: (440)	238-7705	Date: 2/21/23	
This data sheet is for inspecting au	omatic shutoff d	evices and ball flo	at valves. See PE	I/RP1200, Section	n 7 for inspection	n procedures.
Product Grade	RUL A	RUL B	PUL	DSL	K-1	
Tank Number	1	2	3	4	5	
Tank Volume, gallons	9816	9816	9816	9816	4150	
Tank Diameter, inches	91	91	91	91	72	
Overfill Prevention Device Brand	OPW	OPW	OPW	OPW	OPW	
Туре	■ Automatic Shutoff Device □ Ball Float Valve	■ Automatic Shutoff Device □ Ball Float Valve	■ Automatic Shutoff Device □ Ball Float Valve	■ Automatic Shutoff Device □ Ball Float Valve	■ Automatic Shutoff Device □ Ball Float Valve	☐ Automatic Shutoff Device ☐ Ball Float Valve
AUTOMATIC SHUTOFF DEVICE IN	ISPECTION					
1. Drop tube removed from tank?	■ Yes □ No	☐ Yes ■ No	☐ Yes ■ No	■ Yes □ No	■ Yes □ No	☐ Yes ☐ No
2. Drop tube and float mechanisms are free of debris?	■ Yes □ No	■ Yes □ No	■ Yes □ No	■ Yes □ No	■ Yes □ No	□ Yes □ No
3. Float moves freely without binding and poppet moves into flow path?	■Yes □No	□Yes ■No	□ Yes ■ No	■ Yes □ No	■Yes □ No	□ Yes □ No
4. Bypass valve in the drop tube is open and free of blockage (if present)?	☐ Yes ☐ No ■ Not Present	☐ Yes ☐ No ■ Not Present	☐ Yes ☐ No ■ Not Present	☐ Yes ☐ No ■ Not Present	☐ Yes ☐ No ■ Not Present	☐ Yes ☐ No ☐ Not Present
5. Flapper is adjusted to shut off flow at 95% capacity?*	■ Yes □ No	□ Yes ■ No	□ Yes ■ No	☐ Yes ■ No	■ Yes □ No	□Yes □No
A "No" to any item in Lines 1-5 ind	icates a test failu	ıre.				
BALL FLOAT VALVE INSPECTION						
1. Tank top fittings are vaportight and leak-free?	□Yes □No	□ Yes □ No	□ Yes □ No	□ Yes □ No	□ Yes □ No	□Yes □No
2 Ball float cage free of debris?	□Yes □No	□Yes □No	□Yes □No	□Yes □No	□Yes □No	☐ Yes ☐ No
3. Ball is free of holes and cracks and moves freely in cage?	□Yes □No	□Yes □No	□Yes □No	□Yes □No	□Yes □No	□Yes □No
4. Vent hole in pipe is open and near top of tank?	□Yes □No	□Yes □No	□Yes □No	□Yes □No	□Yes □No	□Yes □No
5. Ball float pipe is proper length to restrict flow at 90% capacity?**	□Yes □No	□Yes □No	□Yes □No	□Yes □No	□Yes □No	□Yes □No
A "No" to any item in Lines 1-5 ind	icates a test failu	ıre.				
Test Results	■ Pass □ Fail	☐ Pass ■ Fail	☐ Pass ■ Fail	☐ Pass ■ Fail	■ Pass □ Fail	□ Pass □ Fail
* Use manufacturer's suggested ** Use manufacturer's suggested	•	_				•
Comments: Checked all tanks for ball floats No ball floats present in any tank						



OVERFILL ALARM OPERATION INSPECTION

This procedure is to determine whether the high level alarm is operational and will trigger when the tank is no more than 90% full. See PEI/RP1200, Section 7.3 for the inspection procedure. This procedure is applicable to tank level monitor stems that touch the bottom of the tank when in place.							
Tank Number							
Product Stored							
Tank Level Monitor Brand and Model							
1. Tank Volume, gallons							
2. Tank Diameter, inches							
3. Does the overfill alarm activate in the test mode at the console?	□ Yes □ No	□ Yes □ No	□Yes □No	□ Yes □ No			
4. When activated, can the overfill alarm be heard or seen while delivering to the tank?	□ Yes □ No	□ Yes □ No	□Yes □No	□ Yes □ No			
5. After removing the probe from the tank, has it been inspected and any damaged or missing parts replaced?	□Yes □No	□Yes □No	□ Yes □ No	□Yes □No			
6. Float moves freely on the stem without binding?	□Yes □No	□Yes □No	□Yes □No	□Yes □No			
7. Does moving product level float up the stem trigger alarm?	□ Yes □ No	□ Yes □ No	□Yes □No	□ Yes □ No			
8. Inch level from bottom of stem when 90% alarm is triggered.							
9. Tank volume at inch level in Line 8.							
10. Calculate (Line 9 / Line 1) x 100							
11. Is Line 10 less than 90%?	□Yes □No	□Yes □No	□ Yes □ No	□Yes □No			
12. Does the fuel float level on the console agree with the gauge stick reading?	□ Yes □ No	□ Yes □ No	□Yes □No	□ Yes No			
13. Does the overfill alarm activate at any product level above 90% tank capacity?	□ Yes □ No	□ Yes □ No	□Yes □No	□ Yes □ No			
If any answers in Lines 3, 4, 5, 6, 7 or 11 are "No",	or Line 13 is "Yes",	the system has faile	d the test.				
Test Results	□ Pass □ Fail	☐ Pass ☐ Fail	□ Pass □ Fail	□ Pass □ Fail			
Comments: No external overfill							
Tester's Name Willie Crabtree	То	ester's Signature	aldeli	H			



7400 Skyline Drive E * Columbus, OH 43235 * (614) 923-0154

SPILL BUCKET INTEGRITY TESTING HYDROSTATIC TEST METHOD SINGLE AND DOUBLE-WALLED VACUUM TEST METHOD								
Facility Name: Spee	edway 6116		Owner: Speedway, LLC					
Address: 1640 East			Address: 600 Spe	eedway Drive				
City, State, Zip Code		46201		de: Enon, OH 45	323			
Facility I.D. #: 0067		n County	Phone #: 937-864					
Testing Company: լ			Phone #: 440-238		Date: 3-17-2024			
This procedure is to test method, Section	_		ouble-walled spill b	uckets. See PEI/RF		-		
Tank Number	T1	T2	Т3	T4	T5			
Product Stored	RUL-a	RUL-b	PUL	DSL	KERO			
Spill Bucket Capacity	5 gal							
Manufacturer	OPW	OPW	OPW	OPW	OPW			
Construction	■ Single-walled □ Double-walled	■ Single-walled □ Double-walled	■ Single-walled □ Double-walled	■ Single-walled □ Double-walled	■ Single-walled □ Double-walled	☐ Single-walled ☐ Double-walled		
Test Type	■ Hydrostatic □ Vacuum □ Single-walled □ Double-walled	■ Hydrostatic □ Vacuum □ Single-walled □ Double-walled	■ Hydrostatic □ Vacuum □ Single-walled □ Double-walled	■ Hydrostatic □ Vacuum □ Single-walled □ Double-walled	■ Hydrostatic □ Vacuum □ Single-walled □ Double-walled	☐ Hydrostatic ☐ Vacuum ☐ Single-walled ☐ Double-walled		
Spill Bucket Type	■ Product □ Vapor	■ Product □ Vapor	■ Product □ Vapor	■ Product □ Vapor	■ Product □ Vapor	☐ Product ☐ Vapor		
Liquid and debris removed from spill bucket?*	■Yes □No	■Yes □No	■Yes □No	■Yes □ No	■Yes □No	☐ Yes ☐ No		
Visual Inspection (No cracks, loose parts or separa- tion of the bucket from the fill pipe.)	■ Pass □ Fail	■Pass □ Fail	□ Pass □ Fail					
Tank riser cap included in test?	■Yes □ No □NA	■ Yes □ No □ NA	■ Yes □ No □ NA	■Yes □No □NA	■Yes □No □NA	□ Yes □ No □ NA		
Is drain valve included in test?	□ Yes □ No ■ NA	□ Yes □ No □ NA						
Starting Level	11"	8"	11"	10"	10"			
Test Start Time	10:30 am	10:35 am	10:40 am	10:45 am	10:50 am			
Ending Level	11"	8"	11"	10"	10"			
Test End Time	11:30 am	11:35 am	11:40 am	11:45 am	11:50 am			
Test Period	1 hr							
Level Change	0"	0"	0"	0"	0"			
Pass/fail criteria: M Maintain at least 2						valled only:		
Test Results	■ Pass □ Fail	☐ Pass ☐ Fail						
Comments:								

*All liquids and debris must be disposed of properly.



7400 Skyline Drive East Columbus, OH 43235 (614) 923-0154

AUTOMATIC TANK GAUGE OPERATION INSPECTION									
Facility Name: Speedway #6116		Owner: Speedway	y,LLC						
Address: 1640 E Washington		Address: 600 Spe	edway Dr						
City, State, Zip Code: Indianapolis,IN		City, State, Zip Cod	e: Enon,O	Н					
Facility I.D. #:		Phone #:							
Testing Company: US Tank Alliance		Phone #: (614) 92	3-0154	Date: 2/	13/24				
This procedure is to determine whether the ATG is of This procedure is applicable to tank level monitor st					tion procedure.				
Tank Number	1	2	3		4				
Product Stored	RUL A	RUL B	PUL		DSL				
ATG Brand and Model	TLS 350	TLS 350	TLS 350)	TLS 350				
1. Tank Volume, gallons	9816	9816	9816		9816				
2. Tank Diameter, inches	91	91	91		91				
3. After removing the ATG from the tank, has it been inspected and any damaged or missing parts replaced?	■Yes □ No	■Yes □ No	■ Yes	□No	■Yes □ No				
4. Float moves freely on the stem without binding?	■ Yes □ No	■ Yes □ No	■ Yes	□No	■ Yes □ No				
5. Does the fuel float level agree with the value programmed into the console?	■ Yes □ No	■ Yes □ No	■ Yes	□No	■ Yes □ No				
6. Does the water float level agree with the value programmed into the console?	■ Yes □ No	■ Yes □ No	■ Yes	□No	■ Yes □ No				
7. Inch level from bottom of stem when 90% alarm is triggered.	75	75	7	5	75				
8. Does inch level at which the overfill alarm activates correspond with value programmed in the gauge?	■ Yes □ No	■ Yes □ No	■ Yes	□No	■Yes □ No				
9. Inch level from the bottom when the water float first triggers an alarm.	1	1	1		1				
10. Does inch level at which the water float alarm activates correspond with value programmed in the gauge?	■Yes □ No	■Yes □ No	■ Yes	□No	■Yes □ No				
If any answers in Lines 3, 4, 5, or 6 are "No," the system has failed the test.									
Test Results ■ Pass □ Fail ■ Pass □ Fail ■ Pass □ Fail ■ Pass □ Fail									
COMMENTS: IN Cert # UC20098339 PEI Certified	d								

TECH NAME: Tony Walters

Anthony Watters



7400 Skyline Drive East Columbus, OH 43235 (614) 923-0154

AUTOMATIC TANK GAUGE OPERATION INSPECTION							
Facility Name: Speedway #6116		Owner: Speedway	y,LLC				
Address: 1640 E Washington		Address: 600 Spe	edway Dr				
City, State, Zip Code: Indianapolis,IN		City, State, Zip Cod	e: Enon,O	Н			
Facility I.D. #:		Phone #:					
Testing Company: US Tank Alliance		Phone #: (614) 92	3-0154	Date: 2/	13/24		
This procedure is to determine whether the ATG is o This procedure is applicable to tank level monitor st					tion procedure.		
Tank Number	5				1		
Product Stored	K-1						
ATG Brand and Model	TLS 350						
1. Tank Volume, gallons	4150						
2. Tank Diameter, inches	72						
3. After removing the ATG from the tank, has it been inspected and any damaged or missing parts replaced?	■Yes □ No	□Yes □No	□ Yes	□No	□Yes □No		
4. Float moves freely on the stem without binding?	■ Yes □ No	□ Yes □ No	☐ Yes	□No	□ Yes □ No		
5. Does the fuel float level agree with the value programmed into the console?	■ Yes □ No	□ Yes □ No	□ Yes	□No	□ Yes □ No		
6. Does the water float level agree with the value programmed into the console?	■ Yes □ No	□ Yes □ No	□Yes	□No	□ Yes □ No		
7. Inch level from bottom of stem when 90% alarm is triggered.	60 1/2						
8. Does inch level at which the overfill alarm activates correspond with value programmed in the gauge?	■ Yes □ No	□ Yes □ No	□Yes	□No	□ Yes □ No		
9. Inch level from the bottom when the water float first triggers an alarm.	1						
10. Does inch level at which the water float alarm activates correspond with value programmed in the gauge?	■ Yes □ No	□ Yes □ No	□ Yes	□No	□Yes □No		
If any answers in Lines 3, 4, 5, or 6 are "No," the system has failed the test.							
Test Results	■ Pass □ Fail	☐ Pass ☐ Fail	☐ Pass	□ Fail	☐ Pass ☐ Fail		
COMMENTS: IN Cert # UC20098339 PEI Certified	d						

TECH NAME: Tony Walters

Anthony La Hers

Make/Model of ATG system: Veeder Root TLS 350

Serial Number: A1279240305001

Software Version: 133.01

ATG/Stick Readings

PRODUCT	ATG	STICK	WATER
RUL A	71.37	71.3	0
RUL B	71.60	71.6	0
PUL	42.29	42.2	0
DSL	50.16	50.1	0
K-1	38.21	38.2	0

Backup battery voltage _____3.6

External Overfill Alarms

PRODUCT	90% EXTERNAL ALARM INSTALLED								
RUL A	YES NO								
RUL B	YES NO								
PUL	YES NO								
DSL	YES NO								
K-1	YES NO								
	☐ YES ☐ NO								
	YES NO								
	☐ YES ☐ NO								
	YES NO								
	YES NO								



7400 Skyline Drive E * Columbus, OH * (614) 923-0154

LIQUID SENSOR FUNCTIONALITY TESTING										
Facility Name: Speedway #6116				Owner: Speedway,LLC						
Address: 1640 E Washington				Address:	600 Speedway I	Or				
City, State, Zip Code: Indianapolis,IN				City, Stat	e, Zip Code: Enon	,OH				
Facility I.D. #:				Phone #:						
Testing Company: US Tank Alliance				Phone #:	(440) 238-7705	i	Date: 2-13-24			
This procedure is to determine whether liquid sensors located in the interstitial space of UST systems are able to detect the presence of water and fuel. See PEI/RP1200 Section 8.3 for the test procedure.										
Sensor Location	L1-STP 208	L2-STP 208	L3-STP	208	L4-STP 208	L5-1/2 208	L6-3/4 208	L7-5/6 208		
Product Stored	RUL	PUL	DSL		K-1	RUL/PUL	RUL/PUL/DSL	RUL/PUL		
Type of Sensor	☐ Discriminating ■ Non-discriminating	☐ Discriminating ■ Non-discriminating	☐ Discriminating ■ Non-discriminating		☐ Discriminating ■ Non-discriminating					
Test Liquid	■ Water □ Product	■ Water □ Product	■ Water □ Product		■ Water □ Product					
Is the ATG console clear of any active or recurring warnings or alarms regarding the leak sensor? If the sensor is in alarm and functioning, indicate why.	■ Yes □ No	■ Yes □ No	■ Yes	□No	■ Yes □ No					
Is the sensor alarm circuit operational?	■ Yes □ No	■ Yes □ No	■ Yes	□No	■ Yes □ No					
Has sensor been inspected and in good operating condition?	■ Yes □ No	■ Yes □ No	■ Yes	□No	■ Yes □ No					
When placed in the test liquid, does the sensor trigger an alarm?	■ Yes □ No	■ Yes □ No	■ Yes	□No	■ Yes □ No	■Yes □ No	■ Yes □ No	■ Yes □ No		
When an alarm is triggered, is the sensor properly identified on the ATG console?	■ Yes □ No	■ Yes □ No	■ Yes	□No	■ Yes □ No	■Yes □ No	■ Yes □ No	■Yes □ No		
Any "No" answers indicates the sensor fails the test.										
Test Results	■ Pass □ Fail	■ Pass □ Fail	■ Pass	□ Fail	■ Pass □ Fail	■ Pass □ Fail	■ Pass □ Fail	■ Pass □ Fail		
Comments: IN Cert # UC20098339 PEI Certified										
Tester's Name (print) Tony Walters Tester's Signature Hulling La Hester's Van Hester's Signature										



7400 Skyline Drive E * Columbus, OH * (614) 923-0154

LIQUID SENSOR FUNCTIONALITY TESTING										
Facility Name: Speedway #6116				Owner: Speedway,LLC						
Address: 1640 E Washington				Address:	600 Speedway	Dr				
City, State, Zip Code: Indianapolis, IN				City, Stat	e, Zip Code: Eno	n,OH				
Facility I.D. #:				Phone #:	:					
Testing Company: US Tank Alliance				Phone #: (440) 238-7705 Date: 2-13-24						
This procedure is to determine whether liquid sensors located in the interstitial space of UST systems are able to detect the presence of water and fuel. See PEI/RP1200 Section 8.3 for the test procedure.										
Sensor Location	L8-7/8 208									
Product Stored	RUL/PUL/DSL									
Type of Sensor	☐ Discriminating ■ Non-discriminating	☐ Discriminating☐ Non-discriminating	☐ Discriminating ☐ Non-discrimi- nating		☐ Discriminating☐ Non-discrimi- nating	☐ Discriminating☐ Non-discriminating	☐ Discriminating ☐ Non-discrimi- nating	☐ Discriminating ☐ Non-discriminating		
Test Liquid	■ Water □ Product	□ Water□ Product	☐ Water ☐ Product		□ Water□ Product	□ Water□ Product	☐ Water ☐ Product	□ Water □ Product		
Is the ATG console clear of any active or recurring warnings or alarms regarding the leak sensor? If the sensor is in alarm and functioning, indicate why.	■ Yes □ No	□ Yes □ No	□Yes	□No	□ Yes □ No	□ Yes □ No	□ Yes □ No	□ Yes □ No		
Is the sensor alarm circuit operational?	■ Yes □ No	□ Yes □ No	□ Yes	□No	□ Yes □ No	□ Yes □ No	□ Yes □ No	□ Yes □ No		
Has sensor been inspected and in good operating condition?	■ Yes □ No	□ Yes □ No	□ Yes	□No	□ Yes □ No	□ Yes □ No	□ Yes □ No	□ Yes □ No		
When placed in the test liquid, does the sensor trigger an alarm?	■ Yes □ No	□ Yes □ No	□ Yes	□No	□ Yes □ No	☐ Yes ☐ No	□ Yes □ No	□ Yes □ No		
When an alarm is triggered, is the sensor properly identified on the ATG console?	■Yes □ No	□ Yes □ No	□Yes	□No	□Yes □No	□ Yes □ No	□Yes □No	□Yes □No		
Any "No" answers indicates the sensor fails the test.										
Test Results	■ Pass □ Fail	□ Pass □ Fail	□ Pass	☐ Fail	☐ Pass ☐ Fail	□ Pass □ Fail	□ Pass □ Fail	☐ Pass ☐ Fail		
Comments: IN Cert # UC20098339 PEI Certified										
Tester's Name (print) Tony Walters Tester's Signature Hullway Latters										



7400 Skyline Drive E * Columbus, OH 43235 * (614) 923-0154

MECHANICAL AND ELECTRONIC LINE LEAK DETECTORS PERFORMANCE TESTS									
Facility Name: Speedway #6116	Owner: Speedw	Owner: Speedway,LLC							
Address: 1640 E Washington	Address: 600 Speedway								
City, State, Zip Code: Indianapolis,IN	City, State, Zip	Code: Enon,OH							
Facility I.D. #:	Phone #:								
Testing Company: US Tank Alliance			Phone #: (440) 2	38-7705	Date: 2-13-24				
This data sheet can be used to test mech	nanical line leak) and electronic	line leak detecto	ors (ELLD) with s	submersible				
turbine pump (STP) systems. See PEI/RP1200 Sections 9.1 and 9.2 for test procedures.									
Line Number	1	2	3	4					
Product Stored	RUL	PUL	DSL	K-1					
Leak Detector Manufacturer	Veeder Root	Veeder Root	Veeder Root	Veeder Root					
Leak Detector Model	Elect	Elect	Elect	Elect					
Type of Leak Detector	☐ MLLD ■ ELLD	□ MLLD ■ ELLD	□ MLLD ■ ELLD	□ MLLD ■ ELLD	□ MLLD □ ELLD	□ MLLD □ ELLD			
MLLD (ALL PRESSURE MEASUREMEN	ITS ARE MADE	IN PSIG)							
STP Full Operating Pressure									
Check Valve Holding Pressure									
Line Resiliency (ml) (line bleed back vol- ume as measured from check valve hold- ing pressure to 0 psig)									
Step Through Time in Seconds (time the MLLD hesitates at metering pressure before going to full operating pressure as measured from 0 psig with no leak induced on the line)									
Metering Pressure (STP pressure when simulated leak rate 3 gph at 10 psig)									
Opening Time in Seconds (the time the MLLD opens to allow full pressure after simulated leak is stopped)									
Does the STP pressure remain at or below the metering pressure for at least 60 seconds when the simulated leak is induced?	□Yes □No	□Yes □No	□Yes □No	□Yes □No	□Yes □No	□Yes □No			
Does the leak detector reset (trip) when the line pressure is bled off to zero psig?	□Yes □No	□Yes □No	□Yes □No	□Yes □No	□Yes □No	□Yes □No			
Does the STP properly cycle on/off under normal fuel system operation conditions?	□Yes □No	□ Yes □ No	□Yes □No	□Yes □No	□ Yes □ No	□ Yes □ No			
A "No" answer to either of the above questions indicates the MLLD fails the test.									
ELLD (ALL PRESSURE MEASUREMEN									
STP Full Operating Pressure	29	27	28	26					
How many test cycles are observed before alarm/shutdown occurs?	2	2	2	2					
Does the simulated leak cause an alarm?	■ Yes □ No	■ Yes □ No	■ Yes □ No	■Yes □ No	☐ Yes ☐ No	☐ Yes ☐ No			
A "No" answer to the above question indicates the ELLD fails the test.									
Does the simulated leak cause an STP shutdown?	■ Yes □ No □ NA	■ Yes □ No □ NA	■ Yes □ No □ NA	■ Yes □ No □ NA	☐ Yes ☐ No ☐ NA	☐ Yes ☐ No ☐ NA			
Test Results	■ Pass □ Fail	■ Pass □ Fail	■ Pass □ Fail	■ Pass □ Fail	☐ Pass ☐ Fail	☐ Pass ☐ Fail			
Comments: IN Cert # UC20098339 PEI Certified									
Tester's Name (print) Tony Walters Tester's Signature									





Site Name: Speedway Site Number: 6116 Date: 2-13-	24
Tested at farthest dispenser from tank pad (Line and/or LD testing)	
Operating pressure checked at farthest dispenser from tank pad (Line and/or LD testing)	
LDs were tested "as is", nothing was isolated (valved off) for test (LD testing only)	
Printouts for ELLD tests have been attached	
Lines and/or LD tested from dispenser #: 3/4 & 9	
Any suction lines? *YES *NO Product: *VUP *VAT	
If this is after construction or repair, was final cover down?	



7400 Skyline Drive E * Columbus, OH 43235 * (614) 923-0154

		SH	IEAR VALVE C	PERATION II	NSPECTION				
Facility Name: Speedway #6116					Owner Speedv	vay,LLC			
Address: 1640 E Washington					Address 600 S	peedway Dr			
City, State, Zip Code: Indianapolis	s,IN				City, State, Zip	Code: Enon,OH	I		
Facility I.D. #:					Phone #:				
Testing Company: US Tank Allia	ince				Phone #:		Test Date:	2-13-24	
This data sheet is for inspecting s	hear valves loca	ited inside dispe	nsers. See PEI/	RP1200 Section	n 10 for the ins	pection procedu	ıre.		
Product Grade	RUL	RUL	RUL	RUL	PUL	PUL	PUL	PUL	DSL
Dispenser ID#	1/2	3/4	5/6	7/8	1/2	3/4	5/6	7/8	3/4
Shear ValveType (Product/Vapor)	Product								
1. Is the shear valve rigidly anchored to the dispenser box frame or dispenser island?	■ Yes □ No								
2. Is the shear section positioned between ½ inch above or below the top surface of the dispenser island?	■Yes □ No	■ Yes □ No	■ Yes □ No	■ Yes □ No	■ Yes □ No	■Yes □ No	■Yes □ No	■Yes □ No	■ Yes □ No
3. Is the lever arm free to move?	■ Yes □ No □ NA	■ Yes □ No □ NA	■ Yes □ No □ NA	■ Yes □ No □ NA	■ Yes □ No □ NA				
4. Does the lever arm snap shut the poppet valve?	■ Yes □ No □ NA	■ Yes □ No □ NA	■ Yes □ No □ NA	■ Yes □ No □ NA	■ Yes □ No □ NA	■ Yes □ No □ NA	■ Yes □ No □ NA	■ Yes □ No □ NA	■ Yes □ No □ NA
5. Can any product be dispensed when the product shear valve is closed?	□ Yes ■ No □ NA	□ Yes ■ No □ NA	☐ Yes ■ No ☐ NA	□ Yes ■ No □ NA					
A "No" to Lines 1-4 or a "Yes" for	Line 5 indicates	a test failure.							
Test Results	■ Pass □ Fail								
Comments: [N Cert # UC2009	98339 PEI Certifi	ed							

Tester's Name (print) _____Tony Walters

Tester's Signature Hullhomy Walters



7400 Skyline Drive E * Columbus, OH 43235 * (614) 923-0154

		Sŀ	HEAR VALVE (PERATION I	SPECTION				
Facility Name: Speedway #6116	Facility Name: Speedway #6116 Owner Speedway,LLC								
Address: 1640 E Washington					Address 600 S	Speedway Dr			
City, State, Zip Code: Indianapolis	s,IN				City, State, Zip	Code: Enon,OF	1		
Facility I.D. #:				Phone #:					
Testing Company: US Tank Allia	ince				Phone #:		Test Date	2-13-24	
This data sheet is for inspecting s	hear valves loca	ated inside dispe	ensers. See PEI/	'RP1200 Sectio	n 10 for the ins	pection procedu	ure.		
Product Grade	DSL								
Dispenser ID#	7/8								
Shear ValveType (Product/Vapor)	Product								
Is the shear valve rigidly anchored to the dispenser box frame or dispenser island?	■ Yes □ No	□ Yes □ No	□ Yes □ No	□ Yes □ No	□ Yes □ No	□ Yes □ No	□ Yes □ No	□ Yes □ No	□ Yes □ No
2. Is the shear section positioned between ½ inch above or below the top surface of the dispenser island?	■ Yes □ No	□ Yes □ No	□ Yes □ No	□ Yes □ No	☐ Yes ☐ No	□ Yes □ No			
3. Is the lever arm free to move?	■ Yes □ No □ NA	□ Yes □ No □ NA	□ Yes □ No □ NA	□ Yes □ No □ NA	□ Yes □ No □ NA	□ Yes □ No □ NA	□ Yes □ No □ NA	□ Yes □ No □ NA	□ Yes □ No □ NA
4. Does the lever arm snap shut the poppet valve?	■ Yes □ No □ NA	□ Yes □ No □ NA	□ Yes □ No □ NA	☐ Yes ☐ No ☐ NA	□ Yes □ No □ NA				
5. Can any product be dispensed when the product shear valve is closed?	□ Yes ■ No □ NA	□ Yes □ No □ NA	□ Yes □ No □ NA	□ Yes □ No □ NA	□ Yes □ No □ NA	□ Yes □ No □ NA	□ Yes □ No □ NA	□ Yes □ No □ NA	□ Yes □ No □ NA
A "No" to Lines 1-4 or a "Yes" for	Line 5 indicates	a test failure.							
Test Results	■ Pass □ Fail	□ Pass □ Fail	□ Pass □ Fail	□ Pass □ Fail	□ Pass □ Fail	□ Pass □ Fail	□ Pass □ Fail	□ Pass □ Fail	□ Pass □ Fail
Comments: [N Cert # UC20	0098339 PEI Certi	fied		A					
Tester's Name (print)Tony Wa	ılters		Tester's S	ignature <u>#</u>	Mony	Walt	ers		



7400 Skyline Drive E * Columbus, OH 43235 * (614) 923-0154

EMERGENCY STOP SWITCH OPERATION INSPECTION							
Facility Name: Speedway #611	6		Owner: Speed	way,LLC			
Address: 1640 E Washington			Address: 600 S				
City, State, Zip Code: Indianapoli	s,IN		City, State, Zip C	Code: Enon,OH			
Facility I.D. #:			Phone #:				
Testing Company: US Tank Allia	nce		Phone #: (440)	238-7705	Date: 2-13-24		
This procedure is to verify the operation of all emergency stop switches/buttons (E-stops). Each E-stop must disconnect power to dispensers, submersible turbine pumps (STPs) and all non-intrinsically safe electrical equipment in classified areas. Test each E-stop separately. See PEI/RP1200 Section 11 for the inspection procedure.							
E-stop Number or ID	1						
Location	By Counter						
E-stops labeled and located where easily accessible?	■ Yes □ No	□ Yes □ No	□ Yes □ No	□Yes □No	□Yes □No	□Yes □No	
System fully powered and in normal operating condition?	■ Yes □ No	□Yes □No	□ Yes □ No	□Yes □No	□Yes □No	□Yes □No	
3. After activating E-stop, power	disconnected from	m:					
3a. All dispensing devices on all islands?	■ Yes □ No	□ Yes □ No	□ Yes □ No	□ Yes □ No	□Yes □No	□Yes □No	
3b. All STPs for all fuel grades?	■ Yes □ No	□Yes □No	□ Yes □ No	□Yes □No	□Yes □No	□Yes □No	
3c. All power, control and signal circuits associated with the dispensing devices and the STPs?	■ Yes □ No	□Yes □No	□ Yes □ No	□Yes □No	□Yes □No	□Yes □No	
3d. All other non-intrin- sically safe electrical equipment in classified areas surrounding fuel dispensing devices?	■ Yes □ No	□Yes □No	□Yes □No	□Yes □No	□Yes □No	□Yes □No	
4. All intrinsically safe electrical equipment remains energized after E-stop activation?	■Yes □ No	□Yes □No	□Yes □No	□Yes □No	□Yes □No	□Yes □No	
5. After testing, E-stop has been reset and power reestablished to normal operating condition?	■ Yes □ No	□Yes □No	□ Yes □ No	□Yes □No	□Yes □No	□Yes □No	
A "No" to lines 3a-3d indicates a	test failure.						
Test Results	■ Pass □ Fail	☐ Pass ☐ Fail	□ Pass □ Fail	□ Pass □ Fail	□ Pass □ Fail	□ Pass □ Fail	
Comments: IN Cert # UC200	098339 PEI Certif	fied					

Tester's Name (print) Tony Walters

Tester's Signature Anthony Walters

7-ELEVEN, INC

43768/6116 1640 EAST WASHINGTON ST INDIANAPOLIS, IN 46201-3851



Inspection Date	Completed Date	Inspected By	Pending Review Date	Reviewed By
5/20/2024	5/20/2024	Ryan Green	-	-

Section Name					
Question	Response	Comment	Pass/Fail	# of Attach ments	Score
RECORD KEEPING (Copies	of All Document	s located in SEED	OS)		0
Current Years Financial Responsibility Document available?	Yes		PASS	0	N/A
UST Permit / Certificate to Operate Available and Not Expired?	Yes		PASS	0	N/A
Emergency Response Plan Available?	Yes		PASS	0	N/A
Current Years Release Detection Records available?	Yes		PASS	0	N/A
State/7-11 monthly Inspection Forms completed and available, (12 months worth) and picture uploaded? (Required STATES: IL, KS, OH, TN)	Yes		PASS	0	N/A
UST Operator Documenta					0
Class C Operator Training Certificates Available for All Employees? (If Not, List Employee's Name) (ILINOIS recertification required every 2 years)	Yes		PASS	0	N/A
Class A/B Operator Certificate (s) available?	Yes		PASS	0	N/A
Section Name Question	Response	Comment	Pass/Fail	# of Attach	Score
FACILITY				ments	0
Automatic Tank Gauge					0
Automatic Tank Gauge ATG Accessible to Employees (no obstruction)?	Yes		PASS	0	
ATG Accessible to Employees (no	Yes		PASS PASS	0	0
ATG Accessible to Employees (no obstruction)?					0 N/A
ATG Accessible to Employees (no obstruction)? Is the ATG in alarm? Were ATG reports printed and photo of tapes	No		PASS	0	0 N/A N/A
ATG Accessible to Employees (no obstruction)? Is the ATG in alarm? Were ATG reports printed and photo of tapes taken? Is the ATG Printer working? (Replace paper	No Yes		PASS	0 3	O N/A N/A N/A
ATG Accessible to Employees (no obstruction)? Is the ATG in alarm? Were ATG reports printed and photo of tapes taken? Is the ATG Printer working? (Replace paper if needed)	No Yes		PASS	0 3	0 N/A N/A N/A
ATG Accessible to Employees (no obstruction)? Is the ATG in alarm? Were ATG reports printed and photo of tapes taken? Is the ATG Printer working? (Replace paper if needed) Emergency Shut Off	No Yes Yes		PASS PASS	0 3 0	0 N/A N/A N/A O
ATG Accessible to Employees (no obstruction)? Is the ATG in alarm? Were ATG reports printed and photo of tapes taken? Is the ATG Printer working? (Replace paper if needed) Emergency Shut Off Is there a ESO Accessible to Employees? Is ESO Damaged? (If YES, describe	No Yes Yes		PASS PASS PASS	0 3 0	0 N/A N/A N/A N/A
ATG Accessible to Employees (no obstruction)? Is the ATG in alarm? Were ATG reports printed and photo of tapes taken? Is the ATG Printer working? (Replace paper if needed) Emergency Shut Off Is there a ESO Accessible to Employees? Is ESO Damaged? (If YES, describe damaged)	No Yes Yes		PASS PASS PASS	0 3 0	0 N/A N/A N/A O N/A N/A
ATG Accessible to Employees (no obstruction)? Is the ATG in alarm? Were ATG reports printed and photo of tapes taken? Is the ATG Printer working? (Replace paper if needed) Emergency Shut Off Is there a ESO Accessible to Employees? Is ESO Damaged? (If YES, describe damaged) Fire Extinguishers Is there a Fire Extinguisher within 100 Feet	No Yes Yes Yes No		PASS PASS PASS PASS	0 3 0 0 0	0 N/A N/A N/A N/A 0 N/A N/A

Section Name					
Question	Response	Comment	Pass/Fail	# of Attach ments	Score
TANK PAD					0
STP Sumps					0
Are all STP Sumps Dry and Free of Debris?	Yes		PASS	0	N/A
Are all STP Sump lids and gaskets in good condition?	Yes		PASS	0	N/A
Are the STP and piping connections in the sumps free of any signs of seepage?	Yes		PASS	0	N/A
Spill Buckets					0
All Spill Buckets have Fill Drop Tubes Present and Undamaged?	Yes		PASS	0	N/A
All Spill Buckets free of liquid & debris?	Yes		PASS	0	N/A
All Spill Buckets Drain valve functioning properly?	Yes		PASS	0	N/A
All Spill Buckets Fill Caps have Gaskets & Sealing properly? Inspector to replace if missing or damaged	Yes		PASS	0	N/A
All Spill Buckets in good condition?	Yes		PASS	0	N/A
All Manholes Lids painted and not faded? VENDOR replace & paint if needed	Yes		PASS	0	N/A
Vapor Recovery Buckets					0
All Vapor Poppets Sealing properly after compression and undamaged?	Yes		PASS	0	N/A
All Vapor caps and gasket in good condition? Inspector to replace if missing or damage	Yes		PASS	0	N/A
All Manway cover/lids in good condition? Inspector to replace if missing or damaged	Yes		PASS	0	N/A
Do Manway cover/lids need painted? Inspector to paint as needed	No		PASS	0	N/A
Vent Stack					0
Vent Caps Present?	Yes		PASS	0	N/A
If Vent Box Present, free of liquid & debris?	Yes		PASS	0	N/A
If Sensor is present in Vent box, sitting on the bottom?	Yes		PASS	0	N/A
Are bollards damaged by Vent pipes? Section Name	No		PASS	0	N/A
Question	Response	Comment	Pass/Fail	# of Attach ments	Score
DISPENSERS					0

All Dispenser Nozzles & Swivels functional and show no signs of weeping? If No, list damaged & dispenser #	Yes		PASS	0	N/A
All Dispenser Hoses in good condition, showing no Signs of splitting or cracking? If NO, list dispenser #	Yes		PASS	0	N/A
All Dispensers Hose Length 6", Minimum from Ground or Island? If NO, list dispenser #	Yes		PASS	0	N/A
All Dispensers Breakaways and Whip Hoses in good condition and Show no Signs of weeping? If NO, list dispenser # and equipment	Yes		PASS	0	N/A
Are all UDC's (if present) Free of liquid and debris?	Yes		PASS	0	N/A
Do any of the Dispensers Meter/Union/Filter (s) show signs of weepage? If YES, list dispenser # and equipment	No		PASS	0	N/A
Are all Dispenser Shear Valves mounted correctly & secured? If No, list dispenser # and product	Yes		PASS	0	N/A
If Sensors are Present in UDC's, sitting on the bottom? If No, list UDC #	Yes		PASS	0	N/A
All Dispenser Calibration Metal Tie Lock Seals Intact? If No, list dispenser # and product	Yes		PASS	0	N/A
Do any Dispenser Meter Seals show visible sign of leaks? If Yes, list dispenser #	No		PASS	0	N/A
Dispenser Island Bollards damaged? If Yes, list dispenser #	No		PASS	0	N/A
Any Skimming Device Present? If present shut dispenser down immediately and notify Store Manager and 7-Eleven Compliance personnel. Section Name	No		PASS	0	N/A
Question	Response	Comment	Pass/Fail	# of Attach ments	Score
HAZARDOUS WASTE					0
Are there Hazardous Waste Drums Needing Picked up? If Yes, list contents and # of barrels	No		PASS	0	N/A
Is a drum for solids present?	Yes		N/A	0	N/A
Is the solid drum in good condition?	Yes		PASS	0	N/A
Is the solids drum 75% full?	No		PASS	0	N/A
Is a drum for liquids present?	Yes		N/A	0	N/A
Is the liquid drum in good condition?	Yes		PASS	0	N/A
Is the liquids drum 75% full?	No		PASS	0	N/A

Are the drums properly labeled?	Yes		PASS	0	N/A
Are the labels completely filled out?	Yes		PASS	0	N/A
Section Name					
Question	Response	Comment	Pass/Fail	# of Attach ments	Score
ENVIRONMENTAL					0
Are any Well covers damaged?	No		PASS	0	N/A

7-ELEVEN, INC

43768/6116 1640 EAST WASHINGTON ST INDIANAPOLIS, IN 46201-3851



Inspection Date	Completed Date	Inspected By	Pending Review Date	Reviewed By
4/1/2024	4/1/2024	Marcus Jackson	-	-

Section Name					
Question	Response	Comment	Pass/Fail	# of Attach ments	Score
RECORD KEEPING (Copies	of All Document	s located in SEEC	OS)		0
Current Years Financial Responsibility Document available?	Yes		PASS	0	N/A
UST Permit / Certificate to Operate Available and Not Expired?	Yes		PASS	0	N/A
Emergency Response Plan Available?	Yes		PASS	0	N/A
Current Years Release Detection Records available?	Yes		PASS	0	N/A
State/7-11 monthly Inspection Forms completed and available, (12 months worth) and picture uploaded? (Required STATES: IL, KS, OH, TN)	Yes		PASS	0	N/A
UST Operator Documenta					0
Class C Operator Training Certificates Available for All Employees? (If Not, List Employee's Name) (ILINOIS recertification required every 2 years)	Yes		PASS	0	N/A
Class A/B Operator Certificate (s) available?	Yes		PASS	0	N/A
Section Name					
Question	Response	Comment	Pass/Fail	# of Attach ments	Score
PACILITY	Response	Comment	Pass/Fail	Attach	Score
	Response	Comment	Pass/Fail	Attach	
FACILITY	Yes	Comment	Pass/Fail	Attach	0
FACILITY Automatic Tank Gauge ATG Accessible to Employees (no		Comment		Attach ments	0
FACILITY Automatic Tank Gauge ATG Accessible to Employees (no obstruction)?	Yes	Comment	PASS	Attach ments 0	0 0 N/A
FACILITY Automatic Tank Gauge ATG Accessible to Employees (no obstruction)? Is the ATG in alarm? Were ATG reports printed and photo of tapes	Yes	Comment	PASS PASS	Attach ments 0	0 0 N/A N/A
FACILITY Automatic Tank Gauge ATG Accessible to Employees (no obstruction)? Is the ATG in alarm? Were ATG reports printed and photo of tapes taken? Is the ATG Printer working? (Replace paper	Yes No Yes	Comment	PASS PASS	O 1	0 0 N/A N/A N/A
FACILITY Automatic Tank Gauge ATG Accessible to Employees (no obstruction)? Is the ATG in alarm? Were ATG reports printed and photo of tapes taken? Is the ATG Printer working? (Replace paper if needed)	Yes No Yes	Comment	PASS PASS	O 1	0 N/A N/A N/A
FACILITY Automatic Tank Gauge ATG Accessible to Employees (no obstruction)? Is the ATG in alarm? Were ATG reports printed and photo of tapes taken? Is the ATG Printer working? (Replace paper if needed) Emergency Shut Off	Yes No Yes Yes	Comment	PASS PASS PASS	O 1 1 0	0 0 N/A N/A N/A N/A
FACILITY Automatic Tank Gauge ATG Accessible to Employees (no obstruction)? Is the ATG in alarm? Were ATG reports printed and photo of tapes taken? Is the ATG Printer working? (Replace paper if needed) Emergency Shut Off Is there a ESO Accessible to Employees? Is ESO Damaged? (If YES, describe	Yes No Yes Yes Yes	Comment	PASS PASS PASS	O 1 1 O O	0 0 N/A N/A N/A N/A
FACILITY Automatic Tank Gauge ATG Accessible to Employees (no obstruction)? Is the ATG in alarm? Were ATG reports printed and photo of tapes taken? Is the ATG Printer working? (Replace paper if needed) Emergency Shut Off Is there a ESO Accessible to Employees? Is ESO Damaged? (If YES, describe damaged)	Yes No Yes Yes Yes	Comment	PASS PASS PASS	O 1 1 O O	0 0 N/A N/A N/A 0 N/A N/A
FACILITY Automatic Tank Gauge ATG Accessible to Employees (no obstruction)? Is the ATG in alarm? Were ATG reports printed and photo of tapes taken? Is the ATG Printer working? (Replace paper if needed) Emergency Shut Off Is there a ESO Accessible to Employees? Is ESO Damaged? (If YES, describe damaged) Fire Extinguishers Is there a Fire Extinguisher within 100 Feet	Yes No Yes Yes Yes No	Comment	PASS PASS PASS PASS	0 1 1 0 0 0 0	0 0 N/A N/A N/A N/A 0 N/A N/A

Question	Response	Comment	Pass/Fail	# of Attach ments	Score
TANK PAD					0
STP Sumps					0
Are all STP Sumps Dry and Free of Debris?	Yes		PASS	0	N/A
Are all STP Sump lids and gaskets in good condition?	Yes		PASS	0	N/A
Are the STP and piping connections in the sumps free of any signs of seepage?	Yes		PASS	0	N/A
Spill Buckets					0
All Spill Buckets have Fill Drop Tubes Present and Undamaged?	Yes		PASS	0	N/A
All Spill Buckets free of liquid & debris?	No	No Liquid Wastedrum Onsite	FAIL	0	N/A
All Spill Buckets Drain valve functioning properly?	Yes		PASS	0	N/A
All Spill Buckets Fill Caps have Gaskets & Sealing properly? Inspector to replace if missing or damaged	Yes		PASS	0	N/A
All Spill Buckets in good condition?	No	RUL Lid Needs Replaced	FAIL	1	N/A
All Manholes Lids painted and not faded? VENDOR replace & paint if needed	Yes		PASS	0	N/A
Vapor Recovery Buckets					0
All Vapor Poppets Sealing properly after compression and undamaged?	Yes		PASS	0	N/A
All Vapor caps and gasket in good condition? Inspector to replace if missing or damage	Yes		PASS	0	N/A
All Manway cover/lids in good condition? Inspector to replace if missing or damaged	Yes		PASS	0	N/A
Do Manway cover/lids need painted? Inspector to paint as needed	Yes	Tankpad Painting Needed	FAIL	0	N/A
Vent Stack					0
Vent Caps Present?	Yes		PASS	0	N/A
If Vent Box Present, free of liquid & debris?	NA		PASS	0	N/A
If Sensor is present in Vent box, sitting on the bottom?	NA		PASS	0	N/A
Are bollards damaged by Vent pipes? Section Name	No		PASS	0	N/A
Question	Response	Comment	Pass/Fail	# of Attach ments	Score
DISPENSERS					0

All Dispenser Nozzles & Swivels functional and show no signs of weeping? If No, list damaged & dispenser #	Yes		PASS	0	N/A
All Dispenser Hoses in good condition, showing no Signs of splitting or cracking? If NO, list dispenser #	Yes		PASS	0	N/A
All Dispensers Hose Length 6", Minimum from Ground or Island? If NO, list dispenser #	NA		PASS	0	N/A
All Dispensers Breakaways and Whip Hoses in good condition and Show no Signs of weeping? If NO, list dispenser # and equipment	Yes		PASS	0	N/A
Are all UDC's (if present) Free of liquid and debris?	Yes		PASS	0	N/A
Do any of the Dispensers Meter/Union/Filter (s) show signs of weepage? If YES, list dispenser # and equipment	No		PASS	0	N/A
Are all Dispenser Shear Valves mounted correctly & secured? If No, list dispenser # and product	Yes		PASS	0	N/A
If Sensors are Present in UDC's, sitting on the bottom? If No, list UDC #	Yes		PASS	0	N/A
All Dispenser Calibration Metal Tie Lock Seals Intact? If No, list dispenser # and product	Yes		PASS	0	N/A
Do any Dispenser Meter Seals show visible sign of leaks? If Yes, list dispenser #	No		PASS	0	N/A
Dispenser Island Bollards damaged? If Yes, list dispenser #	No		PASS	0	N/A
Any Skimming Device Present? If present shut dispenser down immediately and notify Store Manager and 7-Eleven Compliance personnel. Section Name	No		PASS	0	N/A
Question	Response	Comment	Pass/Fail	# of Attach ments	Score
HAZARDOUS WASTE					0
Are there Hazardous Waste Drums Needing Picked up? If Yes, list contents and # of barrels	NA		PASS	0	N/A
Is a drum for solids present?	No		N/A	0	N/A
Is the solid drum in good condition?	N/A		N/A	0	N/A
Is the solids drum 75% full?	N/A		N/A	0	N/A
Is a drum for liquids present?	Yes		N/A	0	N/A
Is the liquid drum in good condition?	Yes		PASS	0	N/A
Is the liquids drum 75% full?	No		PASS	0	N/A

Are the drums properly labeled?	Yes		PASS	0	N/A
Are the labels completely filled out?	No		FAIL	0	N/A
Section Name					
Question	Response	Comment	Pass/Fail	# of Attach ments	Score
ENVIRONMENTAL					
Are any Well covers damaged?	No		PASS	0	N/A

7-ELEVEN, INC

43768/6116 1640 EAST WASHINGTON ST INDIANAPOLIS, IN 46201-3851



Inspection Date	Completed Date	Inspected By	Pending Review Date	Reviewed By
3/1/2024	3/1/2024	Marcus Jackson	-	-

Section Name					
Question	Response	Comment	Pass/Fail	# of Attach ments	Score
RECORD KEEPING (Copies	of All Document	s located in SEED	OS)		0
Current Years Financial Responsibility Document available?	Yes		PASS	0	N/A
UST Permit / Certificate to Operate Available and Not Expired?	Yes		PASS	0	N/A
Emergency Response Plan Available?	Yes		PASS	0	N/A
Current Years Release Detection Records available?	Yes		PASS	0	N/A
State/7-11 monthly Inspection Forms completed and available, (12 months worth) and picture uploaded? (Required STATES: IL, KS, OH, TN)	Yes		PASS	0	N/A
UST Operator Documenta					0
Class C Operator Training Certificates Available for All Employees? (If Not, List Employee's Name) (ILINOIS recertification required every 2 years)	Yes		PASS	0	N/A
Class A/B Operator Certificate (s) available?	Yes		PASS	0	N/A
Section Name Question	Response	Comment	Pass/Fail	# of Attach ments	Score
FACILITY					0
Automatic Tank Gauge					0
ATG Accessible to Employees (no obstruction)?	Yes		PASS	0	N/A
Is the ATG in alarm?	Yes	Overfill Alarm	FAIL	1	N/A
Were ATG reports printed and photo of tapes taken?	Yes		PASS	1	N/A
Is the ATG Printer working? (Replace paper					N/A
if needed)	Yes		PASS	0	IN/A
if needed) Emergency Shut Off	Yes		PASS	0	0
	Yes		PASS	0	
Emergency Shut Off					0
Emergency Shut Off Is there a ESO Accessible to Employees? Is ESO Damaged? (If YES, describe	Yes		PASS	0	O N/A
Emergency Shut Off Is there a ESO Accessible to Employees? Is ESO Damaged? (If YES, describe damaged)	Yes		PASS	0	O N/A N/A
Emergency Shut Off Is there a ESO Accessible to Employees? Is ESO Damaged? (If YES, describe damaged) Fire Extinguishers Is there a Fire Extinguisher within 100 Feet	Yes		PASS PASS	0	0 N/A N/A

Section Name Question	Response	Comment	Pass/Fail	# of Attach	Score
	Кезритае	Comment	1 433/1 411	ments	OCOTE
TANK PAD					0
STP Sumps					0
Are all STP Sumps Dry and Free of Debris?	Yes		PASS	0	N/A
Are all STP Sump lids and gaskets in good condition?	Yes		PASS	0	N/A
Are the STP and piping connections in the sumps free of any signs of seepage?	Yes		PASS	0	N/A
Spill Buckets					0
All Spill Buckets have Fill Drop Tubes Present and Undamaged?	Yes		PASS	0	N/A
All Spill Buckets free of liquid & debris?	No	No Liquid Wastedrum Onsite	FAIL	0	N/A
All Spill Buckets Drain valve functioning properly?	Yes		PASS	0	N/A
All Spill Buckets Fill Caps have Gaskets & Sealing properly? Inspector to replace if missing or damaged	Yes		PASS	0	N/A
All Spill Buckets in good condition?	Yes		PASS	0	N/A
All Manholes Lids painted and not faded? VENDOR replace & paint if needed	No	Rul Spill Bucket Lid Needs Replaced	FAIL	0	N/A
Vapor Recovery Buckets					0
All Vapor Poppets Sealing properly after compression and undamaged?	Yes		PASS	0	N/A
All Vapor caps and gasket in good condition? Inspector to replace if missing or damage	Yes		PASS	0	N/A
All Manway cover/lids in good condition? Inspector to replace if missing or damaged	Yes		PASS	0	N/A
Do Manway cover/lids need painted? Inspector to paint as needed	No		PASS	0	N/A
Vent Stack					0
Vent Caps Present?	Yes		PASS	0	N/A
If Vent Box Present, free of liquid & debris?	NA		PASS	0	N/A
If Sensor is present in Vent box, sitting on the bottom?	NA		PASS	0	N/A
Are bollards damaged by Vent pipes?	No		PASS	0	N/A
Question	Response	Comment	Pass/Fail	# of Attach ments	Score
DISPENSERS				HIGHLS	0

All Dispenser Nozzles & Swivels functional and show no signs of weeping? If No, list damaged & dispenser #	Yes		PASS	0	N/A
All Dispenser Hoses in good condition, showing no Signs of splitting or cracking? If NO, list dispenser #	Yes		PASS	0	N/A
All Dispensers Hose Length 6", Minimum from Ground or Island? If NO, list dispenser #	NA		PASS	0	N/A
All Dispensers Breakaways and Whip Hoses in good condition and Show no Signs of weeping? If NO, list dispenser # and equipment	Yes		PASS	0	N/A
Are all UDC's (if present) Free of liquid and debris?	Yes		PASS	0	N/A
Do any of the Dispensers Meter/Union/Filter (s) show signs of weepage? If YES, list dispenser # and equipment	No		PASS	0	N/A
Are all Dispenser Shear Valves mounted correctly & secured? If No, list dispenser # and product	Yes		PASS	0	N/A
If Sensors are Present in UDC's, sitting on the bottom? If No, list UDC #	Yes		PASS	0	N/A
All Dispenser Calibration Metal Tie Lock Seals Intact? If No, list dispenser # and product	Yes		PASS	0	N/A
Do any Dispenser Meter Seals show visible sign of leaks? If Yes, list dispenser #	No		PASS	0	N/A
Dispenser Island Bollards damaged? If Yes, list dispenser #	No		PASS	0	N/A
Any Skimming Device Present? If present shut dispenser down immediately and notify Store Manager and 7-Eleven Compliance personnel. Section Name	No		PASS	0	N/A
Question	Response	Comment	Pass/Fail	# of Attach ments	Score
HAZARDOUS WASTE					0
Are there Hazardous Waste Drums Needing Picked up? If Yes, list contents and # of barrels	No		PASS	0	N/A
Is a drum for solids present?	No		N/A	0	N/A
Is the solid drum in good condition?	N/A		N/A	0	N/A
Is the solids drum 75% full?	N/A		N/A	0	N/A
Is a drum for liquids present?	No		N/A	0	N/A
Is the liquid drum in good condition?	N/A		N/A	0	N/A
Is the liquids drum 75% full?	N/A		N/A	0	N/A

Are the drums properly labeled?	N/A		N/A	0	N/A
Are the labels completely filled out?	N/A		N/A	0	N/A
Section Name					
Question	Response	Comment	Pass/Fail	# of Attach ments	Score
ENVIRONMENTAL					
Are any Well covers damaged?	No		PASS	0	N/A

7-ELEVEN, INC

43768/6116 1640 EAST WASHINGTON ST INDIANAPOLIS, IN 46201-3851



Inspection Date	Completed Date	Inspected By	Pending Review Date	Reviewed By
2/1/2024	2/1/2024	Marcus Jackson	-	-

Section Name						
Question	Response	Comment	Pass/Fail	# of Attach ments	Score	
RECORD KEEPING (Copies	of All Document	s located in SEED	OS)		0	
Current Years Financial Responsibility Document available?	Yes		PASS	0	N/A	
UST Permit / Certificate to Operate Available and Not Expired?	Yes		PASS	0	N/A	
Emergency Response Plan Available?	Yes		PASS	0	N/A	
Current Years Release Detection Records available?	Yes		PASS	0	N/A	
State/7-11 monthly Inspection Forms completed and available, (12 months worth) and picture uploaded? (Required STATES: IL, KS, OH, TN)	Yes		PASS	0	N/A	
UST Operator Documenta					0	
Class C Operator Training Certificates Available for All Employees? (If Not, List Employee's Name) (ILINOIS recertification required every 2 years)	Yes		PASS	0	N/A	
Class A/B Operator Certificate (s) available?	Yes		PASS	0	N/A	
Section Name Question	Response	Comment	Pass/Fail	# of Attach	Score	
				ments		
FACILITY						
					0	
Automatic Tank Gauge					0	
	Yes		PASS	0	_	
Automatic Tank Gauge ATG Accessible to Employees (no	Yes No	Fuel Alarm	PASS PASS	0 1	0	
Automatic Tank Gauge ATG Accessible to Employees (no obstruction)?		Fuel Alarm			0 N/A	
Automatic Tank Gauge ATG Accessible to Employees (no obstruction)? Is the ATG in alarm? Were ATG reports printed and photo of tapes	No	Fuel Alarm	PASS	1	O N/A N/A	
Automatic Tank Gauge ATG Accessible to Employees (no obstruction)? Is the ATG in alarm? Were ATG reports printed and photo of tapes taken? Is the ATG Printer working? (Replace paper	No Yes	Fuel Alarm	PASS	1	0 N/A N/A N/A	
Automatic Tank Gauge ATG Accessible to Employees (no obstruction)? Is the ATG in alarm? Were ATG reports printed and photo of tapes taken? Is the ATG Printer working? (Replace paper if needed)	No Yes	Fuel Alarm	PASS	1	0 N/A N/A N/A	
Automatic Tank Gauge ATG Accessible to Employees (no obstruction)? Is the ATG in alarm? Were ATG reports printed and photo of tapes taken? Is the ATG Printer working? (Replace paper if needed) Emergency Shut Off	No Yes Yes	Fuel Alarm	PASS PASS	1 1 0	0 N/A N/A N/A O	
Automatic Tank Gauge ATG Accessible to Employees (no obstruction)? Is the ATG in alarm? Were ATG reports printed and photo of tapes taken? Is the ATG Printer working? (Replace paper if needed) Emergency Shut Off Is there a ESO Accessible to Employees? Is ESO Damaged? (If YES, describe	No Yes Yes	Fuel Alarm	PASS PASS PASS	1 1 0	0 N/A N/A N/A O N/A	
Automatic Tank Gauge ATG Accessible to Employees (no obstruction)? Is the ATG in alarm? Were ATG reports printed and photo of tapes taken? Is the ATG Printer working? (Replace paper if needed) Emergency Shut Off Is there a ESO Accessible to Employees? Is ESO Damaged? (If YES, describe damaged)	No Yes Yes	Fuel Alarm	PASS PASS PASS	1 1 0	0 N/A N/A N/A N/A O N/A	
Automatic Tank Gauge ATG Accessible to Employees (no obstruction)? Is the ATG in alarm? Were ATG reports printed and photo of tapes taken? Is the ATG Printer working? (Replace paper if needed) Emergency Shut Off Is there a ESO Accessible to Employees? Is ESO Damaged? (If YES, describe damaged) Fire Extinguishers Is there a Fire Extinguisher within 100 Feet	No Yes Yes No	Fuel Alarm	PASS PASS PASS PASS	1 1 0 0 0 0	0 N/A N/A N/A N/A 0 N/A N/A	

Section Name					
Question	Response	Comment	Pass/Fail	# of Attach ments	Score
TANK PAD					0
STP Sumps				·	0
Are all STP Sumps Dry and Free of Debris?	No	K1 Stp Has Water Present	FAIL	1	N/A
Are all STP Sump lids and gaskets in good condition?	Yes		PASS	0	N/A
Are the STP and piping connections in the sumps free of any signs of seepage?	Yes		PASS	0	N/A
Spill Buckets					0
All Spill Buckets have Fill Drop Tubes Present and Undamaged?	Yes		PASS	0	N/A
All Spill Buckets free of liquid & debris?	Yes		PASS	0	N/A
All Spill Buckets Drain valve functioning properly?	Yes		PASS	0	N/A
All Spill Buckets Fill Caps have Gaskets & Sealing properly? Inspector to replace if missing or damaged	Yes		PASS	0	N/A
All Spill Buckets have a Product Tag / Collar present on each riser? If NO, list product and item needed	Yes		PASS	0	N/A
All Spill Buckets in good condition?	Yes		PASS	0	N/A
All Manholes Lids painted and not faded? VENDOR replace & paint if needed	No	Tankpad Painting Needed	FAIL	0	N/A
Vapor Recovery Buckets					0
All Vapor Poppets Sealing properly after compression and undamaged?	Yes		PASS	0	N/A
All Vapor caps and gasket in good condition? Inspector to replace if missing or damage	Yes		PASS	0	N/A
All Manway cover/lids in good condition? Inspector to replace if missing or damaged	Yes		PASS	0	N/A
Do Manway cover/lids need painted? Inspector to paint as needed	Yes	Tankpad Painting Needed	FAIL	0	N/A
Vent Stack					0
Vent Caps Present?	Yes		PASS	0	N/A
If Vent Box Present, free of liquid & debris?	NA		PASS	0	N/A
If Sensor is present in Vent box, sitting on the bottom?	NA		PASS	0	N/A
Are bollards damaged by Vent pipes?	No		PASS	0	N/A
Question	Response	Comment	Pass/Fail	# of Attach ments	Score

DISPENSERS					0
All Dispenser Nozzles & Swivels functional and show no signs of weeping? If No, list damaged & dispenser #	Yes		PASS	0	N/A
All Dispenser Hoses in good condition, showing no Signs of splitting or cracking? If NO, list dispenser #	Yes		PASS	0	N/A
All Dispensers Hose Length 6", Minimum from Ground or Island? If NO, list dispenser #	NA		PASS	0	N/A
All Dispensers Breakaways and Whip Hoses in good condition and Show no Signs of weeping? If NO, list dispenser # and equipment	Yes		PASS	0	N/A
Are all UDC's (if present) Free of liquid and debris?	Yes		PASS	0	N/A
Do any of the Dispensers Meter/Union/Filter (s) show signs of weepage? If YES, list dispenser # and equipment	No		PASS	0	N/A
Are all Dispenser Shear Valves mounted correctly & secured? If No, list dispenser # and product	Yes		PASS	0	N/A
If Sensors are Present in UDC's, sitting on the bottom? If No, list UDC #	Yes		PASS	0	N/A
All Dispenser Calibration Metal Tie Lock Seals Intact? If No, list dispenser # and product	Yes		PASS	0	N/A
Do any Dispenser Meter Seals show visible sign of leaks? If Yes, list dispenser #	No		PASS	0	N/A
Dispenser Island Bollards damaged? If Yes, list dispenser #	No		PASS	0	N/A
Any Skimming Device Present? If present shut dispenser down immediately and notify Store Manager and 7-Eleven Compliance personnel.	No		PASS	0	N/A
Question	Response	Comment	Pass/Fail	# of Attach ments	Score
HAZARDOUS WASTE					0
Are there Hazardous Waste Drums Needing Picked up? If Yes, list contents and # of barrels	No		PASS	0	N/A
Is a drum for solids present?	No		N/A	0	N/A
Is the solid drum in good condition?	N/A		N/A	0	N/A
Is the solids drum 75% full?	N/A		N/A	0	N/A
Is a drum for liquids present?	No		N/A	0	N/A

Is the liquid drum in good condition?	N/A		N/A	0	N/A
Is the liquids drum 75% full?	N/A		N/A	0	N/A
Are the drums properly labeled?	N/A		N/A	0	N/A
Are the labels completely filled out?	N/A		N/A	0	N/A
Section Name					
Question	Response	Comment	Pass/Fail	# of Attach ments	Score
ENVIRONMENTAL					
Are any Well covers damaged?	No		PASS	0	N/A

7-ELEVEN, INC

43768/6116 1640 EAST WASHINGTON ST INDIANAPOLIS, IN 46201-3851





Inspection Date	Completed Date	Inspected By	Pending Review Date	Reviewed By
1/2/2024	1/2/2024	Marcus Jackson	-	-

Section Name		I			
Question	Response	Comment	Pass/Fail	# of Attach ments	Score
RECORD KEEPING (Copies	of All Document	s located in SEED	OS)		0
Current Years Financial Responsibility Document available?	Yes		PASS	0	N/A
UST Permit / Certificate to Operate Available and Not Expired?	Yes		PASS	0	N/A
Emergency Response Plan Available?	Yes		PASS	0	N/A
Current Years Release Detection Records available?	Yes		PASS	0	N/A
State/7-11 monthly Inspection Forms completed and available, (12 months worth) and picture uploaded? (Required STATES: IL, KS, OH, TN)	Yes		PASS	0	N/A
UST Operator Documenta					0
Class C Operator Training Certificates Available for All Employees? (If Not, List Employee's Name) (ILINOIS recertification required every 2 years)	Yes		PASS	0	N/A
Class A/B Operator Certificate (s) available?	Yes		PASS	0	N/A
Section Name					
Question	Response	Comment	Pass/Fail	# of Attach ments	Score
Question	Response	Comment	Pass/Fail	Attach	Score
	Response	Comment	Pass/Fail	Attach	
FACILITY	Yes	Comment	Pass/Fail	Attach	0
FACILITY Automatic Tank Gauge ATG Accessible to Employees (no		Comment		Attach ments	0
FACILITY Automatic Tank Gauge ATG Accessible to Employees (no obstruction)?	Yes	Comment	PASS	Attach ments 0	0 0 N/A
FACILITY Automatic Tank Gauge ATG Accessible to Employees (no obstruction)? Is the ATG in alarm? Were ATG reports printed and photo of tapes	Yes	Comment	PASS PASS	Attach ments 0	0 0 N/A N/A
FACILITY Automatic Tank Gauge ATG Accessible to Employees (no obstruction)? Is the ATG in alarm? Were ATG reports printed and photo of tapes taken? Is the ATG Printer working? (Replace paper	Yes No Yes	Comment	PASS PASS	O O 1	0 0 N/A N/A N/A
FACILITY Automatic Tank Gauge ATG Accessible to Employees (no obstruction)? Is the ATG in alarm? Were ATG reports printed and photo of tapes taken? Is the ATG Printer working? (Replace paper if needed)	Yes No Yes	Comment	PASS PASS	O O 1	0 N/A N/A N/A
FACILITY Automatic Tank Gauge ATG Accessible to Employees (no obstruction)? Is the ATG in alarm? Were ATG reports printed and photo of tapes taken? Is the ATG Printer working? (Replace paper if needed) Emergency Shut Off	Yes No Yes Yes	Comment	PASS PASS PASS	O O O	0 0 N/A N/A N/A N/A
FACILITY Automatic Tank Gauge ATG Accessible to Employees (no obstruction)? Is the ATG in alarm? Were ATG reports printed and photo of tapes taken? Is the ATG Printer working? (Replace paper if needed) Emergency Shut Off Is there a ESO Accessible to Employees? Is ESO Damaged? (If YES, describe	Yes No Yes Yes Yes	Comment	PASS PASS PASS	O O O O	0 0 N/A N/A N/A N/A
FACILITY Automatic Tank Gauge ATG Accessible to Employees (no obstruction)? Is the ATG in alarm? Were ATG reports printed and photo of tapes taken? Is the ATG Printer working? (Replace paper if needed) Emergency Shut Off Is there a ESO Accessible to Employees? Is ESO Damaged? (If YES, describe damaged)	Yes No Yes Yes Yes	Comment	PASS PASS PASS	O O O O	0 0 N/A N/A N/A 0 N/A N/A
FACILITY Automatic Tank Gauge ATG Accessible to Employees (no obstruction)? Is the ATG in alarm? Were ATG reports printed and photo of tapes taken? Is the ATG Printer working? (Replace paper if needed) Emergency Shut Off Is there a ESO Accessible to Employees? Is ESO Damaged? (If YES, describe damaged) Fire Extinguishers Is there a Fire Extinguisher within 100 Feet	Yes No Yes Yes Yes No	Comment	PASS PASS PASS PASS	O O O O O O	0 0 N/A N/A N/A N/A 0 N/A N/A

Section Name					
Question	Response	Comment	Pass/Fail	# of Attach ments	Score
TANK PAD					0
STP Sumps					0
Are all STP Sumps Dry and Free of Debris?	Yes		PASS	0	N/A
Are all STP Sump lids and gaskets in good condition?	Yes		PASS	0	N/A
Are the STP and piping connections in the sumps free of any signs of seepage?	Yes		PASS	0	N/A
Spill Buckets					0
All Spill Buckets have Fill Drop Tubes Present and Undamaged?	Yes		PASS	0	N/A
All Spill Buckets free of liquid & debris?	No	No Liquid Wastedrums Onsite	FAIL	0	N/A
All Spill Buckets Drain valve functioning properly?	Yes		PASS	0	N/A
All Spill Buckets Fill Caps have Gaskets & Sealing properly? Inspector to replace if missing or damaged	Yes		PASS	0	N/A
All Spill Buckets have a Product Tag / Collar present on each riser? If NO, list product and item needed	Yes		PASS	0	N/A
All Spill Buckets in good condition?	Yes		PASS	0	N/A
All Manholes Lids painted and not faded? VENDOR replace & paint if needed	No	Tankpad Painting Needed	FAIL	0	N/A
Vapor Recovery Buckets					0
All Vapor Poppets Sealing properly after compression and undamaged?	Yes		PASS	0	N/A
All Vapor caps and gasket in good condition? Inspector to replace if missing or damage	Yes		PASS	0	N/A
All Manway cover/lids in good condition? Inspector to replace if missing or damaged	Yes		PASS	0	N/A
Do Manway cover/lids need painted? Inspector to paint as needed	Yes	Tankpad Painting Needed	FAIL	0	N/A
Vent Stack					0
Vent Caps Present?	Yes		PASS	0	N/A
If Vent Box Present, free of liquid & debris?	NA		PASS	0	N/A
If Sensor is present in Vent box, sitting on the bottom?	NA		PASS	0	N/A
Are bollards damaged by Vent pipes? Section Name	No		PASS	0	N/A
Question	Response	Comment	Pass/Fail	# of Attach ments	Score

DISPENSERS					0
All Dispenser Nozzles & Swivels functional and show no signs of weeping? If No, list damaged & dispenser #	Yes		PASS	0	N/A
All Dispenser Hoses in good condition, showing no Signs of splitting or cracking? If NO, list dispenser #	Yes		PASS	0	N/A
All Dispensers Hose Length 6", Minimum from Ground or Island? If NO, list dispenser #	NA		PASS	0	N/A
All Dispensers Breakaways and Whip Hoses in good condition and Show no Signs of weeping? If NO, list dispenser # and equipment	Yes		PASS	0	N/A
Are all UDC's (if present) Free of liquid and debris?	Yes		PASS	0	N/A
Do any of the Dispensers Meter/Union/Filter (s) show signs of weepage? If YES, list dispenser # and equipment	No		PASS	0	N/A
Are all Dispenser Shear Valves mounted correctly & secured? If No, list dispenser # and product	Yes		PASS	0	N/A
If Sensors are Present in UDC's, sitting on the bottom? If No, list UDC #	Yes		PASS	0	N/A
All Dispenser Calibration Metal Tie Lock Seals Intact? If No, list dispenser # and product	Yes		PASS	0	N/A
Do any Dispenser Meter Seals show visible sign of leaks? If Yes, list dispenser #	No		PASS	0	N/A
Dispenser Island Bollards damaged? If Yes, list dispenser #	No		PASS	0	N/A
Any Skimming Device Present? If present shut dispenser down immediately and notify Store Manager and 7-Eleven Compliance personnel.	No		PASS	0	N/A
Question	Response	Comment	Pass/Fail	# of Attach ments	Score
HAZARDOUS WASTE					0
Are there Hazardous Waste Drums Needing Picked up? If Yes, list contents and # of barrels	No		PASS	0	N/A
Is a drum for solids present?	No		N/A	0	N/A
Is the solid drum in good condition?	N/A		N/A	0	N/A
Is the solids drum 75% full?	N/A		N/A	0	N/A
Is a drum for liquids present?	No		N/A	0	N/A

Is the liquid drum in good condition?	N/A		N/A	0	N/A
Is the liquids drum 75% full?	N/A		N/A	0	N/A
Are the drums properly labeled?	N/A		N/A	0	N/A
Are the labels completely filled out?	N/A		N/A	0	N/A
Section Name					
Question	Response	Comment	Pass/Fail	# of Attach ments	Score
ENVIRONMENTAL					0
Are any Well covers damaged?	No		PASS	0	N/A

7-ELEVEN, INC

43768/6116 1640 EAST WASHINGTON ST INDIANAPOLIS, IN 46201-3851



Inspection Date	Completed Date	Inspected By	Pending Review Date	Reviewed By
12/1/2023	12/1/2023	Marcus Jackson	-	-

Section Name					
Question	Response	Comment	Pass/Fail	# of Attach ments	Score
RECORD KEEPING (Copies	of All Document	s located in SEED	S)		0
Current Years Financial Responsibility Document available?	Yes		PASS	0	N/A
UST Permit / Certificate to Operate Available and Not Expired?	Yes		PASS	0	N/A
Emergency Response Plan Available?	Yes		PASS	0	N/A
Current Years Release Detection Records available?	Yes		PASS	0	N/A
State/7-11 monthly Inspection Forms completed and available, (12 months worth) and picture uploaded? (Required STATES: IL, KS, OH, TN)	Yes		PASS	0	N/A
UST Operator Documenta					0
Class C Operator Training Certificates Available for All Employees? (If Not, List Employee's Name) (ILINOIS recertification required every 2 years)	Yes		PASS	0	N/A
Class A/B Operator Certificate (s) available?	Yes		PASS	0	N/A
Section Name Question	Response	Comment	Pass/Fail	# of Attach	Score
FACILITY				ments	0
Automatic Tank Gauge					0
ATG Accessible to Employees (no obstruction)?	Yes		PASS	0	N/A
Is the ATG in alarm?	Yes	High Product Alarm, Delivery Needed, Overfill Alarm	FAIL	3	N/A
Were ATG reports printed and photo of tapes taken?	Yes		PASS	1	N/A
Is the ATG Printer working? (Replace paper	Yes		PASS	0	N/A
if needed)					
Emergency Shut Off					0
	Yes		PASS	0	O N/A
Emergency Shut Off	Yes		PASS PASS	0	
Emergency Shut Off Is there a ESO Accessible to Employees? Is ESO Damaged? (If YES, describe					N/A
Emergency Shut Off Is there a ESO Accessible to Employees? Is ESO Damaged? (If YES, describe damaged)					N/A N/A
Emergency Shut Off Is there a ESO Accessible to Employees? Is ESO Damaged? (If YES, describe damaged) Fire Extinguishers Is there a Fire Extinguisher within 100 Feet	No		PASS	0	N/A N/A

Section Name					
Question	Response	Comment	Pass/Fail	# of Attach ments	Score
TANK PAD					0
STP Sumps					0
Are all STP Sumps Dry and Free of Debris?	Yes		PASS	0	N/A
Are all STP Sump lids and gaskets in good condition?	Yes		PASS	0	N/A
Are the STP and piping connections in the sumps free of any signs of seepage?	Yes		PASS	0	N/A
Spill Buckets					0
All Spill Buckets have Fill Drop Tubes Present and Undamaged?	Yes		PASS	0	N/A
All Spill Buckets free of liquid & debris?	Yes		PASS	0	N/A
All Spill Buckets Drain valve functioning properly?	Yes		PASS	0	N/A
All Spill Buckets Fill Caps have Gaskets & Sealing properly? Inspector to replace if missing or damaged	Yes		PASS	0	N/A
All Spill Buckets have a Product Tag / Collar present on each riser? If NO, list product and item needed	Yes		PASS	0	N/A
All Spill Buckets in good condition?	Yes		PASS	0	N/A
All Manholes Lids painted and not faded? VENDOR replace & paint if needed	Yes		PASS	0	N/A
Vapor Recovery Buckets					0
All Vapor Poppets Sealing properly after compression and undamaged?	Yes		PASS	0	N/A
All Vapor caps and gasket in good condition? Inspector to replace if missing or damage	Yes		PASS	0	N/A
All Manway cover/lids in good condition? Inspector to replace if missing or damaged	Yes		PASS	0	N/A
Do Manway cover/lids need painted? Inspector to paint as needed	No		PASS	0	N/A
Vent Stack					0
Vent Caps Present?	Yes		PASS	0	N/A
If Vent Box Present, free of liquid & debris?	NA		PASS	0	N/A
If Sensor is present in Vent box, sitting on the bottom?	NA		PASS	0	N/A
Are bollards damaged by Vent pipes? Section Name	No		PASS	0	N/A
Question	Response	Comment	Pass/Fail	# of Attach ments	Score

DISPENSERS					0
All Dispenser Nozzles & Swivels functional and show no signs of weeping? If No, list damaged & dispenser #	Yes		PASS	0	N/A
All Dispenser Hoses in good condition, showing no Signs of splitting or cracking? If NO, list dispenser #	Yes		PASS	0	N/A
All Dispensers Hose Length 6", Minimum from Ground or Island? If NO, list dispenser #	NA		PASS	0	N/A
All Dispensers Breakaways and Whip Hoses in good condition and Show no Signs of weeping? If NO, list dispenser # and equipment	Yes		PASS	0	N/A
Are all UDC's (if present) Free of liquid and debris?	Yes		PASS	0	N/A
Do any of the Dispensers Meter/Union/Filter (s) show signs of weepage? If YES, list dispenser # and equipment	No		PASS	0	N/A
Are all Dispenser Shear Valves mounted correctly & secured? If No, list dispenser # and product	Yes		PASS	0	N/A
If Sensors are Present in UDC's, sitting on the bottom? If No, list UDC #	Yes		PASS	0	N/A
All Dispenser Calibration Metal Tie Lock Seals Intact? If No, list dispenser # and product	Yes		PASS	0	N/A
Do any Dispenser Meter Seals show visible sign of leaks? If Yes, list dispenser #	No		PASS	0	N/A
Dispenser Island Bollards damaged? If Yes, list dispenser #	No		PASS	0	N/A
Any Skimming Device Present? If present shut dispenser down immediately and notify Store Manager and 7-Eleven Compliance personnel.	No		PASS	0	N/A
Question	Response	Comment	Pass/Fail	# of Attach ments	Score
HAZARDOUS WASTE					0
Are there Hazardous Waste Drums Needing Picked up? If Yes, list contents and # of barrels	Yes	Liquid Wastedrum Cap Rusted And Damaged Can't Get Open	FAIL	0	N/A
Is a drum for solids present?	No		N/A	0	N/A
Is the solid drum in good condition?	N/A		N/A	0	N/A
Is the solids drum 75% full?	N/A		N/A	0	N/A
Is a drum for liquids present?	Yes		N/A	0	N/A

Is the liquid drum in good condition?	No	Liquid Wastedrum Cap Rusted And Damaged Can't Get Open	FAIL	0	N/A
Is the liquids drum 75% full?	Yes		FAIL	1	N/A
Are the drums properly labeled?	Yes		PASS	0	N/A
Are the labels completely filled out?	No		FAIL	0	N/A
Section Name					
Question	Response	Comment	Pass/Fail	# of Attach ments	Score
ENVIRONMENTAL					0
Are any Well covers damaged?	No		PASS	0	N/A

7-ELEVEN, INC

43768/6116 1640 EAST WASHINGTON ST INDIANAPOLIS, IN 46201-3851



Inspection Date	Completed Date	Inspected By	Pending Review Date	Reviewed By
11/1/2023	11/1/2023	Marcus Jackson	-	-

Section Name		I			
Question	Response	Comment	Pass/Fail	# of Attach ments	Score
RECORD KEEPING (Copies	of All Document	s located in SEED	OS)		0
Current Years Financial Responsibility Document available?	Yes		PASS	0	N/A
UST Permit / Certificate to Operate Available and Not Expired?	Yes		PASS	0	N/A
Emergency Response Plan Available?	Yes		PASS	0	N/A
Current Years Release Detection Records available?	Yes		PASS	0	N/A
State/7-11 monthly Inspection Forms completed and available, (12 months worth) and picture uploaded? (Required STATES: IL, KS, OH, TN)	Yes		PASS	0	N/A
UST Operator Documenta					0
Class C Operator Training Certificates Available for All Employees? (If Not, List Employee's Name) (ILINOIS recertification required every 2 years)	Yes		PASS	0	N/A
Class A/B Operator Certificate (s) available?	Yes		PASS	0	N/A
Section Name					
Question	Response	Comment	Pass/Fail	# of Attach ments	Score
Question	Response	Comment	Pass/Fail	Attach	Score
	Response	Comment	Pass/Fail	Attach	
FACILITY	Yes	Comment	Pass/Fail	Attach	0
FACILITY Automatic Tank Gauge ATG Accessible to Employees (no		Comment		Attach ments	0
FACILITY Automatic Tank Gauge ATG Accessible to Employees (no obstruction)?	Yes	Comment	PASS	Attach ments 0	0 0 N/A
FACILITY Automatic Tank Gauge ATG Accessible to Employees (no obstruction)? Is the ATG in alarm? Were ATG reports printed and photo of tapes	Yes	Comment	PASS PASS	Attach ments 0	0 0 N/A N/A
FACILITY Automatic Tank Gauge ATG Accessible to Employees (no obstruction)? Is the ATG in alarm? Were ATG reports printed and photo of tapes taken? Is the ATG Printer working? (Replace paper	Yes No Yes	Comment	PASS PASS	O O 1	0 0 N/A N/A N/A
FACILITY Automatic Tank Gauge ATG Accessible to Employees (no obstruction)? Is the ATG in alarm? Were ATG reports printed and photo of tapes taken? Is the ATG Printer working? (Replace paper if needed)	Yes No Yes	Comment	PASS PASS	O O 1	0 N/A N/A N/A
FACILITY Automatic Tank Gauge ATG Accessible to Employees (no obstruction)? Is the ATG in alarm? Were ATG reports printed and photo of tapes taken? Is the ATG Printer working? (Replace paper if needed) Emergency Shut Off	Yes No Yes Yes	Comment	PASS PASS PASS	O O O	0 0 N/A N/A N/A N/A
FACILITY Automatic Tank Gauge ATG Accessible to Employees (no obstruction)? Is the ATG in alarm? Were ATG reports printed and photo of tapes taken? Is the ATG Printer working? (Replace paper if needed) Emergency Shut Off Is there a ESO Accessible to Employees? Is ESO Damaged? (If YES, describe	Yes No Yes Yes Yes	Comment	PASS PASS PASS	O O O O	0 0 N/A N/A N/A N/A
FACILITY Automatic Tank Gauge ATG Accessible to Employees (no obstruction)? Is the ATG in alarm? Were ATG reports printed and photo of tapes taken? Is the ATG Printer working? (Replace paper if needed) Emergency Shut Off Is there a ESO Accessible to Employees? Is ESO Damaged? (If YES, describe damaged)	Yes No Yes Yes Yes	Comment	PASS PASS PASS	O O O O	0 0 N/A N/A N/A 0 N/A N/A
FACILITY Automatic Tank Gauge ATG Accessible to Employees (no obstruction)? Is the ATG in alarm? Were ATG reports printed and photo of tapes taken? Is the ATG Printer working? (Replace paper if needed) Emergency Shut Off Is there a ESO Accessible to Employees? Is ESO Damaged? (If YES, describe damaged) Fire Extinguishers Is there a Fire Extinguisher within 100 Feet	Yes No Yes Yes Yes No	Comment	PASS PASS PASS PASS	O O O O O O	0 0 N/A N/A N/A N/A 0 N/A N/A

O. allan Nama					
Section Name Question	Response	Comment	Pass/Fail	# of Attach ments	Score
TANK PAD					0
STP Sumps					0
Are all STP Sumps Dry and Free of Debris?	Yes		PASS	0	N/A
Are all STP Sump lids and gaskets in good condition?	Yes		PASS	0	N/A
Are the STP and piping connections in the sumps free of any signs of seepage?	Yes		PASS	0	N/A
Spill Buckets					0
All Spill Buckets have Fill Drop Tubes Present and Undamaged?	Yes		PASS	0	N/A
All Spill Buckets free of liquid & debris?	Yes		PASS	0	N/A
All Spill Buckets Drain valve functioning properly?	Yes		PASS	0	N/A
All Spill Buckets Fill Caps have Gaskets & Sealing properly? Inspector to replace if missing or damaged	Yes		PASS	0	N/A
All Spill Buckets have a Product Tag / Collar present on each riser? If NO, list product and item needed	Yes		PASS	0	N/A
All Spill Buckets in good condition?	Yes		PASS	0	N/A
All Manholes Lids painted and not faded? VENDOR replace & paint if needed	Yes		PASS	0	N/A
Vapor Recovery Buckets					0
All Vapor Poppets Sealing properly after compression and undamaged?	Yes		PASS	0	N/A
All Vapor caps and gasket in good condition? Inspector to replace if missing or damage	Yes		PASS	0	N/A
All Manway cover/lids in good condition? Inspector to replace if missing or damaged	Yes		PASS	0	N/A
Do Manway cover/lids need painted? Inspector to paint as needed	No		PASS	0	N/A
Vent Stack					0
Vent Caps Present?	Yes		PASS	0	N/A
If Vent Box Present, free of liquid & debris?	NA		PASS	0	N/A
If Sensor is present in Vent box, sitting on the bottom?	NA		PASS	0	N/A
Are bollards damaged by Vent pipes? Section Name	No		PASS	0	N/A
Question	Response	Comment	Pass/Fail	# of Attach ments	Score

DISPENSERS					0
All Dispenser Nozzles & Swivels functional and show no signs of weeping? If No, list damaged & dispenser #	Yes		PASS	0	N/A
All Dispenser Hoses in good condition, showing no Signs of splitting or cracking? If NO, list dispenser #	Yes		PASS	0	N/A
All Dispensers Hose Length 6", Minimum from Ground or Island? If NO, list dispenser #	NA		PASS	0	N/A
All Dispensers Breakaways and Whip Hoses in good condition and Show no Signs of weeping? If NO, list dispenser # and equipment	Yes		PASS	0	N/A
Are all UDC's (if present) Free of liquid and debris?	Yes		PASS	0	N/A
Do any of the Dispensers Meter/Union/Filter (s) show signs of weepage? If YES, list dispenser # and equipment	No		PASS	0	N/A
Are all Dispenser Shear Valves mounted correctly & secured? If No, list dispenser # and product	Yes		PASS	0	N/A
If Sensors are Present in UDC's, sitting on the bottom? If No, list UDC #	Yes		PASS	0	N/A
All Dispenser Calibration Metal Tie Lock Seals Intact? If No, list dispenser # and product	Yes		PASS	0	N/A
Do any Dispenser Meter Seals show visible sign of leaks? If Yes, list dispenser #	No		PASS	0	N/A
Dispenser Island Bollards damaged? If Yes, list dispenser #	No		PASS	0	N/A
Any Skimming Device Present? If present shut dispenser down immediately and notify Store Manager and 7-Eleven Compliance personnel. Section Name	No		PASS	0	N/A
Question	Response	Comment	Pass/Fail	# of Attach ments	Score
HAZARDOUS WASTE					0
Are there Hazardous Waste Drums Needing Picked up? If Yes, list contents and # of barrels	No		PASS	0	N/A
Is a drum for solids present?	Yes		N/A	0	N/A
Is the solid drum in good condition?	Yes		PASS	0	N/A
Is the solids drum 75% full?	No		PASS	0	N/A
Is a drum for liquids present?	Yes		N/A	0	N/A

Is the liquid drum in good condition?	Yes		PASS	0	N/A
Is the liquids drum 75% full?	No		PASS	0	N/A
Are the drums properly labeled?	Yes		PASS	0	N/A
Are the labels completely filled out?	Yes		PASS	0	N/A
Section Name					
Question	Response	Comment	Pass/Fail	# of Attach ments	Score
ENVIRONMENTAL					
Are any Well covers damaged?	No		PASS	0	N/A

7-ELEVEN, INC

43768/6116 1640 EAST WASHINGTON ST INDIANAPOLIS, IN 46201-3851



Inspection Date	Completed Date	Inspected By	Pending Review Date	Reviewed By
10/2/2023	10/2/2023	Marcus Jackson	-	-

Section Name									
Question	Response	Comment	Pass/Fail	# of Attach ments	Score				
RECORD KEEPING (Copies	of All Document	s located in SEED	OS)		0				
Current Years Financial Responsibility Document available?	Yes		PASS	0	N/A				
UST Permit / Certificate to Operate Available and Not Expired?	Yes		PASS	0	N/A				
Emergency Response Plan Available?	Yes		PASS	0	N/A				
Current Years Release Detection Records available?	Yes		PASS	0	N/A				
State/7-11 monthly Inspection Forms completed and available, (12 months worth) and picture uploaded? (Required STATES: IL, KS, OH, TN)	Yes		PASS	0	N/A				
UST Operator Documenta					0				
Class C Operator Training Certificates Available for All Employees? (If Not, List Employee's Name) (ILINOIS recertification required every 2 years)	Yes		PASS	0	N/A				
Class A/B Operator Certificate (s) available?	Yes		PASS	0	N/A				
Section Name Question	Response	Comment	Pass/Fail	# of Attach	Score				
EACILITY				ments	0				
Automatic Tank Gauge			FACILITY						
					0				
ATG Accessible to Employees (no obstruction)?	Yes		PASS	0	0 N/A				
	Yes		PASS	0					
obstruction)?					N/A				
obstruction)? Is the ATG in alarm? Were ATG reports printed and photo of tapes	No		PASS	0	N/A N/A				
obstruction)? Is the ATG in alarm? Were ATG reports printed and photo of tapes taken? Is the ATG Printer working? (Replace paper	No Yes		PASS	0	N/A N/A				
obstruction)? Is the ATG in alarm? Were ATG reports printed and photo of tapes taken? Is the ATG Printer working? (Replace paper if needed)	No Yes		PASS	0	N/A N/A N/A				
obstruction)? Is the ATG in alarm? Were ATG reports printed and photo of tapes taken? Is the ATG Printer working? (Replace paper if needed) Emergency Shut Off	No Yes Yes		PASS PASS	0 1 0	N/A N/A N/A O				
obstruction)? Is the ATG in alarm? Were ATG reports printed and photo of tapes taken? Is the ATG Printer working? (Replace paper if needed) Emergency Shut Off Is there a ESO Accessible to Employees? Is ESO Damaged? (If YES, describe	No Yes Yes		PASS PASS PASS	0 1 0	N/A N/A N/A O N/A				
obstruction)? Is the ATG in alarm? Were ATG reports printed and photo of tapes taken? Is the ATG Printer working? (Replace paper if needed) Emergency Shut Off Is there a ESO Accessible to Employees? Is ESO Damaged? (If YES, describe damaged)	No Yes Yes		PASS PASS PASS	0 1 0	N/A N/A N/A O N/A N/A N/A				
obstruction)? Is the ATG in alarm? Were ATG reports printed and photo of tapes taken? Is the ATG Printer working? (Replace paper if needed) Emergency Shut Off Is there a ESO Accessible to Employees? Is ESO Damaged? (If YES, describe damaged) Fire Extinguishers Is there a Fire Extinguisher within 100 Feet	No Yes Yes No		PASS PASS PASS PASS	0 1 0 0 0	N/A N/A N/A N/A O N/A N/A O O O O O O O O O O O O O O O O O O O				

					- rage 3
Section Name Question	Response	Comment	Pass/Fail	# of Attach ments	Score
TANK PAD					0
STP Sumps					0
Are all STP Sumps Dry and Free of Debris?	Yes		PASS	0	N/A
Are all STP Sump lids and gaskets in good condition?	Yes		PASS	0	N/A
Are the STP and piping connections in the sumps free of any signs of seepage?	Yes		PASS	0	N/A
Spill Buckets					0
All Spill Buckets have Fill Drop Tubes Present and Undamaged?	Yes		PASS	0	N/A
All Spill Buckets free of liquid & debris?	Yes		PASS	0	N/A
All Spill Buckets Drain valve functioning properly?	Yes		PASS	0	N/A
All Spill Buckets Fill Caps have Gaskets & Sealing properly? Inspector to replace if missing or damaged	Yes		PASS	0	N/A
All Spill Buckets have a Product Tag / Collar present on each riser? If NO, list product and item needed	Yes		PASS	0	N/A
All Spill Buckets in good condition?	Yes		PASS	0	N/A
All Manholes Lids painted and not faded? VENDOR replace & paint if needed	Yes		PASS	0	N/A
Vapor Recovery Buckets					0
All Vapor Poppets Sealing properly after compression and undamaged?	Yes		PASS	0	N/A
All Vapor caps and gasket in good condition? Inspector to replace if missing or damage	Yes		PASS	0	N/A
All Manway cover/lids in good condition? Inspector to replace if missing or damaged	Yes		PASS	0	N/A
Do Manway cover/lids need painted? Inspector to paint as needed	No		PASS	0	N/A
Vent Stack					0
Vent Caps Present?	Yes		PASS	0	N/A
If Vent Box Present, free of liquid & debris?	NA		PASS	0	N/A
If Sensor is present in Vent box, sitting on the bottom?	NA		PASS	0	N/A
Are bollards damaged by Vent pipes? Section Name	No		PASS	0	N/A
Question	Response	Comment	Pass/Fail	# of Attach ments	Score

TOPEZOE					1 age 4
DISPENSERS					0
All Dispenser Nozzles & Swivels functional and show no signs of weeping? If No, list damaged & dispenser #	Yes		PASS	0	N/A
All Dispenser Hoses in good condition, showing no Signs of splitting or cracking? If NO, list dispenser #	Yes		PASS	0	N/A
All Dispensers Hose Length 6", Minimum from Ground or Island? If NO, list dispenser #	NA		PASS	0	N/A
All Dispensers Breakaways and Whip Hoses in good condition and Show no Signs of weeping? If NO, list dispenser # and equipment	Yes		PASS	0	N/A
Are all UDC's (if present) Free of liquid and debris?	Yes		PASS	0	N/A
Do any of the Dispensers Meter/Union/Filter (s) show signs of weepage? If YES, list dispenser # and equipment	No		PASS	0	N/A
Are all Dispenser Shear Valves mounted correctly & secured? If No, list dispenser # and product	Yes		PASS	0	N/A
If Sensors are Present in UDC's, sitting on the bottom? If No, list UDC #	Yes		PASS	0	N/A
All Dispenser Calibration Metal Tie Lock Seals Intact? If No, list dispenser # and product	Yes		PASS	0	N/A
Do any Dispenser Meter Seals show visible sign of leaks? If Yes, list dispenser #	No		PASS	0	N/A
Dispenser Island Bollards damaged? If Yes, list dispenser #	No		PASS	0	N/A
Any Skimming Device Present? If present shut dispenser down immediately and notify Store Manager and 7-Eleven Compliance personnel. Section Name	No		PASS	0	N/A
Question	Response	Comment	Pass/Fail	# of Attach ments	Score
HAZARDOUS WASTE					0
Are there Hazardous Waste Drums Needing Picked up? If Yes, list contents and # of barrels	No		PASS	0	N/A
Is a drum for solids present?	No		N/A	0	N/A
Is the solid drum in good condition?	N/A		N/A	0	N/A
Is the solids drum 75% full?	N/A		N/A	0	N/A

Is the liquid drum in good condition?	Yes		PASS	0	N/A
Is the liquids drum 75% full?	No		PASS	0	N/A
Are the drums properly labeled?	Yes		PASS	0	N/A
Are the labels completely filled out?	Yes		PASS	0	N/A
Section Name					
Question	Response	Comment	Pass/Fail	# of Attach ments	Score
ENVIRONMENTAL					
Are any Well covers damaged?	No		PASS	0	N/A

7-ELEVEN, INC

43768/6116 1640 EAST WASHINGTON ST INDIANAPOLIS, IN 46201-3851



Inspection Date	Completed Date	Inspected By	Pending Review Date	Reviewed By
9/7/2023	9/13/2023	Marcus Jackson	-	-

Section Name						
Question	Response	Comment	Pass/Fail	# of Attach ments	Score	
RECORD KEEPING (Copies	of All Document	s located in SEED	S)		0	
Current Years Financial Responsibility Document in Binder?	Yes		PASS	0	N/A	
UST Permit / Certificate to Operate Available and Not Expired?	Yes		PASS	0	N/A	
Emergency Response Plan Available?	Yes		PASS	0	N/A	
Current Years Release Detection Records in Binder?	Yes		PASS	0	N/A	
State/7-11 monthly Inspection Forms completed, placed in Binder (12 months worth) and picture uploaded? (Required STATES: IL, KS, OH, TN)	Yes		PASS	0	N/A	
UST Operator Documenta					0	
Class C Operator Training Certificates Available for All Employees? (If Not, List Employee's Name) (ILINOIS recertification required every 2 years)	Yes		PASS	0	N/A	
Class A/B Operator Certificate (s) in Binder?	Yes		PASS	0	N/A	
Section Name Question	Response	Comment	Pass/Fail	# of Attach ments	Score	
FACILITY					0	
Automatic Tank Gauge					0	
Automatic Tank Gauge ATG Accessible to Employees (no obstruction)?	Yes		PASS	0		
ATG Accessible to Employees (no	Yes		PASS PASS	0	0	
ATG Accessible to Employees (no obstruction)?					0 N/A	
ATG Accessible to Employees (no obstruction)? Is the ATG in alarm? Were ATG reports printed and photo of tapes	No		PASS	0	0 N/A N/A	
ATG Accessible to Employees (no obstruction)? Is the ATG in alarm? Were ATG reports printed and photo of tapes taken? Is the ATG Printer working? (Replace paper	No Yes		PASS	0	O N/A N/A	
ATG Accessible to Employees (no obstruction)? Is the ATG in alarm? Were ATG reports printed and photo of tapes taken? Is the ATG Printer working? (Replace paper if needed)	No Yes		PASS	0	0 N/A N/A N/A	
ATG Accessible to Employees (no obstruction)? Is the ATG in alarm? Were ATG reports printed and photo of tapes taken? Is the ATG Printer working? (Replace paper if needed) Emergency Shut Off	No Yes Yes		PASS PASS	0 1 0	0 N/A N/A N/A O	
ATG Accessible to Employees (no obstruction)? Is the ATG in alarm? Were ATG reports printed and photo of tapes taken? Is the ATG Printer working? (Replace paper if needed) Emergency Shut Off Is there a ESO Accessible to Employees? Is ESO Damaged? (If YES, describe	No Yes Yes		PASS PASS PASS	0 1 0	0 N/A N/A N/A N/A	
ATG Accessible to Employees (no obstruction)? Is the ATG in alarm? Were ATG reports printed and photo of tapes taken? Is the ATG Printer working? (Replace paper if needed) Emergency Shut Off Is there a ESO Accessible to Employees? Is ESO Damaged? (If YES, describe damaged)	No Yes Yes		PASS PASS PASS	0 1 0	0 N/A N/A N/A O N/A N/A	
ATG Accessible to Employees (no obstruction)? Is the ATG in alarm? Were ATG reports printed and photo of tapes taken? Is the ATG Printer working? (Replace paper if needed) Emergency Shut Off Is there a ESO Accessible to Employees? Is ESO Damaged? (If YES, describe damaged) Fire Extinguishers Is there a Fire Extinguisher within 100 Feet	No Yes Yes No		PASS PASS PASS	0 1 0 0 0	0 N/A N/A N/A N/A 0 N/A N/A	

Section Name					
Question	Response	Comment	Pass/Fail	# of Attach ments	Score
TANK PAD					0
STP Sumps					0
Are all STP Sumps Dry and Free of Debris?	Yes		PASS	0	N/A
Are all STP Sump lids and gaskets in good condition?	Yes		PASS	0	N/A
Are the STP and piping connections in the sumps free of any signs of seepage?	Yes		PASS	0	N/A
Spill Buckets					0
All Spill Buckets have Fill Drop Tubes Present and Undamaged?	Yes		PASS	0	N/A
All Spill Buckets free of liquid & debris?	Yes		PASS	0	N/A
All Spill Buckets Drain valve functioning properly?	Yes		PASS	0	N/A
All Spill Buckets Fill Caps have Gaskets & Sealing properly? Inspector to replace if missing or damaged	Yes		PASS	0	N/A
All Spill Buckets have a Product Tag / Collar present on each riser? If NO, list product and item needed	Yes		PASS	0	N/A
All Spill Buckets in good condition?	Yes		PASS	0	N/A
All Manholes Lids painted and not faded? VENDOR replace & paint if needed	Yes		PASS	0	N/A
Vapor Recovery Buckets					0
All Vapor Poppets Sealing properly after compression and undamaged?	Yes		PASS	0	N/A
All Vapor caps and gasket in good condition? Inspector to replace if missing or damage	Yes		PASS	0	N/A
All Manway cover/lids in good condition? Inspector to replace if missing or damaged	Yes		PASS	0	N/A
Do Manway cover/lids need painted? Inspector to paint as needed	No		PASS	0	N/A
Vent Stack					0
Vent Caps Present?	Yes		PASS	0	N/A
If Vent Box Present, free of liquid & debris?	NA		PASS	0	N/A
If Sensor is present in Vent box, sitting on the bottom?	NA		PASS	0	N/A
Are bollards damaged by Vent pipes?	No		PASS	0	N/A
Question	Response	Comment	Pass/Fail	# of Attach ments	Score

DISPENSERS					0
All Dispenser Nozzles & Swivels functional and show no signs of weeping? If No, list damaged & dispenser #	Yes		PASS	0	N/A
All Dispenser Hoses in good condition, showing no Signs of splitting or cracking? If NO, list dispenser #	Yes		PASS	0	N/A
All Dispensers Hose Length 6", Minimum from Ground or Island? If NO, list dispenser #	Yes		PASS	0	N/A
All Dispensers Breakaways and Whip Hoses in good condition and Show no Signs of weeping? If NO, list dispenser # and equipment	Yes		PASS	0	N/A
Are all UDC's (if present) Free of liquid and debris?	Yes		PASS	0	N/A
Do any of the Dispensers Meter/Union/Filter (s) show signs of weepage? If YES, list dispenser # and equipment	No		PASS	0	N/A
Are all Dispenser Shear Valves mounted correctly & secured? If No, list dispenser # and product	Yes		PASS	0	N/A
If Sensors are Present in UDC's, sitting on the bottom? If No, list UDC #	Yes		PASS	0	N/A
All Dispenser Calibration Metal Tie Lock Seals Intact? If No, list dispenser # and product	Yes		PASS	0	N/A
Do any Dispenser Meter Seals show visible sign of leaks? If Yes, list dispenser #	No		PASS	0	N/A
Dispenser Island Bollards damaged? If Yes, list dispenser #	No		PASS	0	N/A
Any Skimming Device Present? If present shut dispenser down immediately and notify Store Manager and 7-Eleven Compliance personnel.	No		PASS	0	N/A
Question	Response	Comment	Pass/Fail	# of Attach ments	Score
HAZARDOUS WASTE					0
Are there Hazardous Waste Drums Needing Picked up? If Yes, list contents and # of barrels	No		PASS	0	N/A
Is a drum for solids present?	Yes		N/A	0	N/A
Is the solid drum in good condition?	Yes		PASS	0	N/A
Is the solids drum 75% full?	No		PASS	0	N/A
Is a drum for liquids present?	Yes		N/A	0	N/A

Are any Well covers damaged?	No		PASS	0	N/A
ENVIRONMENTAL					0
Question	Response	Comment	Pass/Fail	# of Attach ments	Score
Section Name					
Are the labels completely filled out?	Yes		PASS	0	N/A
Are the drums properly labeled?	Yes		PASS	0	N/A
Is the liquids drum 75% full?	No		PASS	0	N/A
Is the liquid drum in good condition?	Yes		PASS	0	N/A

7-ELEVEN, INC

43768/6116 1640 EAST WASHINGTON ST INDIANAPOLIS, IN 46201-3851



Inspection Date	Completed Date	Inspected By	Pending Review Date	Reviewed By
8/1/2023	8/1/2023	Marcus Jackson	-	-

- · · · · ·					1 age 2
Section Name Question	Response	Comment	Pass/Fail	# of Attach ments	Score
RECORD KEEPING (Copies	of All Document	ts located in SEEI	DS)		0
Current Years Financial Responsibility Document in Binder?	Yes		PASS	0	N/A
UST Permit / Certificate to Operate Available and Not Expired?	Yes		PASS	0	N/A
Emergency Response Plan Available?	Yes		PASS	0	N/A
Current Years Release Detection Records in Binder?	Yes		PASS	0	N/A
State/7-11 monthly Inspection Forms completed, placed in Binder (12 months worth) and picture uploaded? (Required STATES: IL, KS, OH, TN)	Yes		PASS	0	N/A
UST Operator Documenta					0
Class C Operator Training Certificates Available for All Employees? (If Not, List Employee's Name) (ILINOIS recertification required every 2 years)	Yes		PASS	0	N/A
Class A/B Operator Certificate (s) in Binder? Section Name	Yes		PASS	0	N/A
Question	Response	Comment	Pass/Fail	# of Attach ments	Score
FACILITY					0
Automatic Tank Gauge					0
ATG Accessible to Employees (no obstruction)?	Yes		PASS	0	N/A
Is the ATG in alarm?	No		PASS	0	N/A
Were ATG reports printed and photo of tapes taken?	Yes		PASS	1	N/A
Is the ATG Printer working? (Replace paper if needed)	Yes		PASS	0	N/A
Emergency Shut Off					0
Is there a ESO Accessible to Employees?	Yes		PASS	0	N/A
Is ESO Damaged? (If YES, describe damaged)	No		PASS	0	N/A
Fire Extinguishers					0
Is there a Fire Extinguisher within 100 Feet of dispensers?	Yes		PASS	0	N/A
Are any Outside Fire Extinguishers expired?	No	none outside expired	PASS	0	N/A

					1 age 5
# Of Outside Fire Extinguishers Expired	One Inside Needs Recharge Or Replaced By Main Door		N/A	1	N/A
Section Name				# of	
Question	Response	Comment	Pass/Fail	Attach ments	Score
TANK PAD					0
STP Sumps					0
Are all STP Sumps Dry and Free of Debris?	Yes		PASS	0	N/A
Are all STP Sump lids and gaskets in good condition?	Yes		PASS	0	N/A
Are the STP and piping connections in the sumps free of any signs of seepage?	Yes		PASS	0	N/A
Spill Buckets					0
All Spill Buckets have Fill Drop Tubes Present and Undamaged?	Yes		PASS	0	N/A
All Spill Buckets free of liquid & debris?	Yes		PASS	0	N/A
All Spill Buckets Drain valve functioning properly?	Yes		PASS	0	N/A
All Spill Buckets Fill Caps have Gaskets & Sealing properly? Inspector to replace if missing or damaged	Yes		PASS	0	N/A
All Spill Buckets have a Product Tag / Collar present on each riser? If NO, list product and item needed	Yes		PASS	0	N/A
All Spill Buckets in good condition?	Yes		PASS	0	N/A
All Manholes Lids painted and not faded? VENDOR replace & paint if needed	Yes		PASS	0	N/A
Vapor Recovery Buckets					0
All Vapor Poppets Sealing properly after compression and undamaged?	Yes		PASS	0	N/A
All Vapor caps and gasket in good condition? Inspector to replace if missing or damage	Yes		PASS	0	N/A
All Manway cover/lids in good condition? Inspector to replace if missing or damaged	Yes		PASS	0	N/A
Do Manway cover/lids need painted? Inspector to paint as needed	No		PASS	0	N/A
Vent Stack					0
Vent Caps Present?	Yes		PASS	0	N/A
If Vent Box Present, free of liquid & debris?	NA		PASS	0	N/A
If Sensor is present in Vent box, sitting on the bottom?	NA		PASS	0	N/A
Are bollards damaged by Vent pipes?	No		PASS	0	N/A

Section Name					
Question	Response	Comment	Pass/Fail	# of Attach ments	Score
DISPENSERS					0
All Dispenser Nozzles & Swivels functional and show no signs of weeping? If No, list damaged & dispenser #	Yes		PASS	0	N/A
All Dispenser Hoses in good condition, showing no Signs of splitting or cracking? If NO, list dispenser #	Yes		PASS	0	N/A
All Dispensers Hose Length 6", Minimum from Ground or Island? If NO, list dispenser #	NA		PASS	0	N/A
All Dispensers Breakaways and Whip Hoses in good condition and Show no Signs of weeping? If NO, list dispenser # and equipment	Yes		PASS	0	N/A
Are all UDC's (if present) Free of liquid and debris?	Yes		PASS	0	N/A
Do any of the Dispensers Meter/Union/Filter (s) show signs of weepage? If YES, list dispenser # and equipment	No		PASS	0	N/A
Are all Dispenser Shear Valves mounted correctly & secured? If No, list dispenser # and product	Yes		PASS	0	N/A
If Sensors are Present in UDC's, sitting on the bottom? If No, list UDC #	Yes		PASS	0	N/A
All Dispenser Calibration Metal Tie Lock Seals Intact? If No, list dispenser # and product	Yes		PASS	0	N/A
Do any Dispenser Meter Seals show visible sign of leaks? If Yes, list dispenser #	No		PASS	0	N/A
Dispenser Island Bollards damaged? If Yes, list dispenser #	No		PASS	0	N/A
Any Skimming Device Present? If present shut dispenser down immediately and notify Store Manager and 7-Eleven Compliance personnel. Section Name	No		PASS	0	N/A
Question	Response	Comment	Pass/Fail	# of Attach ments	Score
HAZARDOUS WASTE				orito	0
Are there Hazardous Waste Drums Needing Picked up? If Yes, list contents and # of barrels	No		PASS	0	N/A
Is a drum for solids present?	No		N/A	0	N/A
Is the solid drum in good condition?	N/A		N/A	0	N/A
Is the solids drum 75% full?	N/A		N/A	0	N/A

Yes		N/A	0	N/A
Yes		PASS	0	N/A
No		PASS	0	N/A
Yes		PASS	0	N/A
No		FAIL	0	N/A
Response	Comment	Pass/Fail	# of Attach ments	Score
				0
No		PASS	0	N/A
	Yes No Yes No Response	Yes No Yes No Response Comment	Yes PASS No PASS Yes PASS No FAIL Response Comment Pass/Fail	Yes PASS 0 No PASS 0 Yes PASS 0 No FAIL 0 Response Comment Pass/Fail # of Attach ments

7-ELEVEN, INC

43768/6116 1640 EAST WASHINGTON ST INDIANAPOLIS, IN 46201-3851



Inspection Date	Completed Date	Inspected By	Pending Review Date	Reviewed By
7/7/2023	7/7/2023	Marcus Jackson	-	-

Section Name					
Question	Response	Comment	Pass/Fail	# of Attach ments	Score
RECORD KEEPING (Copies	of All Document	s located in SEED	OS)		0
Current Years Financial Responsibility Document in Binder?	NA		PASS	0	N/A
UST Permit / Certificate to Operate Available and Not Expired?	NA		PASS	0	N/A
Emergency Response Plan Available?	NA		PASS	0	N/A
Current Years Release Detection Records in Binder?	NA		PASS	0	N/A
State/7-11 monthly Inspection Forms completed, placed in Binder (12 months worth) and picture uploaded? (Required STATES: IL, KS, OH, TN)	NA		PASS	0	N/A
UST Operator Documenta					0
Class C Operator Training Certificates Available for All Employees? (If Not, List Employee's Name) (ILINOIS recertification required every 2 years)	NA		PASS	0	N/A
Class A/B Operator Certificate (s) in Binder?	NA		PASS	0	N/A
Section Name Question	Response	Comment	Pass/Fail	# of Attach	Score
	'				
FACILITY				ments	
FACILITY				ments	0
FACILITY Automatic Tank Gauge				ments	0
	Yes		PASS	O	
Automatic Tank Gauge ATG Accessible to Employees (no	Yes		PASS PASS		0
Automatic Tank Gauge ATG Accessible to Employees (no obstruction)?				0	0 N/A
Automatic Tank Gauge ATG Accessible to Employees (no obstruction)? Is the ATG in alarm? Were ATG reports printed and photo of tapes	No		PASS	0 0	0 N/A N/A
Automatic Tank Gauge ATG Accessible to Employees (no obstruction)? Is the ATG in alarm? Were ATG reports printed and photo of tapes taken? Is the ATG Printer working? (Replace paper	No Yes		PASS	0 0 1	O N/A N/A
Automatic Tank Gauge ATG Accessible to Employees (no obstruction)? Is the ATG in alarm? Were ATG reports printed and photo of tapes taken? Is the ATG Printer working? (Replace paper if needed)	No Yes		PASS	0 0 1	0 N/A N/A N/A
Automatic Tank Gauge ATG Accessible to Employees (no obstruction)? Is the ATG in alarm? Were ATG reports printed and photo of tapes taken? Is the ATG Printer working? (Replace paper if needed) Emergency Shut Off	No Yes Yes		PASS PASS	0 0 1 0	0 N/A N/A N/A O
Automatic Tank Gauge ATG Accessible to Employees (no obstruction)? Is the ATG in alarm? Were ATG reports printed and photo of tapes taken? Is the ATG Printer working? (Replace paper if needed) Emergency Shut Off Is there a ESO Accessible to Employees? Is ESO Damaged? (If YES, describe	No Yes Yes		PASS PASS PASS	0 0 1 0	0 N/A N/A N/A N/A
Automatic Tank Gauge ATG Accessible to Employees (no obstruction)? Is the ATG in alarm? Were ATG reports printed and photo of tapes taken? Is the ATG Printer working? (Replace paper if needed) Emergency Shut Off Is there a ESO Accessible to Employees? Is ESO Damaged? (If YES, describe damaged)	No Yes Yes		PASS PASS PASS	0 0 1 0	0 N/A N/A N/A O N/A N/A
Automatic Tank Gauge ATG Accessible to Employees (no obstruction)? Is the ATG in alarm? Were ATG reports printed and photo of tapes taken? Is the ATG Printer working? (Replace paper if needed) Emergency Shut Off Is there a ESO Accessible to Employees? Is ESO Damaged? (If YES, describe damaged) Fire Extinguishers Is there a Fire Extinguisher within 100 Feet	No Yes Yes No		PASS PASS PASS	0 0 1 0 0 0	0 N/A N/A N/A N/A 0 N/A N/A

Section Name					
Question	Response	Comment	Pass/Fail	# of Attach ments	Score
TANK PAD					0
STP Sumps					0
Are all STP Sumps Dry and Free of Debris?	Yes		PASS	0	N/A
Are all STP Sump lids and gaskets in good condition?	Yes		PASS	0	N/A
Are the STP and piping connections in the sumps free of any signs of seepage?	Yes		PASS	0	N/A
Spill Buckets					0
All Spill Buckets have Fill Drop Tubes Present and Undamaged?	Yes		PASS	0	N/A
All Spill Buckets free of liquid & debris?	Yes		PASS	0	N/A
All Spill Buckets Drain valve functioning properly?	Yes		PASS	0	N/A
All Spill Buckets Fill Caps have Gaskets & Sealing properly? Inspector to replace if missing or damaged	Yes		PASS	0	N/A
All Spill Buckets have a Product Tag / Collar present on each riser? If NO, list product and item needed	Yes		PASS	0	N/A
All Spill Buckets in good condition?	Yes		PASS	0	N/A
All Manholes Lids painted and not faded? VENDOR replace & paint if needed	Yes		PASS	0	N/A
Vapor Recovery Buckets					0
All Vapor Poppets Sealing properly after compression and undamaged?	Yes		PASS	0	N/A
All Vapor caps and gasket in good condition? Inspector to replace if missing or damage	Yes		PASS	0	N/A
All Manway cover/lids in good condition? Inspector to replace if missing or damaged	Yes		PASS	0	N/A
Do Manway cover/lids need painted? Inspector to paint as needed	No		PASS	0	N/A
Vent Stack					0
Vent Caps Present?	Yes		PASS	0	N/A
If Vent Box Present, free of liquid & debris?	NA		PASS	0	N/A
If Sensor is present in Vent box, sitting on the bottom?	NA		PASS	0	N/A
Are bollards damaged by Vent pipes?	No		PASS	0	N/A
Question	Response	Comment	Pass/Fail	# of Attach ments	Score

DISPENSERS					0
All Dispenser Nozzles & Swivels functional and show no signs of weeping? If No, list damaged & dispenser #	Yes		PASS	0	N/A
All Dispenser Hoses in good condition, showing no Signs of splitting or cracking? If NO, list dispenser #	Yes		PASS	0	N/A
All Dispensers Hose Length 6", Minimum from Ground or Island? If NO, list dispenser #	NA		PASS	0	N/A
All Dispensers Breakaways and Whip Hoses in good condition and Show no Signs of weeping? If NO, list dispenser # and equipment	Yes		PASS	0	N/A
Are all UDC's (if present) Free of liquid and debris?	Yes		PASS	0	N/A
Do any of the Dispensers Meter/Union/Filter (s) show signs of weepage? If YES, list dispenser # and equipment	No		PASS	0	N/A
Are all Dispenser Shear Valves mounted correctly & secured? If No, list dispenser # and product	Yes		PASS	0	N/A
If Sensors are Present in UDC's, sitting on the bottom? If No, list UDC #	Yes		PASS	0	N/A
All Dispenser Calibration Metal Tie Lock Seals Intact? If No, list dispenser # and product	Yes		PASS	0	N/A
Do any Dispenser Meter Seals show visible sign of leaks? If Yes, list dispenser #	No		PASS	0	N/A
Dispenser Island Bollards damaged? If Yes, list dispenser #	No		PASS	0	N/A
Any Skimming Device Present? If present shut dispenser down immediately and notify Store Manager and 7-Eleven Compliance personnel.	No		PASS	0	N/A
Question	Response	Comment	Pass/Fail	# of Attach ments	Score
HAZARDOUS WASTE					0
Are there Hazardous Waste Drums Needing Picked up? If Yes, list contents and # of barrels	No		PASS	0	N/A
Is a drum for solids present?	Yes		N/A	0	N/A
Is the solid drum in good condition?	Yes		PASS	0	N/A
Is the solids drum 75% full?	No		PASS	0	N/A
Is a drum for liquids present?	Yes		N/A	0	N/A

Is the liquid drum in good condition?	Yes		PASS	0	N/A
Is the liquids drum 75% full?	No		PASS	0	N/A
Are the drums properly labeled?	Yes		PASS	0	N/A
Are the labels completely filled out?	Yes		PASS	0	N/A
Section Name					
Question	Response	Comment	Pass/Fail	# of Attach ments	Score
ENVIRONMENTAL					0
Are any Well covers damaged?	No		PASS	0	N/A

7-ELEVEN, INC

43768/6116 1640 EAST WASHINGTON ST INDIANAPOLIS, IN 46201-3851



Inspection Date	Completed Date	Inspected By	Pending Review Date	Reviewed By
6/1/2023	6/1/2023	Marcus Jackson	-	-

Continu Nama					1 age 2
Section Name Question	Response	Comment	Pass/Fail	# of Attach ments	Score
RECORD KEEPING (Copies	of All Document	s located in SEEI	DS)		0
Current Years Financial Responsibility Document in Binder?	NA		PASS	0	N/A
UST Permit / Certificate to Operate Available and Not Expired?	NA		PASS	0	N/A
Emergency Response Plan Available?	NA		PASS	0	N/A
Current Years Release Detection Records in Binder?	NA		PASS	0	N/A
State/7-11 monthly Inspection Forms completed, placed in Binder (12 months worth) and picture uploaded? (Required STATES: IL, KS, OH, TN)	NA		PASS	0	N/A
UST Operator Documenta					0
Class C Operator Training Certificates Available for All Employees? (If Not, List Employee's Name) (ILINOIS recertification required every 2 years)	NA		PASS	0	N/A
Class A/B Operator Certificate (s) in Binder?	NA		PASS	0	N/A
Section Name Question	Response	Comment	Pass/Fail	# of Attach ments	Score
FACILITY					0
Automatic Tank Gauge					0
ATG Accessible to Employees (no obstruction)?	Yes		PASS	0	N/A
Is the ATG in alarm?	Yes	Periodic Test Fail	FAIL	1	N/A
Were ATG reports printed and photo of tapes taken?	Yes		PASS	1	N/A
Is the ATG Printer working? (Replace paper if needed)	Yes		PASS	0	N/A
Emergency Shut Off					0
Is there a ESO Accessible to Employees?	Yes		PASS	0	N/A
Is ESO Damaged? (If YES, describe damaged)	No		PASS	0	N/A
Fire Extinguishers					0
Is there a Fire Extinguisher within 100 Feet of dispensers?	Yes		PASS	0	N/A
Are any Outside Fire Extinguishers expired?	No		PASS	0	N/A
# Of Outside Fire Extinguishers Expired	None		N/A	0	N/A

Section Name					
Question	Response	Comment	Pass/Fail	# of Attach ments	Score
TANK PAD					0
STP Sumps					0
Are all STP Sumps Dry and Free of Debris?	Yes		PASS	0	N/A
Are all STP Sump lids and gaskets in good condition?	Yes		PASS	0	N/A
Are the STP and piping connections in the sumps free of any signs of seepage?	Yes		PASS	0	N/A
Spill Buckets					0
All Spill Buckets have Fill Drop Tubes Present and Undamaged?	Yes		PASS	0	N/A
All Spill Buckets free of liquid & debris?	Yes		PASS	0	N/A
All Spill Buckets Drain valve functioning properly?	Yes		PASS	0	N/A
All Spill Buckets Fill Caps have Gaskets & Sealing properly? Inspector to replace if missing or damaged	Yes		PASS	0	N/A
All Spill Buckets have a Product Tag / Collar present on each riser? If NO, list product and item needed	Yes		PASS	0	N/A
All Spill Buckets in good condition?	Yes		PASS	0	N/A
All Manholes Lids painted and not faded? VENDOR replace & paint if needed	Yes		PASS	0	N/A
Vapor Recovery Buckets					0
All Vapor Poppets Sealing properly after compression and undamaged?	Yes		PASS	0	N/A
All Vapor caps and gasket in good condition? Inspector to replace if missing or damage	Yes		PASS	0	N/A
All Manway cover/lids in good condition? Inspector to replace if missing or damaged	Yes		PASS	0	N/A
Do Manway cover/lids need painted? Inspector to paint as needed	No		PASS	0	N/A
Vent Stack					0
Vent Caps Present?	Yes		PASS	0	N/A
If Vent Box Present, free of liquid & debris?	NA		PASS	0	N/A
If Sensor is present in Vent box, sitting on the bottom?	NA		PASS	0	N/A
Are bollards damaged by Vent pipes?	No		PASS	0	N/A
Question	Response	Comment	Pass/Fail	# of Attach ments	Score

DISPENSERS					0
All Dispenser Nozzles & Swivels functional and show no signs of weeping? If No, list damaged & dispenser #	Yes		PASS	0	N/A
All Dispenser Hoses in good condition, showing no Signs of splitting or cracking? If NO, list dispenser #	Yes		PASS	0	N/A
All Dispensers Hose Length 6", Minimum from Ground or Island? If NO, list dispenser #	NA		PASS	0	N/A
All Dispensers Breakaways and Whip Hoses in good condition and Show no Signs of weeping? If NO, list dispenser # and equipment	Yes		PASS	0	N/A
Are all UDC's (if present) Free of liquid and debris?	Yes		PASS	0	N/A
Do any of the Dispensers Meter/Union/Filter (s) show signs of weepage? If YES, list dispenser # and equipment	No		PASS	0	N/A
Are all Dispenser Shear Valves mounted correctly & secured? If No, list dispenser # and product	Yes		PASS	0	N/A
If Sensors are Present in UDC's, sitting on the bottom? If No, list UDC #	Yes		PASS	0	N/A
All Dispenser Calibration Metal Tie Lock Seals Intact? If No, list dispenser # and product	Yes		PASS	0	N/A
Do any Dispenser Meter Seals show visible sign of leaks? If Yes, list dispenser #	No		PASS	0	N/A
Dispenser Island Bollards damaged? If Yes, list dispenser #	No		PASS	0	N/A
Any Skimming Device Present? If present shut dispenser down immediately and notify Store Manager and 7-Eleven Compliance personnel. Section Name	No		PASS	0	N/A
Question	Response	Comment	Pass/Fail	# of Attach ments	Score
HAZARDOUS WASTE					0
Are there Hazardous Waste Drums Needing Picked up? If Yes, list contents and # of barrels	No		PASS	0	N/A
Is a drum for solids present?	Yes		N/A	0	N/A
Is the solid drum in good condition?	Yes		PASS	0	N/A
Is the solids drum 75% full?	No		PASS	0	N/A
Is a drum for liquids present?	Yes		N/A	0	N/A

Is the liquid drum in good condition?	Yes		PASS	0	N/A
Is the liquids drum 75% full?	No		PASS	0	N/A
Are the drums properly labeled?	Yes		PASS	0	N/A
Are the labels completely filled out?	No		FAIL	0	N/A
Section Name					
Question	Response	Comment	Pass/Fail	# of Attach ments	Score
ENVIRONMENTAL					0
Are any Well covers damaged?	No		PASS	0	N/A

7-ELEVEN, INC

43768/6116 1640 EAST WASHINGTON ST INDIANAPOLIS, IN 46201-3851



Inspection Date	Completed Date	Inspected By	Pending Review Date	Reviewed By
5/1/2023	5/1/2023	Marcus Jackson	-	-

Page 2

Section Name					
Question	Response	Comment	Pass/Fail	# of Attach ments	Score
RECORD KEEPING (Copies	of All Document	s located in SEED	OS)		0
Current Years Financial Responsibility Document in Binder?	NA		PASS	0	N/A
UST Permit / Certificate to Operate Available and Not Expired?	NA		PASS	0	N/A
Emergency Response Plan Available?	NA		PASS	0	N/A
Current Years Release Detection Records in Binder?	NA		PASS	0	N/A
State/7-11 monthly Inspection Forms completed, placed in Binder (12 months worth) and picture uploaded? (Required STATES: IL, KS, OH, TN)	NA		PASS	0	N/A
UST Operator Documenta					0
Class C Operator Training Certificates Available for All Employees? (If Not, List Employee's Name) (ILINOIS recertification required every 2 years)	NA		PASS	0	N/A
Class A/B Operator Certificate (s) in Binder?	NA		PASS	0	N/A
Section Name Question	Response	Comment	Pass/Fail	# of Attach ments	Score
	Response	Comment	Pass/Fail	Attach	Score
Question	Response	Comment	Pass/Fail	Attach	
Question FACILITY	Yes	Comment	Pass/Fail	Attach	0
FACILITY Automatic Tank Gauge ATG Accessible to Employees (no		Comment		Attach ments	0
FACILITY Automatic Tank Gauge ATG Accessible to Employees (no obstruction)?	Yes	Comment	PASS	Attach ments 0	0 0 N/A
FACILITY Automatic Tank Gauge ATG Accessible to Employees (no obstruction)? Is the ATG in alarm? Were ATG reports printed and photo of tapes	Yes	Comment	PASS PASS	Attach ments 0 0	0 0 N/A N/A
FACILITY Automatic Tank Gauge ATG Accessible to Employees (no obstruction)? Is the ATG in alarm? Were ATG reports printed and photo of tapes taken? Is the ATG Printer working? (Replace paper	Yes No Yes	Comment	PASS PASS	O O 1	0 0 N/A N/A N/A
FACILITY Automatic Tank Gauge ATG Accessible to Employees (no obstruction)? Is the ATG in alarm? Were ATG reports printed and photo of tapes taken? Is the ATG Printer working? (Replace paper if needed)	Yes No Yes	Comment	PASS PASS	O O 1	0 0 N/A N/A N/A
FACILITY Automatic Tank Gauge ATG Accessible to Employees (no obstruction)? Is the ATG in alarm? Were ATG reports printed and photo of tapes taken? Is the ATG Printer working? (Replace paper if needed) Emergency Shut Off	Yes No Yes Yes	Comment	PASS PASS PASS	O O 1	0 0 N/A N/A N/A N/A
FACILITY Automatic Tank Gauge ATG Accessible to Employees (no obstruction)? Is the ATG in alarm? Were ATG reports printed and photo of tapes taken? Is the ATG Printer working? (Replace paper if needed) Emergency Shut Off Is there a ESO Accessible to Employees? Is ESO Damaged? (If YES, describe	Yes No Yes Yes Yes	Comment	PASS PASS PASS	O O O O	0 0 N/A N/A N/A N/A
FACILITY Automatic Tank Gauge ATG Accessible to Employees (no obstruction)? Is the ATG in alarm? Were ATG reports printed and photo of tapes taken? Is the ATG Printer working? (Replace paper if needed) Emergency Shut Off Is there a ESO Accessible to Employees? Is ESO Damaged? (If YES, describe damaged)	Yes No Yes Yes Yes	Comment	PASS PASS PASS	O O O O	0 0 N/A N/A N/A N/A 0 N/A N/A
FACILITY Automatic Tank Gauge ATG Accessible to Employees (no obstruction)? Is the ATG in alarm? Were ATG reports printed and photo of tapes taken? Is the ATG Printer working? (Replace paper if needed) Emergency Shut Off Is there a ESO Accessible to Employees? Is ESO Damaged? (If YES, describe damaged) Fire Extinguishers Is there a Fire Extinguisher within 100 Feet	Yes No Yes Yes Yes No	Comment	PASS PASS PASS PASS	O O O O O	0 0 N/A N/A N/A N/A O N/A O

Section Name					
Question	Response	Comment	Pass/Fail	# of Attach ments	Score
TANK PAD					0
STP Sumps					0
Are all STP Sumps Dry and Free of Debris?	Yes		PASS	0	N/A
Are all STP Sump lids and gaskets in good condition?	Yes		PASS	0	N/A
Are the STP and piping connections in the sumps free of any signs of seepage?	Yes		PASS	0	N/A
Spill Buckets					0
All Spill Buckets have Fill Drop Tubes Present and Undamaged?	Yes		PASS	0	N/A
All Spill Buckets free of liquid & debris?	Yes		PASS	0	N/A
All Spill Buckets Drain valve functioning properly?	Yes		PASS	0	N/A
All Spill Buckets Fill Caps have Gaskets & Sealing properly? Inspector to replace if missing or damaged	Yes		PASS	0	N/A
All Spill Buckets have a Product Tag / Collar present on each riser? If NO, list product and item needed	Yes		PASS	0	N/A
All Spill Buckets in good condition?	Yes		PASS	0	N/A
All Manholes Lids painted and not faded? VENDOR replace & paint if needed	No	Painting Needed	FAIL	0	N/A
Vapor Recovery Buckets					0
All Vapor Poppets Sealing properly after compression and undamaged?	Yes		PASS	0	N/A
All Vapor caps and gasket in good condition? Inspector to replace if missing or damage	Yes		PASS	0	N/A
All Manway cover/lids in good condition? Inspector to replace if missing or damaged	Yes		PASS	0	N/A
Do Manway cover/lids need painted? Inspector to paint as needed	Yes	Painting Needed	FAIL	0	N/A
Vent Stack					0
Vent Caps Present?	Yes		PASS	0	N/A
If Vent Box Present, free of liquid & debris?	NA		PASS	0	N/A
If Sensor is present in Vent box, sitting on the bottom?	NA		PASS	0	N/A
Are bollards damaged by Vent pipes?	No		PASS	0	N/A
Question	Response	Comment	Pass/Fail	# of Attach ments	Score

DISPENSERS					0
All Dispenser Nozzles & Swivels functional and show no signs of weeping? If No, list damaged & dispenser #	Yes		PASS	0	N/A
All Dispenser Hoses in good condition, showing no Signs of splitting or cracking? If NO, list dispenser #	Yes		PASS	0	N/A
All Dispensers Hose Length 6", Minimum from Ground or Island? If NO, list dispenser #	NA		PASS	0	N/A
All Dispensers Breakaways and Whip Hoses in good condition and Show no Signs of weeping? If NO, list dispenser # and equipment	Yes		PASS	0	N/A
Are all UDC's (if present) Free of liquid and debris?	Yes		PASS	0	N/A
Do any of the Dispensers Meter/Union/Filter (s) show signs of weepage? If YES, list dispenser # and equipment	No		PASS	0	N/A
Are all Dispenser Shear Valves mounted correctly & secured? If No, list dispenser # and product	Yes		PASS	0	N/A
If Sensors are Present in UDC's, sitting on the bottom? If No, list UDC #	Yes		PASS	0	N/A
All Dispenser Calibration Metal Tie Lock Seals Intact? If No, list dispenser # and product	Yes		PASS	0	N/A
Do any Dispenser Meter Seals show visible sign of leaks? If Yes, list dispenser #	No		PASS	0	N/A
Dispenser Island Bollards damaged? If Yes, list dispenser #	No		PASS	0	N/A
Any Skimming Device Present? If present shut dispenser down immediately and notify Store Manager and 7-Eleven Compliance personnel.	No		PASS	0	N/A
Question	Response	Comment	Pass/Fail	# of Attach ments	Score
HAZARDOUS WASTE					0
Are there Hazardous Waste Drums Needing Picked up? If Yes, list contents and # of barrels	No		PASS	0	N/A
Is a drum for solids present?	Yes		N/A	0	N/A
Is the solid drum in good condition?	Yes		PASS	0	N/A
Is the solids drum 75% full?	No		PASS	0	N/A
Is a drum for liquids present?	Yes		N/A	0	N/A

Is the liquid drum in good condition?	Yes		PASS	0	N/A
Is the liquids drum 75% full?	No		PASS	0	N/A
Are the drums properly labeled?	Yes		PASS	0	N/A
Are the labels completely filled out?	Yes		PASS	0	N/A
Section Name					
Question	Response	Comment	Pass/Fail	# of Attach ments	Score
ENVIRONMENTAL					0
Are any Well covers damaged?	No		PASS	0	N/A



December 7, 2023

Indiana Department of Environmental Management Office of Land Quality, Underground Storage Tanks Branch 100 North Senate Avenue Indianapolis, IN 46204

Re: 2023-2024 Financial Responsibility for 7-Eleven, Inc. / Speedway LLC

In accordance with rules promulgated by the U.S. Environmental Protection Agency and their state counterparts, 7-Eleven, Inc. and Speedway LLC would like to demonstrate financial responsibility using the attached documentation and herby certifies compliance with the requirements of Subpart H of 40 CFR 280. The attached Certificate is valid through December 18, 2024.

Enclosed for your information:

- > Certificate of Financial Responsibility
- > Certificate of Insurance issued by Ironshore Specialty Insurance Company
- ➤ AON blanket coverage letter
- ➤ Tank Schedule

Please feel free to contact me should you have any questions or concerns or need more information.

Sincerely,

Michael Byrne 7-Eleven, Inc.

Regional Environmental Compliance Manager

Michael.Byrne@7-11.com

Midal Began

937-863-7667

CERTIFICATION OF FINANCIAL RESPONSIBILITY

7-Eleven, Inc. hereby certifies that it is in compliance with the requirements of Subpart H of 40 CFR part 280.

The financial assurance mechanisms used to demonstrate financial responsibility under 40 CFR part 280 are as follows:

Policy No. ISPILL5BFGE001 issued by Ironshore Specialty Insurance Company, effective through December 18, 2024, and covering underground storage tanks for taking corrective action and/or compensating third parties for bodily injury and property damage caused by accidental releases in the amount of ONE MILLION DOLLARS (\$1,000,000) "per occurrence" and TWO MILLION DOLLARS (\$2,000,000) "annual aggregate" as specified by 40 CFR §280.93; and

To the extent of its eligibility, participation in various State funds and State assurance programs as set forth in 40 CFR §280.101.

7-ELEVEN, INC.

By:

Name: Ron Fulenchek

Title: Assistant Secretary and Sr. Director-

Gasoline Environmental Compliance

& Remediation

Date:

11-28-2023

STATE OF TEXAS

COUNTY OF DALLAS

COLLIN A

SUBSCRIBED AND SWORN TO BEFORE ME this

2023.

Notary Public In and For Said County and

State

My Commission Expires: 05-04-2027

ANNIE LIU

Notary Public, State of Texas

Comm. Expires 05-04-2027

Notary ID 134343138

day of NOVIMBLY.



INDIANA STORAGE TANK CERTIFICATE OF INSURANCE TO DEMONSTRATE FINANCIAL RESPONSIBILITY

Facility Name and Address: Per the attached Facility and Tank Schedule

Policy Number: ISPILLSB5FGE001

Period of Coverage: December 18, 2020 to December 18, 2024

Name of Insurer: Ironshore Specialty Insurance Company

Address of Insurer: 175 Berkeley Street, Boston, MA 02116

Name of Insured: 7-Eleven, Inc.

Address of Insured: 3200 Hackberry Road, Irving, TX 75063

CERTIFICATION:

1. Ironshore Specialty Insurance Company, the Insurer, as identified above, hereby certifies that it has issued liability insurance covering the following underground storage tank(s):

Facility ID	Facility Name and Address	Number of Tanks
	Per the attached Facility and Tank schedule	

for taking corrective action and compensating third parties for bodily injury and property damage caused by accidental releases in accordance with and subject to the limits of liability, exclusions, conditions, and other terms of the policy; arising from operating the underground storage tank(s) identified above.

The limits of liability are \$1,000,000 each occurrence and \$2,000,000 annual aggregate, exclusive of the legal defense costs, which are subject to a separate limit under the policy. This coverage is provided under ISPILLSB5FGE001. The effective date of said policy is December 18, 2020.

- 2. The Insurer further certifies the following with respect to the insurance described in Paragraph 1:
 - a. Bankruptcy or insolvency of the insured shall not relieve the Insurer of its obligations under the policy to which this certificate applies.
 - b. The Insurer is liable for the payment of amounts within any deductible applicable to the policy to the provider of corrective action or a damaged third party, with a right of reimbursement by the insured for any such payment made by the Insurer. This provision



IRONSHORE SPECIALTY INSURANCE COMPANY

175 Berkeley Street Boston, MA 02116 Toll Free: (877) IRON411

Endorsement # 29

Policy Number: ISPILLSB5FGE001 Effective Date of Endorsement: December 18, 2020

Insured Name: 7-Eleven, Inc.

THIS ENDORSEMENT CHANGES THE POLICY. PLEASE READ IT CAREFULLY.

BROAD NAMED INSURED ENDORSEMENT AMENDMENT

This endorsement modifies insurance provided under the following:

SITE POLLUTION INCIDENT LEGAL LIABILITY SELECT (SPILLS)

It is hereby agreed that the policy to which this Endorsement is attached is amended as follows:

It is hereby agreed that **Endorsement # 11**, **BROAD NAMED INSURED ENDORSEMENT**, is deleted in its entirety and replaced with the following:

The definition of Named Insured set forth in Section IX. DEFINITIONS is hereby deleted and replaced with the following:

Named Insured means:

- 1. The person or entity identified in **Item 1**. of the Declarations;
- 2. Any subsidiary company (meaning ownership by 7-Eleven, Inc. or subsidiaries thereof of more than 50%) of the **Named Insured** as now constituted, or as may be hereinafter constituted, or, if the **Named Insured** has agreed to provide such insurance, subsidiary companies (meaning ownership by 7-Eleven, Inc. or subsidiaries thereof of more than 50%) that existed in the past;
- 3. Any company, partnership, joint venture, or other organization (and any partner or member thereof as respects his/its liability as such) coming under the **Named Insured's** active managerial control, but only to the extent the **Named Insured** is required by contract to provide such insurance;
- 4. Any company, partnership, joint venture, or other organization (and any partner or member thereof as respects his/its liability as such) in which the **Named Insured** has financial interest but does not exercise active managerial control, but only to the extent of the **Named Insured's** financial interest;
- 5. Any organization acquired by the **Named Insured** during the policy period through consolidation, merger, purchase of assets, or assumption of majority financial interest or active managerial control; and
- 6. The entities scheduled below.

SCHEDULE OF NAMED INSUREDS

Seven & I Holdings Co. Ltd

Seven-Eleven Japan Co. Ltd

WHP Holding Corporation

White Hen Pantry, Inc.

WFI Group LLC

Wilson Farms, Inc

WFI Assets LLC

SEI Fuel Services, Inc

SEJ Asset Management and Investment Company

TFS NewCo LLC

SEI Speedway Holdings, LLC

Speedway Western Holdings LLC

Speedway LLC

Tesoro Sierra Properties, LLC

Tesoro South Coast Company, LLC

Tesoro West Coast Company, LLC

2Go Tesoro, LLC

Giant Four Corners, LLC

Giant Stop-N-Go of New Mexico, LLC

Western Refining Retail, LLC

Tesoro Northstore, LLC

Northern Tier Retail LLC

TRMC Retail LLC

ALL OTHER TERMS, CONDITIONS AND EXCLUSIONS OF THIS POLICY REMAIN UNCHANGED.

Mare Co.	June 11, 2021	
Authorized Representative	Date	

does not apply with respect to that amount of any deductible for which coverage is demonstrated under another mechanism or combination of mechanisms as specified in 40 CFR 280.95-280.102 and 280.104-280.107.

- c. Whenever requested by a Director of an implementing agency, the Insurer agrees to furnish to the Director a signed duplicate original of the policy and all endorsements.
- d. Cancellation or any other termination of the insurance by the Insurer except for non-payment of premium or misrepresentation by the insured, will be effective only upon written notice and only after the expiration of 60 days after a copy of such written notice is received by the insured. Cancellation for non-payment of premium or misrepresentation by the insured will be effective only upon written notice and only after expiration of a minimum of 10 days after a copy of such written notice is received by the insured.
- e. The insurance covers claims otherwise covered by the policy that are reported to the Insurer within six months of the effective date of cancellation or non-renewal of the policy except where the new or renewed policy has the same retroactive date or a retroactive date earlier than that of the prior policy, and which arise out of any covered occurrence that commenced after the policy retroactive date, if applicable, and prior to such policy renewal or termination date. Claims reported during such extended reporting period are subject to the terms, conditions, limits, including limits of liability, and exclusions of the policy.

I hereby certify that the wording of this instrument is identical to the wording in 40 CFR 280.97(b)(2) and that the Insurer is eligible to provide insurance as an excess or surplus lines insurer, in one or more states.

Maurien K. Domenicone

Authorized Representative of Ironshore Specialty Insurance Company

Maureen Domenicone Vice President, Authorized Representative of Ironshore Specialty Insurance Company 175 Berkeley Street Boston, MA 02116



VIA EMAIL

November 28, 2023

Nancy Laughlin
7-Eleven, Inc.
Department of Corporate Insurance and Risk Management
3200 Hackberry Road
Irving, Texas 75063

RE:

7-Eleven, Inc. - Pollution Insurance

Policy No.:

ISPILLSB5FGE001

Dear Ms. Laughlin:

Please let this letter confirm certain coverage matters of the Ironshore Site Pollution Incident Legal Liability Select (SPILLS) insurance policy number ISPILLSB5FGE001 that Aon placed on behalf of 7-Eleven, Inc. for the time period 12-18-23 to 12-18-24.

7-Eleven's Ironshore SPILLS policy does cover all tanks in 7-Eleven's official tank inventory. When tanks are added to 7-Eleven's tank portfolio through acquisitions, new store construction or remodeling, or through replacement of tanks, the insurance policy provides automatic coverage for those additional or replaced tanks. The tanks are added to the policy with a retro date of the acquisition date.

Please note that this insurance policy covers all sites on a blanket basis that were inadvertently left off the location schedule at policy inception. Full coverage is extended to any sites that were inadvertently omitted or that contain incorrect addresses or other clerical errors.

Please let me know if anyone has any other questions or would like to speak to me directly.

Regards,

Jeffrey Hanneman Managing Director

5555 San Felipe Suite 1500

Houston Texas 77056

(832) 476-6853

43748/6051	Managed by Company - Speedway	4502 SOUTH ADAMS STREET	MARION	IN
43748/6060	Managed by Company - Speedway	2875 EAST MARKET STREET	LOGANSPORT	IN
43750/6063	Managed by Company - Speedway	511 SOUTH MAIN STREET	SHERIDAN	IN
43752/6065	Managed by Company - Speedway	1999 CONNER STREET	NOBLESVILLE	IN
43753/6066	Managed by Company - Speedway	8895 EAST 116TH STREET	FISHERS	IN
43754/6078	Managed by Company - Speedway	823 EAST WINONA AVENUE	WARSAW	IN
43755/6080 43756/6085	Managed by Company - Speedway	1228 WEST PLYMOUTH STREET 1901 CASSOPOLIS STREET	BREMEN ELKHART	IN
43758/6092	Managed by Company - Speedway	10471 NORTH US-31	TAYLORSVILLE	IN
	Managed by Company - Speedway		SHELBYVILLE	IN
43759/6094	Managed by Company - Speedway	53 EAST BROADWAY STREET		IN
43760/6095	Managed by Company - Speedway	7103 NORTH KEYSTONE AVE	INDIANAPOLIS	IN
43762/6097	Managed by Company - Speedway	4830 WEST 38TH STREET	INDIANAPOLIS	IN
43763/6101	Managed by Company - Speedway	4535 NORTH SHADELAND AVE	LAWRENCE	IN
43764/6105	Managed by Company - Speedway	9251 CRAWFORDSVILLE ROAD	CLERMONT	IN
43765/6106	Managed by Company - Speedway	3540 WEST 30TH STREET	INDIANAPOLIS	IN
43766/6108	Managed by Company - Speedway	2615 NORTH EMERSON AVENUE	INDIANAPOLIS	IN
43768/6116	Managed by Company - Speedway	1640 EAST WASHINGTON ST	INDIANAPOLIS	IN
43769/6117	Managed by Company - Speedway	2012 ENGLISH AVENUE	INDIANAPOLIS	IN
46780/6120	Managed by Company - Speedway	401 KENTUCKY AVENUE	INDIANAPOLIS	IN
46155/6124	Managed by Company - Speedway	7169 ROCKVILLE ROAD	INDIANAPOLIS	IN
43770/6125	Managed by Company - Speedway	10908 EAST US-36	AVON	IN
43771/6127	Managed by Company - Speedway	3250 WEST MORRIS STREET	INDIANAPOLIS	IN
43772/6128	Managed by Company - Speedway	2355 PROSPECT STREET	INDIANAPOLIS	IN
43773/6131	Managed by Company - Speedway	5959 SOUTHEASTERN AVENUE	INDIANAPOLIS	IN
43774/6132	Managed by Company - Speedway	2954 SOUTH HOLT ROAD	INDIANAPOLIS	IN
43775/6135	Managed by Company - Speedway	3631 SOUTH KEYSTONE AVE	INDIANAPOLIS	IN
43776/6138	Managed by Company - Speedway	1207 SOUTH EAST STREET	INDIANAPOLIS	IN
43777/6139	Managed by Company - Speedway	2125 N STATE ROAD 13	PIERCETON	IN
43778/6140	Managed by Company - Speedway	5221 SOUTH EMERSON AVENUE	INDIANAPOLIS	IN
43779/6141	Managed by Company - Speedway	5508 MADISON AVENUE	INDIANAPOLIS	IN
43780/6143	Managed by Company - Speedway	8010 SOUTH EMERSON AVENUE	INDIANAPOLIS	IN
43781/6144	Managed by Company - Speedway	936 WEST COUNTY LINE ROAD	INDIANAPOLIS	IN
43782/6149	Managed by Company - Speedway	7114 BLUFFTON ROAD	FORT WAYNE	IN
43783/6150	Managed by Company - Speedway	103 LINCOLN HIGHWAY EAST	NEW HAVEN	IN
43784/6195	Managed by Company - Speedway	6001 MICHIGAN ROAD	INDIANAPOLIS	IN
43785/6215	Managed by Company - Speedway	130 STATE ROUTE 135	TRAFALGAR	IN
43786/6218	Managed by Company - Speedway	75 NORTH LYNHURST DRIVE	INDIANAPOLIS	IN
43787/6220	Managed by Company - Speedway	441 EAST HANNA AVENUE	INDIANAPOLIS	IN
43788/6368	Managed by Company - Speedway	2053 SHELBY STREET	INDIANAPOLIS	IN
43789/6372	Managed by Company - Speedway	4743 WEST 16TH STREET	INDIANAPOLIS	IN
43790/6383	Managed by Company - Speedway	1901 ELMWOOD AVENUE	LAFAYETTE	IN
43791/6384	Managed by Company - Speedway	201 EAST MAIN STREET	DANVILLE	IN
46817/6620	Managed by Company - Speedway	1706 SOUTH BEND AVENUE	SOUTH BEND	IN
43792/6621	Managed by Company - Speedway	153 MORTHLAND DRIVE	VALPARAISO	IN
43793/6629	Managed by Company - Speedway	1708 E 116TH ST	CARMEL	IN
43794/6630	Managed by Company - Speedway	2005 MORTHLAND DR.	VALPARAISO	IN
· · · · · · · · · · · · · · · · · · ·	1	1	1	

100 North Senate Ave Indianapolis, Indiana, 46204 (800) 451-6027 . (317) 232-8603 www.idem.IN.gov

Certificate of Completion

Awarded to: Michael Byrne

For completion of IDEM's Underground Storage Tank "A" Operator Training in accordance with 329 IAC 9.

License #: 20091

Issue Date: March 02, 2022

Expiration Date: March 02, 2025

Bruno L. Pigott, Commissioner

IDEM may require operator retraining if a UST System managed by the operator has documented deficiencies per 329 IAC 9.

100 North Senate Ave Indianapolis, Indiana, 46204 (800) 451-6027 . (317) 232-8603 www.idem.IN.gov

Certificate of Completion

Awarded to: Andrew Rice

For completion of IDEM's Underground Storage Tank "B" Operator Training in accordance with 329 IAC 9.

License #: 20665

Issue Date: June 21, 2022

Expiration Date: June 21, 2025

Brian C. Rockensuess, Commissioner

IDEM may require operator retraining if a UST System managed by the operator has documented deficiencies per 329 IAC 9.



C

Indiana Department of Environmental Management Underground Storage Tank Program Operator Training Certification

100 North Senate Avenue Indianapolis, IN 46204 (800) 451-6027, (317) 232-8603 www.idem.IN.gov

This certifies that

Carrie Ann Dugan For Completion of I INDIANA in accordance with 329 IAC 9.

Certificate is applicable to the following location

Training authorized by Michael Byrne License #(s): 20091

Company Name

1636 ENVIRONMENTAL

COMPLIANCE

Class A or B Operator Signature

Address

Training Provided by

Passport

Midal Begon

City

Facility ID

Training Signature

UST Facility ID

Issue Date: December 04, 2022

Expiration Date:

*Certification expires three (3) years from the date os issuance.

IDEM may require operator retraining if i UST System managed by the operator has documented deficiencies per 329 IAC 9



C

Indiana Department of Environmental Management Underground Storage Tank Program Operator Training Certification

100 North Senate Avenue Indianapolis, IN 46204 (800) 451-6027, (317) 232-8603 www.idem.IN.gov

This certifies that

Derek F Smith For Completion of I INDIANA in accordance with 329 IAC 9.

Certificate is applicable to the following location

Training authorized by Michael Byrne License #(s): 20091

Company Name

1636 ENVIRONMENTAL

COMPLIANCE

Class A or B Operator Signature

Passport

Midal Began

Address

City

Facility ID

Training Signature

Training Provided by

UST Facility ID

Issue Date: June 30, 2021

Expiration Date:

*Certification expires three (3) years from the date os issuance.

IDEM may require operator retraining if i UST System managed by the operator has documented deficiencies per 329 IAC 9