



BYPASS / OVERFLOW INCIDENT REPORT

State Form 48373 (R7 / 4-16)
Indiana Department of Environmental Management
Office of Water Quality

☒ Follow-up to Bypass report
previously sent on: 07/15/23

INSTRUCTIONS: Complete all parts of this form and email signed copies to wwreports@idem.in.gov. Submittal of this report will satisfy the Office of Water Quality (OWQ) telephone and written bypass/overflow reporting requirements of your NPDES permit. Please use and the second page of this form as necessary to identify separate locations caused by the same event. If you have any questions while filling out the report form, please contact Renee Repar at (317) 232-6770 or rrepar@idem.in.gov.

To report a spill or if the release is resulting in a fish kill or other severe environmental damage, immediately report the release to the Emergency Response Section spill response line at: (317) 233-7745 or toll free within Indiana at (888) 233-7745.

GENERAL INFORMATION					
(1) Facility Name (Organization) Elkhart Public Works		(2) Mailing Address (reporting organization) 1201 S. Nappanee Street		(3) County Elkhart	(4) NPDES Permit IN00025674
RELEASE INFORMATION (Location 1)					
(5) Outfall Number	(6) Date (mm/dd/yy) and Time Release Began 07/01/24 10:51	(7) Date (mm/dd/yy) and Time Release Stopped 07/01/24 12:16	(8) Location of Release (streets address or Manhole, Lift Station, Force Main etc.) 1200 S. Main	(9) Latitude (Deg Min Sec) 41 40 36 N	(9) Longitude (Deg Min Sec) 85 57 50W
(10) Amount of Flow Released (Always provide a volume.) Check one: <input checked="" type="checkbox"/> Estimated <input type="checkbox"/> Actual 44 Gallons			(11) WWTP Flow During Release 12.1 MGD	(12) WWTP Peak Design Flow Rate 44.0 MGD	
(13) Overflow Type (Select one.) <input type="checkbox"/> Sanitary Sewer Overflow <input type="checkbox"/> Treatment Bypass (at wastewater plant) <input type="checkbox"/> Prohibited Combined Sewer Overflow <input checked="" type="checkbox"/> Dry Weather Combined Sewer Overflow <input type="checkbox"/> Combined Sewer System Release			(14) Describe any damage to aquatic life or receiving stream: none		
(15) Reason for Bypass / Overflow (Select one or more.) <input type="checkbox"/> Construction Related <input type="checkbox"/> Power Failure <input type="checkbox"/> Equipment Failure <input checked="" type="checkbox"/> Grease <input type="checkbox"/> Unknown <input type="checkbox"/> Exceeded Max Capacity <input type="checkbox"/> Precipitation Inches					
(16) System Component(s) (Select one or more.) <input type="checkbox"/> Manhole <input type="checkbox"/> House Lateral <input type="checkbox"/> Pipe Failure <input type="checkbox"/> Pump Station Failure <input type="checkbox"/> Treatment Bypassed <input type="checkbox"/> Other <input type="checkbox"/> Influent Structure <input type="checkbox"/> Air Relief Valve <input type="checkbox"/> Sewer Clean Out Describe Other: (in the box below) grease		(17) Additional Description of the Bypass / Overflow Event: call came in at 10:51 am, Crews found line plugged with grease. Plug removed and flows returned to normal at 12:16 pm.		(18) Description of the Area Impacted (Check all that apply.) <input type="checkbox"/> Affected Private Property <input checked="" type="checkbox"/> Basement Backup <input type="checkbox"/> Occurred at Treatment Plant <input type="checkbox"/> Reached Public Land <input type="checkbox"/> Reached Receiving Water Name of Receiving Water Impacted: none	
(19) Additional organizations notified by facility, if necessary (Select one or more.) <input type="checkbox"/> IDEM Emergency Response <input type="checkbox"/> Health Dept. <input type="checkbox"/> DNR Fish and Wildlife <input type="checkbox"/> Local Emergency Management <input type="checkbox"/> Other: <div style="text-align: right;">n/a</div>					
(20) Actions Taken to Prevent, Minimize, or Mitigate Damage including Clean-up and Treatment of Affected Area (Select one or more of the following, then add a written description.) <input checked="" type="checkbox"/> Removed Blockage <input type="checkbox"/> Repaired Pipe <input type="checkbox"/> Repaired Pump Station <input type="checkbox"/> Other <input type="checkbox"/> Lime <input type="checkbox"/> Clean-Up Debris cleared plug of grease within 1.5 hours of being informed of problem					
(21) Resolution: Actions Taken or Planned to Prevent Recurrence will be sending fliers of proper grease disposal to residents in area					
(22)					
CERTIFICATION AND SIGNATURE					
I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations. (The area below is for a handwritten signature or an electronic substitute then fax or scan to PDF for emailing.)					
SIGNATURE: <u>Laura Kolo</u>			DATE (month, day, year): <u>07/02/24</u>		
Individual Making Report (printed) Laura Kolo	Telephone Number (574) 293-2572	Contact Email laura.kolo@coei.org	Date (month, day, year) / Time IDEM Notified 07/02/24 10:40	<input checked="" type="checkbox"/> AM <input type="checkbox"/> PM	