



# INDIANA DEPARTMENT OF ENVIRONMENTAL MANAGEMENT

*We Protect Hoosiers and Our Environment.*

100 N. Senate Avenue • Indianapolis, IN 46204

(800) 451-6027 • (317) 232-8603 • [www.idem.IN.gov](http://www.idem.IN.gov)

**Eric J. Holcomb**  
*Governor*

**Brian C. Rockensuess**  
*Commissioner*

## **NOTICE OF 30-DAY PERIOD FOR PUBLIC COMMENT**

Preliminary Findings Regarding a Significant Revision to a  
Federally Enforceable State Operating Permit (FESOP)

for AstraZeneca Pharmaceuticals LP in Posey County

FESOP SPR: F129-47826-00021

The Indiana Department of Environmental Management (IDEM) has received an application from AstraZeneca Pharmaceuticals LP, located at 4601 Hwy 62 East, Mt. Vernon, IN 47620, for a significant revision of its FESOP issued on April 18, 2016. If approved by IDEM's Office of Air Quality (OAQ), this proposed revision would allow AstraZeneca Pharmaceuticals LP to make certain changes at its existing source. AstraZeneca Pharmaceuticals LP has applied to add one (1) natural gas fired temporary boiler station, identified as (TB1), and to remove the two (2) natural gas fired boilers installed in 1970, identified as Boiler #1 (S1) and Boiler #2 (S2).

The applicant intends to construct and operate new equipment that will emit air pollutants; therefore, the permit contains new or different permit conditions. In addition, some conditions from previously issued permits/approvals have been corrected, changed, or removed. These corrections, changes, and removals may include Title I changes (e.g., changes that add or modify synthetic minor emission limits). The potential to emit regulated air pollutants will continue to be limited to less than the Title V major threshold levels. IDEM has reviewed this application and has developed preliminary findings, consisting of a draft permit and several supporting documents, which would allow the applicant to make this change.

A copy of the permit application and IDEM's preliminary findings have been sent to:

Alexandrian Public Library  
115 W 5th St  
Mount Vernon, IN 47620

and

IDEM Southwest Regional Office  
114 South 7th Street  
P.O. Box 128  
Petersburg, IN 47567-0128

A copy of the preliminary findings is available on the Internet at: <http://www.in.gov/ai/appfiles/idem-caats/>.

A copy of the application and preliminary findings is also available via IDEM's Virtual File Cabinet (VFC). To access VFC, please go to: <https://www.in.gov/idem/> and enter VFC in the search box. You will then have the option to search for permit documents using a variety of criteria.

### **How can you participate in this process?**

This notice is posted on IDEM's website (<https://www.in.gov/idem/public-notices/>). The date that this notice is posted on IDEM's website marks the beginning of a 30-day public comment period. If the 30<sup>th</sup> day of the comment period falls on a day when IDEM offices are closed for business, all comments must be postmarked or delivered in person on the next business day that IDEM is open.

You may request that IDEM hold a public hearing about this draft permit. If adverse comments concerning the **air pollution impact** of this draft permit are received, with a request for a public hearing, IDEM will decide whether or not to hold a public hearing. IDEM could also decide to hold a public meeting instead of, or in addition to, a public hearing. If IDEM decides to conduct a public hearing and/or public meeting, IDEM will post a separate announcement of the date, time, and location of that public hearing and/or public meeting on IDEM's website (<https://www.in.gov/idem/public-notices/>). At a hearing, you would have an opportunity to submit written comments and make verbal comments. At a meeting, you would have an opportunity to submit written comments, ask questions, and discuss any air pollution concerns with IDEM staff.

Comments and supporting documentation, or a request for a public hearing should be sent in writing to IDEM at the address below. If you comment via e-mail, please include your full U.S. mailing address so that you can be added to IDEM's mailing list to receive notice of future action related to this permit. If you do not want to comment at this time, but would like to receive notice of future action related to this permit application, please contact IDEM at the address below. Please refer to permit number SPR 129-47826-00021 in all correspondence.

**Comments should be sent to:**

Hind Mohamed  
IDEM, Office of Air Quality  
100 North Senate Avenue  
MC 61-53 IGCN 1003  
Indianapolis, Indiana 46204-2251  
(800) 451-6027, ask for Hind Mohamed  
or (317) 234-6543  
Or dial directly: (317) 234-6543  
Fax: (317) 232-6749 attn: Hind Mohamed  
E-mail: [HMohamed@idem.IN.gov](mailto:HMohamed@idem.IN.gov)


All comments will be considered by IDEM when we make a decision to issue or deny the permit. Comments that are most likely to affect final permit decisions are those based on the rules and laws governing this permitting process (326 IAC 2), air quality issues, and technical issues. IDEM does not have legal authority to regulate zoning, odor, or noise. For such issues, please contact your local officials.

For additional information about air permits and how the public and interested parties can participate, refer to the IDEM Air Permits page on the Internet at: <https://www.in.gov/idem/airpermit/public-participation/>; and the Citizens' Guide to IDEM on the Internet at: <https://www.in.gov/idem/resources/citizens-guide-to-idem/>.

**What will happen after IDEM makes a decision?**

Following the end of the public comment period, IDEM will issue a Notice of Decision stating whether the permit has been issued or denied. If the permit is issued, it may be different than the draft permit because of comments that were received during the public comment period. If comments are received during the public notice period, the final decision will include a document that summarizes the comments and IDEM's response to those comments. If you have submitted comments or have asked to be added to the mailing list, you will receive a Notice of the Decision. The notice will provide details on how you may appeal IDEM's decision, if you disagree with that decision. The final decision will also be available on the Internet at the address indicated above and will also be sent to the local library indicated above, the IDEM Regional Office indicated above, and the IDEM public file room on the 12<sup>th</sup> floor of the Indiana Government Center North, 100 N. Senate Avenue, Indianapolis, Indiana 46204-2251.

If you have any questions, please contact Hind Mohamed of my staff at the above address.



Ghassan Shalabi, Section Chief  
Permits Branch  
Office of Air Quality



# INDIANA DEPARTMENT OF ENVIRONMENTAL MANAGEMENT

*We Protect Hoosiers and Our Environment.*

100 N. Senate Avenue • Indianapolis, IN 46204

(800) 451-6027 • (317) 232-8603 • www.idem.IN.gov

**Eric J. Holcomb**  
Governor

DRAFT

**Brian C. Rockensuess**  
Commissioner

Mr. Kevin Conkright  
AstraZeneca Pharmaceuticals LP  
4601 Highway 62 East  
Mt. Vernon, IN 47620

Re: 129-47826-00021  
Significant Revision to  
F129-36688-00021

Dear Kevin Conkright:

AstraZeneca Pharmaceuticals LP was issued a Federally Enforceable State Operating Permit (FESOP) Renewal No. F129-36688-00021, on April 18, 2021, for a stationary pharmaceutical formulation and packaging source located at 4601 Highway 62 East, Mt. Vernon, IN 47620. On May 08, 2024, the Office of Air Quality (OAQ) received an application from the source requesting to add one (1) natural gas fired temporary boiler station, identified as (TB1), and remove two (2) natural gas fired boilers installed in 1970, identified as Boiler #1 (S1) and Boiler #2 (S2). Pursuant to the provisions of 326 IAC 2-8-11.1, these changes to the permit are required to be reviewed in accordance with the Significant Permit Revision (SPR) procedures of 326 IAC 2-8-11.1 (f). Pursuant to the provisions of 326 IAC 2-8-11.1, a Significant Permit Revision to this permit is hereby approved as described in the attached Technical Support Document (TSD).

Pursuant to 326 IAC 2-8-11.1, the following emission unit is approved for construction at the source:

- (a) One (1) natural gas fired temporary boiler station, identified as (TB1), approved in 2024 for construction, with a maximum operating input rate of 60 MMBtu/hr, uses No. 2 fuel oil as back up fuel, using no control, and exhausting to stack S-1.

The following construction conditions are applicable to the proposed project:

#### General Construction Conditions

1. The data and information supplied with the application shall be considered part of this permit revision approval. Prior to any proposed change in construction which may affect the potential to emit (PTE) of the proposed project, the change must be approved by the Office of Air Quality (OAQ).
2. This approval to construct does not relieve the Permittee of the responsibility to comply with the provisions of the Indiana Environmental Management Law (IC 13-11 through 13-20; 13-22 through 13-25; and 13-30), the Air Pollution Control Law (IC 13-17) and the rules promulgated thereunder, as well as other applicable local, state, and federal requirements.

#### Effective Date of the Permit

3. Pursuant to IC 13-15-5-3, this approval becomes effective upon its issuance.

#### Commenced Construction

4. Pursuant to 326 IAC 2-1.1-9 (Revocation), the Commissioner may revoke this approval if construction is not commenced within eighteen (18) months after receipt of this approval or if construction is suspended for a continuous period of one (1) year or more.

DRAFT

5. All requirements and conditions of this construction approval shall remain in effect unless modified in a manner consistent with procedures established pursuant to 326 IAC 2.

Pursuant to 326 IAC 2-8-11.1, this permit shall be revised by incorporating the Significant Permit Revision into the permit.

All other conditions of the permit shall remain unchanged and in effect. Please find attached the entire FESOP as revised, including the following revised attachment(s):

Attachment B: 40 CFR 60, Subpart IIII, Standards of Performance for Stationary Compression Ignition Internal Combustion Engines *revised*.

Attachment C: 40 CFR 63, Subpart ZZZZ, NATIONAL EMISSION STANDARDS FOR HAZARDOUS AIR POLLUTANTS FOR SOURCE CATEGORIES *revised*

The permit references the below listed attachment(s). Since this attachment has been provided in previously issued approvals for this source, IDEM OAQ has not included a copy of this attachment with this revision:

Attachment A: 40 CFR 60, Subpart Dc, Standards of Performance for Small Industrial-Commercial-Institutional Steam Generating Units.

Previously issued approvals for this source containing these attachments are available on the Internet at: <http://www.in.gov/ai/appfiles/idem-caats/>.

Previously issued approvals for this source are also available via IDEM's Virtual File Cabinet (VFC). To access VFC, please go to: <https://www.in.gov/idem/> and enter VFC in the search box. You will then have the option to search for permit documents using a variety of criteria.

Federal rules under Title 40 of United States Code of Federal Regulations may also be found on the U.S. Government Printing Office's Electronic Code of Federal Regulations (eCFR) website, located on the Internet at: [http://www.ecfr.gov/cgi-bin/text-idx?tpl=/ecfrbrowse/Title40/40tab\\_02.tpl](http://www.ecfr.gov/cgi-bin/text-idx?tpl=/ecfrbrowse/Title40/40tab_02.tpl).

A copy of the permit is available on the Internet at: <http://www.in.gov/ai/appfiles/idem-caats/>. A copy of the application and permit is also available via IDEM's Virtual File Cabinet (VFC). To access VFC, please go to: <https://www.in.gov/idem/> and enter VFC in the search box. You will then have the option to search for permit documents using a variety of criteria. For additional information about air permits and how the public and interested parties can participate, refer to the IDEM Air Permits page on the Internet at: <https://www.in.gov/idem/airpermit/public-participation/>; and the Citizens' Guide to IDEM on the Internet at: <https://www.in.gov/idem/resources/citizens-guide-to-idem/>.

This decision is subject to the Indiana Administrative Orders and Procedures Act - IC 4-21.5-3-5.

DRAFT

If you have any questions regarding this matter, please contact Hind Mohamed, Indiana Department Environmental Management, Office of Air Quality, Permits Branch, 100 North Senate Avenue, MC 61-53 IGCN 1003, Indianapolis, Indiana 46204-2251, or by telephone at (317) 234-6543 or (800) 451-6027, and ask for Hind Mohamed or (317) 234-6543.

Sincerely,

Ghassan Shalabi, Section Chief  
Permits Branch  
Office of Air Quality

Attachments: Revised permit and Technical Support Document.

cc: File - Posey County  
Posey County Health Department  
U.S. EPA, Region 5  
Compliance and Enforcement Branch



# INDIANA DEPARTMENT OF ENVIRONMENTAL MANAGEMENT

*We Protect Hoosiers and Our Environment.*

100 N. Senate Avenue • Indianapolis, IN 46204

(800) 451-6027 • (317) 232-8603 • www.idem.IN.gov

Eric J. Holcomb  
Governor

Brian C. Rockensuess  
Commissioner

## DRAFT

# Federally Enforceable State Operating Permit Renewal OFFICE OF AIR QUALITY

**AstraZeneca Pharmaceuticals LP  
4601 Highway 62 East  
Mt. Vernon, Indiana 47620**

(herein known as the Permittee) is hereby authorized to operate subject to the conditions contained herein, the source described in Section A (Source Summary) of this permit.

**The Permittee must comply with all conditions of this permit. Noncompliance with any provisions of this permit is grounds for enforcement action; permit termination, revocation and reissuance, or modification; or denial of a permit renewal application. It shall not be a defense for the Permittee in an enforcement action that it would have been necessary to halt or reduce the permitted activity in order to maintain compliance with the conditions of this permit. An emergency does constitute an affirmative defense in an enforcement action provided the Permittee complies with the applicable requirements set forth in Section B, Emergency Provisions.**

This permit is issued in accordance with 326 IAC 2 and 40 CFR Part 70 Appendix A and contains the conditions and provisions specified in 326 IAC 2-8 as required by 42 U.S.C. 7401, et. seq. (Clean Air Act as amended by the 1990 Clean Air Act Amendments), 40 CFR Part 70.6, IC 13-15 and IC 13-17.

Indiana statutes from IC 13 and rules from 326 IAC, quoted in conditions in this permit, are those applicable at the time the permit was issued. The issuance or possession of this permit shall not alone constitute a defense against an alleged violation of any law, regulation or standard, except for the requirement to obtain a FESOP under 326 IAC 2-8.

Operation Permit No.: F129-36688-00021	
Master Agency Interest ID: 53313	
Issued by: Tripurari P. Sinha, Ph. D., Section Chief Permits Branch Office of Air Quality	Issuance Date: April 18, 2016  Expiration Date: April 18, 2026

Minor Permit Revision No.: 129-37120-00021, issued June 14, 2016  
Administrative Amendment No.: 129-38325-00021, issued April 24, 2017  
Administrative Amendment No.: 129-40490-00021, issued November 19, 2018  
Significant Permit Revision No.: 129-43243-00021, issued April 23, 2021

Significant Permit Revision No.: 129-47826-00021	
Issued by:  Ghassan Shalabi, Section Chief Permits Branch Office of Air Quality	Issuance Date:  Expiration Date: April 18, 2026

DRAFT

**TABLE OF CONTENTS**

**TABLE OF CONTENTS ..... 2**

**SECTION A SOURCE SUMMARY ..... 5**

A.1 General Information [326 IAC 2-8-3(b)]

A.2 Emission Units and Pollution Control Equipment Summary [326 IAC 2-8-3(c)(3)]

A.3 Specifically Regulated Insignificant Activities [326 IAC 2-7-1(21)][326 IAC 2-8-3(c)(3)(I)]

A.4 Insignificant Activities [326 IAC 2-7-1(21)][326 IAC 2-8-3(c)(3)(I)]

A.5 FESOP Applicability [326 IAC 2-8-2]

**SECTION B GENERAL CONDITIONS ..... 11**

B.1 Definitions [326 IAC 2-8-1]

B.2 Permit Term [326 IAC 2-8-4(2)][326 IAC 2-1.1-9.5][IC 13-15-3-6(a)]

B.3 Term of Conditions [326 IAC 2-1.1-9.5]

B.4 Enforceability [326 IAC 2-8-6][IC 13-17-12]

B.5 Severability [326 IAC 2-8-4(4)]

B.6 Property Rights or Exclusive Privilege [326 IAC 2-8-4(5)(D)]

B.7 Duty to Provide Information [326 IAC 2-8-4(5)(E)]

B.8 Certification [326 IAC 2-8-3(d)][326 IAC 2-8-4(3)(C)(i)][326 IAC 2-8-5(1)]

B.9 Annual Compliance Certification [326 IAC 2-8-5(a)(1)]

B.10 Compliance Order Issuance [326 IAC 2-8-5(b)]

B.11 Preventive Maintenance Plan [326 IAC 1-6-3][326 IAC 2-8-4(9)]

B.12 Emergency Provisions [326 IAC 2-8-12]

B.13 Prior Permits Superseded [326 IAC 2-1.1-9.5]

B.14 Termination of Right to Operate [326 IAC 2-8-9][326 IAC 2-8-3(h)]

B.15 Permit Modification, Reopening, Revocation and Reissuance, or Termination [326 IAC 2-8-4(5)(C)][326 IAC 2-8-7(a)][326 IAC 2-8-8]

B.16 Permit Renewal [326 IAC 2-8-3(h)]

B.17 Permit Amendment or Revision [326 IAC 2-8-10][326 IAC 2-8-11.1]

B.18 Operational Flexibility [326 IAC 2-8-15][326 IAC 2-8-11.1]

B.19 Source Modification Requirement [326 IAC 2-8-11.1]

B.20 Inspection and Entry [326 IAC 2-8-5(a)(2)][IC 13-14-2-2][IC 13-17-3-2][IC 13-30-3-1]

B.21 Transfer of Ownership or Operational Control [326 IAC 2-8-10]

B.22 Annual Fee Payment [326 IAC 2-7-19][326 IAC 2-8-4(6)][326 IAC 2-8-16][326 IAC 2-1.1-7]

B.23 Credible Evidence [326 IAC 2-8-4(3)][326 IAC 2-8-5][62 FR 8314][326 IAC 1-1-6]

**SECTION C SOURCE OPERATION CONDITIONS ..... 21**

**Emission Limitations and Standards [326 IAC 2-8-4(1)] ..... 21**

C.1 Particulate Emission Limitations For Processes with Process Weight Rates Less Than One Hundred (100) Pounds per Hour [326 IAC 6-3-2]

C.2 Overall Source Limit [326 IAC 2-8]

C.3 Opacity [326 IAC 5-1]

C.4 Open Burning [326 IAC 4-1][IC 13-17-9]

C.5 Incineration [326 IAC 4-2][326 IAC 9-1-2]

C.6 Fugitive Dust Emissions [326 IAC 6-4]

C.7 Asbestos Abatement Projects [326 IAC 14-10][326 IAC 18][40 CFR 61, Subpart M]

**Testing Requirements [326 IAC 2-8-4(3)] ..... 23**

C.8 Performance Testing [326 IAC 3-6]

**Compliance Requirements [326 IAC 2-1.1-11] ..... 23**

C.9 Compliance Requirements [326 IAC 2-1.1-11]

DRAFT

<b>Compliance Monitoring Requirements [326 IAC 2-8-4(1)][326 IAC 2-8-5(a)(1)]</b> .....	<b>24</b>
C.10 Compliance Monitoring [326 IAC 2-8-4(3)][326 IAC 2-8-5(a)(1)]	
C.11 Instrument Specifications [326 IAC 2-1.1-11][326 IAC 2-8-4(3)][326 IAC 2-8-5(1)]	
<b>Corrective Actions and Response Steps [326 IAC 2-8-4][326 IAC 2-8-5(a)(1)]</b> .....	<b>24</b>
C.12 Risk Management Plan [326 IAC 2-8-4][40 CFR 68]	
C.13 Response to Excursions or Exceedances [326 IAC 2-8-4][326 IAC 2-8-5]	
C.14 Actions Related to Noncompliance Demonstrated by a Stack Test [326 IAC 2-8-4][326 IAC 2-8-5]	
<b>Record Keeping and Reporting Requirements [326 IAC 2-8-4(3)]</b> .....	<b>25</b>
C.15 General Record Keeping Requirements [326 IAC 2-8-4(3)][326 IAC 2-8-5]	
C.16 General Reporting Requirements [326 IAC 2-8-4(3)(C)][326 IAC 2-1.1-11]	
<b>Stratospheric Ozone Protection</b> .....	<b>27</b>
C.17 Compliance with 40 CFR 82 and 326 IAC 22-1	
<b>SECTION D.1 EMISSIONS UNIT OPERATION CONDITIONS</b> .....	<b>28</b>
<b>Emission Limitations and Standards [326 IAC 2-8-4(1)]</b> .....	<b>28</b>
D.1.1 FESOP Minor Limits [326 IAC 2-8-4]	
D.1.2 Particulate Emission Limitations [326 IAC 6-2-3]	
D.1.3 Sulfur Dioxide (SO <sub>2</sub> ) Limits [326 IAC 7-1.1-2]	
D.1.4 Preventive Maintenance Plan [326 IAC 2-8-4(9)]	
<b>Compliance Determination Requirements [326 IAC 2-8-4(1)]</b> .....	<b>29</b>
D.1.5 Sulfur Dioxide Emissions and Sulfur Content	
<b>Compliance Monitoring Requirements [326 IAC 2-8-4(1)][326 IAC 2-8-5(a)(1)]</b> .....	<b>29</b>
D.1.6 Visible Emission Notations	
<b>Record Keeping and Reporting Requirements [326 IAC 2-8-4(3)]</b> .....	<b>30</b>
D.1.7 Record Keeping Requirement	
D.1.8 Reporting Requirements	
<b>SECTION D.2 EMISSIONS UNIT OPERATION CONDITIONS</b> .....	<b>32</b>
<b>Emission Limitations and Standards [326 IAC 2-8-4(1)]</b> .....	<b>32</b>
D.2.1 Particulate Emission Limitation [326 IAC 6-3-2]	
D.2.2 Preventive Maintenance Plan [326 IAC 2-8-4(9)]	
<b>Compliance Determination Requirements [326 IAC 2-8-4(1)]</b> .....	<b>33</b>
D.2.3 Particulate Control	
<b>Compliance Monitoring Requirements [326 IAC 2-8-4(1)][326 IAC 2-8-5(a)(1)]</b> .....	<b>33</b>
D.2.4 Semi-Annual Filter Inspections	
<b>Record Keeping and Reporting Requirements [326 IAC 2-8-4(3)]</b> .....	<b>34</b>
D.2.5 Record Keeping Requirement	
<b>SECTION D.3 EMISSIONS UNIT OPERATION CONDITIONS</b> .....	<b>35</b>
<b>Emission Limitations and Standards [326 IAC 2-8-4(1)]</b> .....	<b>35</b>
D.3.1 Material Requirements for Cold Cleaner Degreasers [326 IAC 8-3-8]	
D.3.2 Preventive Maintenance Plan [326 IAC 2-8-4(9)]	
<b>Record Keeping and Reporting Requirement [326 IAC 2-8-4(3)]</b> .....	<b>35</b>
D.3.3 Record Keeping Requirements	
<b>SECTION E.1 NSPS</b> .....	<b>36</b>
<b>New Source Performance Standards (NSPS) Requirements [326 IAC 2-8-4(1)]</b> .....	<b>36</b>
E.1.1 General Provisions Relating to New Source Performance Standards [326 IAC 12-1][40 CFR Part 60, Subpart A]	



DRAFT

E.1.2 New Source Performance Standard for Small Industrial-Commercial-Institutional Steam Generating Units NSPS [326 IAC 12][40 CFR Part 60, Subpart Dc]

**SECTION E.2 NSPS ..... 37**

**New Source Performance Standards (NSPS) Requirements [326 IAC 2-8-4(1)]..... 38**

E.2.1 General Provisions Relating to New Source Performance Standards [326 IAC 12-1][40 CFR Part 60, Subpart A]

E.2.2 New Source Performance Standard for Stationary Compression Ignition Internal Combustion Engines NSPS [326 IAC 12][40 CFR Part 60, Subpart IIII]

**SECTION E.3 NESHAP ..... 40**

**National Emission Standards for Hazardous Air Pollutants (NESHAP) Requirements [326 IAC 2-8-4(1)]..... 41**

E.3.1 General Provisions Relating to National Emission Standards for Hazardous Air Pollutants under 40 CFR Part 63 [326 IAC 20-1][40 CFR Part 63, Subpart A]

E.3.2 National Emission Standards for Hazardous Air Pollutants for Stationary Reciprocating Internal Combustion Engines NESHAP [40 CFR Part 63, Subpart ZZZZ][326 IAC 20-82]

E.3.3 Preventive Maintenance Plan [326 IAC 2-8-4(9)]

**CERTIFICATION ..... 43**

**EMERGENCY OCCURRENCE REPORT ..... 44**

**FESOP Usage Report..... 46**

**QUARTERLY DEVIATION AND COMPLIANCE MONITORING REPORT ..... 47**

Attachment A: 40 CFR 60, Subpart Dc, NSPS for Small Industrial-Commercial-Institutional Steam Generating Units

Attachment B: 40 CFR 60, Subpart IIII, NSPS for Stationary Compression Ignition Internal Combustion Engines

Attachment C: 40 CFR 63, Subpart ZZZZ, NESHAP for Stationary Reciprocating Internal Combustion Engines

DRAFT

## SECTION A

## SOURCE SUMMARY

This permit is based on information requested by the Indiana Department of Environmental Management (IDEM), Office of Air Quality (OAQ). The information describing the source contained in conditions A.1 through A.3 is descriptive information and does not constitute enforceable conditions. However, the Permittee should be aware that a physical change or a change in the method of operation that may render this descriptive information obsolete or inaccurate may trigger requirements for the Permittee to obtain additional permits or seek modification of this permit pursuant to 326 IAC 2, or change other applicable requirements presented in the permit application.

### A.1 General Information [326 IAC 2-8-3(b)]

---

The Permittee owns and operates a stationary pharmaceutical formulation and packaging source.

Source Address:	4601 Highway 62 East, Mt. Vernon, Indiana 47620
General Source Phone Number:	812-307-3018
SIC Code:	2834 (Pharmaceutical Preparations)
County Location:	Posey
Source Location Status:	Attainment for all criteria pollutants
Source Status:	Federally Enforceable State Operating Permit Program Minor Source, under PSD Rules Minor Source, Section 112 of the Clean Air Act Not 1 of 28 Source Categories

### A.2 Emission Units and Pollution Control Equipment Summary [326 IAC 2-8-3(c)(3)]

---

This stationary source consists of the following emission units and pollution control devices:

- (a) one (1) natural gas fired temporary boiler station, identified as (TB1), approved in 2024 for construction, with a maximum operating input rate of 60 MMBtu/hr, uses No. 2 fuel oil as back up fuel, using no control, and exhausting to stacks S-1.  
  
[Under 40 CFR 60, Subpart Dc, this is an affected source.]
- (b) One (1) natural gas fired boiler installed in 2005, identified as Boiler #3 (S27), with a maximum heat input rate of 60.8 MMBtu per hour, using low NOx burners and Flue Gas Recirculation, and exhausting through stack S-27. Boiler #3 uses No. 2 fuel oil as back-up fuel.  
  
[Under 40 CFR 60, Subpart Dc, this is an affected source.]
- (c) One (1) tablet core press machines, located in Building 122, Room 1109, installed in 2016, with maximum capacity of 425 pounds per hour, controlled by a common Henlex pre-filter dust collector and Henlex HEPA filter.
- (d) One (1) tablet core press machines, located in Building 122, Room 1111, installed in 2016, with maximum capacity of 425 pounds per hour, controlled by a common Henlex pre-filter dust collector and Henlex HEPA filter.
- (e) One (1) Granulator and one (1) GEA fluid-bed dryer for aqueous wet granulations located in Building 123, Room 1202, constructed in 2013, with a maximum capacity of 290 lbs/hr. Granulator and fluid-bed dryer controlled by a common Flanders pre-filter and Flanders HEPA filter.
- (f) One (1) Granulator and one (1) GEA fluid-bed dryer for aqueous wet granulations located in Building 123, Room 1235, constructed in 2016, with a maximum capacity of 290 lbs/hr. Granulator and fluid-bed dryer controlled by a common Flanders pre-filter and Flanders

DRAFT

HEPA filter.

- (g) One (1) 1,400kW diesel engine-driven emergency generator, identified as S-3, located outside southwest of Building 104, with maximum capacity of 1,400 kW, and exhausting through stack S-3. This generator was constructed before July 11, 2005 and manufactured before April 1, 2006.

[Under 40 CFR 63, Subpart ZZZZ, this is considered an affected source.]

- (h) One (1) 1,500kW diesel engine-driven emergency generator, identified as S32, located outside on southeast of Building 104, constructed in 2009, with a maximum capacity of 1,500kW, and exhausting to Stack S-32.

[Under 40 CFR 60, Subpart IIII, this is considered an affected source.]

[Under 40 CFR 63, Subpart ZZZZ, this is considered a new affected source.]

- (i) One (1) 3,000 kW diesel engine-driven emergency generator located outside of Building 122, identified as S35, constructed in 2011, with a maximum capacity of 3,000 kW, and exhausting to Stack S-35.

[Under 40 CFR 60, Subpart IIII, this is considered an affected source.]

[Under 40 CFR 63, Subpart ZZZZ, this is considered a new affected source.]

- (j) One (1) 3,000 kW diesel engine-driven emergency generator, identified as S45, located outside northwest of Building 104, constructed in 2015, with a maximum capacity of 3,000 kW, and exhausting to stack S-45.

[Under 40 CFR 60, Subpart IIII, this is considered an affected source.]

[Under 40 CFR 63, Subpart ZZZZ, this is considered a new affected source.]

A.3 Specifically Regulated Insignificant Activities [326 IAC 2-7-1(21)] [326 IAC 2-8-3(c)(3)(I)]

This stationary source also includes the following insignificant activities which are specifically regulated, as defined in 326 IAC 2-7-1(21):

- (a) The following emission units located in Building 122:
- (1) One (1) tablet core press machine, located in Building 122, Room 1113, installed in 1998, with maximum capacity of 165 pounds per hour, and controlled by a fabric dust collector.
  - (2) One (1) powder encapsulator machine, located in Building 122, Room 1124, installed in 2009, with a maximum powder throughput of 185 pounds per hour, and controlled by a fabric filter dust collector.
- (b) The following emission units located in Building 123:
- (1) One (1) tablet coating unit (Thomas Flex 500) located in Building 123, Room 1151, with a maximum capacity (spray rate) of 106 lbs/hr, constructed in 2013, and controlled by Torit fabric filter dust collector.
  - (2) One (1) Central Vacuum System, located in Building 123, and controlled by existing Torit fabric filter dust collector, installed in 2008 and relocated in 2014.

DRAFT

- (c) One (1) 350kW diesel engine-driven emergency generator, identified as S34, located outside west of Building 106, constructed in 2011, with a maximum capacity of 350 kW and exhausting to Stack S-34.  
 [Under 40 CFR 60, Subpart IIII, this is considered an affected source]  
 [Under 40 CFR 63, Subpart ZZZZ, this is considered an affected source]
- (d) One (1) 200 kW diesel engine-driven emergency generator, identified as S44, located outside of Building 113, constructed in 2015, with a maximum capacity of 200 kW, and exhausting to stack S-44.  
 [Under 40 CFR 60, Subpart IIII, this is considered an affected source]  
 [Under 40 CFR 63, Subpart ZZZZ, this is considered an affected source]
- (e) One (1) 246 hp diesel-fired emergency pump engine, identified as S7, located in Building 103, constructed in 2014, permitted in 2015, and exhausting to stack S-7.  
 [Under 40 CFR 60, Subpart IIII, this is considered an affected source]  
 [Under 40 CFR 63, Subpart ZZZZ, this is considered an affected source]
- (f) One (1) 350 kW diesel engine-driven emergency generator engine, identified as S46, located outside southeast of Building 123, with a brake HP rating of 539.0, constructed in 2021, and using no control.  
 [Under 40 CFR 60, Subpart IIII, this is considered an affected source]  
 [Under 40 CFR 63, Subpart ZZZZ, this is considered an affected source]
- (g) Cold solvent cleaning station (2 square feet) installed in 1970.

A.4 Insignificant Activities [326 IAC 2-7-1(21)] [326 IAC 2-8-3(c)(3)(I)]

This stationary source also includes the following insignificant activities:

- (a) Two (2) Bohle Table Coaters, each consisting of a single pan tablet coating machine and three coating suspension prep tanks, each with a maximum production capacity of 880 lbs of tablets per 36-hour batch, and using voluntary Torit Model DFT 2-16-R fabric filter dust collector for particulate control during tablet charging and voluntary scrubbers.

Emission Unit	Year Constructed	Exhaust Stack	Charging Exhaust Stack
Bohle Tablet Coater #1	2006	S-30	S-30a
Bohle Tablet Coater #2	2006	S-33	S-33a

- (b) Seven (7) Bohle Table Coaters, each consisting of a single pan tablet coating machine and three coating suspension prep tanks, with a maximum production capacity of 1,540 lbs of tablets per 36-hour batch, and using voluntary scrubbers.

Emission Unit	Year Constructed	Exhaust Stack
Bohle Tablet Coater #3	2011	S-36
Bohle Tablet Coater #4	2011	S-37
Bohle Tablet Coater #5	2012	S-38
Bohle Tablet Coater #6	2012	S-39
Bohle Tablet Coater #7	2012	S-40
Bohle Tablet Coater #8	2012	S-41
Bohle Tablet Coater #9	2013	S-42

DRAFT

- (c) Three (3) Fette tablet core press machines and room exhausts, constructed in 2013, and each controlled by voluntary Camfil-Farr dust collectors and voluntary Camfil-Farr HEPA filters.

Emission Unit	Location	Maximum Capacity (lb/hr)
Fette 64	Building 123, Room 1142	844
Fette 65	Building 123, Room 1144	840
Fette 65	Building 123, Room 1205	840

- (d) The following emission units located in Building 121:
- (1) Tablet core press machine located in Building 121, Room 116c, installed in 2001, with a maximum capacity of 80 lbs/hr, controlled by Torit fabric filter/dust collector.
  - (2) Tablet core press machine and room exhaust located in Building 121, Room 1014, installed in 2004, with a maximum capacity of 80 lbs/hr, and controlled by Mac fabric filter/dust collector.
  - (3) Tablet coating unit (1-pan coater) located in Building 121, Room 116c, installed in 2001, with a maximum capacity of 50 lbs/hr, and controlled by Torit fabric filter/dust collector.
  - (4) Tablet coating unit (1-pan coater) located in Building 121, Room 1023, installed in 2004, with a maximum capacity of 50 lbs/hr, and controlled by Torit fabric filter/dust collector.
  - (5) Tablet coating unit (1-pan coater) located in Building 121, Room 1032, installed in 2021, with a maximum capacity of 50 lbs/hr, and controlled by fabric filter/dust collector.
  - (6) One (1) Mac Central Vacuum System, located in Building 121 mezzanine, and controlled by fabric filter dust collector, installed in 2004.
- (e) The following emission units located in Building 122:
- (1) One (1) Granulator and one (1) Glatt 120 fluid-bed dryer for aqueous wet granulations located in Building 122, Room 1119, installed in 1999, with a maximum capacity of 98 lbs/hr. Granulator controlled by Torit fabric filter/dust collector and fluid-bed dryer controlled by Torit fabric filter/dust collector.
  - (2) One (1) Powder encapsulator machine, located in Building 122, Room 1123, installed in 2009, with a maximum powder throughput of 110 pounds per hour, and controlled by a common fabric filter dust collector.
  - (3) One (1) Spencer Central Vacuum System, located at Building 122, and controlled by a fabric filter dust collector, installed in 1998.
- (f) The following emission units located in Building 123:
- (1) Bin Charging system located in Building 123, Room 1227, with a maximum capacity of 800 lbs/hr, constructed in 2013, and controlled by Torit fabric filter dust collector and Flanders HEPA filter.

DRAFT

- (2) Four (4) tablet printers located in Building 123, each with a maximum capacity of 3,000 lbs/day, constructed in 2013 and modified in 2015.
  - (3) Four (4) rooms for dry material weighing and dispensing, located in Building 123, each with a maximum capacity of 1,237 lbs/hr, and controlled by fabric filters.
  - (4) One (1) weigh room, identified as Building 123, Room 1228, permitted in 2017, with a maximum capacity of 1,323 pounds per hour. The material input into the vacuum transfer system is controlled with a HEPA filter prior to exhausting to atmosphere. The vacuum transfer into the receiver source vents indoors.
- (g) The following emission units located in Building 124:
- (1) Pharmaceutical packaging line 20 (previously line 3), located in Building 124, installed in 2004, with a maximum capacity of 442 lbs/hr, and controlled by a dust collector for PM.
  - (2) Pharmaceutical packaging lines 8, 9, 11, 12 (installed in 2004) and line 10 (installed in 2016), located in Building 124, with a maximum capacity of 3,236 lbs/hr. Packaging lines 8, 9, 11, and 10 are controlled by a common dust collector for PM and line 12 is controlled by a separate dust collector for PM.
  - (3) One (1) pharmaceutical packaging line, identified as line 15, located in Building 124, constructed in 2015, with a maximum capacity of 200 lb/hr, controlled by a common dust collector for particulate control.
  - (4) One (1) pharmaceutical packaging line, identified as line 16, located in Building 124, constructed in 2018, with a maximum capacity of 200 lbs/hr, controlled by a common dust collector for particulate control.
  - (5) One (1) pharmaceutical packaging line, identified as line 17, located in Building 124, constructed in 2021, with a maximum capacity of 200 lbs/hr, controlled by a common dust collector for particulate control.
  - (6) Six (6) warm air tray electric dryers used to dry water-based granulations, located in Building 124, Room 1130, installed in 2009, with a maximum total capacity of 1,830 pounds per batch. These units have no emissions.
  - (7) One (1) Central Vacuum System, located in Building 124, and controlled by Torit fabric filter dust collector, installed in 2013.
- (h) The following diesel storage tanks:
- (1) One (1) 20,000 gallon aboveground VOC storage tank containing diesel fuel oil, installed in 1997, located at Building 104 and connected to temporary boiler (TB1), Boiler S27, emergency generator S3, emergency generator S32, and emergency generator S45.
  - (2) One (1) 100 gallon aboveground VOC storage tank containing diesel fuel oil, located at Building 104 and connected to emergency generator S3.
  - (3) One (1) 270 gallon aboveground VOC storage tank containing diesel fuel oil, located at Building 103 and connected to fire pump engine S7.
  - (4) One (1) 775 gallon aboveground VOC storage tank containing diesel fuel oil that is part of Building 106 emergency generator S34, installed in 2011.

DRAFT

- (5) One (1) 5,200 gallon aboveground VOC storage tank containing diesel fuel oil, constructed in 2011, located at Building 122, and connected to Building 122 emergency generator S35.
  - (6) One (1) diesel storage tank, located at Building 104 and connected to Building 104 emergency generator S32, constructed in 2015, with a maximum capacity of 100 gallons.
  - (7) One (1) diesel storage tank that is part of Building 113 emergency generator S44, constructed in 2015, with a maximum capacity of 395 gallons.
  - (8) One (1) diesel storage tank, located at Building 104 and connected to Building 104 emergency generator S45, constructed in 2015, with a maximum capacity of 200 gallons.
- (i) Paved and unpaved roads and parking lots with public access, installed in 1970.

A.5 FESOP Applicability [326 IAC 2-8-2]

This stationary source, otherwise required to have a Part 70 permit as described in 326 IAC 2-7-2(a), has applied to the Indiana Department of Environmental Management (IDEM), Office of Air Quality (OAQ) to renew a Federally Enforceable State Operating Permit (FESOP).

DRAFT

## SECTION B GENERAL CONDITIONS

### B.1 Definitions [326 IAC 2-8-1]

---

Terms in this permit shall have the definition assigned to such terms in the referenced regulation. In the absence of definitions in the referenced regulation, the applicable definitions found in the statutes or regulations (IC 13-11, 326 IAC 1-2 and 326 IAC 2-7) shall prevail.

### B.2 Permit Term [326 IAC 2-8-4(2)][326 IAC 2-1.1-9.5][IC 13-15-3-6(a)]

---

(a) This permit, F129-36688-00021, is issued for a fixed term of ten (10) years from the issuance date of this permit, as determined in accordance with IC 4-21.5-3-5(f) and IC 13-15-5-3. Subsequent revisions, modifications, or amendments of this permit do not affect the expiration date of this permit.

(b) If IDEM, OAQ, upon receiving a timely and complete renewal permit application, fails to issue or deny the permit renewal prior to the expiration date of this permit, this existing permit shall not expire and all terms and conditions shall continue in effect, until the renewal permit has been issued or denied.

### B.3 Term of Conditions [326 IAC 2-1.1-9.5]

---

Notwithstanding the permit term of a permit to construct, a permit to operate, or a permit modification, any condition established in a permit issued pursuant to a permitting program approved in the state implementation plan shall remain in effect until:

(a) the condition is modified in a subsequent permit action pursuant to Title I of the Clean Air Act; or

(b) the emission unit to which the condition pertains permanently ceases operation.

### B.4 Enforceability [326 IAC 2-8-6][IC 13-17-12]

---

Unless otherwise stated, all terms and conditions in this permit, including any provisions designed to limit the source's potential to emit, are enforceable by IDEM, the United States Environmental Protection Agency (U.S. EPA) and by citizens in accordance with the Clean Air Act.

### B.5 Severability [326 IAC 2-8-4(4)]

---

The provisions of this permit are severable; a determination that any portion of this permit is invalid shall not affect the validity of the remainder of the permit.

### B.6 Property Rights or Exclusive Privilege [326 IAC 2-8-4(5)(D)]

---

This permit does not convey any property rights of any sort or any exclusive privilege.

### B.7 Duty to Provide Information [326 IAC 2-8-4(5)(E)]

---

(a) The Permittee shall furnish to IDEM, OAQ, within a reasonable time, any information that IDEM, OAQ may request in writing to determine whether cause exists for modifying, revoking and reissuing, or terminating this permit, or to determine compliance with this permit. Upon request, the Permittee shall also furnish to IDEM, OAQ copies of records required to be kept by this permit.

(b) For information furnished by the Permittee to IDEM, OAQ, the Permittee may include a claim of confidentiality in accordance with 326 IAC 17.1. When furnishing copies of requested records directly to U. S. EPA, the Permittee may assert a claim of confidentiality in accordance with 40 CFR 2, Subpart B.

### B.8 Certification [326 IAC 2-8-3(d)][326 IAC 2-8-4(3)(C)(i)][326 IAC 2-8-5(1)]

---

(a) A certification required by this permit meets the requirements of 326 IAC 2-8-5(a)(1) if:



DRAFT

- (1) it contains a certification by an "authorized individual", as defined by 326 IAC 2-1.1-1(1), and
  - (2) the certification states that, based on information and belief formed after reasonable inquiry, the statements and information in the document are true, accurate, and complete.
- (b) The Permittee may use the attached Certification Form, or its equivalent with each submittal requiring certification. One (1) certification may cover multiple forms in one (1) submittal.
  - (c) An "authorized individual" is defined at 326 IAC 2-1.1-1(1).

B.9 Annual Compliance Certification [326 IAC 2-8-5(a)(1)]

- (a) The Permittee shall annually submit a compliance certification report which addresses the status of the source's compliance with the terms and conditions contained in this permit, including emission limitations, standards, or work practices. All certifications shall cover the time period from January 1 to December 31 of the previous year, and shall be submitted no later than July 1 of each year to:

Indiana Department of Environmental Management  
Compliance and Enforcement Branch, Office of Air Quality  
100 North Senate Avenue  
MC 61-53 IGCN 1003  
Indianapolis, Indiana 46204-2251

- (b) The annual compliance certification report required by this permit shall be considered timely if the date postmarked on the envelope or certified mail receipt, or affixed by the shipper on the private shipping receipt, is on or before the date it is due. If the document is submitted by any other means, it shall be considered timely if received by IDEM, OAQ on or before the date it is due.
- (c) The annual compliance certification report shall include the following:
  - (1) The appropriate identification of each term or condition of this permit that is the basis of the certification;
  - (2) The compliance status;
  - (3) Whether compliance was continuous or intermittent;
  - (4) The methods used for determining the compliance status of the source, currently and over the reporting period consistent with 326 IAC 2-8-4(3); and
  - (5) Such other facts, as specified in Sections D of this permit, as IDEM, OAQ may require to determine the compliance status of the source.

The submittal by the Permittee does require a certification that meets the requirements of 326 IAC 2-8-5(a)(1) by an "authorized individual" as defined by 326 IAC 2-1.1-1(1).

B.10 Compliance Order Issuance [326 IAC 2-8-5(b)]

IDEM, OAQ may issue a compliance order to this Permittee upon discovery that this permit is in nonconformance with an applicable requirement. The order may require immediate compliance or contain a schedule for expeditious compliance with the applicable requirement.

DRAFT

B.11 Preventive Maintenance Plan [326 IAC 1-6-3][326 IAC 2-8-4(9)]

- (a) A Preventive Maintenance Plan meets the requirements of 326 IAC 1-6-3 if it includes, at a minimum:
- (1) Identification of the individual(s) responsible for inspecting, maintaining, and repairing emission control devices;
  - (2) A description of the items or conditions that will be inspected and the inspection schedule for said items or conditions; and
  - (3) Identification and quantification of the replacement parts that will be maintained in inventory for quick replacement.

The Permittee shall implement the PMPs.

- (b) If required by specific condition(s) in Section D of this permit where no PMP was previously required, the Permittee shall prepare and maintain Preventive Maintenance Plans (PMPs) no later than ninety (90) days after issuance of this permit or ninety (90) days after initial start-up, whichever is later, including the following information on each facility:
- (1) Identification of the individual(s) responsible for inspecting, maintaining, and repairing emission control devices;
  - (2) A description of the items or conditions that will be inspected and the inspection schedule for said items or conditions; and
  - (3) Identification and quantification of the replacement parts that will be maintained in inventory for quick replacement.

If, due to circumstances beyond the Permittee's control, the PMPs cannot be prepared and maintained within the above time frame, the Permittee may extend the date an additional ninety (90) days provided the Permittee notifies:

Indiana Department of Environmental Management  
Compliance and Enforcement Branch, Office of Air Quality  
100 North Senate Avenue  
MC 61-53 IGCN 1003  
Indianapolis, Indiana 46204-2251

The PMP extension notification does not require a certification that meets the requirements of 326 IAC 2-8-5(a)(1) by an "authorized individual" as defined by 326 IAC 2-1.1-1(1).

The Permittee shall implement the PMPs.

- (c) A copy of the PMPs shall be submitted to IDEM, OAQ upon request and within a reasonable time, and shall be subject to review and approval by IDEM, OAQ. IDEM, OAQ may require the Permittee to revise its PMPs whenever lack of proper maintenance causes or is the primary contributor to an exceedance of any limitation on emissions. The PMPs and their submittal do not require a certification that meets the requirements of 326 IAC 2-8-5(a)(1) by an "authorized individual" as defined by 326 IAC 2-1.1-1(1).

DRAFT

- (d) To the extent the Permittee is required by 40 CFR Part 60/63 to have an Operation Maintenance, and Monitoring (OMM) Plan for a unit, such Plan is deemed to satisfy the PMP requirements of 326 IAC 1-6-3 for that unit.

B.12 Emergency Provisions [326 IAC 2-8-12]

- (a) An emergency, as defined in 326 IAC 2-7-1(12), is not an affirmative defense for an action brought for noncompliance with a federal or state health-based emission limitation except as provided in 326 IAC 2-8-12.

- (b) An emergency, as defined in 326 IAC 2-7-1(12), constitutes an affirmative defense to an action brought for noncompliance with a health-based or technology-based emission limitation if the affirmative defense of an emergency is demonstrated through properly signed, contemporaneous operating logs or other relevant evidence that describe the following:

- (1) An emergency occurred and the Permittee can, to the extent possible, identify the causes of the emergency;
- (2) The permitted facility was at the time being properly operated;
- (3) During the period of an emergency, the Permittee took all reasonable steps to minimize levels of emissions that exceeded the emission standards or other requirements in this permit;
- (4) For each emergency lasting one (1) hour or more, the Permittee notified IDEM, OAQ or Southwest Regional Office within four (4) daytime business hours after the beginning of the emergency, or after the emergency was discovered or reasonably should have been discovered;

Telephone Number: 1-800-451-6027 (ask for Office of Air Quality, Compliance and Enforcement Branch), or  
Telephone Number: 317-233-0178 (ask for Office of Air Quality, Compliance and Enforcement Branch)  
Facsimile Number: 317-233-6865  
Southwest Regional Office phone: (812) 380-2305; fax: (812) 380-2304.

- (5) For each emergency lasting one (1) hour or more, the Permittee submitted the attached Emergency Occurrence Report Form or its equivalent, either by mail or facsimile to:

Indiana Department of Environmental Management  
Compliance and Enforcement Branch, Office of Air Quality  
100 North Senate Avenue  
MC 61-53 IGCN 1003  
Indianapolis, Indiana 46204-2251

within two (2) working days of the time when emission limitations were exceeded due to the emergency.

The notice fulfills the requirement of 326 IAC 2-8-4(3)(C)(ii) and must contain the following:

- (A) A description of the emergency;
- (B) Any steps taken to mitigate the emissions; and

DRAFT

(C) Corrective actions taken.

The notification which shall be submitted by the Permittee does not require a certification that meets the requirements of 326 IAC 2-8-5(a)(1) by an "authorized individual" as defined by 326 IAC 2-1.1-1(1).

- (6) The Permittee immediately took all reasonable steps to correct the emergency.
- (c) In any enforcement proceeding, the Permittee seeking to establish the occurrence of an emergency has the burden of proof.
- (d) This emergency provision supersedes 326 IAC 1-6 (Malfunctions). This permit condition is in addition to any emergency or upset provision contained in any applicable requirement.
- (e) The Permittee seeking to establish the occurrence of an emergency shall make records available upon request to ensure that failure to implement a PMP did not cause or contribute to an exceedance of any limitations on emissions. However, IDEM, OAQ may require that the Preventive Maintenance Plans required under 326 IAC 2-8-3(c)(6) be revised in response to an emergency.
- (f) Failure to notify IDEM, OAQ by telephone or facsimile of an emergency lasting more than one (1) hour in accordance with (b)(4) and (5) of this condition shall constitute a violation of 326 IAC 2-8 and any other applicable rules.
- (g) Operations may continue during an emergency only if the following conditions are met:
- (1) If the emergency situation causes a deviation from a technology-based limit, the Permittee may continue to operate the affected emitting facilities during the emergency provided the Permittee immediately takes all reasonable steps to correct the emergency and minimize emissions.
- (2) If an emergency situation causes a deviation from a health-based limit, the Permittee may not continue to operate the affected emissions facilities unless:
- (A) The Permittee immediately takes all reasonable steps to correct the emergency situation and to minimize emissions; and
- (B) Continued operation of the facilities is necessary to prevent imminent injury to persons, severe damage to equipment, substantial loss of capital investment, or loss of product or raw material of substantial economic value.

Any operations shall continue no longer than the minimum time required to prevent the situations identified in (g)(2)(B) of this condition.

B.13 Prior Permits Superseded [326 IAC 2-1.1-9.5]

- (a) All terms and conditions of permits established prior to F129-36688-00021 and issued pursuant to permitting programs approved into the state implementation plan have been either:
- (1) incorporated as originally stated,
- (2) revised, or

DRAFT

(3) deleted.

(b) All previous registrations and permits are superseded by this permit.

**B.14 Termination of Right to Operate [326 IAC 2-8-9][326 IAC 2-8-3(h)]**

---

The Permittee's right to operate this source terminates with the expiration of this permit unless a timely and complete renewal application is submitted at least nine (9) months prior to the date of expiration of the source's existing permit, consistent with 326 IAC 2-8-3(h) and 326 IAC 2-8-9.

**B.15 Permit Modification, Reopening, Revocation and Reissuance, or Termination  
[326 IAC 2-8-4(5)(C)][326 IAC 2-8-7(a)][326 IAC 2-8-8]**

---

- (a) This permit may be modified, reopened, revoked and reissued, or terminated for cause. The filing of a request by the Permittee for a Federally Enforceable State Operating Permit modification, revocation and reissuance, or termination, or of a notification of planned changes or anticipated noncompliance does not stay any condition of this permit. [326 IAC 2-8-4(5)(C)] The notification by the Permittee does require a certification that meets the requirements of 326 IAC 2-8-5(a)(1) by an "authorized individual" as defined by 326 IAC 2-1.1-1(1).
- (b) This permit shall be reopened and revised under any of the circumstances listed in IC 13-15-7-2 or if IDEM, OAQ determines any of the following:
- (1) That this permit contains a material mistake.
  - (2) That inaccurate statements were made in establishing the emissions standards or other terms or conditions.
  - (3) That this permit must be revised or revoked to assure compliance with an applicable requirement. [326 IAC 2-8-8(a)]
- (c) Proceedings by IDEM, OAQ to reopen and revise this permit shall follow the same procedures as apply to initial permit issuance and shall affect only those parts of this permit for which cause to reopen exists. Such reopening and revision shall be made as expeditiously as practicable. [326 IAC 2-8-8(b)]
- (d) The reopening and revision of this permit, under 326 IAC 2-8-8(a), shall not be initiated before notice of such intent is provided to the Permittee by IDEM, OAQ at least thirty (30) days in advance of the date this permit is to be reopened, except that IDEM, OAQ may provide a shorter time period in the case of an emergency. [326 IAC 2-8-8(c)]

**B.16 Permit Renewal [326 IAC 2-8-3(h)]**

---

- (a) The application for renewal shall be submitted using the application form or forms prescribed by IDEM, OAQ and shall include the information specified in 326 IAC 2-8-3. Such information shall be included in the application for each emission unit at this source, except those emission units included on the trivial or insignificant activities list contained in 326 IAC 2-7-1(21) and 326 IAC 2-7-1(42). The renewal application does require a certification that meets the requirements of 326 IAC 2-8-5(a)(1) by an "authorized individual" as defined by 326 IAC 2-1.1-1(1).

Request for renewal shall be submitted to:

Indiana Department of Environmental Management  
Permit Administration and Support Section, Office of Air Quality  
100 North Senate Avenue  
MC 61-53 IGCN 1003

DRAFT

Indianapolis, Indiana 46204-2251

- (b) A timely renewal application is one that is:
- (1) Submitted at least nine (9) months prior to the date of the expiration of this permit; and
  - (2) If the date postmarked on the envelope or certified mail receipt, or affixed by the shipper on the private shipping receipt, is on or before the date it is due. If the document is submitted by any other means, it shall be considered timely if received by IDEM, OAQ on or before the date it is due.
- (c) If the Permittee submits a timely and complete application for renewal of this permit, the source's failure to have a permit is not a violation of 326 IAC 2-8 until IDEM, OAQ takes final action on the renewal application, except that this protection shall cease to apply if, subsequent to the completeness determination, the Permittee fails to submit by the deadline specified, pursuant to 326 IAC 2-8-3(g), in writing by IDEM, OAQ any additional information identified as being needed to process the application.

B.17 Permit Amendment or Revision [326 IAC 2-8-10][326 IAC 2-8-11.1]

- (a) Permit amendments and revisions are governed by the requirements of 326 IAC 2-8-10 or 326 IAC 2-8-11.1 whenever the Permittee seeks to amend or modify this permit.
- (b) Any application requesting an amendment or modification of this permit shall be submitted to:
- Indiana Department of Environmental Management  
Permit Administration and Support Section, Office of Air Quality  
100 North Senate Avenue  
MC 61-53 IGCN 1003  
Indianapolis, Indiana 46204-2251
- Any such application does require a certification that meets the requirements of 326 IAC 2-8-5(a)(1) by an "authorized individual" as defined by 326 IAC 2-1.1-1(1).
- (c) The Permittee may implement administrative amendment changes addressed in the request for an administrative amendment immediately upon submittal of the request. [326 IAC 2-8-10(b)(3)]

B.18 Operational Flexibility [326 IAC 2-8-15][326 IAC 2-8-11.1]

- (a) The Permittee may make any change or changes at the source that are described in 326 IAC 2-8-15(b) and (c) without a prior permit revision, if each of the following conditions is met:
- (1) The changes are not modifications under any provision of Title I of the Clean Air Act;
  - (2) Any approval required by 326 IAC 2-8-11.1 has been obtained;
  - (3) The changes do not result in emissions which exceed the limitations provided in this permit (whether expressed herein as a rate of emissions or in terms of total emissions);
  - (4) The Permittee notifies the:

DRAFT

Indiana Department of Environmental Management  
Permit Administration and Support Section, Office of Air Quality  
100 North Senate Avenue  
MC 61-53 IGCN 1003  
Indianapolis, Indiana 46204-2251

and

United States Environmental Protection Agency, Region V  
Air and Radiation Division, Regulation Development Branch - Indiana (AR-18J)  
77 West Jackson Boulevard  
Chicago, Illinois 60604-3590

in advance of the change by written notification at least ten (10) days in advance of the proposed change. The Permittee shall attach every such notice to the Permittee's copy of this permit; and

- (5) The Permittee maintains records on-site, on a rolling five (5) year basis, which document all such changes and emission trades that are subject to 326 IAC 2-8-15(b)(1) and (c). The Permittee shall make such records available, upon reasonable request, for public review.

Such records shall consist of all information required to be submitted to IDEM, OAQ in the notices specified in 326 IAC 2-8-15(b)(1) and (c).

- (b) **Emission Trades [326 IAC 2-8-15(b)]**  
The Permittee may trade emissions increases and decreases at the source, where the applicable SIP provides for such emission trades without requiring a permit revision, subject to the constraints of Section (a) of this condition and those in 326 IAC 2-8-15(b).
- (c) **Alternative Operating Scenarios [326 IAC 2-8-15(c)]**  
The Permittee may make changes at the source within the range of alternative operating scenarios that are described in the terms and conditions of this permit in accordance with 326 IAC 2-8-4(7). No prior notification of IDEM, OAQ or U.S. EPA is required.
- (d) Backup fuel switches specifically addressed in, and limited under, Section D of this permit shall not be considered alternative operating scenarios. Therefore, the notification requirements of part (a) of this condition do not apply.

**B.19 Source Modification Requirement [326 IAC 2-8-11.1]**

---

A modification, construction, or reconstruction is governed by the requirements of 326 IAC 2.

**B.20 Inspection and Entry [326 IAC 2-8-5(a)(2)][IC 13-14-2-2][IC 13-17-3-2][IC 13-30-3-1]**

---

Upon presentation of proper identification cards, credentials, and other documents as may be required by law, and subject to the Permittee's right under all applicable laws and regulations to assert that the information collected by the agency is confidential and entitled to be treated as such, the Permittee shall allow IDEM, OAQ, U.S. EPA, or an authorized representative to perform the following:

- (a) Enter upon the Permittee's premises where a FESOP source is located, or emissions related activity is conducted, or where records must be kept under the conditions of this permit;

DRAFT

- (b) As authorized by the Clean Air Act, IC 13-14-2-2, IC 13-17-3-2, and IC 13-30-3-1, have access to and copy, at reasonable times, any records that must be kept under the conditions of this permit;
- (c) As authorized by the Clean Air Act, IC 13-14-2-2, IC 13-17-3-2, and IC 13-30-3-1, inspect, at reasonable times, any facilities, equipment (including monitoring and air pollution control equipment), practices, or operations regulated or required under this permit;
- (d) As authorized by the Clean Air Act, IC 13-14-2-2, IC 13-17-3-2, and IC 13-30-3-1, sample or monitor, at reasonable times, substances or parameters for the purpose of assuring compliance with this permit or applicable requirements; and
- (e) As authorized by the Clean Air Act, IC 13-14-2-2, IC 13-17-3-2, and IC 13-30-3-1, utilize any photographic, recording, testing, monitoring, or other equipment for the purpose of assuring compliance with this permit or applicable requirements.

B.21 Transfer of Ownership or Operational Control [326 IAC 2-8-10]

- (a) The Permittee must comply with the requirements of 326 IAC 2-8-10 whenever the Permittee seeks to change the ownership or operational control of the source and no other change in the permit is necessary.
- (b) Any application requesting a change in the ownership or operational control of the source shall contain a written agreement containing a specific date for transfer of permit responsibility, coverage and liability between the current and new Permittee. The application shall be submitted to:  
  
Indiana Department of Environmental Management  
Permit Administration and Support Section, Office of Air Quality  
100 North Senate Avenue  
MC 61-53 IGCN 1003  
Indianapolis, Indiana 46204-2251  
  
Any such application does require a certification that meets the requirements of 326 IAC 2-8-5(a)(1) by an "authorized individual" as defined by 326 IAC 2-1.1-1(1).
- (c) The Permittee may implement administrative amendment changes addressed in the request for an administrative amendment immediately upon submittal of the request. [326 IAC 2-8-10(b)(3)]

B.22 Annual Fee Payment [326 IAC 2-7-19][326 IAC 2-8-4(6)][326 IAC 2-8-16][326 IAC 2-1.1-7]

- (a) The Permittee shall pay annual fees to IDEM, OAQ no later than thirty (30) calendar days of receipt of a billing. Pursuant to 326 IAC 2-7-19(b), if the Permittee does not receive a bill from IDEM, OAQ the applicable fee is due April 1 of each year.
- (b) Failure to pay may result in administrative enforcement action or revocation of this permit.
- (c) The Permittee may call the following telephone numbers: 1-800-451-6027 or 317-233-8590 (ask for OAQ, Billing, Licensing, and Training Section), to determine the appropriate permit fee.

B.23 Credible Evidence [326 IAC 2-8-4(3)][326 IAC 2-8-5][62 FR 8314][326 IAC 1-1-6]

For the purpose of submitting compliance certifications or establishing whether or not the Permittee has violated or is in violation of any condition of this permit, nothing in this permit shall preclude the use, including the exclusive use, of any credible evidence or information relevant to



DRAFT

whether the Permittee would have been in compliance with the condition of this permit if the appropriate performance or compliance test or procedure had been performed.

DRAFT

**SECTION C**

**SOURCE OPERATION CONDITIONS**

Entire Source

**Emission Limitations and Standards [326 IAC 2-8-4(1)]**

**C.1 Particulate Emission Limitations For Processes with Process Weight Rates Less Than One Hundred (100) Pounds per Hour [326 IAC 6-3-2]**

Pursuant to 326 IAC 6-3-2(e)(2), particulate emissions from any process not exempt under 326 IAC 6-3-1(b) or (c) which has a maximum process weight rate less than 100 pounds per hour and the methods in 326 IAC 6-3-2(b) through (d) do not apply shall not exceed 0.551 pounds per hour.

**C.2 Overall Source Limit [326 IAC 2-8]**

The purpose of this permit is to limit this source's potential to emit to less than major source levels for the purpose of Section 502(a) of the Clean Air Act.

(a) Pursuant to 326 IAC 2-8:

- (1) The potential to emit any regulated pollutant, except particulate matter (PM), from the entire source shall be limited to less than one hundred (100) tons per twelve (12) consecutive month period.
- (2) The potential to emit any individual hazardous air pollutant (HAP) from the entire source shall be limited to less than ten (10) tons per twelve (12) consecutive month period; and
- (3) The potential to emit any combination of HAPs from the entire source shall be limited to less than twenty-five (25) tons per twelve (12) consecutive month period.

(b) Pursuant to 326 IAC 2-2 (PSD), potential to emit particulate matter (PM) from the entire source shall be limited to less than one hundred (100) tons per twelve (12) consecutive month period.

(c) This condition shall include all emission points at this source including those that are insignificant as defined in 326 IAC 2-7-1(21). The source shall be allowed to add insignificant activities not already listed in this permit, provided that the source's potential to emit does not exceed the above specified limits.

(d) Section D of this permit contains independently enforceable provisions to satisfy this requirement.

**C.3 Opacity [326 IAC 5-1]**

Pursuant to 326 IAC 5-1-2 (Opacity Limitations), except as provided in 326 IAC 5-1-1 (Applicability) and 326 IAC 5-1-3 (Temporary Alternative Opacity Limitations), opacity shall meet the following, unless otherwise stated in this permit:

- (a) Opacity shall not exceed an average of forty percent (40%) in any one (1) six (6) minute averaging period as determined in 326 IAC 5-1-4.
- (b) Opacity shall not exceed sixty percent (60%) for more than a cumulative total of fifteen (15) minutes (sixty (60) readings as measured according to 40 CFR 60, Appendix A,

DRAFT

Method 9 or fifteen (15) one (1) minute nonoverlapping integrated averages for a continuous opacity monitor) in a six (6) hour period.

C.4 Open Burning [326 IAC 4-1][IC 13-17-9]

---

The Permittee shall not open burn any material except as provided in 326 IAC 4-1-3, 326 IAC 4-1-4 or 326 IAC 4-1-6. The previous sentence notwithstanding, the Permittee may open burn in accordance with an open burning approval issued by the Commissioner under 326 IAC 4-1-4.1.

C.5 Incineration [326 IAC 4-2][326 IAC 9-1-2]

---

The Permittee shall not operate an incinerator except as provided in 326 IAC 4-2 or in this permit. The Permittee shall not operate a refuse incinerator or refuse burning equipment except as provided in 326 IAC 9-1-2 or in this permit.

C.6 Fugitive Dust Emissions [326 IAC 6-4]

---

The Permittee shall not allow fugitive dust to escape beyond the property line or boundaries of the property, right-of-way, or easement on which the source is located, in a manner that would violate 326 IAC 6-4 (Fugitive Dust Emissions).

C.7 Asbestos Abatement Projects [326 IAC 14-10][326 IAC 18][40 CFR 61, Subpart M]

---

- (a) Notification requirements apply to each owner or operator. If the combined amount of regulated asbestos containing material (RACM) to be stripped, removed or disturbed is at least 260 linear feet on pipes or 160 square feet on other facility components, or at least thirty-five (35) cubic feet on all facility components, then the notification requirements of 326 IAC 14-10-3 are mandatory. All demolition projects require notification whether or not asbestos is present.
- (b) The Permittee shall ensure that a written notification is sent on a form provided by the Commissioner at least ten (10) working days before asbestos stripping or removal work or before demolition begins, per 326 IAC 14-10-3, and shall update such notice as necessary, including, but not limited to the following:
- (1) When the amount of affected asbestos containing material increases or decreases by at least twenty percent (20%); or
  - (2) If there is a change in the following:
    - (A) Asbestos removal or demolition start date;
    - (B) Removal or demolition contractor; or
    - (C) Waste disposal site.
- (c) The Permittee shall ensure that the notice is postmarked or delivered according to the guidelines set forth in 326 IAC 14-10-3(c).
- (d) The notice to be submitted shall include the information enumerated in 326 IAC 14-10-3(d).

All required notifications shall be submitted to:

Indiana Department of Environmental Management  
Compliance and Enforcement Branch, Office of Air Quality  
100 North Senate Avenue  
MC 61-53 IGCN 1003

DRAFT

Indianapolis, Indiana 46204-2251

The notice shall include a signed certification from the owner or operator that the information provided in this notification is correct and that only Indiana licensed workers and project supervisors will be used to implement the asbestos removal project. The notifications do not require a certification that meets the requirements of 326 IAC 2-8-5(a)(1) by an "authorized individual" as defined by 326 IAC 2-1.1-1(1).

- (e) **Procedures for Asbestos Emission Control**  
The Permittee shall comply with the applicable emission control procedures in 326 IAC 14-10-4 and 40 CFR 61.145(c). Per 326 IAC 14-10-1, emission control requirements are applicable for any removal or disturbance of RACM greater than three (3) linear feet on pipes or three (3) square feet on any other facility components or a total of at least 0.75 cubic feet on all facility components.
- (f) **Demolition and Renovation**  
The Permittee shall thoroughly inspect the affected facility or part of the facility where the demolition or renovation will occur for the presence of asbestos pursuant to 40 CFR 61.145(a).
- (g) **Indiana Licensed Asbestos Inspector**  
The Permittee shall comply with 326 IAC 14-10-1(a) that requires the owner or operator, prior to a renovation/demolition, to use an Indiana Licensed Asbestos Inspector to thoroughly inspect the affected portion of the facility for the presence of asbestos.

### **Testing Requirements [326 IAC 2-8-4(3)]**

#### **C.8 Performance Testing [326 IAC 3-6]**

---

- (a) For performance testing required by this permit, a test protocol, except as provided elsewhere in this permit, shall be submitted to:  
  
Indiana Department of Environmental Management  
Compliance and Enforcement Branch, Office of Air Quality  
100 North Senate Avenue  
MC 61-53 IGCN 1003  
Indianapolis, Indiana 46204-2251  
  
no later than thirty-five (35) days prior to the intended test date. The protocol submitted by the Permittee does not require a certification that meets the requirements of 326 IAC 2-8-5(a)(1) by an "authorized individual" as defined by 326 IAC 2-1.1-1(1).
- (b) The Permittee shall notify IDEM, OAQ of the actual test date at least fourteen (14) days prior to the actual test date. The notification submitted by the Permittee does not require a certification that meets the requirements of 326 IAC 2-8-5(a)(1) by an "authorized individual" as defined by 326 IAC 2-1.1-1(1).
- (c) Pursuant to 326 IAC 3-6-4(b), all test reports must be received by IDEM, OAQ not later than forty-five (45) days after the completion of the testing. An extension may be granted by IDEM, OAQ if the Permittee submits to IDEM, OAQ a reasonable written explanation not later than five (5) days prior to the end of the initial forty-five (45) day period.

### **Compliance Requirements [326 IAC 2-1.1-11]**

#### **C.9 Compliance Requirements [326 IAC 2-1.1-11]**

---

The commissioner may require stack testing, monitoring, or reporting at any time to assure compliance with all applicable requirements by issuing an order under 326 IAC 2-1.1-11. Any

DRAFT

monitoring or testing shall be performed in accordance with 326 IAC 3 or other methods approved by the commissioner or the U. S. EPA.

### **Compliance Monitoring Requirements [326 IAC 2-8-4(1)][326 IAC 2-8-5(a)(1)]**

#### **C.10 Compliance Monitoring [326 IAC 2-8-4(3)] [326 IAC 2-8-5(a)(1)]**

---

- (a) For new units:  
Unless otherwise specified in the approval for the new emission unit(s), compliance monitoring for new emission units shall be implemented on and after the date of initial start-up.
- (b) For existing units:  
Unless otherwise specified in this permit, for all monitoring requirements not already legally required, the Permittee shall be allowed up to ninety (90) days from the date of permit issuance to begin such monitoring. If, due to circumstances beyond the Permittee's control, any monitoring equipment required by this permit cannot be installed and operated no later than ninety (90) days after permit issuance, the Permittee may extend the compliance schedule related to the equipment for an additional ninety (90) days provided the Permittee notifies:

Indiana Department of Environmental Management  
Compliance and Enforcement Branch, Office of Air Quality  
100 North Senate Avenue  
MC 61-53 IGCN 1003  
Indianapolis, Indiana 46204-2251

in writing, prior to the end of the initial ninety (90) day compliance schedule, with full justification of the reasons for the inability to meet this date.

The notification which shall be submitted by the Permittee does require a certification that meets the requirements of 326 IAC 2-8-5(a)(1) by an "authorized individual" as defined by 326 IAC 2-1.1-1(1).

#### **C.11 Instrument Specifications [326 IAC 2-1.1-11] [326 IAC 2-8-4(3)][326 IAC 2-8-5(1)]**

---

- (a) When required by any condition of this permit, an analog instrument used to measure a parameter related to the operation of an air pollution control device shall have a scale such that the expected maximum reading for the normal range shall be no less than twenty percent (20%) of full scale. The analog instrument shall be capable of measuring values outside of the normal range.
- (b) The Permittee may request that the IDEM, OAQ approve the use of an instrument that does not meet the above specifications provided the Permittee can demonstrate that an alternative instrument specification will adequately ensure compliance with permit conditions requiring the measurement of the parameters.

### **Corrective Actions and Response Steps [326 IAC 2-8-4][326 IAC 2-8-5(a)(1)]**

#### **C.12 Risk Management Plan [326 IAC 2-8-4][40 CFR 68]**

---

If a regulated substance, as defined in 40 CFR 68, is present at a source in more than a threshold quantity, the Permittee must comply with the applicable requirements of 40 CFR 68.

#### **C.13 Response to Excursions or Exceedances [326 IAC 2-8-4][326 IAC 2-8-5]**

---

Upon detecting an excursion where a response step is required by the D Section or an exceedance of a limitation in this permit:

DRAFT

- (a) The Permittee shall take reasonable response steps to restore operation of the emissions unit (including any control device and associated capture system) to its normal or usual manner of operation as expeditiously as practicable in accordance with good air pollution control practices for minimizing excess emissions.
- (b) The response shall include minimizing the period of any startup, shutdown or malfunction. The response may include, but is not limited to, the following:
  - (1) initial inspection and evaluation;
  - (2) recording that operations returned or are returning to normal without operator action (such as through response by a computerized distribution control system); or
  - (3) any necessary follow-up actions to return operation to normal or usual manner of operation.
- (c) A determination of whether the Permittee has used acceptable procedures in response to an excursion or exceedance will be based on information available, which may include, but is not limited to, the following:
  - (1) monitoring results;
  - (2) review of operation and maintenance procedures and records; and/or
  - (3) inspection of the control device, associated capture system, and the process.
- (d) Failure to take reasonable response steps shall be considered a deviation from the permit.
- (e) The Permittee shall record the reasonable response steps taken.

**C.14 Actions Related to Noncompliance Demonstrated by a Stack Test [326 IAC 2-8-4][326 IAC 2-8-5]**

- (a) When the results of a stack test performed in conformance with Section C - Performance Testing, of this permit exceed the level specified in any condition of this permit, the Permittee shall submit a description of its response actions to IDEM, OAQ no later than seventy-five (75) days after the date of the test.
- (b) A retest to demonstrate compliance shall be performed no later than one hundred eighty (180) days after the date of the test. Should the Permittee demonstrate to IDEM, OAQ that retesting in one hundred eighty (180) days is not practicable, IDEM, OAQ may extend the retesting deadline.
- (c) IDEM, OAQ reserves the authority to take any actions allowed under law in response to noncompliant stack tests.

The response action documents submitted pursuant to this condition do require a certification that meets the requirements of 326 IAC 2-8-5(a)(1) by an "authorized individual" as defined by 326 IAC 2-1.1-1(1).

**Record Keeping and Reporting Requirements [326 IAC 2-8-4(3)]**

**C.15 General Record Keeping Requirements [326 IAC 2-8-4(3)][326 IAC 2-8-5]**

- (a) Records of all required monitoring data, reports and support information required by this permit shall be retained for a period of at least five (5) years from the date of monitoring

DRAFT

sample, measurement, report, or application. Support information includes the following, where applicable:

- (AA) All calibration and maintenance records.
- (BB) All original strip chart recordings for continuous monitoring instrumentation.
- (CC) Copies of all reports required by the FESOP.

Records of required monitoring information include the following, where applicable:

- (AA) The date, place, as defined in this permit, and time of sampling or measurements.
- (BB) The dates analyses were performed.
- (CC) The company or entity that performed the analyses.
- (DD) The analytical techniques or methods used.
- (EE) The results of such analyses.
- (FF) The operating conditions as existing at the time of sampling or measurement.

These records shall be physically present or electronically accessible at the source location for a minimum of three (3) years. The records may be stored elsewhere for the remaining two (2) years as long as they are available upon request. If the Commissioner makes a request for records to the Permittee, the Permittee shall furnish the records to the Commissioner within a reasonable time.

- (b) Unless otherwise specified in this permit, for all record keeping requirements not already legally required, the Permittee shall be allowed up to ninety (90) days from the date of permit issuance or the date of initial start-up, whichever is later, to begin such record keeping.

C.16 General Reporting Requirements [326 IAC 2-8-4(3)(C)][326 IAC 2-1.1-11]

- (a) The Permittee shall submit the attached Quarterly Deviation and Compliance Monitoring Report or its equivalent. Proper notice submittal under Section B -Emergency Provisions satisfies the reporting requirements of this paragraph. Any deviation from permit requirements, the date(s) of each deviation, the cause of the deviation, and the response steps taken must be reported except that a deviation required to be reported pursuant to an applicable requirement that exists independent of this permit, shall be reported according to the schedule stated in the applicable requirement and does not need to be included in this report. This report shall be submitted not later than thirty (30) days after the end of the reporting period. The Quarterly Deviation and Compliance Monitoring Report shall include a certification that meets the requirements of 326 IAC 2-8-5(a)(1) by an "authorized individual" as defined by 326 IAC 2-1.1-1(1). A deviation is an exceedance of a permit limitation or a failure to comply with a requirement of the permit.
- (b) The address for report submittal is:  
  
Indiana Department of Environmental Management  
Compliance and Enforcement Branch, Office of Air Quality  
100 North Senate Avenue  
MC 61-53 IGCN 1003  
Indianapolis, Indiana 46204-2251
- (c) Unless otherwise specified in this permit, any notice, report, or other submission required by this permit shall be considered timely if the date postmarked on the envelope or certified mail receipt, or affixed by the shipper on the private shipping receipt, is on or before the date it is due. If the document is submitted by any other means, it shall be considered timely if received by IDEM, OAQ on or before the date it is due.

DRAFT

- (d) Reporting periods are based on calendar years, unless otherwise specified in this permit. For the purpose of this permit "calendar year" means the twelve (12) month period from January 1 to December 31 inclusive.
- (e) If the Permittee is a member of IDEM's Environmental Stewardship Program (ESP), the Permittee may report in the manner below for any reporting requirement except for Paragraph A of this condition:
- (1) Each report shall be submitted semi-annually, covering the period from April 1 to September 30 or October 1 to March 31.
  - (2) Each report, shall be considered timely if the date postmarked on the envelope or certified mail receipt, or affixed by the shipper on the private shipping receipt, is on or before the date it is due. If the document is submitted by any other means, it shall be considered timely if received by IDEM, OAQ on or before the date it is due.
  - (3) Each report shall be submitted within thirty (30) days of the end of the reporting period. All reports do require the certification by an "authorized individual" as defined by 326 IAC 2-1.1-1(1).
  - (4) The Permittee shall use the attached reporting Environmental Stewardship Program forms or their equivalent.
  - (5) Each report shall be submitted to the address listed in paragraph (b) of this condition.

If the Permittee is removed from or withdraws from the ESP, the Permittee shall begin quarterly reporting according to paragraphs (a) through (e) of this condition and the condition(s) requiring the reporting. If the Permittee is removed from or withdraws from the ESP during the second quarter of a semi-annual period, the Permittee shall submit all reports for the first quarter of the period within thirty (30) days of the removal or withdrawal.

### **Stratospheric Ozone Protection**

#### **C.17 Compliance with 40 CFR 82 and 326 IAC 22-1**

---

Pursuant to 40 CFR 82 (Protection of Stratospheric Ozone), Subpart F, except as provided for motor vehicle air conditioners in Subpart B, the Permittee shall comply with applicable standards for recycling and emissions reduction.



DRAFT

**SECTION D.1**

**EMISSIONS UNIT OPERATION CONDITIONS**

**Emissions Unit Description:**

- (a) One (1) natural gas fired temporary boiler station, identified as (TB1), approved in 2024 for construction, with a maximum operating input rate of 60 MMBtu/hr, uses No. 2 fuel oil as back up fuel, using no control, and exhausting to stacks S-1.  
  
[Under 40 CFR 60, Subpart Dc, this is an affected source.]
- (b) One (1) natural gas fired boiler installed in 2005, identified as Boiler #3 (S27), with a maximum heat input rate of 60.8 MMBtu per hour, using low NOx Burners and Flue Gas Recirculation, and exhausting through stack S-27. Boiler #3 uses No. 2 fuel oil as back-up fuel.  
  
[This is an affected source under 40 CFR 60, Subpart Dc.]

(The information describing the process contained in this emissions unit description box is descriptive information and does not constitute enforceable conditions.)

**Emission Limitations and Standards [326 IAC 2-8-4(1)]**

**D.1.1 FESOP Minor Limits [326 IAC 2-8-4]**

Pursuant to 326 IAC 2-8-4 (FESOP) and in order to render the requirements of 326 IAC 2-7 (Part 70 Permits) not applicable, the Permittee shall comply with the following:

- (a) The total input of fuel oil No. 2 and fuel oil No. 2 equivalents to the one (1) temporary boiler station identified as (TB1), and one (1) 60.8 MMBtu/hr boiler #3 (S27), shall be limited to less than 1,057,500 U.S. gallons per twelve (12) consecutive month period with compliance determined at the end of each month.
- (b) The sulfur content of distillate fuel oil No. 2 shall not exceed 0.3% by weight.
- (c) For purposes of determining compliance with paragraph (a) of this condition, the following shall apply:  
  
Every one (1) million cubic feet of natural gas burned shall be equivalent to 14 gallons of No. 2 distillate fuel oil burned based on SO<sub>2</sub> emissions, such that the total usage of No. 2 distillate fuel oil with a maximum sulfur content of 0.3% and No. 2 oil equivalent input does not exceed the limit specified.
- (d) NOx emissions shall not exceed 20.0 lb/kgal of fuel oil.

Compliance with these limits, combined with the potential to emit SO<sub>2</sub> and NOx from all other emission units at this source, shall limit the source-wide total potential to emit of SO<sub>2</sub> and NOx to less than one-hundred (100) tons per twelve (12) consecutive month period, each, and shall render the requirements of 326 IAC 2-7 (Part 70 Permits) not applicable.

**D.1.2 Particulate Emissions [326 IAC 6-2-4]**

Pursuant to 326 IAC 6-2-4 (Particulate Emission Limitations for Sources of Indirect Heating), the PM emissions from the following units shall be limited to the PM emission limit (Pt) in pounds per MMBtu heat input as specified in the following table:

Emission Unit	Unit ID	Pt (lb/MMBtu)
Boiler #3 (S27)	#3 (S27)	0.37

DRAFT

Temporary boiler (TB1)	(TB1)	0.31
------------------------	-------	------

**D.1.3 Sulfur Dioxide (SO<sub>2</sub>) Limits [326 IAC 7-1.1-2]**

Pursuant to 326 IAC 7-1.1-2(a)(3) (Sulfur dioxide emission limitations) the SO<sub>2</sub> emissions from the Temporary Boiler station identified as (TB1) and #3 (S27), shall not exceed five tenths (0.5) pounds per MMBtu heat input for distillate oil combustion. SO<sub>2</sub> emissions will be determined based on monthly average.

**D.1.4 Preventive Maintenance Plan [326 IAC 2-8-4(9)]**

A Preventive Maintenance Plan is required for these facilities. Section B - Preventive Maintenance Plan contains the Permittee's obligation with regard to the preventive maintenance plan required by this condition.

**Compliance Determination Requirements [326 IAC 2-8-4(1)]**

**D.1.5 Sulfur Dioxide Emissions and Sulfur Content**

In order to assure compliance with Conditions D.1.1(b) and D.1.3, the Permittee shall comply with the following:

- (a) Pursuant to 326 IAC 7-2-1(d)(2), compliance shall be determined using a calendar month average sulfur dioxide emission rate in pounds per MMBtu.
- (b) Compliance shall be determined using one of the following options:
  - (1) Pursuant to 326 IAC 7-2-1(h)(3) and (4), the Permittee shall demonstrate compliance by:
    - (A) Providing vendor analysis of fuel delivered, if accompanied by a vendor certification, in accordance with 326 IAC 3-7; or
    - (B) Analyzing the oil sample to determine the sulfur content of the oil via the procedures in 40 CFR 60, Appendix A, Method 19.
      - (i) Oil samples may be collected from the fuel tank immediately after the fuel tank is filled and before any oil is combusted; and
      - (ii) If a partially empty fuel tank is refilled, a new sample and analysis would be required upon filling.
  - (2) Pursuant to 326 IAC 7-2-1(h)(1), compliance may also be determined by conducting a stack test for sulfur dioxide emissions from the boilers TB1 and S-27 using 40 CFR 60, Appendix A, Method 6 in accordance with the procedures in 326 IAC 3-6.

A determination of noncompliance pursuant to any of the methods specified in (1) or (2) above shall not be refuted by evidence of compliance pursuant to the other method.

**Compliance Monitoring Requirements [326 IAC 2-8-4(1)] [326 IAC 2-8-5(a)(1)]**

**D.1.6 Visible Emission Notations**

- (a) Visible emission notations of Boilers (TB1) and #3 (S27) stack exhausts shall be performed once per day during normal daylight operations when combusting fuel oil. A trained employee shall record whether emissions are normal or abnormal.
- (b) For processes operated continuously, "normal" means those conditions prevailing, or

DRAFT

expected to prevail, eighty percent (80%) of the time the process is in operation, not counting startup or shut down time.

- (c) In the case of batch or discontinuous operations, readings shall be taken during that part of the operation that would normally be expected to cause the greatest emissions.
- (d) A trained employee is an employee who has worked at the plant at least one (1) month and has been trained in the appearance and characteristics of normal visible emissions for that specific process.
- (e) If abnormal emissions are observed, the Permittee shall take a reasonable response. Section C - Response to Excursions and Exceedances contains the Permittee's obligation with regard to the reasonable response steps required by this condition. Failure to take response steps shall be considered a deviation from this permit.

### **Record Keeping and Reporting Requirements [326 IAC 2-8-4(3)]**

#### **D.1.7 Record Keeping Requirement**

---

- (a) To document the compliance status with Conditions D.1.1(a), D.1.1(b) and D.1.3, the Permittee shall maintain records in accordance with (1) through (6) below. Records maintained for (1) through (6) shall be taken monthly and shall be complete and sufficient to establish compliance with the limits in Conditions D.1.1(a), D.1.1(b), and D.1.3.
  - (1) Calendar dates covered in the compliance determination period;
  - (2) Actual fuel oil usage and fuel oil equivalents for the month and twelve (12) consecutive month period;
  - (3) A certification, signed by the owner or operator, that the records of the fuel supplier certifications represent all of the fuel combusted during the period, and
  - (4) If the fuel supplier certification is used to demonstrate compliance the following, as a minimum, shall be maintained:
    - (i) Fuel supplier certifications.
    - (ii) The name of the fuel supplier; and
    - (iii) A statement from the fuel supplier that certifies the sulfur content of the fuel oil.
  - (5) If oil sampling is used to determine the sulfur content of the oil and to demonstrate compliance, analysis of the oil sample shall be maintained.
  - (6) If conducting a stack test for sulfur dioxide emissions is used to demonstrate compliance, the stack test results, as a minimum, shall be maintained.
- (b) To document the compliance status with Condition D.1.6, the Permittee shall maintain records of daily visible emission notations of stack exhausts when combusting fuel oil. The Permittee shall include in its daily record when a visible emission notation is not taken and the reason for the lack of visible emissions notation (e.g. the process did not operate that day).
- (c) Section C - General Record Keeping Requirements contains the Permittee's obligation with regard to the records required by this condition.

DRAFT

#### D.1.8 Reporting Requirements

---

(a) If the Permittee is a member of IDEM's Environmental Stewardship Program (ESP) program, the Permittee may submit reports summarizing the information to document compliance with Condition D.1.1 according to the provisions of Condition C.16(e) of Section C General Reporting Requirements.

(b) A semi-annual report of No. 2 fuel oil and No. 2 oil equivalent usage and a semi-annual summary of the information to document the compliance status with D.1.1(a) shall be submitted not later than thirty (30) days after the end of the quarter being reported. Section C - General Reporting contains the Permittee's obligation with regard to the reporting required by this condition.

Otherwise, a quarterly summary of the information to document the compliance status with Condition D.1.1 shall be submitted not later than thirty (30) days after the end of the quarter being reported. Section C - General Reporting contains the Permittee's obligation with regard to the reporting required by this condition. The report submitted by the Permittee does require a certification that meets the requirements of 326 IAC 2-8-5(a)(1) by an authorized individual as defined by 326 IAC 2-1.1-1(1).

DRAFT

## SECTION D.2

## EMISSIONS UNIT OPERATION CONDITIONS

### Emissions Unit Description:

- (c) One (1) tablet core press machines, located in Building 122, Room 1109, installed in 2016, with maximum capacity of 425 pounds per hour, controlled by a common Henlex pre-filter dust collector and Henlex HEPA filter.
- (d) One (1) tablet core press machines, located in Building 122, Room 1111, installed in 2016, with maximum capacity of 425 pounds per hour, controlled by a common Henlex pre-filter dust collector and Henlex HEPA filter.
- (e) One (1) Granulator and one (1) GEA fluid-bed dryer for aqueous wet granulations located in Building 123, Room 1202, constructed in 2013, with a maximum capacity of 290 lbs/hr. Granulator and fluid-bed dryer controlled by a common Flanders pre-filter and Flanders HEPA filter.
- (f) One (1) Granulator and one (1) GEA fluid-bed dryer for aqueous wet granulations located in Building 123, Room 1235, constructed in 2016, with a maximum capacity of 290 lbs/hr. Granulator and fluid-bed dryer controlled by a common Flanders pre-filter and Flanders HEPA filter.

### Insignificant activities:

- (a) The following emission units located in Building 122:
  - (1) One (1) tablet core press machine, located in Building 122, Room 1113, installed in 1998, with maximum capacity of 165 pounds per hour, and controlled by a common fabric dust collector.
  - (2) One (1) Powder encapsulator machine, located in Building 122, Room 1124, installed in 2009, with a maximum powder throughput of 185 pounds per hour, and controlled by a common fabric filter dust collector.
- (b) The following emission units located in Building 123:
  - (1) One (1) tablet coating unit (Thomas Flex 500) located in Building 123, Room 1151, with a maximum capacity (spray rate) of 106 lbs/hr, constructed in 2013, and controlled by Torit fabric filter dust collector.
  - (2) One (1) Central Vacuum System, located in Building 123, and controlled by existing Torit Model DFT 2-4 fabric filter dust collector, installed in 2008 and relocated in 2014.

(The information describing the process contained in this emissions unit description box is descriptive information and does not constitute enforceable conditions.)

### Emission Limitations and Standards [326 IAC 2-8-4(1)]

#### D.2.1 Particulate Emission Limitation [326 IAC 6-3-2]

- (a) Pursuant to 326 IAC 6-3-2 (Particulate Emission Limitations for Manufacturing Processes), the particulate emission rate from the following emission units shall be limited as follows:

DRAFT

Emission Unit	Process Weight Rate (P) (tons/hr)	Allowable PM Emissions (E) (326 IAC 6-3-2) (lb/hr)
Tablet Core Press Machine (Building 122, Room 1109)	0.21	1.44
Tablet Core Press Machine (Building 122, Room 1111)	0.21	1.44
GEA fluid bed dryer (Building 123, Room 1202)	0.15	0.32
GEA fluid bed dryer (Building 123, Room 1229)	0.15	1.15
Tablet Core Press machine (Building 122, Room 1113)	0.08	0.77
Powder Encapsulator machine (Building 122, Room 1124)	0.09	0.83
Tablet Core Press (Building 123, Room 1144)	0.099	0.87
Central Vacuum System (Building 123)	<100 lb/hr	0.551

The pounds per hour limitations were calculated using the following equation:

Interpolation and extrapolation of the data for the process weight rate up to 60,000 pounds per hour shall be accomplished by use of the equation:

$$E = 4.10 P^{0.67} \quad \text{where } E = \text{rate of emission in pounds per hour; and} \\ P = \text{process weight rate in tons per hour.}$$

- (b) Pursuant to 326 IAC 6-3-2(d), the particulate from the tablet coating unit (Thomas Flex 500) located in Building 123, shall be controlled by a fabric filter/dust collector, and the Permittee shall operate the control device in accordance with manufacturer's specifications.

**D.2.2 Preventive Maintenance Plan [326 IAC 2-8-4(9)]**

A Preventive Maintenance Plan is required for these facilities and their control devices. Section B - Preventive Maintenance Plan contains the Permittee's obligation with regard to the preventive maintenance plan required by this condition.

**Compliance Determination Requirements [326 IAC 2-8-4(1)]**

**D.2.3 Particulate Control**

In order to assure compliance with Condition D.2.1, the Permittee shall operate the following control devices for particulate control at all times the respective emission units are in operation:

Emission Unit	Location	Control Device(s)
Tablet core press machine	Building 122, Rooms 1109	Pre-filter dust collector and HEPA filter
Tablet core press machine	Building 122, Rooms 1111	Pre-filter dust collector and HEPA filter
GEA fluid-bed dryer	Building 123, Room 1202	Pre-filter and HEPA filter
GEA fluid-bed dryer	Building 123, Room 1229	Pre-filter and HEPA filter
Tablet coating (Thomas Flex 500)	Building 123, Room 1151	Fabric filter dust collector
Central Vacuum System	Building 123	Fabric filter dust collector

**Compliance Monitoring Requirements [326 IAC 2-8-4(1)][326 IAC 2-8-5(a)(1)]**

**D.2.4 Semi-Annual Filter Inspections**

The Permittee shall perform semi-annual inspections of the filters listed in Condition D.2.3 controlling particulate emissions from the respective emission units to verify that they are being operated and maintained in accordance with the manufacturer's specifications. Inspections required by this condition shall not be performed in consecutive months. All defective bags and/or filters shall be replaced.

DRAFT

## **Record Keeping and Reporting Requirements [326 IAC 2-8-4(3)]**

### **D.2.5 Record Keeping Requirement**

---

- (a) To document the compliance status with Condition D.2.4, the Permittee shall maintain records of the dates and results of the semi-annual inspections required under Condition D.2.4.
  
- (b) Section C - General Record Keeping Requirements contains the Permittee's obligation with regard to the records required by this condition.

DRAFT

## SECTION D.3

## EMISSIONS UNIT OPERATION CONDITIONS

### Emissions Unit Description:

Insignificant activities:

- (g) Cold solvent cleaning station (2 square feet) installed in 1970.

(The information describing the process contained in this emissions unit description box is descriptive information and does not constitute enforceable conditions.)

### Emission Limitations and Standards [326 IAC 2-8-4(1)]

#### D.3.1 Material Requirements for Cold Cleaner Degreasers [326 IAC 8-3-8]

Pursuant to 326 IAC 8-3-8 (Material Requirements for Cold Cleaner Degreasers), the Permittee shall not operate a cold cleaning degreaser with a solvent that has a VOC composite partial vapor pressure that exceeds one (1) millimeter of mercury (nineteen-thousandths (0.019) pound per square inch) measured at twenty (20) degrees Celsius (sixty-eight (68) degrees Fahrenheit).

#### D.3.2 Preventive Maintenance Plan [326 IAC 2-8-4(9)]

A Preventive Maintenance Plan is required for this unit. Section B - Preventive Maintenance Plan contains the Permittee's obligation with regard to the preventive maintenance plan required by this condition.

### Record Keeping and Reporting Requirement [326 IAC 2-8-4(3)]

#### D.3.3 Record Keeping Requirements

- (a) To document the compliance status with Condition D.3.1, the Permittee shall maintain the following records for each purchase of solvent used in the cold cleaner degreasing operations. These records shall be retained on-site or accessible electronically for the most recent three (3) year period and shall be reasonably accessible for an additional two (2) year period.
  - (1) The name and address of the solvent supplier.
  - (2) The date of purchase (or invoice/bill dates of contract servicer indicating service date).
  - (3) The type of solvent purchased.
  - (4) The total volume of the solvent purchased.
  - (5) The true vapor pressure of the solvent measured in millimeters of mercury at twenty (20) degrees Celsius (sixty-eight (68) degrees Fahrenheit).
- (b) Section C - General Record Keeping Requirements contains the Permittee's obligations with regard to the records required by this condition.



DRAFT

**SECTION E.1**

**NSPS**

**Emissions Unit Description:**

- (a) One (1) natural gas fired temporary boiler station, identified as (TB1), approved in 2024 for construction, with a maximum operating input rate of 60 MMBtu/hr, uses No. 2 fuel oil as back up fuel, using no control, and exhausting to stacks S-1.

[Under 40 CFR 60, Subpart Dc, this is an affected source.]

- (b) One (1) natural gas fired boiler installed in 2005, identified as Boiler #3 (S27), with a maximum heat input rate of 60.8 MMBtu per hour, using low NOx burners and Flue Gas Recirculation, and exhausting through stack S-27. Boiler #3 uses No. 2 fuel oil as back-up fuel.

[Under 40 CFR 60, Subpart Dc, this is an affected source.]

(The information describing the process contained in this emissions unit description box is descriptive information and does not constitute enforceable conditions.)

**New Source Performance Standards (NSPS) Requirements [326 IAC 2-8-4(1)]**

**E.1.1 General Provisions Relating to New Source Performance Standards [326 IAC 12-1][40 CFR Part 60, Subpart A]**

- (a) Pursuant to 40 CFR 60.1, the Permittee shall comply with the provisions of 40 CFR Part 60, Subpart A - General Provisions, which are incorporated by reference as 326 IAC 12-1, for the emission units listed above, except as otherwise specified in 40 CFR Part 60, Subpart Dc.

- (b) Pursuant to 40 CFR 60.4, the Permittee shall submit all required notifications and reports to:

Indiana Department of Environmental Management  
Compliance and Enforcement Branch, Office of Air Quality  
100 North Senate Avenue  
MC 61-53 IGCN 1003  
Indianapolis, Indiana 46204-2251

**E.1.2 New Source Performance Standard for Small Industrial-Commercial-Institutional Steam Generating Units NSPS [326 IAC 12][40 CFR Part 60, Subpart Dc]**

The Permittee shall comply with the following provisions of 40 CFR Part 60, Subpart Dc (included as Attachment A to the operating permit), which are incorporated by reference as 326 IAC 12, for the emission unit(s) listed above:

- (1) 40 CFR 60.40c(a) through (d), and (g)
- (2) 40 CFR 60.41c
- (3) 40 CFR 60.42c(d), (f), through (j)
- (4) 40 CFR 60.43c(c) and (d)
- (5) 40 CFR 60.44c(c), (g), and (h)
- (6) 40 CFR 60.45c(c)
- (7) 40 CFR 60.46c(e)
- (8) 40 CFR 60.47c(c)
- (9) 40 CFR 60.48c(a)(1) through (a)(4), (d), (e)(1) through (e)(3), (e)(11), and (f) through (j)

DRAFT

**SECTION E.2**

**NSPS**

**Emissions Unit Description:**

- (h) One (1) 1,500kW diesel engine-driven emergency generator, identified as S32, located outside on southeast of Building 104, constructed in 2009, with a maximum capacity of 1,500kW, and exhausting to Stack S-32.

[[Under 40 CFR 60, Subpart IIII, this is considered an affected source]  
[Under 40 CFR 63, Subpart ZZZZ, this is considered a new affected source.]

- (i) One (1) 3,000 kW diesel engine-driven emergency generator located outside of Building 122, identified as S35, constructed in 2011, with a maximum capacity of 3,000 kW, and exhausting to Stack S-35.

[Under 40 CFR 60, Subpart IIII, this is considered an affected source]  
[Under 40 CFR 63, Subpart ZZZZ, this is considered a new affected source.]

- (j) One (1) 3,000 kW diesel engine-driven emergency generator, identified as S45, located outside northwest of Building 104, constructed in 2015, with a maximum capacity of 3,000 kW, and exhausting to stack S-45

[Under 40 CFR 60, Subpart IIII, this is considered an affected source]  
[Under 40 CFR 63, Subpart ZZZZ, this is considered a new affected source.]

**Insignificant Activities:**

- (c) One (1) 350kW diesel engine-driven emergency generator, identified as S34, located outside west of Building 106, constructed in 2011, with a maximum capacity of 350 kW and exhausting to Stack S-34.

[Under 40 CFR 60, Subpart IIII, this is considered an affected source]  
[Under 40 CFR 63, Subpart ZZZZ, this is considered an affected source]

- (d) One (1) 200 kW diesel engine-driven emergency generator, identified as S44, located outside of Building 113, constructed in 2015, with a maximum capacity of 200 kW, and exhausting to stack S-44.

[Under 40 CFR 60, Subpart IIII, this is considered an affected source]  
[Under 40 CFR 63, Subpart ZZZZ, this is considered an affected source]

- (e) One (1) 246 hp diesel-fired emergency pump engine, identified as S7, located in Building 103, constructed in 2014, permitted in 2015, and exhausting to stack S-7.

[Under 40 CFR 60, Subpart IIII, this is considered an affected source]  
[Under 40 CFR 63, Subpart ZZZZ, this is considered an affected source]

- (f) One (1) 350 kW diesel engine-driven emergency generator engine, identified as S46, located outside southeast of Building 123, with a brake HP rating of 539.0, constructed in 2021, and using no control.

[Under 40 CFR 60, Subpart IIII, this is considered an affected source]  
[Under 40 CFR 63, Subpart ZZZZ, this is considered an affected source]

(The information describing the process contained in this emissions unit description box is descriptive

DRAFT

information and does not constitute enforceable conditions.)

### **New Source Performance Standards (NSPS) Requirements [326 IAC 2-8-4(1)]**

#### **E.2.1 General Provisions Relating to New Source Performance Standards [326 IAC 12-1][40 CFR Part 60, Subpart A]**

(a) Pursuant to 40 CFR 60.1, the Permittee shall comply with the provisions of 40 CFR Part 60, Subpart A - General Provisions, which are incorporated by reference as 326 IAC 12-1, for the emission unit(s) listed above, except as otherwise specified in 40 CFR Part 60, Subpart IIII.

(b) Pursuant to 40 CFR 60.4, the Permittee shall submit all required notifications and reports to:

Indiana Department of Environmental Management  
Compliance and Enforcement Branch, Office of Air Quality  
100 North Senate Avenue  
MC 61-53 IGCN 1003  
Indianapolis, Indiana 46204-2251

#### **E.2.2 New Source Performance Standard for Stationary Compression Ignition Internal Combustion Engines NSPS [326 IAC 12][40 CFR Part 60, Subpart IIII]**

The Permittee shall comply with the following provisions of 40 CFR Part 60, Subpart IIII (included as Attachment B to the operating permit), which are incorporated by reference as 326 IAC 12.

(a) The three (3) diesel emergency generators, identified as S32, S34, and S35:

- (1) 40 CFR 60.4200(a)(2)(i) and (c)
- (2) 40 CFR 60.4205
- (3) 40 CFR 60.4206
- (4) 40 CFR 60.4207(a), (b), and (c)
- (5) 40 CFR 60.4208
- (6) 40 CFR 60.4209(a)
- (7) 40 CFR 60.4211(a) through (e), (f)(1), (f)(2)(i), (f)(3), (g), and (h)
- (8) 40 CFR 60.4214(b)
- (9) 40 CFR 60.4218
- (10) 40 CFR 60.4219
- (11) Table 1 to 40 CFR 60, Subpart IIII
- (12) Table 8 to 40 CFR 60, Subpart IIII

(b) The diesel emergency fire pump engine (S7):

- (1) 40 CFR 60.4200(a)(2)(ii) and (c)
- (2) 40 CFR 60.4205(c)
- (3) 40 CFR 60.4206
- (4) 40 CFR 60.4207(b)
- (5) 40 CFR 60.4208
- (6) 40 CFR 60.4209
- (7) 40 CFR 60.4211(a), (c), (f)(1), (f)(2)(i), and (f)(3)
- (8) 40 CFR 60.4214(b)
- (9) 40 CFR 60.4218
- (10) 40 CFR 60.4219
- (11) Table 4 to 40 CFR 60, Subpart IIII
- (12) Table 8 to 40 CFR 60, Subpart IIII

(c) The three (3) diesel emergency generators, identified as S44, S45, and S46:

- (1) 40 CFR 60.4200(a)(2)(i) and (c)

DRAFT

- (2) 40 CFR 60.4205(b)
- (3) 40 CFR 60.4206
- (4) 40 CFR 60.4207(b)
- (5) 40 CFR 60.4208
- (6) 40 CFR 60.4209
- (7) 40 CFR 60.4211(a), (c), (f)(1), (f)(2)(i), and (f)(3)
- (8) 40 CFR 60.4214(b)
- (9) 40 CFR 60.4218
- (10) 40 CFR 60.4219
- (11) Table 8 to 40 CFR 60, Subpart IIII

DRAFT

**SECTION E.3**

**NESHAP**

**Emissions Unit Description:**

- (g) One (1) 1,400 kW diesel engine-driven emergency generator, identified as S-3, located outside southwest of Building 104, with capacity of 1,400 kW, and exhausting through stack S-3. This generator was constructed before July 11, 2005 and manufactured before April 1, 2006.

[Under 40 CFR 63, Subpart ZZZZ, this is considered an affected source.]

- (h) One (1) 1,500kW diesel engine-driven emergency generator, identified as S32, located outside on southeast of Building 104, constructed in 2009, with a maximum capacity of 1,500kW, and exhausting to Stack S-32.

[Under 40 CFR 60, Subpart IIII, this is considered an affected source]

[Under 40 CFR 63, Subpart ZZZZ, this is considered a new affected source.]

- (i) One (1) 3,000 kW diesel engine-driven emergency generator located outside of Building 122, identified as S35, constructed in 2011, with a maximum capacity of 3,000 kW, and exhausting to Stack S-35.

[Under 40 CFR 60, Subpart IIII, this is considered an affected source]

[Under 40 CFR 63, Subpart ZZZZ, this is considered a new affected source.]

- (j) One (1) diesel engine-driven emergency generator, identified as S45, located outside northwest of Building 104, constructed in 2015, with a maximum capacity of 3,000 kW, and exhausting to stack S-45.

[Under 40 CFR 60, Subpart IIII, this is considered an affected source]

[Under 40 CFR 63, Subpart ZZZZ, this is considered a new affected source.]

**Insignificant Activities:**

- (c) One (1) diesel engine-driven emergency generator, identified as S34, located outside west of Building 106, constructed in 2011, with a maximum capacity of 350 kW and exhausting to Stack S-34.

[Under 40 CFR 60, Subpart IIII, this is considered an affected source]

[Under 40 CFR 63, Subpart ZZZZ, this is considered an affected source]

- (d) One (1) diesel engine-driven emergency generator, identified as S44, located outside of Building 113, constructed in 2015, with a maximum capacity of 200 kW, and exhausting to stack S-44.

[Under 40 CFR 60, Subpart IIII, this is considered an affected source]

[Under 40 CFR 63, Subpart ZZZZ, this is considered an affected source]

- (e) One (1) 246 hp diesel-fired emergency pump engine, identified as S7, located in Building 103, constructed in 2014, permitted in 2015, and exhausting to stack S-7.

[Under 40 CFR 60, Subpart IIII, this is considered an affected source]

[Under 40 CFR 63, Subpart ZZZZ, this is considered an affected source]

- (f) One (1) 350 kW diesel engine-driven emergency generator engine, identified as S46, located southeast of Building 123, with a brake HP rating of 539.0, constructed in 2021, and using no control.

DRAFT

[Under 40 CFR 60, Subpart IIII, this is considered an affected source]  
[Under 40 CFR 63, Subpart ZZZZ, this is considered an affected source]

(The information describing the process contained in this emissions unit description box is descriptive information and does not constitute enforceable conditions.)

### **National Emission Standards for Hazardous Air Pollutants (NESHAP) Requirements [326 IAC 2-8-4(1)]**

#### **E.3.1 General Provisions Relating to National Emission Standards for Hazardous Air Pollutants under 40 CFR Part 63 [326 IAC 20-1][40 CFR Part 63, Subpart A]**

- (a) Pursuant to 40 CFR 63.1 the Permittee shall comply with the provisions of 40 CFR Part 63, Subpart A - General Provisions, which are incorporated by reference as 326 IAC 20-1, for the emission unit(s) listed above, except as otherwise specified in 40 CFR Part 63, Subpart ZZZZ.
- (b) Pursuant to 40 CFR 63.10, the Permittee shall submit all required notifications and reports to:

Indiana Department of Environmental Management  
Compliance and Enforcement Branch, Office of Air Quality  
100 North Senate Avenue  
MC 61-53 IGCN 1003  
Indianapolis, Indiana 46204-2251

#### **E.3.2 National Emission Standards for Hazardous Air Pollutants for Stationary Reciprocating Internal Combustion Engines NESHAP [40 CFR Part 63, Subpart ZZZZ][326 IAC 20-82]**

The Permittee shall comply with the following provisions of 40 CFR Part 63, Subpart ZZZZ (included as Attachment C to the operating permit), which are incorporated by reference as 326 IAC 20-82;

- (a) The diesel emergency generator (S-3):
- (1) 40 CFR 63.6580
  - (2) 40 CFR 63.6585
  - (3) 40 CFR 63.6590(a)(1)(iii) and (iv)
  - (4) 40 CFR 63.6595(a)(1), (b), and (c)
  - (5) 40 CFR 63.6603(a)
  - (6) 40 CFR 63.6605
  - (7) 40 CFR 63.6625(e)(3), (f), (h), and (i)
  - (8) 40 CFR 63.6635
  - (9) 40 CFR 63.6640(a) through (e), (f)(1), (f)(2)(i), (f)(3), and (f)(4)
  - (10) 40 CFR 63.6645(a)(5)
  - (11) 40 CFR 63.6650
  - (12) 40 CFR 63.6655
  - (13) 40 CFR 63.6660
  - (14) 40 CFR 63.6665
  - (15) 40 CFR 63.6670
  - (16) 40 CFR 63.6675
  - (17) Table 2d (item 4)
  - (18) Table 6 (item 9)
  - (19) Table 8
- (b) The diesel emergency generators, identified as S45, S44, S46, S32, S,34, S35, and diesel fire pump, identified as S7:

DRAFT

- (1) 40 CFR 63.6580
- (2) 40 CFR 63.6585
- (3) 40 CFR 63.6590(a)(2)(iii) and (c)(1)
- (4) 40 CFR 63.6595(a)(7)
- (5) 40 CFR 63.6665
- (6) 40 CFR 63.6670
- (7) 40 CFR 63.6675

E.3.3 Preventive Maintenance Plan [326 IAC 2-8-4(9)]

A Preventive Maintenance Plan is required for these units. Section B - Preventive Maintenance Plan contains the Permittee's obligation with regard to the preventive maintenance plan required by this condition.

DRAFT

**INDIANA DEPARTMENT OF ENVIRONMENTAL MANAGEMENT  
OFFICE OF AIR QUALITY  
COMPLIANCE AND ENFORCEMENT BRANCH**

**FEDERALLY ENFORCEABLE STATE OPERATING PERMIT (FESOP)  
CERTIFICATION**

Source Name: AstraZeneca Pharmaceuticals LP  
Source Address: 4601 Highway 62 East, Mt. Vernon, Indiana 47620  
FESOP Permit No.: F129-36688-00021

**This certification shall be included when submitting monitoring, testing reports/results or other documents as required by this permit.**

Please check what document is being certified:

- Annual Compliance Certification Letter
- Test Result (specify) \_\_\_\_\_
- Report (specify) \_\_\_\_\_
- Notification (specify) \_\_\_\_\_
- Affidavit (specify) \_\_\_\_\_
- Other (specify) \_\_\_\_\_

I certify that, based on information and belief formed after reasonable inquiry, the statements and information in the document are true, accurate, and complete.

Signature: \_\_\_\_\_

Printed Name: \_\_\_\_\_

Title/Position: \_\_\_\_\_

Email Address: _____	Phone: _____
Date: _____	



DRAFT

**INDIANA DEPARTMENT OF ENVIRONMENTAL MANAGEMENT  
OFFICE OF AIR QUALITY  
COMPLIANCE AND ENFORCEMENT BRANCH  
100 North Senate Avenue  
MC 61-53 IGCN 1003  
Indianapolis, Indiana 46204-2251  
Phone: (317) 233-0178  
Fax: (317) 233-6865**

**FEDERALLY ENFORCEABLE STATE OPERATING PERMIT (FESOP)  
EMERGENCY OCCURRENCE REPORT**

Source Name: AstraZeneca Pharmaceuticals LP  
Source Address: 4601 Highway 62 East, Mt. Vernon, Indiana 47620  
FESOP Permit No.: F129-36688-00021

**This form consists of 2 pages**

**Page 1 of 2**

- |  |
|--|
| <p><input type="checkbox"/> This is an emergency as defined in 326 IAC 2-7-1(12)</p> <ul style="list-style-type: none"><li>• The Permittee must notify the Office of Air Quality (OAQ), within four (4) daytime business hours (1-800-451-6027 or 317-233-0178, ask for Compliance Section); and</li><li>• The Permittee must submit notice in writing or by facsimile within two (2) working days (Facsimile Number: 317-233-6865), and follow the other requirements of 326 IAC 2-8-12</li></ul> |
|--|

If any of the following are not applicable, mark N/A

Facility/Equipment/Operation:
Control Equipment:
Permit Condition or Operation Limitation in Permit:
Description of the Emergency:
Describe the cause of the Emergency:

DRAFT

Page 2 of 2

If any of the following are not applicable, mark N/A

Date/Time Emergency started:
Date/Time Emergency was corrected:
Was the facility being properly operated at the time of the emergency?    Y    N Describe:
Type of Pollutants Emitted: TSP, PM-10, SO <sub>2</sub> , VOC, NO <sub>x</sub> , CO, Pb, other:
Estimated amount of pollutant(s) emitted during emergency:
Describe the steps taken to mitigate the problem:
Describe the corrective actions/response steps taken:
Describe the measures taken to minimize emissions:
If applicable, describe the reasons why continued operation of the facilities are necessary to prevent imminent injury to persons, severe damage to equipment, substantial loss of capital investment, or loss of product or raw materials of substantial economic value:

Form Completed by: \_\_\_\_\_

Title / Position: \_\_\_\_\_

Date: \_\_\_\_\_

Phone: \_\_\_\_\_

DRAFT

**INDIANA DEPARTMENT OF ENVIRONMENTAL MANAGEMENT  
 OFFICE OF AIR QUALITY  
 COMPLIANCE AND ENFORCEMENT BRANCH**

**FESOP Usage Report**

Source Name: AstraZeneca Pharmaceuticals LP  
 Source Address: 4601 Highway 62 East, Mt. Vernon, Indiana 47620  
 FESOP Permit No.: F129-36688-00021  
 Facility: One (1) Temporary Boiler (TB1) and one (1) 60.8 MMBtu/hr Boiler #3 (S27)  
 Parameter: Fuel oil no. 2 equivalent usage  
 Limit: Total input of distillate fuel oil no. 2 distillate fuel oil equivalents to one (1) Temporary Boiler (TB1), and #3 (S27) shall be limited to 1,057,500 gallons per twelve (12) consecutive month period, with compliance determined at the end of each month.

Quarter: \_\_\_\_\_ YEAR: \_\_\_\_\_

Month	Column 1	Column 2	Column 1 + Column 2
	No. 2 Distillate Fuel Oil Equivalent Usage This Month (gallons)	No. 2 Distillate Fuel Oil Equivalent Usage Previous 11 Months (gallons)	12 Month Total No. 2 Distillate Fuel Oil Equivalent Usage (gallons)

- No deviation occurred in this quarter.
- Deviation/s occurred in this quarter.  
 Deviation has been reported on: \_\_\_\_\_

Submitted by: \_\_\_\_\_  
 Title / Position: \_\_\_\_\_  
 Signature: \_\_\_\_\_  
 Date: \_\_\_\_\_  
 Phone: \_\_\_\_\_

DRAFT

**INDIANA DEPARTMENT OF ENVIRONMENTAL MANAGEMENT  
OFFICE OF AIR QUALITY  
COMPLIANCE AND ENFORCEMENT BRANCH  
FEDERALLY ENFORCEABLE STATE OPERATING PERMIT (FESOP)  
QUARTERLY DEVIATION AND COMPLIANCE MONITORING REPORT**

Source Name: AstraZeneca Pharmaceuticals LP  
Source Address: 4601 Highway 62 East, Mt. Vernon, Indiana 47620  
FESOP Permit No.: F129-36688-00021

Months: \_\_\_\_\_ to \_\_\_\_\_ Year: \_\_\_\_\_

Page 1 of 2

<p>This report shall be submitted quarterly based on a calendar year. Proper notice submittal under Section B -Emergency Provisions satisfies the reporting requirements of paragraph (a) of Section C- General Reporting. Any deviation from the requirements of this permit, the date(s) of each deviation, the probable cause of the deviation, and the response steps taken must be reported. A deviation required to be reported pursuant to an applicable requirement that exists independent of the permit, shall be reported according to the schedule stated in the applicable requirement and does not need to be included in this report. Additional pages may be attached if necessary. If no deviations occurred, please specify in the box marked "No deviations occurred this reporting period".</p>	
<input type="checkbox"/> NO DEVIATIONS OCCURRED THIS REPORTING PERIOD.	
<input type="checkbox"/> THE FOLLOWING DEVIATIONS OCCURRED THIS REPORTING PERIOD	
<b>Permit Requirement</b> (specify permit condition #)	
<b>Date of Deviation:</b>	<b>Duration of Deviation:</b>
<b>Number of Deviations:</b>	
<b>Probable Cause of Deviation:</b>	
<b>Response Steps Taken:</b>	
<b>Permit Requirement</b> (specify permit condition #)	
<b>Date of Deviation:</b>	<b>Duration of Deviation:</b>
<b>Number of Deviations:</b>	
<b>Probable Cause of Deviation:</b>	
<b>Response Steps Taken:</b>	

DRAFT

Page 2 of 2

<b>Permit Requirement</b> (specify permit condition #)	
<b>Date of Deviation:</b>	<b>Duration of Deviation:</b>
<b>Number of Deviations:</b>	
<b>Probable Cause of Deviation:</b>	
<b>Response Steps Taken:</b>	
<b>Permit Requirement</b> (specify permit condition #)	
<b>Date of Deviation:</b>	<b>Duration of Deviation:</b>
<b>Number of Deviations:</b>	
<b>Probable Cause of Deviation:</b>	
<b>Response Steps Taken:</b>	
<b>Permit Requirement</b> (specify permit condition #)	
<b>Date of Deviation:</b>	<b>Duration of Deviation:</b>
<b>Number of Deviations:</b>	
<b>Probable Cause of Deviation:</b>	
<b>Response Steps Taken:</b>	

Form Completed by: \_\_\_\_\_

Title / Position: \_\_\_\_\_

Date: \_\_\_\_\_

Phone: \_\_\_\_\_

## Attachment B

### Federally Enforceable State Operating Permit (FESOP) No: 127-36688-00021

[Downloaded from the eCFR on March 29, 2023]

#### Electronic Code of Federal Regulations

#### Title 40: Protection of Environment

#### PART 60—STANDARDS OF PERFORMANCE FOR NEW STATIONARY SOURCES

#### Subpart IIII—Standards of Performance for Stationary Compression Ignition Internal Combustion Engines

Source: 71 FR 39172, July 11, 2006, unless otherwise noted.

#### What This Subpart Covers

#### § 60.4200 Am I subject to this subpart?

(a) The provisions of this subpart are applicable to manufacturers, owners, and operators of stationary compression ignition (CI) internal combustion engines (ICE) and other persons as specified in paragraphs (a)(1) through (4) of this section. For the purposes of this subpart, the date that construction commences is the date the engine is ordered by the owner or operator.

(1) Manufacturers of stationary CI ICE with a displacement of less than 30 liters per cylinder where the model year is:

(i) 2007 or later, for engines that are not fire pump engines;

(ii) The model year listed in Table 3 to this subpart or later model year, for fire pump engines.

(2) Owners and operators of stationary CI ICE that commence construction after July 11, 2005, where the stationary CI ICE are:

(i) Manufactured after April 1, 2006, and are not fire pump engines, or

(ii) Manufactured as a certified National Fire Protection Association (NFPA) fire pump engine after July 1, 2006.

(3) Owners and operators of any stationary CI ICE that are modified or reconstructed after July 11, 2005 and any person that modifies or reconstructs any stationary CI ICE after July 11, 2005.

(4) The provisions of § 60.4208 of this subpart are applicable to all owners and operators of stationary CI ICE that commence construction after July 11, 2005.

(b) The provisions of this subpart are not applicable to stationary CI ICE being tested at a stationary CI ICE test cell/stand.

(c) If you are an owner or operator of an area source subject to this subpart, you are exempt from the obligation to obtain a permit under 40 CFR part 70 or 40 CFR part 71, provided you are not required to obtain a permit under 40 CFR 70.3(a) or 40 CFR 71.3(a) for a reason other than your status as an area source under this subpart. Notwithstanding the previous sentence, you must continue to comply with the provisions of this subpart applicable to area sources.

(d) Stationary CI ICE may be eligible for exemption from the requirements of this subpart as described in 40 CFR part 1068, subpart C, except that owners and operators, as well as manufacturers, may be eligible to request an exemption for national security.

(e) Owners and operators of facilities with CI ICE that are acting as temporary replacement units and that are located at a stationary source for less than 1 year and that have been properly certified as meeting the standards that would be applicable to such engine under the appropriate nonroad engine provisions, are not required to meet any other provisions under this subpart with regard to such engines.

[71 FR 39172, July 11, 2006, as amended at 76 FR 37967, June 28, 2011; 86 FR 34357, June 29, 2021]

## **Emission Standards for Manufacturers**

### **§ 60.4201 What emission standards must I meet for non-emergency engines if I am a stationary CI internal combustion engine manufacturer?**

(a) Stationary CI internal combustion engine manufacturers must certify their 2007 model year and later non-emergency stationary CI ICE with a maximum engine power less than or equal to 2,237 kilowatt (KW) (3,000 horsepower (HP)) and a displacement of less than 10 liters per cylinder to the certification emission standards for new nonroad CI engines in 40 CFR 1039.101, 1039.102, 1039.104, 1039.105, 1039.107, and 1039.115 and 40 CFR part 1039, appendix I, as applicable, for all pollutants, for the same model year and maximum engine power.

(b) Stationary CI internal combustion engine manufacturers must certify their 2007 through 2010 model year non-emergency stationary CI ICE with a maximum engine power greater than 2,237 KW (3,000 HP) and a displacement of less than 10 liters per cylinder to the emission standards in table 1 to this subpart, for all pollutants, for the same maximum engine power.

(c) Stationary CI internal combustion engine manufacturers must certify their 2011 model year and later non-emergency stationary CI ICE with a maximum engine power greater than 2,237 KW (3,000 HP) and a displacement of less than 10 liters per cylinder to the certification emission standards for new nonroad CI engines in 40 CFR 1039.101, 40 CFR 1039.102, 40 CFR 1039.104, 40 CFR 1039.105, 40 CFR 1039.107, and 40 CFR 1039.115, as applicable, for all pollutants, for the same maximum engine power.

(d) Stationary CI internal combustion engine manufacturers must certify the following non-emergency stationary CI ICE to the appropriate Tier 2 emission standards for new marine CI engines as described in 40 CFR part 1042, appendix I, for all pollutants, for the same displacement and rated power:

(1) Their 2007 model year through 2012 non-emergency stationary CI ICE with a displacement of greater than or equal to 10 liters per cylinder and less than 30 liters per cylinder;

(2) Their 2013 model year non-emergency stationary CI ICE with a maximum engine power greater than or equal to 3,700 KW (4,958 HP) and a displacement of greater than or equal to 10 liters per cylinder and less than 15 liters per cylinder; and

(3) Their 2013 model year non-emergency stationary CI ICE with a displacement of greater than or equal to 15 liters per cylinder and less than 30 liters per cylinder.

(e) Stationary CI internal combustion engine manufacturers must certify the following non-emergency stationary CI ICE to the certification emission standards and other requirements for new marine CI engines in 40 CFR 1042.101, 40 CFR 1042.107, 40 CFR 1042.110, 40 CFR 1042.115, 40 CFR 1042.120, and 40 CFR 1042.145, as applicable, for all pollutants, for the same displacement and maximum engine power:

(1) Their 2013 model year non-emergency stationary CI ICE with a maximum engine power less than 3,700 KW (4,958 HP) and a displacement of greater than or equal to 10 liters per cylinder and less than 15 liters per cylinder; and

(2) Their 2014 model year and later non-emergency stationary CI ICE with a displacement of greater than or equal to 10 liters per cylinder and less than 30 liters per cylinder.

(f) Notwithstanding the requirements in paragraphs (a) through (c) of this section, stationary non-emergency CI ICE identified in paragraphs (a) and (c) of this section may be certified to the provisions of 40 CFR part 1042 for commercial engines that are applicable for the engine's model year, displacement, power density, and maximum engine power if the engines will be used solely in either or both of the following locations:

- (1) Remote areas of Alaska; and
- (2) Marine offshore installations.

(g) Notwithstanding the requirements in paragraphs (a) through (f) of this section, stationary CI internal combustion engine manufacturers are not required to certify reconstructed engines; however manufacturers may elect to do so. The reconstructed engine must be certified to the emission standards specified in paragraphs (a) through (e) of this section that are applicable to the model year, maximum engine power, and displacement of the reconstructed stationary CI ICE.

(h) Stationary CI ICE certified to the standards in 40 CFR part 1039 and equipped with auxiliary emission control devices (AECs) as specified in 40 CFR 1039.665 must meet the Tier 1 certification emission standards for new nonroad CI engines in 40 CFR part 1039, appendix I, while the AEC is activated during a qualified emergency situation. A qualified emergency situation is defined in 40 CFR 1039.665. When the qualified emergency situation has ended and the AEC is deactivated, the engine must resume meeting the otherwise applicable emission standard specified in this section.

[71 FR 39172, July 11, 2006, as amended at 76 FR 37967, June 28, 2011; 81 FR 44219, July 7, 2016; 86 FR 34357, June 29, 2021]

**§ 60.4202 What emission standards must I meet for emergency engines if I am a stationary CI internal combustion engine manufacturer?**

(a) Stationary CI internal combustion engine manufacturers must certify their 2007 model year and later emergency stationary CI ICE with a maximum engine power less than or equal to 2,237 KW (3,000 HP) and a displacement of less than 10 liters per cylinder that are not fire pump engines to the emission standards specified in paragraphs (a)(1) through (2) of this section.

(1) For engines with a maximum engine power less than 37 KW (50 HP):

- (i) The Tier 2 emission standards for new nonroad CI engines for the appropriate rated power as described in 40 CFR part 1039, appendix I, for all pollutants and the smoke standards as specified in 40 CFR 1039.105 for model year 2007 engines; and
- (ii) The certification emission standards for new nonroad CI engines in 40 CFR 1039.104, 40 CFR 1039.105, 40 CFR 1039.107, 40 CFR 1039.115, and table 2 to this subpart, for 2008 model year and later engines.

(2) For engines with a rated power greater than or equal to 37 KW (50 HP), the Tier 2 or Tier 3 emission standards for new nonroad CI engines for the same rated power as described in 40 CFR part 1039, appendix I, for all pollutants and the smoke standards as specified in 40 CFR 1039.105 beginning in model year 2007.

(b) Stationary CI internal combustion engine manufacturers must certify their 2007 model year and later emergency stationary CI ICE with a maximum engine power greater than 2,237 KW (3,000 HP) and a displacement of less than 10 liters per cylinder that are not fire pump engines to the emission standards specified in paragraphs (b)(1) through (2) of this section.

(1) For 2007 through 2010 model years, the emission standards in table 1 to this subpart, for all pollutants, for the same maximum engine power.



(2) For 2011 model year and later, the Tier 2 emission standards as described in 40 CFR part 1039, appendix I, for all pollutants and the smoke standards as specified in 40 CFR 1039.105.

(c) [Reserved]

(d) Beginning with the model years in table 3 to this subpart, stationary CI internal combustion engine manufacturers must certify their fire pump stationary CI ICE to the emission standards in table 4 to this subpart, for all pollutants, for the same model year and NFPA nameplate power.

(e) Stationary CI internal combustion engine manufacturers must certify the following emergency stationary CI ICE that are not fire pump engines to the appropriate Tier 2 emission standards for new marine CI engines as described in 40 CFR part 1042, appendix I, for all pollutants, for the same displacement and rated power:

(1) Their 2007 model year through 2012 emergency stationary CI ICE with a displacement of greater than or equal to 10 liters per cylinder and less than 30 liters per cylinder;

(2) Their 2013 model year and later emergency stationary CI ICE with a maximum engine power greater than or equal to 3,700 KW (4,958 HP) and a displacement of greater than or equal to 10 liters per cylinder and less than 15 liters per cylinder;

(3) Their 2013 model year emergency stationary CI ICE with a displacement of greater than or equal to 15 liters per cylinder and less than 30 liters per cylinder; and

(4) Their 2014 model year and later emergency stationary CI ICE with a maximum engine power greater than or equal to 2,000 KW (2,682 HP) and a displacement of greater than or equal to 15 liters per cylinder and less than 30 liters per cylinder.

(f) Stationary CI internal combustion engine manufacturers must certify the following emergency stationary CI ICE to the certification emission standards and other requirements applicable to Tier 3 new marine CI engines in 40 CFR 1042.101, 40 CFR 1042.107, 40 CFR 1042.115, 40 CFR 1042.120, and 40 CFR 1042.145, for all pollutants, for the same displacement and maximum engine power:

(1) Their 2013 model year and later emergency stationary CI ICE with a maximum engine power less than 3,700 KW (4,958 HP) and a displacement of greater than or equal to 10 liters per cylinder and less than 15 liters per cylinder; and

(2) Their 2014 model year and later emergency stationary CI ICE with a maximum engine power less than 2,000 KW (2,682 HP) and a displacement of greater than or equal to 15 liters per cylinder and less than 30 liters per cylinder.

(g) Notwithstanding the requirements in paragraphs (a) through (d) of this section, stationary emergency CI ICE identified in paragraphs (a) and (c) of this section may be certified to the provisions of 40 CFR part 1042 for commercial engines that are applicable for the engine's model year, displacement, power density, and maximum engine power if the engines will be used solely in either or both of the locations identified in paragraphs (g)(1) and (2) of this section. Engines that would be subject to the Tier 4 standards in 40 CFR part 1042 that are used solely in either or both of the locations identified in paragraphs (g)(1) and (2) of this section may instead continue to be certified to the previous tier of standards in 40 CFR part 1042. The previous tier is Tier 3 in most cases; however, the previous tier is Tier 2 if there are no Tier 3 standards specified for engines of a certain size or power rating.

(1) Remote areas of Alaska; and

(2) Marine offshore installations.

(h) Notwithstanding the requirements in paragraphs (a) through (f) of this section, stationary CI internal combustion engine manufacturers are not required to certify reconstructed engines; however manufacturers may elect to do so. The reconstructed engine must be certified to the emission standards specified in paragraphs (a) through (f) of this

section that are applicable to the model year, maximum engine power and displacement of the reconstructed emergency stationary CI ICE.

[71 FR 39172, July 11, 2006, as amended at 76 FR 37968, June 28, 2011; 81 FR 44219, July 7, 2016; 86 FR 34358, June 29, 2021; 88 FR 4471, Jan. 24, 2023]

**§ 60.4203 How long must my engines meet the emission standards if I am a manufacturer of stationary CI internal combustion engines?**

Engines manufactured by stationary CI internal combustion engine manufacturers must meet the emission standards as required in §§ 60.4201 and 60.4202 during the certified emissions life of the engines.

[76 FR 37968, June 28, 2011]

**Emission Standards for Owners and Operators**

**§ 60.4204 What emission standards must I meet for non-emergency engines if I am an owner or operator of a stationary CI internal combustion engine?**

(a) Owners and operators of pre-2007 model year non-emergency stationary CI ICE with a displacement of less than 10 liters per cylinder must comply with the emission standards in table 1 to this subpart. Owners and operators of pre-2007 model year non-emergency stationary CI ICE with a displacement of greater than or equal to 10 liters per cylinder and less than 30 liters per cylinder must comply with the Tier 1 emission standards in 40 CFR part 1042, appendix I.

(b) Owners and operators of 2007 model year and later non-emergency stationary CI ICE with a displacement of less than 30 liters per cylinder must comply with the emission standards for new CI engines in § 60.4201 for their 2007 model year and later stationary CI ICE, as applicable.

(c) Owners and operators of non-emergency stationary CI engines with a displacement of greater than or equal to 30 liters per cylinder must meet the following requirements:

(1) For engines installed prior to January 1, 2012, limit the emissions of NO<sub>x</sub> in the stationary CI internal combustion engine exhaust to the following:

(i) 17.0 grams per kilowatt-hour (g/KW-hr) (12.7 grams per horsepower-hr (g/HP-hr)) when maximum engine speed is less than 130 revolutions per minute (rpm);

(ii)  $45 \cdot n^{-0.2}$  g/KW-hr ( $34 \cdot n^{-0.2}$  g/HP-hr) when maximum engine speed is 130 or more but less than 2,000 rpm, where n is maximum engine speed; and

(iii) 9.8 g/KW-hr (7.3 g/HP-hr) when maximum engine speed is 2,000 rpm or more.

(2) For engines installed on or after January 1, 2012 and before January 1, 2016, limit the emissions of NO<sub>x</sub> in the stationary CI internal combustion engine exhaust to the following:

(i) 14.4 g/KW-hr (10.7 g/HP-hr) when maximum engine speed is less than 130 rpm;

(ii)  $44 \cdot n^{-0.23}$  g/KW-hr ( $33 \cdot n^{-0.23}$  g/HP-hr) when maximum engine speed is greater than or equal to 130 but less than 2,000 rpm and where n is maximum engine speed; and

(iii) 7.7 g/KW-hr (5.7 g/HP-hr) when maximum engine speed is greater than or equal to 2,000 rpm.

(3) For engines installed on or after January 1, 2016, limit the emissions of NO<sub>x</sub> in the stationary CI internal combustion engine exhaust to the following:

- (i) 3.4 g/KW-hr (2.5 g/HP-hr) when maximum engine speed is less than 130 rpm;
- (ii)  $9.0 \cdot n^{-0.20}$  g/KW-hr ( $6.7 \cdot n^{-0.20}$  g/HP-hr) where n (maximum engine speed) is 130 or more but less than 2,000 rpm; and
- (iii) 2.0 g/KW-hr (1.5 g/HP-hr) where maximum engine speed is greater than or equal to 2,000 rpm.

(4) Reduce particulate matter (PM) emissions by 60 percent or more, or limit the emissions of PM in the stationary CI internal combustion engine exhaust to 0.15 g/KW-hr (0.11 g/HP-hr).

(d) Owners and operators of non-emergency stationary CI ICE with a displacement of less than 30 liters per cylinder who conduct performance tests in-use must meet the not-to-exceed (NTE) standards as indicated in § 60.4212.

(e) Owners and operators of any modified or reconstructed non-emergency stationary CI ICE subject to this subpart must meet the emission standards applicable to the model year, maximum engine power, and displacement of the modified or reconstructed non-emergency stationary CI ICE that are specified in paragraphs (a) through (d) of this section.

(f) Owners and operators of stationary CI ICE certified to the standards in 40 CFR part 1039 and equipped with AECDs as specified in 40 CFR 1039.665 must meet the Tier 1 certification emission standards for new nonroad CI engines in 40 CFR part 1039, appendix I, while the AECD is activated during a qualified emergency situation. A qualified emergency situation is defined in 40 CFR 1039.665. When the qualified emergency situation has ended and the AECD is deactivated, the engine must resume meeting the otherwise applicable emission standard specified in this section.

[71 FR 39172, July 11, 2006, as amended at 76 FR 37968, June 28, 2011; 81 FR 44219, July 7, 2016; 86 FR 34358, June 29, 2021]

**§ 60.4205 What emission standards must I meet for emergency engines if I am an owner or operator of a stationary CI internal combustion engine?**

(a) Owners and operators of pre-2007 model year emergency stationary CI ICE with a displacement of less than 10 liters per cylinder that are not fire pump engines must comply with the emission standards in Table 1 to this subpart. Owners and operators of pre-2007 model year emergency stationary CI ICE with a displacement of greater than or equal to 10 liters per cylinder and less than 30 liters per cylinder that are not fire pump engines must comply with the Tier 1 emission standards in 40 CFR part 1042, appendix I.

(b) Owners and operators of 2007 model year and later emergency stationary CI ICE with a displacement of less than 30 liters per cylinder that are not fire pump engines must comply with the emission standards for new nonroad CI engines in § 60.4202, for all pollutants, for the same model year and maximum engine power for their 2007 model year and later emergency stationary CI ICE.

(c) Owners and operators of fire pump engines with a displacement of less than 30 liters per cylinder must comply with the emission standards in table 4 to this subpart, for all pollutants.

(d) Owners and operators of emergency stationary CI engines with a displacement of greater than or equal to 30 liters per cylinder must meet the requirements in this section.

(1) For engines installed prior to January 1, 2012, limit the emissions of NO<sub>x</sub> in the stationary CI internal combustion engine exhaust to the following:

- (i) 17.0 g/KW-hr (12.7 g/HP-hr) when maximum engine speed is less than 130 rpm;
- (ii)  $45 \cdot n^{-0.2}$  g/KW-hr ( $34 \cdot n^{-0.2}$  g/HP-hr) when maximum engine speed is 130 or more but less than 2,000 rpm, where n is maximum engine speed; and

(iii) 9.8 g/kW-hr (7.3 g/HP-hr) when maximum engine speed is 2,000 rpm or more.

(2) For engines installed on or after January 1, 2012, limit the emissions of NO<sub>x</sub> in the stationary CI internal combustion engine exhaust to the following:

(i) 14.4 g/KW-hr (10.7 g/HP-hr) when maximum engine speed is less than 130 rpm;

(ii)  $44 \cdot n^{-0.23}$  g/KW-hr ( $33 \cdot n^{-0.23}$  g/HP-hr) when maximum engine speed is greater than or equal to 130 but less than 2,000 rpm and where n is maximum engine speed; and

(iii) 7.7 g/KW-hr (5.7 g/HP-hr) when maximum engine speed is greater than or equal to 2,000 rpm.

(3) Limit the emissions of PM in the stationary CI internal combustion engine exhaust to 0.40 g/KW-hr (0.30 g/HP-hr).

(e) Owners and operators of emergency stationary CI ICE with a displacement of less than 30 liters per cylinder who conduct performance tests in-use must meet the NTE standards as indicated in § 60.4212.

(f) Owners and operators of any modified or reconstructed emergency stationary CI ICE subject to this subpart must meet the emission standards applicable to the model year, maximum engine power, and displacement of the modified or reconstructed CI ICE that are specified in paragraphs (a) through (e) of this section.

[71 FR 39172, July 11, 2006, as amended at 76 FR 37969, June 28, 2011; 86 FR 34358, June 29, 2021]

**§ 60.4206 How long must I meet the emission standards if I am an owner or operator of a stationary CI internal combustion engine?**

Owners and operators of stationary CI ICE must operate and maintain stationary CI ICE that achieve the emission standards as required in §§ 60.4204 and 60.4205 over the entire life of the engine.

[76 FR 37969, June 28, 2011]

**Fuel Requirements for Owners and Operators**

**§ 60.4207 What fuel requirements must I meet if I am an owner or operator of a stationary CI internal combustion engine subject to this subpart?**

(a) [Reserved]

(b) Beginning October 1, 2010, owners and operators of stationary CI ICE subject to this subpart with a displacement of less than 30 liters per cylinder that use diesel fuel must use diesel fuel that meets the requirements of 40 CFR 1090.305 for nonroad diesel fuel, except that any existing diesel fuel purchased (or otherwise obtained) prior to October 1, 2010, may be used until depleted.

(c) [Reserved]

(d) Beginning June 1, 2012, owners and operators of stationary CI ICE subject to this subpart with a displacement of greater than or equal to 30 liters per cylinder must use diesel fuel that meets a maximum per-gallon sulfur content of 1,000 parts per million (ppm).

(e) Stationary CI ICE that have a national security exemption under § 60.4200(d) are also exempt from the fuel requirements in this section.

[71 FR 39172, July 11, 2006, as amended at 76 FR 37969, June 28, 2011; 78 FR 6695, Jan. 30, 2013; 85 FR 78463, Dec. 4, 2020]

## Other Requirements for Owners and Operators

### **§ 60.4208 What is the deadline for importing or installing stationary CI ICE produced in previous model years?**

- (a) After December 31, 2008, owners and operators may not install stationary CI ICE (excluding fire pump engines) that do not meet the applicable requirements for 2007 model year engines.
- (b) After December 31, 2009, owners and operators may not install stationary CI ICE with a maximum engine power of less than 19 KW (25 HP) (excluding fire pump engines) that do not meet the applicable requirements for 2008 model year engines.
- (c) After December 31, 2014, owners and operators may not install non-emergency stationary CI ICE with a maximum engine power of greater than or equal to 19 KW (25 HP) and less than 56 KW (75 HP) that do not meet the applicable requirements for 2013 model year non-emergency engines.
- (d) After December 31, 2013, owners and operators may not install non-emergency stationary CI ICE with a maximum engine power of greater than or equal to 56 KW (75 HP) and less than 130 KW (175 HP) that do not meet the applicable requirements for 2012 model year non-emergency engines.
- (e) After December 31, 2012, owners and operators may not install non-emergency stationary CI ICE with a maximum engine power of greater than or equal to 130 KW (175 HP), including those above 560 KW (750 HP), that do not meet the applicable requirements for 2011 model year non-emergency engines.
- (f) After December 31, 2016, owners and operators may not install non-emergency stationary CI ICE with a maximum engine power of greater than or equal to 560 KW (750 HP) that do not meet the applicable requirements for 2015 model year non-emergency engines.
- (g) After December 31, 2018, owners and operators may not install non-emergency stationary CI ICE with a maximum engine power greater than or equal to 600 KW (804 HP) and less than 2,000 KW (2,680 HP) and a displacement of greater than or equal to 10 liters per cylinder and less than 30 liters per cylinder that do not meet the applicable requirements for 2017 model year non-emergency engines.
- (h) In addition to the requirements specified in §§ 60.4201, 60.4202, 60.4204, and 60.4205, it is prohibited to import stationary CI ICE with a displacement of less than 30 liters per cylinder that do not meet the applicable requirements specified in paragraphs (a) through (g) of this section after the dates specified in paragraphs (a) through (g) of this section.
- (i) The requirements of this section do not apply to owners or operators of stationary CI ICE that have been modified, reconstructed, and do not apply to engines that were removed from one existing location and reinstalled at a new location.

[71 FR 39172, July 11, 2006, as amended at 76 FR 37969, June 28, 2011]

### **§ 60.4209 What are the monitoring requirements if I am an owner or operator of a stationary CI internal combustion engine?**

If you are an owner or operator, you must meet the monitoring requirements of this section. In addition, you must also meet the monitoring requirements specified in § 60.4211.

- (a) If you are an owner or operator of an emergency stationary CI internal combustion engine that does not meet the standards applicable to non-emergency engines, you must install a non-resettable hour meter prior to startup of the engine.
- (b) If you are an owner or operator of a stationary CI internal combustion engine equipped with a diesel particulate filter to comply with the emission standards in § 60.4204, the diesel particulate filter must be installed with a

backpressure monitor that notifies the owner or operator when the high backpressure limit of the engine is approached.

[71 FR 39172, July 11, 2006, as amended at 76 FR 37969, June 28, 2011]

## Compliance Requirements

### § 60.4210 What are my compliance requirements if I am a stationary CI internal combustion engine manufacturer?

(a) Stationary CI internal combustion engine manufacturers must certify their stationary CI ICE with a displacement of less than 10 liters per cylinder to the emission standards specified in §§ 60.4201(a) through (c) and 60.4202(a), (b), and (d) using the certification procedures required in 40 CFR part 1039, subpart C, and must test their engines as specified in 40 CFR part 1039. For the purposes of this subpart, engines certified to the standards in Table 1 to this subpart shall be subject to the same certification procedures required for engines certified to the Tier 1 standards in 40 CFR part 1039, appendix I. For the purposes of this subpart, engines certified to the standards in Table 4 to this subpart shall be subject to the same certification procedures required for engines certified to the Tier 1 standards in 40 CFR part 1039, appendix I, except that engines with NFPA nameplate power of less than 37 KW (50 HP) certified to model year 2011 or later standards shall be subject to the same requirements as engines certified to the standards in 40 CFR part 1039.

(b) Stationary CI internal combustion engine manufacturers must certify their stationary CI ICE with a displacement of greater than or equal to 10 liters per cylinder and less than 30 liters per cylinder to the emission standards specified in §§ 60.4201(d) and (e) and 60.4202(e) and (f) using the certification procedures required in 40 CFR part 1042, subpart C, and must test their engines as specified in 40 CFR part 1042.

(c) Stationary CI internal combustion engine manufacturers must meet the requirements of 40 CFR 1039.120, 1039.125, 1039.130, and 1039.135 and 40 CFR part 1068 for engines that are certified to the emission standards in 40 CFR part 1039. Stationary CI internal combustion engine manufacturers must meet the corresponding provisions of 40 CFR part 1042 for engines that would be covered by that part if they were nonroad (including marine) engines. Labels on such engines must refer to stationary engines, rather than or in addition to nonroad or marine engines, as appropriate. Stationary CI internal combustion engine manufacturers must label their engines according to paragraphs (c)(1) through (3) of this section.

(1) Stationary CI internal combustion engines manufactured from January 1, 2006 to March 31, 2006 (January 1, 2006 to June 30, 2006 for fire pump engines), other than those that are part of certified engine families under the nonroad CI engine regulations, must be labeled according to 40 CFR 1039.20.

(2) Stationary CI internal combustion engines manufactured from April 1, 2006 to December 31, 2006 (or, for fire pump engines, July 1, 2006 to December 31 of the year preceding the year listed in table 3 to this subpart) must be labeled according to paragraphs (c)(2)(i) through (iii) of this section:

(i) Stationary CI internal combustion engines that are part of certified engine families under the nonroad regulations must meet the labeling requirements for nonroad CI engines, but do not have to meet the labeling requirements in 40 CFR 1039.20.

(ii) Stationary CI internal combustion engines that meet Tier 1 requirements (or requirements for fire pumps) under this subpart, but do not meet the requirements applicable to nonroad CI engines must be labeled according to 40 CFR 1039.20. The engine manufacturer may add language to the label clarifying that the engine meets Tier 1 requirements (or requirements for fire pumps) of this subpart.

(iii) Stationary CI internal combustion engines manufactured after April 1, 2006 that do not meet Tier 1 requirements of this subpart, or fire pumps engines manufactured after July 1, 2006 that do not meet the requirements for fire pumps under this subpart, may not be used in the U.S. If any such engines are manufactured in the U.S. after April 1, 2006 (July 1, 2006 for fire pump engines), they must be exported or must be brought into compliance with the appropriate standards prior to initial operation. The export provisions of 40 CFR 1068.230 would apply to engines for export and the manufacturers must label such engines according to 40 CFR 1068.230.

(3) Stationary CI internal combustion engines manufactured after January 1, 2007 (for fire pump engines, after January 1 of the year listed in table 3 to this subpart, as applicable) must be labeled according to paragraphs (c)(3)(i) through (iii) of this section.

(i) Stationary CI internal combustion engines that meet the requirements of this subpart and the corresponding requirements for nonroad (including marine) engines of the same model year and HP must be labeled according to the provisions in 40 CFR part 1039 or 1042, as appropriate.

(ii) Stationary CI internal combustion engines that meet the requirements of this subpart, but are not certified to the standards applicable to nonroad (including marine) engines of the same model year and HP must be labeled according to the provisions in 40 CFR part 1039 or 1042, as appropriate, but the words "stationary" must be included instead of "nonroad" or "marine" on the label. In addition, such engines must be labeled according to 40 CFR 1039.20.

(iii) Stationary CI internal combustion engines that do not meet the requirements of this subpart must be labeled according to 40 CFR 1068.230 and must be exported under the provisions of 40 CFR 1068.230.

(d) An engine manufacturer certifying an engine family or families to standards under this subpart that are identical to standards applicable under 40 CFR part 1039 or 1042 for that model year may certify any such family that contains both nonroad (including marine) and stationary engines as a single engine family and/or may include any such family containing stationary engines in the averaging, banking, and trading provisions applicable for such engines under those parts.

(e) Manufacturers of engine families discussed in paragraph (d) of this section may meet the labeling requirements referred to in paragraph (c) of this section for stationary CI ICE by either adding a separate label containing the information required in paragraph (c) of this section or by adding the words "and stationary" after the word "nonroad" or "marine," as appropriate, to the label.

(f) Starting with the model years shown in table 5 to this subpart, stationary CI internal combustion engine manufacturers must add a permanent label stating that the engine is for stationary emergency use only to each new emergency stationary CI internal combustion engine greater than or equal to 19 KW (25 HP) that meets all the emission standards for emergency engines in § 60.4202 but does not meet all the emission standards for non-emergency engines in § 60.4201. The label must be added according to the labeling requirements specified in 40 CFR 1039.135(b). Engine manufacturers must specify in the owner's manual that operation of emergency engines is limited to emergency operations and required maintenance and testing.

(g) Manufacturers of fire pump engines may use the test cycle in table 6 to this subpart for testing fire pump engines and may test at the NFPA certified nameplate HP, provided that the engine is labeled as "Fire Pump Applications Only".

(h) Engine manufacturers, including importers, may introduce into commerce uncertified engines or engines certified to earlier standards that were manufactured before the new or changed standards took effect until inventories are depleted, as long as such engines are part of normal inventory. For example, if the engine manufacturers' normal industry practice is to keep on hand a one-month supply of engines based on its projected sales, and a new tier of standards starts to apply for the 2009 model year, the engine manufacturer may manufacture engines based on the normal inventory requirements late in the 2008 model year, and sell those engines for installation. The engine manufacturer may not circumvent the provisions of § 60.4201 or § 60.4202 by stockpiling engines that are built before new or changed standards take effect. Stockpiling of such engines beyond normal industry practice is a violation of this subpart.

(i) The replacement engine provisions of 40 CFR 1068.240 are applicable to stationary CI engines replacing existing equipment that is less than 15 years old.

(j) Stationary CI ICE manufacturers may equip their stationary CI internal combustion engines certified to the emission standards in 40 CFR part 1039 with AECDs for qualified emergency situations according to the requirements of 40 CFR 1039.665. Manufacturers of stationary CI ICE equipped with AECDs as allowed by 40 CFR 1039.665 must meet all the requirements in 40 CFR 1039.665 that apply to manufacturers. Manufacturers must document that the engine complies with the Tier 1 standard in 40 CFR part 1039, appendix I, when the AECD is activated. Manufacturers must provide any relevant testing, engineering analysis, or other information in

sufficient detail to support such statement when applying for certification (including amending an existing certificate) of an engine equipped with an AECD as allowed by 40 CFR 1039.665.

(k) Manufacturers of any size may certify their emergency stationary CI internal combustion engines under this section using assigned deterioration factors established by EPA, consistent with 40 CFR 1039.240 and 1042.240.

[71 FR 39172, July 11, 2006, as amended at 76 FR 37969, June 28, 2011; 81 FR 44219, July 7, 2016; 86 FR 34358, June 29, 2021]

**§ 60.4211 What are my compliance requirements if I am an owner or operator of a stationary CI internal combustion engine?**

(a) If you are an owner or operator and must comply with the emission standards specified in this subpart, you must do all of the following, except as permitted under paragraph (g) of this section:

(1) Operate and maintain the stationary CI internal combustion engine and control device according to the manufacturer's emission-related written instructions;

(2) Change only those emission-related settings that are permitted by the manufacturer; and

(3) Meet the requirements of 40 CFR part 1068, as they apply to you.

(b) If you are an owner or operator of a pre-2007 model year stationary CI internal combustion engine and must comply with the emission standards specified in § 60.4204(a) or § 60.4205(a), or if you are an owner or operator of a CI fire pump engine that is manufactured prior to the model years in table 3 to this subpart and must comply with the emission standards specified in § 60.4205(c), you must demonstrate compliance according to one of the methods specified in paragraphs (b)(1) through (5) of this section.

(1) Purchasing an engine certified to emission standards for the same model year and maximum engine power as described in 40 CFR parts 1039 and 1042, as applicable. The engine must be installed and configured according to the manufacturer's specifications.

(2) Keeping records of performance test results for each pollutant for a test conducted on a similar engine. The test must have been conducted using the same methods specified in this subpart and these methods must have been followed correctly.

(3) Keeping records of engine manufacturer data indicating compliance with the standards.

(4) Keeping records of control device vendor data indicating compliance with the standards.

(5) Conducting an initial performance test to demonstrate compliance with the emission standards according to the requirements specified in § 60.4212, as applicable.

(c) If you are an owner or operator of a 2007 model year and later stationary CI internal combustion engine and must comply with the emission standards specified in § 60.4204(b) or § 60.4205(b), or if you are an owner or operator of a CI fire pump engine that is manufactured during or after the model year that applies to your fire pump engine power rating in table 3 to this subpart and must comply with the emission standards specified in § 60.4205(c), you must comply by purchasing an engine certified to the emission standards in § 60.4204(b), or § 60.4205(b) or (c), as applicable, for the same model year and maximum (or in the case of fire pumps, NFPA nameplate) engine power. The engine must be installed and configured according to the manufacturer's emission-related specifications, except as permitted in paragraph (g) of this section.

(d) If you are an owner or operator and must comply with the emission standards specified in § 60.4204(c) or § 60.4205(d), you must demonstrate compliance according to the requirements specified in paragraphs (d)(1) through (3) of this section.



(1) Conducting an initial performance test to demonstrate initial compliance with the emission standards as specified in § 60.4213.

(2) Establishing operating parameters to be monitored continuously to ensure the stationary internal combustion engine continues to meet the emission standards. The owner or operator must petition the Administrator for approval of operating parameters to be monitored continuously. The petition must include the information described in paragraphs (d)(2)(i) through (v) of this section.

(i) Identification of the specific parameters you propose to monitor continuously;

(ii) A discussion of the relationship between these parameters and NO<sub>x</sub> and PM emissions, identifying how the emissions of these pollutants change with changes in these parameters, and how limitations on these parameters will serve to limit NO<sub>x</sub> and PM emissions;

(iii) A discussion of how you will establish the upper and/or lower values for these parameters which will establish the limits on these parameters in the operating limitations;

(iv) A discussion identifying the methods and the instruments you will use to monitor these parameters, as well as the relative accuracy and precision of these methods and instruments; and

(v) A discussion identifying the frequency and methods for recalibrating the instruments you will use for monitoring these parameters.

(3) For non-emergency engines with a displacement of greater than or equal to 30 liters per cylinder, conducting annual performance tests to demonstrate continuous compliance with the emission standards as specified in § 60.4213.

(e) If you are an owner or operator of a modified or reconstructed stationary CI internal combustion engine and must comply with the emission standards specified in § 60.4204(e) or § 60.4205(f), you must demonstrate compliance according to one of the methods specified in paragraphs (e)(1) or (2) of this section.

(1) Purchasing, or otherwise owning or operating, an engine certified to the emission standards in § 60.4204(e) or § 60.4205(f), as applicable.

(2) Conducting a performance test to demonstrate initial compliance with the emission standards according to the requirements specified in § 60.4212 or § 60.4213, as appropriate. The test must be conducted within 60 days after the engine commences operation after the modification or reconstruction.

(f) If you own or operate an emergency stationary ICE, you must operate the emergency stationary ICE according to the requirements in paragraphs (f)(1) through (3) of this section. In order for the engine to be considered an emergency stationary ICE under this subpart, any operation other than emergency operation, maintenance and testing, and operation in non-emergency situations for 50 hours per year, as described in paragraphs (f)(1) through (3), is prohibited. If you do not operate the engine according to the requirements in paragraphs (f)(1) through (3), the engine will not be considered an emergency engine under this subpart and must meet all requirements for non-emergency engines.

(1) There is no time limit on the use of emergency stationary ICE in emergency situations.

(2) You may operate your emergency stationary ICE for the purpose specified in paragraph (f)(2)(i) of this section for a maximum of 100 hours per calendar year. Any operation for non-emergency situations as allowed by paragraph (f)(3) of this section counts as part of the 100 hours per calendar year allowed by this paragraph (f)(2).

(i) Emergency stationary ICE may be operated for maintenance checks and readiness testing, provided that the tests are recommended by federal, state or local government, the manufacturer, the vendor, the regional transmission organization or equivalent balancing authority and transmission operator, or the insurance company associated with the engine. The owner or operator may petition the Administrator for approval of additional hours to be used for maintenance checks and readiness testing, but a petition is not required if the

owner or operator maintains records indicating that federal, state, or local standards require maintenance and testing of emergency ICE beyond 100 hours per calendar year.

(ii)-(iii) [Reserved]

(3) Emergency stationary ICE may be operated for up to 50 hours per calendar year in non-emergency situations. The 50 hours of operation in non-emergency situations are counted as part of the 100 hours per calendar year for maintenance and testing provided in paragraph (f)(2) of this section. Except as provided in paragraph (f)(3)(i) of this section, the 50 hours per calendar year for non-emergency situations cannot be used for peak shaving or non-emergency demand response, or to generate income for a facility to an electric grid or otherwise supply power as part of a financial arrangement with another entity.

(i) The 50 hours per year for non-emergency situations can be used to supply power as part of a financial arrangement with another entity if all of the following conditions are met:

(A) The engine is dispatched by the local balancing authority or local transmission and distribution system operator;

(B) The dispatch is intended to mitigate local transmission and/or distribution limitations so as to avert potential voltage collapse or line overloads that could lead to the interruption of power supply in a local area or region.

(C) The dispatch follows reliability, emergency operation or similar protocols that follow specific NERC, regional, state, public utility commission or local standards or guidelines.

(D) The power is provided only to the facility itself or to support the local transmission and distribution system.

(E) The owner or operator identifies and records the entity that dispatches the engine and the specific NERC, regional, state, public utility commission or local standards or guidelines that are being followed for dispatching the engine. The local balancing authority or local transmission and distribution system operator may keep these records on behalf of the engine owner or operator.

(ii) [Reserved]

(g) If you do not install, configure, operate, and maintain your engine and control device according to the manufacturer's emission-related written instructions, or you change emission-related settings in a way that is not permitted by the manufacturer, you must demonstrate compliance as follows:

(1) If you are an owner or operator of a stationary CI internal combustion engine with maximum engine power less than 100 HP, you must keep a maintenance plan and records of conducted maintenance to demonstrate compliance and must, to the extent practicable, maintain and operate the engine in a manner consistent with good air pollution control practice for minimizing emissions. In addition, if you do not install and configure the engine and control device according to the manufacturer's emission-related written instructions, or you change the emission-related settings in a way that is not permitted by the manufacturer, you must conduct an initial performance test to demonstrate compliance with the applicable emission standards within 1 year of such action.

(2) If you are an owner or operator of a stationary CI internal combustion engine greater than or equal to 100 HP and less than or equal to 500 HP, you must keep a maintenance plan and records of conducted maintenance and must, to the extent practicable, maintain and operate the engine in a manner consistent with good air pollution control practice for minimizing emissions. In addition, you must conduct an initial performance test to demonstrate compliance with the applicable emission standards within 1 year of startup, or within 1 year after an engine and control device is no longer installed, configured, operated, and maintained in accordance with the manufacturer's emission-related written instructions, or within 1 year after you change emission-related settings in a way that is not permitted by the manufacturer.

(3) If you are an owner or operator of a stationary CI internal combustion engine greater than 500 HP, you must keep a maintenance plan and records of conducted maintenance and must, to the extent practicable, maintain

and operate the engine in a manner consistent with good air pollution control practice for minimizing emissions. In addition, you must conduct an initial performance test to demonstrate compliance with the applicable emission standards within 1 year of startup, or within 1 year after an engine and control device is no longer installed, configured, operated, and maintained in accordance with the manufacturer's emission-related written instructions, or within 1 year after you change emission-related settings in a way that is not permitted by the manufacturer. You must conduct subsequent performance testing every 8,760 hours of engine operation or 3 years, whichever comes first, thereafter to demonstrate compliance with the applicable emission standards.

(h) The requirements for operators and prohibited acts specified in 40 CFR 1039.665 apply to owners or operators of stationary CI ICE equipped with AECDs for qualified emergency situations as allowed by 40 CFR 1039.665.

[71 FR 39172, July 11, 2006, as amended at 76 FR 37970, June 28, 2011; 78 FR 6695, Jan. 30, 2013; 81 FR 44219, July 7, 2016; 86 FR 34359, June 29, 2021; 87 FR 48605, Aug. 10, 2022]

### Testing Requirements for Owners and Operators

#### **§ 60.4212 What test methods and other procedures must I use if I am an owner or operator of a stationary CI internal combustion engine with a displacement of less than 30 liters per cylinder?**

Owners and operators of stationary CI ICE with a displacement of less than 30 liters per cylinder who conduct performance tests pursuant to this subpart must do so according to paragraphs (a) through (e) of this section.

(a) The performance test must be conducted according to the in-use testing procedures in 40 CFR part 1039, subpart F, for stationary CI ICE with a displacement of less than 10 liters per cylinder, and according to 40 CFR part 1042, subpart F, for stationary CI ICE with a displacement of greater than or equal to 10 liters per cylinder and less than 30 liters per cylinder. Alternatively, stationary CI ICE that are complying with Tier 2 or Tier 3 emission standards as described in 40 CFR part 1039, appendix I, or with Tier 2 emission standards as described in 40 CFR part 1042, appendix I, may follow the testing procedures specified in § 60.4213, as appropriate.

(b) Exhaust emissions from stationary CI ICE that are complying with the emission standards for new CI engines in 40 CFR part 1039 must not exceed the not-to-exceed (NTE) standards for the same model year and maximum engine power as required in 40 CFR 1039.101(e) and 40 CFR 1039.102(g)(1), except as specified in 40 CFR 1039.104(d). This requirement starts when NTE requirements take effect for nonroad diesel engines under 40 CFR part 1039.

(c) Exhaust emissions from stationary CI ICE subject to Tier 2 or Tier 3 emission standards as described in 40 CFR part 1039, appendix I, or Tier 2 emission standards as described in 40 CFR part 1042, appendix I, must not exceed the NTE numerical requirements, rounded to the same number of decimal places as the applicable standard, determined from the following equation:

$$\text{NTE requirement for each pollutant} = (1.25) \times (\text{STD}) \text{ (Eq. 1)}$$

Where:

STD = The standard specified for that pollutant in 40 CFR part 1039 or 1042, as applicable.

(d) Exhaust emissions from stationary CI ICE that are complying with the emission standards for pre-2007 model year engines in § 60.4204(a), § 60.4205(a), or § 60.4205(c) must not exceed the NTE numerical requirements, rounded to the same number of decimal places as the applicable standard in § 60.4204(a), § 60.4205(a), or § 60.4205(c), determined from the equation in paragraph (c) of this section.

Where:

STD = The standard specified for that pollutant in § 60.4204(a), § 60.4205(a), or § 60.4205(c).

Alternatively, stationary CI ICE that are complying with the emission standards for pre-2007 model year engines in § 60.4204(a), § 60.4205(a), or § 60.4205(c) may follow the testing procedures specified in § 60.4213, as appropriate.

(e) Exhaust emissions from stationary CI ICE that are complying with the emission standards for new CI engines in 40 CFR part 1042 must not exceed the NTE standards for the same model year and maximum engine power as required in 40 CFR 1042.101(c).

[71 FR 39172, July 11, 2006, as amended at 76 FR 37971, June 28, 2011; 86 FR 34359, June 29, 2021]

**§ 60.4213 What test methods and other procedures must I use if I am an owner or operator of a stationary CI internal combustion engine with a displacement of greater than or equal to 30 liters per cylinder?**

Owners and operators of stationary CI ICE with a displacement of greater than or equal to 30 liters per cylinder must conduct performance tests according to paragraphs (a) through (f) of this section.

(a) Each performance test must be conducted according to the requirements in § 60.8 and under the specific conditions that this subpart specifies in table 7. The test must be conducted within 10 percent of 100 percent peak (or the highest achievable) load.

(b) You may not conduct performance tests during periods of startup, shutdown, or malfunction, as specified in § 60.8(c).

(c) You must conduct three separate test runs for each performance test required in this section, as specified in § 60.8(f). Each test run must last at least 1 hour.

(d) To determine compliance with the percent reduction requirement, you must follow the requirements as specified in paragraphs (d)(1) through (3) of this section.

(1) You must use Equation 2 of this section to determine compliance with the percent reduction requirement:

$$\frac{C_i - C_o}{C_i} \times 100 = R \quad (\text{Eq. 2})$$

Where:

$C_i$  = concentration of NO<sub>x</sub> or PM at the control device inlet,

$C_o$  = concentration of NO<sub>x</sub> or PM at the control device outlet, and

R = percent reduction of NO<sub>x</sub> or PM emissions.

(2) You must normalize the NO<sub>x</sub> or PM concentrations at the inlet and outlet of the control device to a dry basis and to 15 percent oxygen (O<sub>2</sub>) using Equation 3 of this section, or an equivalent percent carbon dioxide (CO<sub>2</sub>) using the procedures described in paragraph (d)(3) of this section.

$$C_{\text{adj}} = C_d \frac{5.9}{20.9 - \% \text{ O}_2} \quad (\text{Eq. 3})$$

Where:

$C_{adj}$  = Calculated NO<sub>x</sub> or PM concentration adjusted to 15 percent O<sub>2</sub>.

$C_d$  = Measured concentration of NO<sub>x</sub> or PM, uncorrected.

5.9 = 20.9 percent O<sub>2</sub>-15 percent O<sub>2</sub>, the defined O<sub>2</sub> correction value, percent.

%O<sub>2</sub> = Measured O<sub>2</sub> concentration, dry basis, percent.

(3) If pollutant concentrations are to be corrected to 15 percent O<sub>2</sub> and CO<sub>2</sub> concentration is measured in lieu of O<sub>2</sub> concentration measurement, a CO<sub>2</sub> correction factor is needed. Calculate the CO<sub>2</sub> correction factor as described in paragraphs (d)(3)(i) through (iii) of this section.

(i) Calculate the fuel-specific  $F_o$  value for the fuel burned during the test using values obtained from Method 19, Section 5.2, and the following equation:

$$F_o = \frac{0.209 F_d}{F_c} \quad (\text{Eq. 4})$$

Where:

$F_o$  = Fuel factor based on the ratio of O<sub>2</sub> volume to the ultimate CO<sub>2</sub> volume produced by the fuel at zero percent excess air.

0.209 = Fraction of air that is O<sub>2</sub>, percent/100.

$F_d$  = Ratio of the volume of dry effluent gas to the gross calorific value of the fuel from Method 19, dsm<sup>3</sup>/J (dscf/10<sup>6</sup> Btu).

$F_c$  = Ratio of the volume of CO<sub>2</sub> produced to the gross calorific value of the fuel from Method 19, dsm<sup>3</sup>/J (dscf/10<sup>6</sup> Btu).

(ii) Calculate the CO<sub>2</sub> correction factor for correcting measurement data to 15 percent O<sub>2</sub>, as follows:

$$X_{CO_2} = \frac{5.9}{F_o} \quad (\text{Eq. 5})$$

Where:

$X_{CO_2}$  = CO<sub>2</sub> correction factor, percent.

5.9 = 20.9 percent O<sub>2</sub>-15 percent O<sub>2</sub>, the defined O<sub>2</sub> correction value, percent.

(iii) Calculate the NO<sub>x</sub> and PM gas concentrations adjusted to 15 percent O<sub>2</sub> using CO<sub>2</sub> as follows:

$$C_{\text{adj}} = C_d \frac{X_{\text{CO}_2}}{\% \text{CO}_2} \quad (\text{Eq. 6})$$

Where:

$C_{\text{adj}}$  = Calculated NO<sub>x</sub> or PM concentration adjusted to 15 percent O<sub>2</sub>.

$C_d$  = Measured concentration of NO<sub>x</sub> or PM, uncorrected.

%CO<sub>2</sub> = Measured CO<sub>2</sub> concentration, dry basis, percent.

(e) To determine compliance with the NO<sub>x</sub> mass per unit output emission limitation, convert the concentration of NO<sub>x</sub> in the engine exhaust using Equation 7 of this section:

$$\text{ER} = \frac{C_d \times 1.912 \times 10^{-3} \times Q \times T}{\text{KW-hour}} \quad (\text{Eq. 7})$$

Where:

ER = Emission rate in grams per KW-hour.

$C_d$  = Measured NO<sub>x</sub> concentration in ppm.

$1.912 \times 10^{-3}$  = Conversion constant for ppm NO<sub>x</sub> to grams per standard cubic meter at 25 degrees Celsius.

Q = Stack gas volumetric flow rate, in standard cubic meter per hour.

T = Time of test run, in hours.

KW-hour = Brake work of the engine, in KW-hour.

(f) To determine compliance with the PM mass per unit output emission limitation, convert the concentration of PM in the engine exhaust using Equation 8 of this section:

$$\text{ER} = \frac{C_{\text{adj}} \times Q \times T}{\text{KW-hour}} \quad (\text{Eq. 8})$$

Where:

ER = Emission rate in grams per KW-hour.

$C_{\text{adj}}$  = Calculated PM concentration in grams per standard cubic meter.

Q = Stack gas volumetric flow rate, in standard cubic meter per hour.

T = Time of test run, in hours.

KW-hour = Energy output of the engine, in KW.

[71 FR 39172, July 11, 2006, as amended at 76 FR 37971, June 28, 2011]

### **Notification, Reports, and Records for Owners and Operators**

#### **§ 60.4214 What are my notification, reporting, and recordkeeping requirements if I am an owner or operator of a stationary CI internal combustion engine?**

(a) Owners and operators of non-emergency stationary CI ICE that are greater than 2,237 KW (3,000 HP), or have a displacement of greater than or equal to 10 liters per cylinder, or are pre-2007 model year engines that are greater than 130 KW (175 HP) and not certified, must meet the requirements of paragraphs (a)(1) and (2) of this section.

(1) Submit an initial notification as required in § 60.7(a)(1). The notification must include the information in paragraphs (a)(1)(i) through (v) of this section.

(i) Name and address of the owner or operator;

(ii) The address of the affected source;

(iii) Engine information including make, model, engine family, serial number, model year, maximum engine power, and engine displacement;

(iv) Emission control equipment; and

(v) Fuel used.

(2) Keep records of the information in paragraphs (a)(2)(i) through (iv) of this section.

(i) All notifications submitted to comply with this subpart and all documentation supporting any notification.

(ii) Maintenance conducted on the engine.

(iii) If the stationary CI internal combustion is a certified engine, documentation from the manufacturer that the engine is certified to meet the emission standards.

(iv) If the stationary CI internal combustion is not a certified engine, documentation that the engine meets the emission standards.

(b) If the stationary CI internal combustion engine is an emergency stationary internal combustion engine, the owner or operator is not required to submit an initial notification. Starting with the model years in table 5 to this subpart, if the emergency engine does not meet the standards applicable to non-emergency engines in the applicable model year, the owner or operator must keep records of the operation of the engine in emergency and non-emergency service that are recorded through the non-resettable hour meter. The owner must record the time of operation of the engine and the reason the engine was in operation during that time.

(c) If the stationary CI internal combustion engine is equipped with a diesel particulate filter, the owner or operator must keep records of any corrective action taken after the backpressure monitor has notified the owner or operator that the high backpressure limit of the engine is approached.

(d) If you own or operate an emergency stationary CI ICE with a maximum engine power more than 100 HP that operates for the purpose specified in § 60.4211(f)(3)(i), you must submit an annual report according to the requirements in paragraphs (d)(1) through (3) of this section.

(1) The report must contain the following information:

- (i) Company name and address where the engine is located.
- (ii) Date of the report and beginning and ending dates of the reporting period.
- (iii) Engine site rating and model year.
- (iv) Latitude and longitude of the engine in decimal degrees reported to the fifth decimal place.
- (v)-(vi) [Reserved]
- (vii) Hours spent for operation for the purposes specified in § 60.4211(f)(3)(i), including the date, start time, and end time for engine operation for the purposes specified in § 60.4211(f)(3)(i). The report must also identify the entity that dispatched the engine and the situation that necessitated the dispatch of the engine.

(2) The first annual report must cover the calendar year 2015 and must be submitted no later than March 31, 2016. Subsequent annual reports for each calendar year must be submitted no later than March 31 of the following calendar year.

(3) The annual report must be submitted electronically using the subpart specific reporting form in the Compliance and Emissions Data Reporting Interface (CEDRI) that is accessed through EPA's Central Data Exchange (CDX) ([www.epa.gov/cdx](http://www.epa.gov/cdx)). However, if the reporting form specific to this subpart is not available in CEDRI at the time that the report is due, the written report must be submitted to the Administrator at the appropriate address listed in § 60.4.

(e) Owners or operators of stationary CI ICE equipped with AECDs pursuant to the requirements of 40 CFR 1039.665 must report the use of AECDs as required by 40 CFR 1039.665(e).

[71 FR 39172, July 11, 2006, as amended at 78 FR 6696, Jan. 30, 2013; 81 FR 44219, July 7, 2016; 87 FR 48606, Aug. 10, 2022]

### Special Requirements

#### § 60.4215 What requirements must I meet for engines used in Guam, American Samoa, or the Commonwealth of the Northern Mariana Islands?

- (a) Stationary CI ICE with a displacement of less than 30 liters per cylinder that are used in Guam, American Samoa, or the Commonwealth of the Northern Mariana Islands are required to meet the applicable emission standards in §§ 60.4202 and 60.4205.
- (b) Stationary CI ICE that are used in Guam, American Samoa, or the Commonwealth of the Northern Mariana Islands are not required to meet the fuel requirements in § 60.4207.
- (c) Stationary CI ICE with a displacement of greater than or equal to 30 liters per cylinder that are used in Guam, American Samoa, or the Commonwealth of the Northern Mariana Islands are required to meet the following emission standards:
  - (1) For engines installed prior to January 1, 2012, limit the emissions of NO<sub>x</sub> in the stationary CI internal combustion engine exhaust to the following:
    - (i) 17.0 g/KW-hr (12.7 g/HP-hr) when maximum engine speed is less than 130 rpm;
    - (ii)  $45 \cdot n^{-0.2}$  g/KW-hr ( $34 \cdot n^{-0.2}$  g/HP-hr) when maximum engine speed is 130 or more but less than 2,000 rpm, where n is maximum engine speed; and



(iii) 9.8 g/KW-hr (7.3 g/HP-hr) when maximum engine speed is 2,000 rpm or more.

(2) For engines installed on or after January 1, 2012, limit the emissions of NO<sub>x</sub> in the stationary CI internal combustion engine exhaust to the following:

(i) 14.4 g/KW-hr (10.7 g/HP-hr) when maximum engine speed is less than 130 rpm;

(ii)  $44 \cdot n^{-0.23}$  g/KW-hr ( $33 \cdot n^{-0.23}$  g/HP-hr) when maximum engine speed is greater than or equal to 130 but less than 2,000 rpm and where n is maximum engine speed; and

(iii) 7.7 g/KW-hr (5.7 g/HP-hr) when maximum engine speed is greater than or equal to 2,000 rpm.

(3) Limit the emissions of PM in the stationary CI internal combustion engine exhaust to 0.40 g/KW-hr (0.30 g/HP-hr).

[71 FR 39172, July 11, 2006, as amended at 76 FR 37971, June 28, 2011]

### **§ 60.4216 What requirements must I meet for engines used in Alaska?**

(a) Prior to December 1, 2010, owners and operators of stationary CI ICE with a displacement of less than 30 liters per cylinder located in areas of Alaska not accessible by the FAHS should refer to 40 CFR part 69 to determine the diesel fuel requirements applicable to such engines.

(b) Except as indicated in paragraph (c) of this section, manufacturers, owners and operators of stationary CI ICE with a displacement of less than 10 liters per cylinder located in remote areas of Alaska may meet the requirements of this subpart by manufacturing and installing engines meeting the Tier 2 or Tier 3 emission standards described in 40 CFR part 1042 for the same model year, displacement, and maximum engine power, as appropriate, rather than the otherwise applicable requirements of 40 CFR part 1039, as indicated in §§ 60.4201(f) and 60.4202(g).

(c) Manufacturers, owners, and operators of stationary CI ICE that are located in remote areas of Alaska may choose to meet the applicable emission standards for emergency engines in §§ 60.4202 and 60.4205, and not those for non-emergency engines in §§ 60.4201 and 60.4204, except that for 2014 model year and later nonemergency CI ICE, the owner or operator of any such engine must have that engine certified as meeting at least the Tier 3 PM standards identified in appendix I of 40 CFR part 1039 or in 40 CFR 1042.101.

(d) The provisions of § 60.4207 do not apply to owners and operators of pre-2014 model year stationary CI ICE subject to this subpart that are located in remote areas of Alaska.

(e) The provisions of § 60.4208(a) do not apply to owners and operators of stationary CI ICE subject to this subpart that are located in areas of Alaska not accessible by the FAHS until after December 31, 2009.

(f) The provisions of this section and § 60.4207 do not prevent owners and operators of stationary CI ICE subject to this subpart that are located in remote areas of Alaska from using fuels mixed with used lubricating oil, in volumes of up to 1.75 percent of the total fuel. The sulfur content of the used lubricating oil must be less than 200 parts per million. The used lubricating oil must meet the on-specification levels and properties for used oil in 40 CFR 279.11.

[76 FR 37971, June 28, 2011, as amended at 81 FR 44219, July 7, 2016; 86 FR 34359, June 29, 2021]

**§ 60.4217 What emission standards must I meet if I am an owner or operator of a stationary internal combustion engine using special fuels?**

Owners and operators of stationary CI ICE that do not use diesel fuel may petition the Administrator for approval of alternative emission standards, if they can demonstrate that they use a fuel that is not the fuel on which the manufacturer of the engine certified the engine and that the engine cannot meet the applicable standards required in § 60.4204 or § 60.4205 using such fuels and that use of such fuel is appropriate and reasonably necessary, considering cost, energy, technical feasibility, human health and environmental, and other factors, for the operation of the engine.

[76 FR 37972, June 28, 2011]

**General Provisions**

**§ 60.4218 What General Provisions and confidential information provisions apply to me?**

(a) Table 8 to this subpart shows which parts of the General Provisions in §§ 60.1 through 60.19 apply to you.

(b) The provisions of 40 CFR 1068.10 and 1068.11 apply for engine manufacturers. For others, the general confidential business information (CBI) provisions apply as described in 40 CFR part 2.

[88 FR 4471, Jan. 24, 2023]

**Definitions**

**§ 60.4219 What definitions apply to this subpart?**

As used in this subpart, all terms not defined herein shall have the meaning given them in the CAA and in subpart A of this part.

*Alaska Railbelt Grid* means the service areas of the six regulated public utilities that extend from Fairbanks to Anchorage and the Kenai Peninsula. These utilities are Golden Valley Electric Association; Chugach Electric Association; Matanuska Electric Association; Homer Electric Association; Anchorage Municipal Light & Power; and the City of Seward Electric System.

*Certified emissions life* means the period during which the engine is designed to properly function in terms of reliability and fuel consumption, without being remanufactured, specified as a number of hours of operation or calendar years, whichever comes first. The values for certified emissions life for stationary CI ICE with a displacement of less than 10 liters per cylinder are given in 40 CFR 1039.101(g). The values for certified emissions life for stationary CI ICE with a displacement of greater than or equal to 10 liters per cylinder and less than 30 liters per cylinder are given in 40 CFR 1042.101(e).

*Combustion turbine* means all equipment, including but not limited to the turbine, the fuel, air, lubrication and exhaust gas systems, control systems (except emissions control equipment), and any ancillary components and sub-components comprising any simple cycle combustion turbine, any regenerative/recuperative cycle combustion turbine, the combustion turbine portion of any cogeneration cycle combustion system, or the combustion turbine portion of any combined cycle steam/electric generating system.

*Compression ignition* means relating to a type of stationary internal combustion engine that is not a spark ignition engine.

*Date of manufacture* means one of the following things:

- (1) For freshly manufactured engines and modified engines, date of manufacture means the date the engine is originally produced.
- (2) For reconstructed engines, date of manufacture means the date the engine was originally produced, except as specified in paragraph (3) of this definition.
- (3) Reconstructed engines are assigned a new date of manufacture if the fixed capital cost of the new and refurbished components exceeds 75 percent of the fixed capital cost of a comparable entirely new facility. An engine that is produced from a previously used engine block does not retain the date of manufacture of the engine in which the engine block was previously used if the engine is produced using all new components except for the engine block. In these cases, the date of manufacture is the date of reconstruction or the date the new engine is produced.

*Diesel fuel* means any liquid obtained from the distillation of petroleum with a boiling point of approximately 150 to 360 degrees Celsius. One commonly used form is number 2 distillate oil.

*Diesel particulate filter* means an emission control technology that reduces PM emissions by trapping the particles in a flow filter substrate and periodically removes the collected particles by either physical action or by oxidizing (burning off) the particles in a process called regeneration.

*Emergency stationary internal combustion engine* means any stationary reciprocating internal combustion engine that meets all of the criteria in paragraphs (1) through (3) of this definition. All emergency stationary ICE must comply with the requirements specified in § 60.4211(f) in order to be considered emergency stationary ICE. If the engine does not comply with the requirements specified in § 60.4211(f), then it is not considered to be an emergency stationary ICE under this subpart.

- (1) The stationary ICE is operated to provide electrical power or mechanical work during an emergency situation. Examples include stationary ICE used to produce power for critical networks or equipment (including power supplied to portions of a facility) when electric power from the local utility (or the normal power source, if the facility runs on its own power production) is interrupted, or stationary ICE used to pump water in the case of fire or flood, etc.
- (2) The stationary ICE is operated under limited circumstances for situations not included in paragraph (1) of this definition, as specified in § 60.4211(f).
- (3) The stationary ICE operates as part of a financial arrangement with another entity in situations not included in paragraph (1) of this definition only as allowed in § 60.4211(f)(3)(i).

*Engine manufacturer* means the manufacturer of the engine. See the definition of "manufacturer" in this section.

*Fire pump engine* means an emergency stationary internal combustion engine certified to NFPA requirements that is used to provide power to pump water for fire suppression or protection.

*Freshly manufactured engine* means an engine that has not been placed into service. An engine becomes freshly manufactured when it is originally produced.

*Installed* means the engine is placed and secured at the location where it is intended to be operated.

*Manufacturer* has the meaning given in section 216(1) of the Act. In general, this term includes any person who manufactures a stationary engine for sale in the United States or otherwise introduces a new stationary engine into commerce in the United States. This includes importers who import stationary engines for sale or resale.

*Maximum engine power* means maximum engine power as defined in 40 CFR 1039.801.

*Model year* means the calendar year in which an engine is manufactured (see “date of manufacture”), except as follows:

(1) Model year means the annual new model production period of the engine manufacturer in which an engine is manufactured (see “date of manufacture”), if the annual new model production period is different than the calendar year and includes January 1 of the calendar year for which the model year is named. It may not begin before January 2 of the previous calendar year and it must end by December 31 of the named calendar year.

(2) For an engine that is converted to a stationary engine after being placed into service as a nonroad or other non-stationary engine, model year means the calendar year or new model production period in which the engine was manufactured (see “date of manufacture”).

*Other internal combustion engine* means any internal combustion engine, except combustion turbines, which is not a reciprocating internal combustion engine or rotary internal combustion engine.

*Reciprocating internal combustion engine* means any internal combustion engine which uses reciprocating motion to convert heat energy into mechanical work.

*Remote areas of Alaska* means areas of Alaska that meet either paragraph (1) or (2) of this definition.

(1) Areas of Alaska that are not accessible by the Federal Aid Highway System (FAHS).

(2) Areas of Alaska that meet all of the following criteria:

(i) The only connection to the FAHS is through the Alaska Marine Highway System, or the stationary CI ICE operation is within an isolated grid in Alaska that is not connected to the statewide electrical grid referred to as the Alaska Railbelt Grid.

(ii) At least 10 percent of the power generated by the stationary CI ICE on an annual basis is used for residential purposes.

(iii) The generating capacity of the source is less than 12 megawatts, or the stationary CI ICE is used exclusively for backup power for renewable energy.

*Rotary internal combustion engine* means any internal combustion engine which uses rotary motion to convert heat energy into mechanical work.

*Spark ignition* means relating to a gasoline, natural gas, or liquefied petroleum gas fueled engine or any other type of engine with a spark plug (or other sparking device) and with operating characteristics significantly similar to the theoretical Otto combustion cycle. Spark ignition engines usually use a throttle to regulate intake air flow to control power during normal operation. Dual-fuel engines in which a liquid fuel (typically diesel fuel) is used for CI and gaseous fuel (typically natural gas) is used as the primary fuel at an annual average ratio of less than 2 parts diesel fuel to 100 parts total fuel on an energy equivalent basis are spark ignition engines.

*Stationary internal combustion engine* means any internal combustion engine, except combustion turbines, that converts heat energy into mechanical work and is not mobile. Stationary ICE differ from mobile ICE in that a stationary internal combustion engine is not a nonroad engine as defined at 40 CFR 1068.30 (excluding paragraph (2)(ii) of that definition), and is not used to propel a motor vehicle, aircraft, or a vehicle used solely for competition. Stationary ICE include reciprocating ICE, rotary ICE, and other ICE, except combustion turbines.

*Subpart* means 40 CFR part 60, subpart III.

**Table 1 to Subpart III of Part 60—Emission Standards for Stationary Pre-2007 Model Year Engines With a Displacement of <10 Liters per Cylinder and 2007-2010 Model Year Engines >2,237 KW (3,000 HP) and With a Displacement of <10 Liters per Cylinder**

[As stated in §§60.4201(b), 60.4202(b), 60.4204(a), and 60.4205(a), you must comply with the following emission standards]

Maximum engine power	Emission standards for stationary pre-2007 model year engines with a displacement of <10 liters per cylinder and 2007-2010 model year engines >2,237 KW (3,000 HP) and with a displacement of <10 liters per cylinder in g/KW-hr (g/HP-hr)				
	NMHC + NO <sub>x</sub>	HC	NO <sub>x</sub>	CO	PM
KW<8 (HP<11)	10.5 (7.8)			8.0 (6.0)	1.0 (0.75)
8≤KW<19 (11≤HP<25)	9.5 (7.1)			6.6 (4.9)	0.80 (0.60)
19≤KW<37 (25≤HP<50)	9.5 (7.1)			5.5 (4.1)	0.80 (0.60)
37≤KW<56 (50≤HP<75)			9.2 (6.9)		
56≤KW<75 (75≤HP<100)			9.2 (6.9)		
75≤KW<130 (100≤HP<175)			9.2 (6.9)		
130≤KW<225 (175≤HP<300)		1.3 (1.0)	9.2 (6.9)	11.4 (8.5)	0.54 (0.40)
225≤KW<450 (300≤HP<600)		1.3 (1.0)	9.2 (6.9)	11.4 (8.5)	0.54 (0.40)
450≤KW≤560 (600≤HP≤750)		1.3 (1.0)	9.2 (6.9)	11.4 (8.5)	0.54 (0.40)
KW>560 (HP>750)		1.3 (1.0)	9.2 (6.9)	11.4 (8.5)	0.54 (0.40)

**Table 2 to Subpart III of Part 60—Emission Standards for 2008 Model Year and Later Emergency Stationary CI ICE <37 KW (50 HP) With a Displacement of <10 Liters per Cylinder**

[As stated in §60.4202(a)(1), you must comply with the following emission standards]

Engine power	Emission standards for 2008 model year and later emergency stationary CI ICE <37 KW (50 HP) with a displacement of <10 liters per cylinder in g/KW-hr (g/HP-hr)			
	Model year(s)	NO <sub>x</sub> + NMHC	CO	PM
KW<8 (HP<11)	2008 +	7.5 (5.6)	8.0 (6.0)	0.40 (0.30)
8≤KW<19 (11≤HP<25)	2008 +	7.5 (5.6)	6.6 (4.9)	0.40 (0.30)
19≤KW<37 (25≤HP<50)	2008 +	7.5 (5.6)	5.5 (4.1)	0.30 (0.22)

**Table 3 to Subpart IIII of Part 60—Certification Requirements for Stationary Fire Pump Engines**

As stated in §60.4202(d), you must certify new stationary fire pump engines beginning with the following model years:

<b>Engine power</b>	<b>Starting model year engine manufacturers must certify new stationary fire pump engines according to §60.4202(d)<sup>1</sup></b>
KW<75 (HP<100)	2011
75≤KW<130 (100≤HP<175)	2010
130≤KW≤560 (175≤HP≤750)	2009
KW>560 (HP>750)	2008

<sup>1</sup>Manufacturers of fire pump stationary CI ICE with a maximum engine power greater than or equal to 37 kW (50 HP) and less than 450 KW (600 HP) and a rated speed of greater than 2,650 revolutions per minute (rpm) are not required to certify such engines until three model years following the model year indicated in this Table 3 for engines in the applicable engine power category.

[71 FR 39172, July 11, 2006, as amended at 76 FR 37972, June 28, 2011]

**Table 4 to Subpart IIII of Part 60—Emission Standards for Stationary Fire Pump Engines**

[As stated in §§60.4202(d) and 60.4205(c), you must comply with the following emission standards for stationary fire pump engines]

<b>Maximum engine power</b>	<b>Model year(s)</b>	<b>NMHC + NO<sub>x</sub></b>	<b>CO</b>	<b>PM</b>
KW<8 (HP<11)	2010 and earlier	10.5 (7.8)	8.0 (6.0)	1.0 (0.75)
	2011 +	7.5 (5.6)		0.40 (0.30)
8≤KW<19 (11≤HP<25)	2010 and earlier	9.5 (7.1)	6.6 (4.9)	0.80 (0.60)
	2011 +	7.5 (5.6)		0.40 (0.30)
19≤KW<37 (25≤HP<50)	2010 and earlier	9.5 (7.1)	5.5 (4.1)	0.80 (0.60)
	2011 +	7.5 (5.6)		0.30 (0.22)
37≤KW<56 (50≤HP<75)	2010 and earlier	10.5 (7.8)	5.0 (3.7)	0.80 (0.60)
	2011 + <sup>1</sup>	4.7 (3.5)		0.40 (0.30)
56≤KW<75 (75≤HP<100)	2010 and earlier	10.5 (7.8)	5.0 (3.7)	0.80 (0.60)
	2011 + <sup>1</sup>	4.7 (3.5)		0.40 (0.30)
75≤KW<130 (100≤HP<175)	2009 and earlier	10.5 (7.8)	5.0 (3.7)	0.80 (0.60)
	2010 + <sup>2</sup>	4.0 (3.0)		0.30 (0.22)
130≤KW<225 (175≤HP<300)	2008 and earlier	10.5 (7.8)	3.5 (2.6)	0.54 (0.40)

Maximum engine power	Model year(s)	NMHC + NO <sub>x</sub>	CO	PM
	2009 + <sup>3</sup>	4.0 (3.0)		0.20 (0.15)
225≤KW<450 (300≤HP<600)	2008 and earlier	10.5 (7.8)	3.5 (2.6)	0.54 (0.40)
	2009 + <sup>3</sup>	4.0 (3.0)		0.20 (0.15)
450≤KW≤560 (600≤HP≤750)	2008 and earlier	10.5 (7.8)	3.5 (2.6)	0.54 (0.40)
	2009 +	4.0 (3.0)		0.20 (0.15)
KW>560 (HP>750)	2007 and earlier	10.5 (7.8)	3.5 (2.6)	0.54 (0.40)
	2008 +	6.4 (4.8)		0.20 (0.15)

<sup>1</sup>For model years 2011-2013, manufacturers, owners and operators of fire pump stationary CI ICE in this engine power category with a rated speed of greater than 2,650 revolutions per minute (rpm) may comply with the emission limitations for 2010 model year engines.

<sup>2</sup>For model years 2010-2012, manufacturers, owners and operators of fire pump stationary CI ICE in this engine power category with a rated speed of greater than 2,650 rpm may comply with the emission limitations for 2009 model year engines.

<sup>3</sup>In model years 2009-2011, manufacturers of fire pump stationary CI ICE in this engine power category with a rated speed of greater than 2,650 rpm may comply with the emission limitations for 2008 model year engines.

**Table 5 to Subpart III of Part 60—Labeling and Recordkeeping Requirements for New Stationary Emergency Engines**

[You must comply with the labeling requirements in §60.4210(f) and the recordkeeping requirements in §60.4214(b) for new emergency stationary CI ICE beginning in the following model years:]

Engine power	Starting model year
19≤KW<56 (25≤HP<75)	2013
56≤KW<130 (75≤HP<175)	2012
KW≥130 (HP≥175)	2011

**Table 6 to Subpart III of Part 60—Optional 3-Mode Test Cycle for Stationary Fire Pump Engines**

[As stated in §60.4210(g), manufacturers of fire pump engines may use the following test cycle for testing fire pump engines:]

Mode No.	Engine speed <sup>1</sup>	Torque (percent) <sup>2</sup>	Weighting factors
1	Rated	100	0.30
2	Rated	75	0.50
3	Rated	50	0.20

<sup>1</sup>Engine speed: ±2 percent of point.

<sup>2</sup>Torque: NFPA certified nameplate HP for 100 percent point. All points should be ±2 percent of engine percent load value.

**Table 7 to Subpart III of Part 60—Requirements for Performance Tests for Stationary CI ICE With a Displacement of  $\geq 30$  Liters per Cylinder**

As stated in §60.4213, you must comply with the following requirements for performance tests for stationary CI ICE with a displacement of  $\geq 30$  liters per cylinder:

Each	Complying with the requirement to	You must	Using	According to the following requirements
1. Stationary CI internal combustion engine with a displacement of $\geq 30$ liters per cylinder	a. Reduce NO <sub>x</sub> emissions by 90 percent or more;	i. Select the sampling port location and number/location of traverse points at the inlet and outlet of the control device;		(a) For NO <sub>x</sub> , O <sub>2</sub> , and moisture measurement, ducts $\leq 6$ inches in diameter may be sampled at a single point located at the duct centroid and ducts $>6$ and $\leq 12$ inches in diameter may be sampled at 3 traverse points located at 16.7, 50.0, and 83.3% of the measurement line ('3-point long line'). If the duct is $>12$ inches in diameter <i>and</i> the sampling port location meets the two and half-diameter criterion of Section 11.1.1 of Method 1 of 40 CFR part 60, appendix A-1, the duct may be sampled at '3-point long line'; otherwise, conduct the stratification testing and select sampling points according to Section 8.1.2 of Method 7E of 40 CFR part 60, appendix A-4.
		ii. Measure O <sub>2</sub> at the inlet and outlet of the control device;	(1) Method 3, 3A, or 3B of 40 CFR part 60, appendix A-2	(b) Measurements to determine O <sub>2</sub> concentration must be made at the same time as the measurements for NO <sub>x</sub> concentration.
		iii. If necessary, measure moisture content at the inlet and outlet of the control device; and	(2) Method 4 of 40 CFR part 60, appendix A-3, Method 320 of 40 CFR part 63, appendix A, or ASTM D 6348-03 (incorporated by reference, see §60.17)	(c) Measurements to determine moisture content must be made at the same time as the measurements for NO <sub>x</sub> concentration.
		iv. Measure NO <sub>x</sub> at the inlet and outlet of the control device.	(3) Method 7E of 40 CFR part 60, appendix A-4, Method 320 of 40 CFR part 63, appendix A, or ASTM D 6348-03 (incorporated by reference, see §60.17)	(d) NO <sub>x</sub> concentration must be at 15 percent O <sub>2</sub> , dry basis. Results of this test consist of the average of the three 1-hour or longer runs.



Each	Complying with the requirement to	You must	Using	According to the following requirements
	b. Limit the concentration of NO <sub>x</sub> in the stationary CI internal combustion engine exhaust.	i. Select the sampling port location and number/location of traverse points at the exhaust of the stationary internal combustion engine;		(a) For NO <sub>x</sub> , O <sub>2</sub> , and moisture measurement, ducts ≤6 inches in diameter may be sampled at a single point located at the duct centroid and ducts >6 and ≤12 inches in diameter may be sampled at 3 traverse points located at 16.7, 50.0, and 83.3% of the measurement line ('3-point long line'). If the duct is >12 inches in diameter <i>and</i> the sampling port location meets the two and half-diameter criterion of Section 11.1.1 of Method 1 of 40 CFR part 60, appendix A-1, the duct may be sampled at '3-point long line'; otherwise, conduct the stratification testing and select sampling points according to Section 8.1.2 of Method 7E of 40 CFR part 60, appendix A-4.
		ii. Determine the O <sub>2</sub> concentration of the stationary internal combustion engine exhaust at the sampling port location;	(1) Method 3, 3A, or 3B of 40 CFR part 60, appendix A-2	(b) Measurements to determine O <sub>2</sub> concentration must be made at the same time as the measurement for NO <sub>x</sub> concentration.
		iii. If necessary, measure moisture content of the stationary internal combustion engine exhaust at the sampling port location; and	(2) Method 4 of 40 CFR part 60, appendix A-3, Method 320 of 40 CFR part 63, appendix A, or ASTM D 6348-03 (incorporated by reference, see §60.17)	(c) Measurements to determine moisture content must be made at the same time as the measurement for NO <sub>x</sub> concentration.
		iv. Measure NO <sub>x</sub> at the exhaust of the stationary internal combustion engine; if using a control device, the sampling site must be located at the outlet of the control device.	(3) Method 7E of 40 CFR part 60, appendix A-4, Method 320 of 40 CFR part 63, appendix A, or ASTM D 6348-03 (incorporated by reference, see §60.17)	(d) NO <sub>x</sub> concentration must be at 15 percent O <sub>2</sub> , dry basis. Results of this test consist of the average of the three 1-hour or longer runs.
	c. Reduce PM emissions by 60 percent or more	i. Select the sampling port location and the number of traverse points;	(1) Method 1 or 1A of 40 CFR part 60, appendix A-1	(a) Sampling sites must be located at the inlet and outlet of the control device.

Each	Complying with the requirement to	You must	Using	According to the following requirements
		ii. Measure O <sub>2</sub> at the inlet and outlet of the control device;	(2) Method 3, 3A, or 3B of 40 CFR part 60, appendix A-2	(b) Measurements to determine O <sub>2</sub> concentration must be made at the same time as the measurements for PM concentration.
		iii. If necessary, measure moisture content at the inlet and outlet of the control device; and	(3) Method 4 of 40 CFR part 60, appendix A-3	(c) Measurements to determine and moisture content must be made at the same time as the measurements for PM concentration.
		iv. Measure PM at the inlet and outlet of the control device.	(4) Method 5 of 40 CFR part 60, appendix A-3	(d) PM concentration must be at 15 percent O <sub>2</sub> , dry basis. Results of this test consist of the average of the three 1-hour or longer runs.
	d. Limit the concentration of PM in the stationary CI internal combustion engine exhaust	i. Select the sampling port location and the number of traverse points;	(1) Method 1 or 1A of 40 CFR part 60, appendix A-1	(a) If using a control device, the sampling site must be located at the outlet of the control device.
		ii. Determine the O <sub>2</sub> concentration of the stationary internal combustion engine exhaust at the sampling port location;	(2) Method 3, 3A, or 3B of 40 CFR part 60, appendix A-2	(b) Measurements to determine O <sub>2</sub> concentration must be made at the same time as the measurements for PM concentration.
		iii. If necessary, measure moisture content of the stationary internal combustion engine exhaust at the sampling port location; and	(3) Method 4 of 40 CFR part 60, appendix A-3	(c) Measurements to determine moisture content must be made at the same time as the measurements for PM concentration.
		iv. Measure PM at the exhaust of the stationary internal combustion engine.	(4) Method 5 of 40 CFR part 60, appendix A-3	(d) PM concentration must be at 15 percent O <sub>2</sub> , dry basis. Results of this test consist of the average of the three 1-hour or longer runs.

**Table 8 to Subpart III of Part 60—Applicability of General Provisions to Subpart III**

[As stated in §60.4218, you must comply with the following applicable General Provisions:]

<b>General Provisions citation</b>	<b>Subject of citation</b>	<b>Applies to subpart</b>	<b>Explanation</b>
§60.1	General applicability of the General Provisions	Yes	
§60.2	Definitions	Yes	Additional terms defined in §60.4219.
§60.3	Units and abbreviations	Yes	
§60.4	Address	Yes	
§60.5	Determination of construction or modification	Yes	
§60.6	Review of plans	Yes	
§60.7	Notification and Recordkeeping	Yes	Except that §60.7 only applies as specified in §60.4214(a).
§60.8	Performance tests	Yes	Except that §60.8 only applies to stationary CI ICE with a displacement of (≥30 liters per cylinder and engines that are not certified.
§60.9	Availability of information	Yes	
§60.10	State Authority	Yes	
§60.11	Compliance with standards and maintenance requirements	No	Requirements are specified in subpart III.
§60.12	Circumvention	Yes	
§60.13	Monitoring requirements	Yes	Except that §60.13 only applies to stationary CI ICE with a displacement of (≥30 liters per cylinder.
§60.14	Modification	Yes	
§60.15	Reconstruction	Yes	
§60.16	Priority list	Yes	
§60.17	Incorporations by reference	Yes	
§60.18	General control device requirements	No	
§60.19	General notification and reporting requirements	Yes	

## Attachment C

### Federally Enforceable State Operating Permit (FESOP) No: 129-36688-00021

[Downloaded from the eCFR on June 1, 2023]

#### Electronic Code of Federal Regulations

#### Title 40: Protection of Environment

#### PART 63—NATIONAL EMISSION STANDARDS FOR HAZARDOUS AIR POLLUTANTS FOR SOURCE CATEGORIES

#### Subpart ZZZZ—National Emissions Standards for Hazardous Air Pollutants for Stationary Reciprocating Internal Combustion Engines

SOURCE: 69 FR 33506, June 15, 2004, unless otherwise noted.

#### What This Subpart Covers

#### § 63.6580 What is the purpose of subpart ZZZZ?

Subpart ZZZZ establishes national emission limitations and operating limitations for hazardous air pollutants (HAP) emitted from stationary reciprocating internal combustion engines (RICE) located at major and area sources of HAP emissions. This subpart also establishes requirements to demonstrate initial and continuous compliance with the emission limitations and operating limitations.

[73 FR 3603, Jan. 18, 2008]

#### § 63.6585 Am I subject to this subpart?

You are subject to this subpart if you own or operate a stationary RICE at a major or area source of HAP emissions, except if the stationary RICE is being tested at a stationary RICE test cell/stand.

- (a) A stationary RICE is any internal combustion engine which uses reciprocating motion to convert heat energy into mechanical work and which is not mobile. Stationary RICE differ from mobile RICE in that a stationary RICE is not a non-road engine as defined at 40 CFR 1068.30, and is not used to propel a motor vehicle or a vehicle used solely for competition.
- (b) A major source of HAP emissions is a plant site that emits or has the potential to emit any single HAP at a rate of 10 tons (9.07 megagrams) or more per year or any combination of HAP at a rate of 25 tons (22.68 megagrams) or more per year, except that for oil and gas production facilities, a major source of HAP emissions is determined for each surface site.
- (c) An area source of HAP emissions is a source that is not a major source.
- (d) If you are an owner or operator of an area source subject to this subpart, your status as an entity subject to a standard or other requirements under this subpart does not subject you to the obligation to obtain a permit under 40 CFR part 70 or 71, provided you are not required to obtain a permit under 40 CFR 70.3(a) or 40 CFR 71.3(a) for a reason other than your status as an area source under this subpart. Notwithstanding the previous sentence, you must continue to comply with the provisions of this subpart as applicable.
- (e) If you are an owner or operator of a stationary RICE used for national security purposes, you may be eligible to request an exemption from the requirements of this subpart as described in 40 CFR part 1068, subpart C.

(f) The emergency stationary RICE listed in paragraphs (f)(1) through (3) of this section are not subject to this subpart. The stationary RICE must meet the definition of an emergency stationary RICE in § 63.6675, which includes operating according to the provisions specified in § 63.6640(f).

(1) Existing residential emergency stationary RICE located at an area source of HAP emissions that do not operate for the purpose specified in § 63.6640(f)(4)(ii).

(2) Existing commercial emergency stationary RICE located at an area source of HAP emissions that do not operate for the purpose specified in § 63.6640(f)(4)(ii).

(3) Existing institutional emergency stationary RICE located at an area source of HAP emissions that do not operate for the purpose specified in § 63.6640(f)(4)(ii).

[69 FR 33506, June 15, 2004, as amended at 73 FR 3603, Jan. 18, 2008; 78 FR 6700, Jan. 30, 2013; 87 FR 48607, Aug. 10, 2022]

**§ 63.6590 What parts of my plant does this subpart cover?**

This subpart applies to each affected source.

(a) **Affected source.** An affected source is any existing, new, or reconstructed stationary RICE located at a major or area source of HAP emissions, excluding stationary RICE being tested at a stationary RICE test cell/stand.

**(1) Existing stationary RICE.**

(i) For stationary RICE with a site rating of more than 500 brake horsepower (HP) located at a major source of HAP emissions, a stationary RICE is existing if you commenced construction or reconstruction of the stationary RICE before December 19, 2002.

(ii) For stationary RICE with a site rating of less than or equal to 500 brake HP located at a major source of HAP emissions, a stationary RICE is existing if you commenced construction or reconstruction of the stationary RICE before June 12, 2006.

(iii) For stationary RICE located at an area source of HAP emissions, a stationary RICE is existing if you commenced construction or reconstruction of the stationary RICE before June 12, 2006.

(iv) A change in ownership of an existing stationary RICE does not make that stationary RICE a new or reconstructed stationary RICE.

**(2) New stationary RICE.**

(i) A stationary RICE with a site rating of more than 500 brake HP located at a major source of HAP emissions is new if you commenced construction of the stationary RICE on or after December 19, 2002.

(ii) A stationary RICE with a site rating of equal to or less than 500 brake HP located at a major source of HAP emissions is new if you commenced construction of the stationary RICE on or after June 12, 2006.

(iii) A stationary RICE located at an area source of HAP emissions is new if you commenced construction of the stationary RICE on or after June 12, 2006.

**(3) Reconstructed stationary RICE.**

(i) A stationary RICE with a site rating of more than 500 brake HP located at a major source of HAP emissions is reconstructed if you meet the definition of reconstruction in § 63.2 and reconstruction is commenced on or after December 19, 2002.

(ii) A stationary RICE with a site rating of equal to or less than 500 brake HP located at a major source of HAP emissions is reconstructed if you meet the definition of reconstruction in § 63.2 and reconstruction is commenced on or after June 12, 2006.

(iii) A stationary RICE located at an area source of HAP emissions is reconstructed if you meet the definition of reconstruction in § 63.2 and reconstruction is commenced on or after June 12, 2006.

**(b) Stationary RICE subject to limited requirements.**

(1) An affected source which meets either of the criteria in paragraphs (b)(1)(i) through (ii) of this section does not have to meet the requirements of this subpart and of subpart A of this part except for the initial notification requirements of § 63.6645(f).

(i) The stationary RICE is a new or reconstructed emergency stationary RICE with a site rating of more than 500 brake HP located at a major source of HAP emissions.

(ii) The stationary RICE is a new or reconstructed limited use stationary RICE with a site rating of more than 500 brake HP located at a major source of HAP emissions.

(2) A new or reconstructed stationary RICE with a site rating of more than 500 brake HP located at a major source of HAP emissions which combusts landfill or digester gas equivalent to 10 percent or more of the gross heat input on an annual basis must meet the initial notification requirements of § 63.6645(f) and the requirements of §§ 63.6625(c), 63.6650(g), and 63.6655(c). These stationary RICE do not have to meet the emission limitations and operating limitations of this subpart.

(3) The following stationary RICE do not have to meet the requirements of this subpart and of subpart A of this part, including initial notification requirements:

(i) Existing spark ignition 2 stroke lean burn (2SLB) stationary RICE with a site rating of more than 500 brake HP located at a major source of HAP emissions;

(ii) Existing spark ignition 4 stroke lean burn (4SLB) stationary RICE with a site rating of more than 500 brake HP located at a major source of HAP emissions;

(iii) Existing emergency stationary RICE with a site rating of more than 500 brake HP located at a major source of HAP emissions.

(iv) Existing limited use stationary RICE with a site rating of more than 500 brake HP located at a major source of HAP emissions;

(v) Existing stationary RICE with a site rating of more than 500 brake HP located at a major source of HAP emissions that combusts landfill gas or digester gas equivalent to 10 percent or more of the gross heat input on an annual basis;

**(c) Stationary RICE subject to Regulations under 40 CFR Part 60.** An affected source that meets any of the criteria in paragraphs (c)(1) through (7) of this section must meet the requirements of this part by meeting the requirements of 40 CFR part 60 subpart IIII, for compression ignition engines or 40 CFR part 60 subpart JJJJ, for spark ignition engines. No further requirements apply for such engines under this part.

(1) A new or reconstructed stationary RICE located at an area source;

(2) A new or reconstructed 2SLB stationary RICE with a site rating of less than or equal to 500 brake HP located at a major source of HAP emissions;

(3) A new or reconstructed 4SLB stationary RICE with a site rating of less than 250 brake HP located at a major source of HAP emissions;

(4) A new or reconstructed spark ignition 4 stroke rich burn (4SRB) stationary RICE with a site rating of less than or equal to 500 brake HP located at a major source of HAP emissions;

(5) A new or reconstructed stationary RICE with a site rating of less than or equal to 500 brake HP located at a major source of HAP emissions which combusts landfill or digester gas equivalent to 10 percent or more of the gross heat input on an annual basis;

(6) A new or reconstructed emergency or limited use stationary RICE with a site rating of less than or equal to 500 brake HP located at a major source of HAP emissions;

(7) A new or reconstructed compression ignition (CI) stationary RICE with a site rating of less than or equal to 500 brake HP located at a major source of HAP emissions.

[69 FR 33506, June 15, 2004, as amended at 73 FR 3604, Jan. 18, 2008; 75 FR 9674, Mar. 3, 2010; 75 FR 37733, June 30, 2010; 75 FR 51588, Aug. 20, 2010; 78 FR 6700, Jan. 30, 2013; 87 FR 48607, Aug. 10, 2022]

**§ 63.6595 When do I have to comply with this subpart?**

**(a) *Affected sources.***

(1) If you have an existing stationary RICE, excluding existing non-emergency CI stationary RICE, with a site rating of more than 500 brake HP located at a major source of HAP emissions, you must comply with the applicable emission limitations, operating limitations and other requirements no later than June 15, 2007. If you have an existing non-emergency CI stationary RICE with a site rating of more than 500 brake HP located at a major source of HAP emissions, an existing stationary CI RICE with a site rating of less than or equal to 500 brake HP located at a major source of HAP emissions, or an existing stationary CI RICE located at an area source of HAP emissions, you must comply with the applicable emission limitations, operating limitations, and other requirements no later than May 3, 2013. If you have an existing stationary SI RICE with a site rating of less than or equal to 500 brake HP located at a major source of HAP emissions, or an existing stationary SI RICE located at an area source of HAP emissions, you must comply with the applicable emission limitations, operating limitations, and other requirements no later than October 19, 2013.

(2) If you start up your new or reconstructed stationary RICE with a site rating of more than 500 brake HP located at a major source of HAP emissions before August 16, 2004, you must comply with the applicable emission limitations and operating limitations in this subpart no later than August 16, 2004.

(3) If you start up your new or reconstructed stationary RICE with a site rating of more than 500 brake HP located at a major source of HAP emissions after August 16, 2004, you must comply with the applicable emission limitations and operating limitations in this subpart upon startup of your affected source.

(4) If you start up your new or reconstructed stationary RICE with a site rating of less than or equal to 500 brake HP located at a major source of HAP emissions before January 18, 2008, you must comply with the applicable emission limitations and operating limitations in this subpart no later than January 18, 2008.

(5) If you start up your new or reconstructed stationary RICE with a site rating of less than or equal to 500 brake HP located at a major source of HAP emissions after January 18, 2008, you must comply with the applicable emission limitations and operating limitations in this subpart upon startup of your affected source.

(6) If you start up your new or reconstructed stationary RICE located at an area source of HAP emissions before January 18, 2008, you must comply with the applicable emission limitations and operating limitations in this subpart no later than January 18, 2008.

(7) If you start up your new or reconstructed stationary RICE located at an area source of HAP emissions after January 18, 2008, you must comply with the applicable emission limitations and operating limitations in this subpart upon startup of your affected source.

(b) **Area sources that become major sources.** If you have an area source that increases its emissions or its potential to emit such that it becomes a major source of HAP, the compliance dates in paragraphs (b)(1) and (2) of this section apply to you.

(1) Any stationary RICE for which construction or reconstruction is commenced after the date when your area source becomes a major source of HAP must be in compliance with this subpart upon startup of your affected source.

(2) Any stationary RICE for which construction or reconstruction is commenced before your area source becomes a major source of HAP must be in compliance with the provisions of this subpart that are applicable to RICE located at major sources within 3 years after your area source becomes a major source of HAP.

(c) If you own or operate an affected source, you must meet the applicable notification requirements in § 63.6645 and in 40 CFR part 63, subpart A.

[69 FR 33506, June 15, 2004, as amended at 73 FR 3604, Jan. 18, 2008; 75 FR 9675, Mar. 3, 2010; 75 FR 51589, Aug. 20, 2010; 78 FR 6701, Jan. 30, 2013]

### **Emission and Operating Limitations**

#### **§ 63.6600 What emission limitations and operating limitations must I meet if I own or operate a stationary RICE with a site rating of more than 500 brake HP located at a major source of HAP emissions?**

Compliance with the numerical emission limitations established in this subpart is based on the results of testing the average of three 1-hour runs using the testing requirements and procedures in § 63.6620 and Table 4 to this subpart.

(a) If you own or operate an existing, new, or reconstructed spark ignition 4SRB stationary RICE with a site rating of more than 500 brake HP located at a major source of HAP emissions, you must comply with the emission limitations in Table 1a to this subpart and the operating limitations in Table 1b to this subpart which apply to you.

(b) If you own or operate a new or reconstructed 2SLB stationary RICE with a site rating of more than 500 brake HP located at major source of HAP emissions, a new or reconstructed 4SLB stationary RICE with a site rating of more than 500 brake HP located at major source of HAP emissions, or a new or reconstructed CI stationary RICE with a site rating of more than 500 brake HP located at a major source of HAP emissions, you must comply with the emission limitations in Table 2a to this subpart and the operating limitations in Table 2b to this subpart which apply to you.

(c) If you own or operate any of the following stationary RICE with a site rating of more than 500 brake HP located at a major source of HAP emissions, you do not need to comply with the emission limitations in Tables 1a, 2a, 2c, and 2d to this subpart or operating limitations in Tables 1b and 2b to this subpart: an existing 2SLB stationary RICE; an existing 4SLB stationary RICE; a stationary RICE that combusts landfill gas or digester gas equivalent to 10 percent or more of the gross heat input on an annual basis; an emergency stationary RICE; or a limited use stationary RICE.

(d) If you own or operate an existing non-emergency stationary CI RICE with a site rating of more than 500 brake HP located at a major source of HAP emissions, you must comply with the emission limitations in Table 2c to this subpart and the operating limitations in Table 2b to this subpart which apply to you.

[73 FR 3605, Jan. 18, 2008, as amended at 75 FR 9675, Mar. 3, 2010]



**§ 63.6601 What emission limitations must I meet if I own or operate a new or reconstructed 4SLB stationary RICE with a site rating of greater than or equal to 250 brake HP and less than or equal to 500 brake HP located at a major source of HAP emissions?**

Compliance with the numerical emission limitations established in this subpart is based on the results of testing the average of three 1-hour runs using the testing requirements and procedures in § 63.6620 and Table 4 to this subpart. If you own or operate a new or reconstructed 4SLB stationary RICE with a site rating of greater than or equal to 250 and less than or equal to 500 brake HP located at major source of HAP emissions manufactured on or after January 1, 2008, you must comply with the emission limitations in Table 2a to this subpart and the operating limitations in Table 2b to this subpart which apply to you.

[73 FR 3605, Jan. 18, 2008, as amended at 75 FR 9675, Mar. 3, 2010; 75 FR 51589, Aug. 20, 2010]

**§ 63.6602 What emission limitations and other requirements must I meet if I own or operate an existing stationary RICE with a site rating of equal to or less than 500 brake HP located at a major source of HAP emissions?**

If you own or operate an existing stationary RICE with a site rating of equal to or less than 500 brake HP located at a major source of HAP emissions, you must comply with the emission limitations and other requirements in Table 2c to this subpart which apply to you. Compliance with the numerical emission limitations established in this subpart is based on the results of testing the average of three 1-hour runs using the testing requirements and procedures in § 63.6620 and Table 4 to this subpart.

[78 FR 6701, Jan. 30, 2013]

**§ 63.6603 What emission limitations, operating limitations, and other requirements must I meet if I own or operate an existing stationary RICE located at an area source of HAP emissions?**

Compliance with the numerical emission limitations established in this subpart is based on the results of testing the average of three 1-hour runs using the testing requirements and procedures in § 63.6620 and Table 4 to this subpart.

(a) If you own or operate an existing stationary RICE located at an area source of HAP emissions, you must comply with the requirements in Table 2d to this subpart and the operating limitations in Table 2b to this subpart that apply to you.

(b) If you own or operate an existing stationary non-emergency CI RICE with a site rating of more than 300 HP located at an area source of HAP that meets either paragraph (b)(1) or (2) of this section, you do not have to meet the numerical CO emission limitations specified in Table 2d of this subpart. Existing stationary non-emergency CI RICE with a site rating of more than 300 HP located at an area source of HAP that meet either paragraph (b)(1) or (2) of this section must meet the management practices that are shown for stationary non-emergency CI RICE with a site rating of less than or equal to 300 HP in Table 2d of this subpart.

(1) The area source is located in an area of Alaska that is not accessible by the Federal Aid Highway System (FAHS).

(2) The stationary RICE is located at an area source that meets paragraphs (b)(2)(i), (ii), and (iii) of this section.

(i) The only connection to the FAHS is through the Alaska Marine Highway System (AMHS), or the stationary RICE operation is within an isolated grid in Alaska that is not connected to the statewide electrical grid referred to as the Alaska Railbelt Grid.

(ii) At least 10 percent of the power generated by the stationary RICE on an annual basis is used for residential purposes.

(iii) The generating capacity of the area source is less than 12 megawatts, or the stationary RICE is used exclusively for backup power for renewable energy.

(c) If you own or operate an existing stationary non-emergency CI RICE with a site rating of more than 300 HP located on an offshore vessel that is an area source of HAP and is a nonroad vehicle that is an Outer Continental Shelf (OCS) source as defined in 40 CFR 55.2, you do not have to meet the numerical CO emission limitations specified in Table 2d of this subpart. You must meet all of the following management practices:

(1) Change oil every 1,000 hours of operation or annually, whichever comes first. Sources have the option to utilize an oil analysis program as described in § 63.6625(i) in order to extend the specified oil change requirement.

(2) Inspect and clean air filters every 750 hours of operation or annually, whichever comes first, and replace as necessary.

(3) Inspect fuel filters and belts, if installed, every 750 hours of operation or annually, whichever comes first, and replace as necessary.

(4) Inspect all flexible hoses every 1,000 hours of operation or annually, whichever comes first, and replace as necessary.

(d) If you own or operate an existing non-emergency CI RICE with a site rating of more than 300 HP located at an area source of HAP emissions that is certified to the Tier 1 or Tier 2 emission standards in Table 1 of 40 CFR 89.112 and that is subject to an enforceable state or local standard that requires the engine to be replaced no later than June 1, 2018, you may until January 1, 2015, or 12 years after the installation date of the engine (whichever is later), but not later than June 1, 2018, choose to comply with the management practices that are shown for stationary non-emergency CI RICE with a site rating of less than or equal to 300 HP in Table 2d of this subpart instead of the applicable emission limitations in Table 2d, operating limitations in Table 2b, and crankcase ventilation system requirements in § 63.6625(g). You must comply with the emission limitations in Table 2d and operating limitations in Table 2b that apply for non-emergency CI RICE with a site rating of more than 300 HP located at an area source of HAP emissions by January 1, 2015, or 12 years after the installation date of the engine (whichever is later), but not later than June 1, 2018. You must also comply with the crankcase ventilation system requirements in § 63.6625(g) by January 1, 2015, or 12 years after the installation date of the engine (whichever is later), but not later than June 1, 2018.

(e) If you own or operate an existing non-emergency CI RICE with a site rating of more than 300 HP located at an area source of HAP emissions that is certified to the Tier 3 (Tier 2 for engines above 560 kilowatt (kW)) emission standards in Table 1 of 40 CFR 89.112, you may comply with the requirements under this part by meeting the requirements for Tier 3 engines (Tier 2 for engines above 560 kW) in 40 CFR part 60 subpart IIII instead of the emission limitations and other requirements that would otherwise apply under this part for existing non-emergency CI RICE with a site rating of more than 300 HP located at an area source of HAP emissions.

(f) An existing non-emergency SI 4SLB and 4SRB stationary RICE with a site rating of more than 500 HP located at area sources of HAP must meet the definition of remote stationary RICE in § 63.6675 on the initial compliance date for the engine, October 19, 2013, in order to be considered a remote stationary RICE under this subpart. Owners and operators of existing non-emergency SI 4SLB and 4SRB stationary RICE with a site rating of more than 500 HP located at area sources of HAP that meet the definition of remote stationary RICE in § 63.6675 of this subpart as of October 19, 2013 must evaluate the status of their stationary RICE every 12 months. Owners and operators must keep records of the initial and annual evaluation of the status of the engine. If the evaluation indicates that the stationary RICE no longer meets the definition of remote stationary RICE in § 63.6675 of this subpart, the owner or operator must comply with all of the requirements for existing non-emergency SI 4SLB and 4SRB stationary RICE with a site rating of more than 500 HP located at area sources of HAP that are not remote stationary RICE within 1 year of the evaluation.

[75 FR 9675, Mar. 3, 2010, as amended at 75 FR 51589, Aug. 20, 2010; 76 FR 12866, Mar. 9, 2011; 78 FR 6701, Jan. 30, 2013]

**§ 63.6604 What fuel requirements must I meet if I own or operate a stationary CI RICE?**

(a) If you own or operate an existing non-emergency, non-black start CI stationary RICE with a site rating of more than 300 brake HP with a displacement of less than 30 liters per cylinder that uses diesel fuel, you must use diesel fuel that meets the requirements in 40 CFR 1090.305 for nonroad diesel fuel.

(b) Beginning January 1, 2015, if you own or operate an existing emergency CI stationary RICE with a site rating of more than 100 brake HP and a displacement of less than 30 liters per cylinder that uses diesel fuel and operates for the purpose specified in § 63.6640(f)(4)(ii), you must use diesel fuel that meets the requirements in 40 CFR 1090.305 for nonroad diesel fuel, except that any existing diesel fuel purchased (or otherwise obtained) prior to January 1, 2015, may be used until depleted.

(c) [Reserved]

(d) Existing CI stationary RICE located in Guam, American Samoa, the Commonwealth of the Northern Mariana Islands, at area sources in areas of Alaska that meet either § 63.6603(b)(1) or § 63.6603(b)(2), or are on offshore vessels that meet § 63.6603(c) are exempt from the requirements of this section.

[78 FR 6702, Jan. 30, 2013, as amended at 85 FR 78463, Dec. 4, 2020; 87 FR 48607, Aug. 10, 2022]

**General Compliance Requirements**

**§ 63.6605 What are my general requirements for complying with this subpart?**

(a) You must be in compliance with the emission limitations, operating limitations, and other requirements in this subpart that apply to you at all times.

(b) At all times you must operate and maintain any affected source, including associated air pollution control equipment and monitoring equipment, in a manner consistent with safety and good air pollution control practices for minimizing emissions. The general duty to minimize emissions does not require you to make any further efforts to reduce emissions if levels required by this standard have been achieved. Determination of whether such operation and maintenance procedures are being used will be based on information available to the Administrator which may include, but is not limited to, monitoring results, review of operation and maintenance procedures, review of operation and maintenance records, and inspection of the source.

[75 FR 9675, Mar. 3, 2010, as amended at 78 FR 6702, Jan. 30, 2013]

**Testing and Initial Compliance Requirements**

**§ 63.6610 By what date must I conduct the initial performance tests or other initial compliance demonstrations if I own or operate a stationary RICE with a site rating of more than 500 brake HP located at a major source of HAP emissions?**

If you own or operate a stationary RICE with a site rating of more than 500 brake HP located at a major source of HAP emissions you are subject to the requirements of this section.

(a) You must conduct the initial performance test or other initial compliance demonstrations in Table 4 to this subpart that apply to you within 180 days after the compliance date that is specified for your stationary RICE in § 63.6595 and according to the provisions in § 63.7(a)(2).

(b) If you commenced construction or reconstruction between December 19, 2002 and June 15, 2004 and own or operate stationary RICE with a site rating of more than 500 brake HP located at a major source of HAP emissions, you must demonstrate initial compliance with either the proposed emission limitations or the promulgated emission limitations no later than February 10, 2005 or no later than 180 days after startup of the source, whichever is later, according to § 63.7(a)(2)(ix).

(c) If you commenced construction or reconstruction between December 19, 2002 and June 15, 2004 and own or operate stationary RICE with a site rating of more than 500 brake HP located at a major source of HAP emissions, and you chose to comply with the proposed emission limitations when demonstrating initial compliance, you must conduct a second performance test to demonstrate compliance with the promulgated emission limitations by December 13, 2007 or after startup of the source, whichever is later, according to § 63.7(a)(2)(ix).

(d) An owner or operator is not required to conduct an initial performance test on units for which a performance test has been previously conducted, but the test must meet all of the conditions described in paragraphs (d)(1) through (5) of this section.

(1) The test must have been conducted using the same methods specified in this subpart, and these methods must have been followed correctly.

(2) The test must not be older than 2 years.

(3) The test must be reviewed and accepted by the Administrator.

(4) Either no process or equipment changes must have been made since the test was performed, or the owner or operator must be able to demonstrate that the results of the performance test, with or without adjustments, reliably demonstrate compliance despite process or equipment changes.

(5) The test must be conducted at any load condition within plus or minus 10 percent of 100 percent load.

[69 FR 33506, June 15, 2004, as amended at 73 FR 3605, Jan. 18, 2008]

**§ 63.6611 By what date must I conduct the initial performance tests or other initial compliance demonstrations if I own or operate a new or reconstructed 4SLB SI stationary RICE with a site rating of greater than or equal to 250 and less than or equal to 500 brake HP located at a major source of HAP emissions?**

If you own or operate a new or reconstructed 4SLB stationary RICE with a site rating of greater than or equal to 250 and less than or equal to 500 brake HP located at a major source of HAP emissions, you must conduct an initial performance test within 240 days after the compliance date that is specified for your stationary RICE in § 63.6595 and according to the provisions specified in Table 4 to this subpart, as appropriate.

[73 FR 3605, Jan. 18, 2008, as amended at 75 FR 51589, Aug. 20, 2010]

**§ 63.6612 By what date must I conduct the initial performance tests or other initial compliance demonstrations if I own or operate an existing stationary RICE with a site rating of less than or equal to 500 brake HP located at a major source of HAP emissions or an existing stationary RICE located at an area source of HAP emissions?**

If you own or operate an existing stationary RICE with a site rating of less than or equal to 500 brake HP located at a major source of HAP emissions or an existing stationary RICE located at an area source of HAP emissions you are subject to the requirements of this section.

(a) You must conduct any initial performance test or other initial compliance demonstration according to Tables 4 and 5 to this subpart that apply to you within 180 days after the compliance date that is specified for your stationary RICE in § 63.6595 and according to the provisions in § 63.7(a)(2).

(b) An owner or operator is not required to conduct an initial performance test on a unit for which a performance test has been previously conducted, but the test must meet all of the conditions described in paragraphs (b)(1) through (4) of this section.

(1) The test must have been conducted using the same methods specified in this subpart, and these methods must have been followed correctly.

(2) The test must not be older than 2 years.

(3) The test must be reviewed and accepted by the Administrator.

(4) Either no process or equipment changes must have been made since the test was performed, or the owner or operator must be able to demonstrate that the results of the performance test, with or without adjustments, reliably demonstrate compliance despite process or equipment changes.

[75 FR 9676, Mar. 3, 2010, as amended at 75 FR 51589, Aug. 20, 2010]

**§ 63.6615 When must I conduct subsequent performance tests?**

If you must comply with the emission limitations and operating limitations, you must conduct subsequent performance tests as specified in Table 3 of this subpart.

**§ 63.6620 What performance tests and other procedures must I use?**

(a) You must conduct each performance test in Tables 3 and 4 of this subpart that applies to you.

(b) Each performance test must be conducted according to the requirements that this subpart specifies in Table 4 to this subpart. If you own or operate a non-operational stationary RICE that is subject to performance testing, you do not need to start up the engine solely to conduct the performance test. Owners and operators of a non-operational engine can conduct the performance test when the engine is started up again. The test must be conducted at any load condition within plus or minus 10 percent of 100 percent load for the stationary RICE listed in paragraphs (b)(1) through (4) of this section.

(1) Non-emergency 4SRB stationary RICE with a site rating of greater than 500 brake HP located at a major source of HAP emissions.

(2) New non-emergency 4SLB stationary RICE with a site rating of greater than or equal to 250 brake HP located at a major source of HAP emissions.

(3) New non-emergency 2SLB stationary RICE with a site rating of greater than 500 brake HP located at a major source of HAP emissions.

(4) New non-emergency CI stationary RICE with a site rating of greater than 500 brake HP located at a major source of HAP emissions.

(c) [Reserved]

(d) You must conduct three separate test runs for each performance test required in this section, as specified in § 63.7(e)(3). Each test run must last at least 1 hour, unless otherwise specified in this subpart.

(e)

(1) You must use Equation 1 of this section to determine compliance with the percent reduction requirement:

$$\frac{C_i - C_o}{C_i} \times 100 = R \quad (\text{Eq. 1})$$

Where:

C<sub>i</sub> = concentration of carbon monoxide (CO), total hydrocarbons (THC), or formaldehyde at the control device inlet,

$C_o$  = concentration of CO, THC, or formaldehyde at the control device outlet, and

R = percent reduction of CO, THC, or formaldehyde emissions.

(2) You must normalize the CO, THC, or formaldehyde concentrations at the inlet and outlet of the control device to a dry basis and to 15 percent oxygen, or an equivalent percent carbon dioxide (CO<sub>2</sub>). If pollutant concentrations are to be corrected to 15 percent oxygen and CO<sub>2</sub> concentration is measured in lieu of oxygen concentration measurement, a CO<sub>2</sub> correction factor is needed. Calculate the CO<sub>2</sub> correction factor as described in paragraphs (e)(2)(i) through (iii) of this section.

(i) Calculate the fuel-specific  $F_o$  value for the fuel burned during the test using values obtained from Method 19, Section 5.2, and the following equation:

$$F_o = \frac{0.209 F_d}{F_c} \quad (\text{Eq. 2})$$

Where:

$F_o$  = Fuel factor based on the ratio of oxygen volume to the ultimate CO<sub>2</sub> volume produced by the fuel at zero percent excess air.

0.209 = Fraction of air that is oxygen, percent/100.

$F_d$  = Ratio of the volume of dry effluent gas to the gross calorific value of the fuel from Method 19, dsm<sup>3</sup>/J (dscf/10<sup>6</sup> Btu).

$F_c$  = Ratio of the volume of CO<sub>2</sub> produced to the gross calorific value of the fuel from Method 19, dsm<sup>3</sup>/J (dscf/10<sup>6</sup> Btu)

(ii) Calculate the CO<sub>2</sub> correction factor for correcting measurement data to 15 percent O<sub>2</sub>, as follows:

$$X_{CO_2} = \frac{5.9}{F_o} \quad (\text{Eq. 3})$$

Where:

$X_{CO_2}$  = CO<sub>2</sub> correction factor, percent.

5.9 = 20.9 percent O<sub>2</sub> - 15 percent O<sub>2</sub>, the defined O<sub>2</sub> correction value, percent.

(iii) Calculate the CO, THC, and formaldehyde gas concentrations adjusted to 15 percent O<sub>2</sub> using CO<sub>2</sub> as follows:

$$C_{adj} = C_d \frac{X_{CO_2}}{\%CO_2} \quad (\text{Eq. 4})$$

Where:

$C_{adj}$  = Calculated concentration of CO, THC, or formaldehyde adjusted to 15 percent O<sub>2</sub>.

$C_d$  = Measured concentration of CO, THC, or formaldehyde, uncorrected.

$X_{CO_2}$  = CO<sub>2</sub> correction factor, percent.

%CO<sub>2</sub> = Measured CO<sub>2</sub> concentration measured, dry basis, percent.

(f) If you comply with the emission limitation to reduce CO and you are not using an oxidation catalyst, if you comply with the emission limitation to reduce formaldehyde and you are not using NSCR, or if you comply with the emission limitation to limit the concentration of formaldehyde in the stationary RICE exhaust and you are not using an oxidation catalyst or NSCR, you must petition the Administrator for operating limitations to be established during the initial performance test and continuously monitored thereafter; or for approval of no operating limitations. You must not conduct the initial performance test until after the petition has been approved by the Administrator.

(g) If you petition the Administrator for approval of operating limitations, your petition must include the information described in paragraphs (g)(1) through (5) of this section.

(1) Identification of the specific parameters you propose to use as operating limitations;

(2) A discussion of the relationship between these parameters and HAP emissions, identifying how HAP emissions change with changes in these parameters, and how limitations on these parameters will serve to limit HAP emissions;

(3) A discussion of how you will establish the upper and/or lower values for these parameters which will establish the limits on these parameters in the operating limitations;

(4) A discussion identifying the methods you will use to measure and the instruments you will use to monitor these parameters, as well as the relative accuracy and precision of these methods and instruments; and

(5) A discussion identifying the frequency and methods for recalibrating the instruments you will use for monitoring these parameters.

(h) If you petition the Administrator for approval of no operating limitations, your petition must include the information described in paragraphs (h)(1) through (7) of this section.

(1) Identification of the parameters associated with operation of the stationary RICE and any emission control device which could change intentionally (e.g., operator adjustment, automatic controller adjustment, etc.) or unintentionally (e.g., wear and tear, error, etc.) on a routine basis or over time;

(2) A discussion of the relationship, if any, between changes in the parameters and changes in HAP emissions;

(3) For the parameters which could change in such a way as to increase HAP emissions, a discussion of whether establishing limitations on the parameters would serve to limit HAP emissions;

(4) For the parameters which could change in such a way as to increase HAP emissions, a discussion of how you could establish upper and/or lower values for the parameters which would establish limits on the parameters in operating limitations;

(5) For the parameters, a discussion identifying the methods you could use to measure them and the instruments you could use to monitor them, as well as the relative accuracy and precision of the methods and instruments;

(6) For the parameters, a discussion identifying the frequency and methods for recalibrating the instruments you could use to monitor them; and

(7) A discussion of why, from your point of view, it is infeasible or unreasonable to adopt the parameters as operating limitations.

(i) The engine percent load during a performance test must be determined by documenting the calculations, assumptions, and measurement devices used to measure or estimate the percent load in a specific application. A written report of the average percent load determination must be included in the notification of compliance status. The following information must be included in the written report: the engine model number, the engine manufacturer, the year of purchase, the manufacturer's site-rated brake horsepower, the ambient temperature, pressure, and humidity during the performance test, and all assumptions that were made to estimate or calculate percent load during the performance test must be clearly explained. If measurement devices such as flow meters, kilowatt meters, beta analyzers, stain gauges, etc. are used, the model number of the measurement device, and an estimate of its accurate in percentage of true value must be provided.

[69 FR 33506, June 15, 2004, as amended at 75 FR 9676, Mar. 3, 2010; 78 FR 6702, Jan. 30, 2013]

**§ 63.6625 What are my monitoring, installation, collection, operation, and maintenance requirements?**

(a) If you elect to install a CEMS as specified in Table 5 of this subpart, you must install, operate, and maintain a CEMS to monitor CO and either O<sub>2</sub> or CO<sub>2</sub> according to the requirements in paragraphs (a)(1) through (4) of this section. If you are meeting a requirement to reduce CO emissions, the CEMS must be installed at both the inlet and outlet of the control device. If you are meeting a requirement to limit the concentration of CO, the CEMS must be installed at the outlet of the control device.

(1) Each CEMS must be installed, operated, and maintained according to the applicable performance specifications of 40 CFR part 60, appendix B.

(2) You must conduct an initial performance evaluation and an annual relative accuracy test audit (RATA) of each CEMS according to the requirements in § 63.8 and according to the applicable performance specifications of 40 CFR part 60, appendix B as well as daily and periodic data quality checks in accordance with 40 CFR part 60, appendix F, procedure 1.

(3) As specified in § 63.8(c)(4)(ii), each CEMS must complete a minimum of one cycle of operation (sampling, analyzing, and data recording) for each successive 15-minute period. You must have at least two data points, with each representing a different 15-minute period, to have a valid hour of data.

(4) The CEMS data must be reduced as specified in § 63.8(g)(2) and recorded in parts per million or parts per billion (as appropriate for the applicable limitation) at 15 percent oxygen or the equivalent CO<sub>2</sub> concentration.

(b) If you are required to install a continuous parameter monitoring system (CPMS) as specified in Table 5 of this subpart, you must install, operate, and maintain each CPMS according to the requirements in paragraphs (b)(1) through (6) of this section. For an affected source that is complying with the emission limitations and operating limitations on March 9, 2011, the requirements in paragraph (b) of this section are applicable September 6, 2011.

(1) You must prepare a site-specific monitoring plan that addresses the monitoring system design, data collection, and the quality assurance and quality control elements outlined in paragraphs (b)(1)(i) through (v) of this section and in § 63.8(d). As specified in § 63.8(f)(4), you may request approval of monitoring system quality assurance and quality control procedures alternative to those specified in paragraphs (b)(1) through (5) of this section in your site-specific monitoring plan.

(i) The performance criteria and design specifications for the monitoring system equipment, including the sample interface, detector signal analyzer, and data acquisition and calculations;

(ii) Sampling interface (e.g., thermocouple) location such that the monitoring system will provide representative measurements;

(iii) Equipment performance evaluations, system accuracy audits, or other audit procedures;



(iv) Ongoing operation and maintenance procedures in accordance with provisions in § 63.8(c)(1)(ii) and (c)(3); and

(v) Ongoing reporting and recordkeeping procedures in accordance with provisions in § 63.10(c), (e)(1), and (e)(2)(i).

(2) You must install, operate, and maintain each CPMS in continuous operation according to the procedures in your site-specific monitoring plan.

(3) The CPMS must collect data at least once every 15 minutes (see also § 63.6635).

(4) For a CPMS for measuring temperature range, the temperature sensor must have a minimum tolerance of 2.8 degrees Celsius (5 degrees Fahrenheit) or 1 percent of the measurement range, whichever is larger.

(5) You must conduct the CPMS equipment performance evaluation, system accuracy audits, or other audit procedures specified in your site-specific monitoring plan at least annually.

(6) You must conduct a performance evaluation of each CPMS in accordance with your site-specific monitoring plan.

(c) If you are operating a new or reconstructed stationary RICE which fires landfill gas or digester gas equivalent to 10 percent or more of the gross heat input on an annual basis, you must monitor and record your fuel usage daily with separate fuel meters to measure the volumetric flow rate of each fuel. In addition, you must operate your stationary RICE in a manner which reasonably minimizes HAP emissions.

(d) If you are operating a new or reconstructed emergency 4SLB stationary RICE with a site rating of greater than or equal to 250 and less than or equal to 500 brake HP located at a major source of HAP emissions, you must install a non-resettable hour meter prior to the startup of the engine.

(e) If you own or operate any of the following stationary RICE, you must operate and maintain the stationary RICE and after-treatment control device (if any) according to the manufacturer's emission-related written instructions or develop your own maintenance plan which must provide to the extent practicable for the maintenance and operation of the engine in a manner consistent with good air pollution control practice for minimizing emissions:

(1) An existing stationary RICE with a site rating of less than 100 HP located at a major source of HAP emissions;

(2) An existing emergency or black start stationary RICE with a site rating of less than or equal to 500 HP located at a major source of HAP emissions;

(3) An existing emergency or black start stationary RICE located at an area source of HAP emissions;

(4) An existing non-emergency, non-black start stationary CI RICE with a site rating less than or equal to 300 HP located at an area source of HAP emissions;

(5) An existing non-emergency, non-black start 2SLB stationary RICE located at an area source of HAP emissions;

(6) An existing non-emergency, non-black start stationary RICE located at an area source of HAP emissions which combusts landfill or digester gas equivalent to 10 percent or more of the gross heat input on an annual basis.

(7) An existing non-emergency, non-black start 4SLB stationary RICE with a site rating less than or equal to 500 HP located at an area source of HAP emissions;

(8) An existing non-emergency, non-black start 4SRB stationary RICE with a site rating less than or equal to 500 HP located at an area source of HAP emissions;

(9) An existing, non-emergency, non-black start 4SLB stationary RICE with a site rating greater than 500 HP located at an area source of HAP emissions that is operated 24 hours or less per calendar year; and

(10) An existing, non-emergency, non-black start 4SRB stationary RICE with a site rating greater than 500 HP located at an area source of HAP emissions that is operated 24 hours or less per calendar year.

(f) If you own or operate an existing emergency stationary RICE with a site rating of less than or equal to 500 brake HP located at a major source of HAP emissions or an existing emergency stationary RICE located at an area source of HAP emissions, you must install a non-resettable hour meter if one is not already installed.

(g) If you own or operate an existing non-emergency, non-black start CI engine greater than or equal to 300 HP that is not equipped with a closed crankcase ventilation system, you must comply with either paragraph (g)(1) or paragraph (2) of this section. Owners and operators must follow the manufacturer's specified maintenance requirements for operating and maintaining the open or closed crankcase ventilation systems and replacing the crankcase filters, or can request the Administrator to approve different maintenance requirements that are as protective as manufacturer requirements. Existing CI engines located at area sources in areas of Alaska that meet either § 63.6603(b)(1) or § 63.6603(b)(2) do not have to meet the requirements of this paragraph (g). Existing CI engines located on offshore vessels that meet § 63.6603(c) do not have to meet the requirements of this paragraph (g).

(1) Install a closed crankcase ventilation system that prevents crankcase emissions from being emitted to the atmosphere, or

(2) Install an open crankcase filtration emission control system that reduces emissions from the crankcase by filtering the exhaust stream to remove oil mist, particulates and metals.

(h) If you operate a new, reconstructed, or existing stationary engine, you must minimize the engine's time spent at idle during startup and minimize the engine's startup time to a period needed for appropriate and safe loading of the engine, not to exceed 30 minutes, after which time the emission standards applicable to all times other than startup in Tables 1a, 2a, 2c, and 2d to this subpart apply.

(i) If you own or operate a stationary CI engine that is subject to the work, operation or management practices in items 1 or 2 of Table 2c to this subpart or in items 1 or 4 of Table 2d to this subpart, you have the option of utilizing an oil analysis program in order to extend the specified oil change requirement in Tables 2c and 2d to this subpart. The oil analysis must be performed at the same frequency specified for changing the oil in Table 2c or 2d to this subpart. The analysis program must at a minimum analyze the following three parameters: Total Base Number, viscosity, and percent water content. The condemning limits for these parameters are as follows: Total Base Number is less than 30 percent of the Total Base Number of the oil when new; viscosity of the oil has changed by more than 20 percent from the viscosity of the oil when new; or percent water content (by volume) is greater than 0.5. If all of these condemning limits are not exceeded, the engine owner or operator is not required to change the oil. If any of the limits are exceeded, the engine owner or operator must change the oil within 2 business days of receiving the results of the analysis; if the engine is not in operation when the results of the analysis are received, the engine owner or operator must change the oil within 2 business days or before commencing operation, whichever is later. The owner or operator must keep records of the parameters that are analyzed as part of the program, the results of the analysis, and the oil changes for the engine. The analysis program must be part of the maintenance plan for the engine.

(j) If you own or operate a stationary SI engine that is subject to the work, operation or management practices in items 6, 7, or 8 of Table 2c to this subpart or in items 5, 6, 7, 9, or 11 of Table 2d to this subpart, you have the option of utilizing an oil analysis program in order to extend the specified oil change requirement in Tables 2c and 2d to this subpart. The oil analysis must be performed at the same frequency specified for changing the oil in Table 2c or 2d to this subpart. The analysis program must at a minimum analyze the following three parameters: Total Acid Number, viscosity, and percent water content. The condemning limits for these parameters are as follows: Total Acid Number increases by more than 3.0 milligrams of potassium hydroxide (KOH) per gram from Total Acid Number of the oil when new; viscosity of the oil has changed by more than 20 percent from the viscosity of the oil when new; or percent water content (by volume) is greater than 0.5. If all of these condemning limits are not

exceeded, the engine owner or operator is not required to change the oil. If any of the limits are exceeded, the engine owner or operator must change the oil within 2 business days of receiving the results of the analysis; if the engine is not in operation when the results of the analysis are received, the engine owner or operator must change the oil within 2 business days or before commencing operation, whichever is later. The owner or operator must keep records of the parameters that are analyzed as part of the program, the results of the analysis, and the oil changes for the engine. The analysis program must be part of the maintenance plan for the engine.

[69 FR 33506, June 15, 2004, as amended at 73 FR 3606, Jan. 18, 2008; 75 FR 9676, Mar. 3, 2010; 75 FR 51589, Aug. 20, 2010; 76 FR 12866, Mar. 9, 2011; 78 FR 6703, Jan. 30, 2013]

**§ 63.6630 How do I demonstrate initial compliance with the emission limitations, operating limitations, and other requirements?**

- (a) You must demonstrate initial compliance with each emission limitation, operating limitation, and other requirement that applies to you according to Table 5 of this subpart.
- (b) During the initial performance test, you must establish each operating limitation in Tables 1b and 2b of this subpart that applies to you.
- (c) You must submit the Notification of Compliance Status containing the results of the initial compliance demonstration according to the requirements in § 63.6645.
- (d) Non-emergency 4SRB stationary RICE complying with the requirement to reduce formaldehyde emissions by 76 percent or more can demonstrate initial compliance with the formaldehyde emission limit by testing for THC instead of formaldehyde. The testing must be conducted according to the requirements in Table 4 of this subpart. The average reduction of emissions of THC determined from the performance test must be equal to or greater than 30 percent.
- (e) The initial compliance demonstration required for existing non-emergency 4SLB and 4SRB stationary RICE with a site rating of more than 500 HP located at an area source of HAP that are not remote stationary RICE and that are operated more than 24 hours per calendar year must be conducted according to the following requirements:
  - (1) The compliance demonstration must consist of at least three test runs.
  - (2) Each test run must be of at least 15 minute duration, except that each test conducted using the method in appendix A to this subpart must consist of at least one measurement cycle and include at least 2 minutes of test data phase measurement.
  - (3) If you are demonstrating compliance with the CO concentration or CO percent reduction requirement, you must measure CO emissions using one of the CO measurement methods specified in Table 4 of this subpart, or using appendix A to this subpart.
  - (4) If you are demonstrating compliance with the THC percent reduction requirement, you must measure THC emissions using Method 25A, reported as propane, of 40 CFR part 60, appendix A.
  - (5) You must measure O<sub>2</sub> using one of the O<sub>2</sub> measurement methods specified in Table 4 of this subpart. Measurements to determine O<sub>2</sub> concentration must be made at the same time as the measurements for CO or THC concentration.
  - (6) If you are demonstrating compliance with the CO or THC percent reduction requirement, you must measure CO or THC emissions and O<sub>2</sub> emissions simultaneously at the inlet and outlet of the control device.

[69 FR 33506, June 15, 2004, as amended at 78 FR 6704, Jan. 30, 2013]

## Continuous Compliance Requirements

### § 63.6635 How do I monitor and collect data to demonstrate continuous compliance?

- (a) If you must comply with emission and operating limitations, you must monitor and collect data according to this section.
- (b) Except for monitor malfunctions, associated repairs, required performance evaluations, and required quality assurance or control activities, you must monitor continuously at all times that the stationary RICE is operating. A monitoring malfunction is any sudden, infrequent, not reasonably preventable failure of the monitoring to provide valid data. Monitoring failures that are caused in part by poor maintenance or careless operation are not malfunctions.
- (c) You may not use data recorded during monitoring malfunctions, associated repairs, and required quality assurance or control activities in data averages and calculations used to report emission or operating levels. You must, however, use all the valid data collected during all other periods.

[69 FR 33506, June 15, 2004, as amended at 76 FR 12867, Mar. 9, 2011]

### § 63.6640 How do I demonstrate continuous compliance with the emission limitations, operating limitations, and other requirements?

- (a) You must demonstrate continuous compliance with each emission limitation, operating limitation, and other requirements in Tables 1a and 1b, Tables 2a and 2b, Table 2c, and Table 2d to this subpart that apply to you according to methods specified in Table 6 to this subpart.
- (b) You must report each instance in which you did not meet each emission limitation or operating limitation in Tables 1a and 1b, Tables 2a and 2b, Table 2c, and Table 2d to this subpart that apply to you. These instances are deviations from the emission and operating limitations in this subpart. These deviations must be reported according to the requirements in § 63.6650. If you change your catalyst, you must reestablish the values of the operating parameters measured during the initial performance test. When you reestablish the values of your operating parameters, you must also conduct a performance test to demonstrate that you are meeting the required emission limitation applicable to your stationary RICE.
- (c) The annual compliance demonstration required for existing non-emergency 4SLB and 4SRB stationary RICE with a site rating of more than 500 HP located at an area source of HAP that are not remote stationary RICE and that are operated more than 24 hours per calendar year must be conducted according to the following requirements:
  - (1) The compliance demonstration must consist of at least one test run.
  - (2) Each test run must be of at least 15 minute duration, except that each test conducted using the method in appendix A to this subpart must consist of at least one measurement cycle and include at least 2 minutes of test data phase measurement.
  - (3) If you are demonstrating compliance with the CO concentration or CO percent reduction requirement, you must measure CO emissions using one of the CO measurement methods specified in Table 4 of this subpart, or using appendix A to this subpart.
  - (4) If you are demonstrating compliance with the THC percent reduction requirement, you must measure THC emissions using Method 25A, reported as propane, of 40 CFR part 60, appendix A.
  - (5) You must measure O<sub>2</sub> using one of the O<sub>2</sub> measurement methods specified in Table 4 of this subpart. Measurements to determine O<sub>2</sub> concentration must be made at the same time as the measurements for CO or THC concentration.

(6) If you are demonstrating compliance with the CO or THC percent reduction requirement, you must measure CO or THC emissions and O<sub>2</sub> emissions simultaneously at the inlet and outlet of the control device.

(7) If the results of the annual compliance demonstration show that the emissions exceed the levels specified in Table 6 of this subpart, the stationary RICE must be shut down as soon as safely possible, and appropriate corrective action must be taken (e.g., repairs, catalyst cleaning, catalyst replacement). The stationary RICE must be retested within 7 days of being restarted and the emissions must meet the levels specified in Table 6 of this subpart. If the retest shows that the emissions continue to exceed the specified levels, the stationary RICE must again be shut down as soon as safely possible, and the stationary RICE may not operate, except for purposes of startup and testing, until the owner/operator demonstrates through testing that the emissions do not exceed the levels specified in Table 6 of this subpart.

(d) For new, reconstructed, and rebuilt stationary RICE, deviations from the emission or operating limitations that occur during the first 200 hours of operation from engine startup (engine burn-in period) are not violations. Rebuilt stationary RICE means a stationary RICE that has been rebuilt as that term is defined in 40 CFR 94.11(a).

(e) You must also report each instance in which you did not meet the requirements in Table 8 to this subpart that apply to you. If you own or operate a new or reconstructed stationary RICE with a site rating of less than or equal to 500 brake HP located at a major source of HAP emissions (except new or reconstructed 4SLB engines greater than or equal to 250 and less than or equal to 500 brake HP), a new or reconstructed stationary RICE located at an area source of HAP emissions, or any of the following RICE with a site rating of more than 500 brake HP located at a major source of HAP emissions, you do not need to comply with the requirements in Table 8 to this subpart: An existing 2SLB stationary RICE, an existing 4SLB stationary RICE, an existing emergency stationary RICE, an existing limited use stationary RICE, or an existing stationary RICE which fires landfill gas or digester gas equivalent to 10 percent or more of the gross heat input on an annual basis. If you own or operate any of the following RICE with a site rating of more than 500 brake HP located at a major source of HAP emissions, you do not need to comply with the requirements in Table 8 to this subpart, except for the initial notification requirements: a new or reconstructed stationary RICE that combusts landfill gas or digester gas equivalent to 10 percent or more of the gross heat input on an annual basis, a new or reconstructed emergency stationary RICE, or a new or reconstructed limited use stationary RICE.

(f) If you own or operate an emergency stationary RICE, you must operate the emergency stationary RICE according to the requirements in paragraphs (f)(1) through (4) of this section. In order for the engine to be considered an emergency stationary RICE under this subpart, any operation other than emergency operation, maintenance and testing, and operation in non-emergency situations for 50 hours per year, as described in paragraphs (f)(1) through (4), is prohibited. If you do not operate the engine according to the requirements in paragraphs (f)(1) through (4), the engine will not be considered an emergency engine under this subpart and must meet all requirements for non-emergency engines.

(1) There is no time limit on the use of emergency stationary RICE in emergency situations.

(2) You may operate your emergency stationary RICE for the purpose specified in paragraph (f)(2)(i) of this section for a maximum of 100 hours per calendar year. Any operation for non-emergency situations as allowed by paragraphs (f)(3) and (4) of this section counts as part of the 100 hours per calendar year allowed by this paragraph (f)(2).

(i) Emergency stationary RICE may be operated for maintenance checks and readiness testing, provided that the tests are recommended by federal, state or local government, the manufacturer, the vendor, the regional transmission organization or equivalent balancing authority and transmission operator, or the insurance company associated with the engine. The owner or operator may petition the Administrator for approval of additional hours to be used for maintenance checks and readiness testing, but a petition is not required if the owner or operator maintains records indicating that federal, state, or local standards require maintenance and testing of emergency RICE beyond 100 hours per calendar year.

(ii)-(iii) [Reserved]

(3) Emergency stationary RICE located at major sources of HAP may be operated for up to 50 hours per calendar year in non-emergency situations. The 50 hours of operation in non-emergency situations are counted as part of the 100 hours per calendar year for maintenance and testing provided in paragraph (f)(2) of this

section. The 50 hours per year for non-emergency situations cannot be used for peak shaving or non-emergency demand response, or to generate income for a facility to supply power to an electric grid or otherwise supply power as part of a financial arrangement with another entity.

(4) Emergency stationary RICE located at area sources of HAP may be operated for up to 50 hours per calendar year in non-emergency situations. The 50 hours of operation in non-emergency situations are counted as part of the 100 hours per calendar year for maintenance and testing provided in paragraph (f)(2) of this section. Except as provided in paragraphs (f)(4)(i) and (ii) of this section, the 50 hours per year for non-emergency situations cannot be used for peak shaving or non-emergency demand response, or to generate income for a facility to an electric grid or otherwise supply power as part of a financial arrangement with another entity.

(i) Prior to May 3, 2014, the 50 hours per year for non-emergency situations can be used for peak shaving or non-emergency demand response to generate income for a facility, or to otherwise supply power as part of a financial arrangement with another entity if the engine is operated as part of a peak shaving (load management program) with the local distribution system operator and the power is provided only to the facility itself or to support the local distribution system.

(ii) The 50 hours per year for non-emergency situations can be used to supply power as part of a financial arrangement with another entity if all of the following conditions are met:

(A) The engine is dispatched by the local balancing authority or local transmission and distribution system operator.

(B) The dispatch is intended to mitigate local transmission and/or distribution limitations so as to avert potential voltage collapse or line overloads that could lead to the interruption of power supply in a local area or region.

(C) The dispatch follows reliability, emergency operation or similar protocols that follow specific NERC, regional, state, public utility commission or local standards or guidelines.

(D) The power is provided only to the facility itself or to support the local transmission and distribution system.

(E) The owner or operator identifies and records the entity that dispatches the engine and the specific NERC, regional, state, public utility commission or local standards or guidelines that are being followed for dispatching the engine. The local balancing authority or local transmission and distribution system operator may keep these records on behalf of the engine owner or operator.

[69 FR 33506, June 15, 2004, as amended at 71 FR 20467, Apr. 20, 2006; 73 FR 3606, Jan. 18, 2008; 75 FR 9676, Mar. 3, 2010; 75 FR 51591, Aug. 20, 2010; 78 FR 6704, Jan. 30, 2013; 87 FR 48607, Aug. 10, 2022]

## **Notifications, Reports, and Records**

### **§ 63.6645 What notifications must I submit and when?**

(a) You must submit all of the notifications in §§ 63.7(b) and (c), 63.8(e), (f)(4) and (f)(6), 63.9(b) through (e), and (g) and (h) that apply to you by the dates specified if you own or operate any of the following;

(1) An existing stationary RICE with a site rating of less than or equal to 500 brake HP located at a major source of HAP emissions.

(2) An existing stationary RICE located at an area source of HAP emissions.

(3) A stationary RICE with a site rating of more than 500 brake HP located at a major source of HAP emissions.

(4) A new or reconstructed 4SLB stationary RICE with a site rating of greater than or equal to 250 HP located at a major source of HAP emissions.

(5) This requirement does not apply if you own or operate an existing stationary RICE less than 100 HP, an existing stationary emergency RICE, or an existing stationary RICE that is not subject to any numerical emission standards.

(b) As specified in § 63.9(b)(2), if you start up your stationary RICE with a site rating of more than 500 brake HP located at a major source of HAP emissions before the effective date of this subpart, you must submit an Initial Notification not later than December 13, 2004, or no later than 120 days after the source becomes subject to this subpart, whichever is later.

(c) If you start up your new or reconstructed stationary RICE with a site rating of more than 500 brake HP located at a major source of HAP emissions on or after August 16, 2004, you must submit an Initial Notification not later than 120 days after you become subject to this subpart.

(d) As specified in § 63.9(b)(2), if you start up your stationary RICE with a site rating of equal to or less than 500 brake HP located at a major source of HAP emissions before the effective date of this subpart and you are required to submit an initial notification, you must submit an Initial Notification not later than July 16, 2008, or no later than 120 days after the source becomes subject to this subpart, whichever is later.

(e) If you start up your new or reconstructed stationary RICE with a site rating of equal to or less than 500 brake HP located at a major source of HAP emissions on or after March 18, 2008 and you are required to submit an initial notification, you must submit an Initial Notification not later than 120 days after you become subject to this subpart.

(f) If you are required to submit an Initial Notification but are otherwise not affected by the requirements of this subpart, in accordance with § 63.6590(b), your notification should include the information in § 63.9(b)(2)(i) through (v), and a statement that your stationary RICE has no additional requirements and explain the basis of the exclusion (for example, that it operates exclusively as an emergency stationary RICE if it has a site rating of more than 500 brake HP located at a major source of HAP emissions).

(g) If you are required to conduct a performance test, you must submit a Notification of Intent to conduct a performance test at least 60 days before the performance test is scheduled to begin as required in § 63.7(b)(1).

(h) If you are required to conduct a performance test or other initial compliance demonstration as specified in Tables 4 and 5 to this subpart, you must submit a Notification of Compliance Status according to § 63.9(h)(2)(ii).

(1) For each initial compliance demonstration required in Table 5 to this subpart that does not include a performance test, you must submit the Notification of Compliance Status before the close of business on the 30th day following the completion of the initial compliance demonstration.

(2) For each initial compliance demonstration required in Table 5 to this subpart that includes a performance test conducted according to the requirements in Table 3 to this subpart, you must submit the Notification of Compliance Status, including the performance test results, before the close of business on the 60th day following the completion of the performance test according to § 63.10(d)(2).

(i) If you own or operate an existing non-emergency CI RICE with a site rating of more than 300 HP located at an area source of HAP emissions that is certified to the Tier 1 or Tier 2 emission standards in Table 1 of 40 CFR 89.112 and subject to an enforceable state or local standard requiring engine replacement and you intend to meet management practices rather than emission limits, as specified in § 63.6603(d), you must submit a notification by March 3, 2013, stating that you intend to use the provision in § 63.6603(d) and identifying the state or local regulation that the engine is subject to.

**§ 63.6650 What reports must I submit and when?**

(a) You must submit each report in Table 7 of this subpart that applies to you.

(b) Unless the Administrator has approved a different schedule for submission of reports under § 63.10(a), you must submit each report by the date in Table 7 of this subpart and according to the requirements in paragraphs (b)(1) through (b)(9) of this section.

(1) For semiannual Compliance reports, the first Compliance report must cover the period beginning on the compliance date that is specified for your affected source in § 63.6595 and ending on June 30 or December 31, whichever date is the first date following the end of the first calendar half after the compliance date that is specified for your source in § 63.6595.

(2) For semiannual Compliance reports, the first Compliance report must be postmarked or delivered no later than July 31 or January 31, whichever date follows the end of the first calendar half after the compliance date that is specified for your affected source in § 63.6595.

(3) For semiannual Compliance reports, each subsequent Compliance report must cover the semiannual reporting period from January 1 through June 30 or the semiannual reporting period from July 1 through December 31.

(4) For semiannual Compliance reports, each subsequent Compliance report must be postmarked or delivered no later than July 31 or January 31, whichever date is the first date following the end of the semiannual reporting period.

(5) For each stationary RICE that is subject to permitting regulations pursuant to 40 CFR part 70 or 71, and if the permitting authority has established dates for submitting semiannual reports pursuant to 40 CFR 70.6(a)(3)(iii)(A) or 40 CFR 71.6 (a)(3)(iii)(A), you may submit the first and subsequent Compliance reports according to the dates the permitting authority has established instead of according to the dates in paragraphs (b)(1) through (b)(4) of this section.

(6) For annual Compliance reports, the first Compliance report must cover the period beginning on the compliance date that is specified for your affected source in § 63.6595 and ending on December 31.

(7) For annual Compliance reports, the first Compliance report must be postmarked or delivered no later than January 31 following the end of the first calendar year after the compliance date that is specified for your affected source in § 63.6595.

(8) For annual Compliance reports, each subsequent Compliance report must cover the annual reporting period from January 1 through December 31.

(9) For annual Compliance reports, each subsequent Compliance report must be postmarked or delivered no later than January 31.

(c) The Compliance report must contain the information in paragraphs (c)(1) through (6) of this section.

(1) Company name and address.

(2) Statement by a responsible official, with that official's name, title, and signature, certifying the accuracy of the content of the report.

(3) Date of report and beginning and ending dates of the reporting period.

(4) If you had a malfunction during the reporting period, the compliance report must include the number, duration, and a brief description for each type of malfunction which occurred during the reporting period and which caused or may have caused any applicable emission limitation to be exceeded. The report must also include a



description of actions taken by an owner or operator during a malfunction of an affected source to minimize emissions in accordance with § 63.6605(b), including actions taken to correct a malfunction.

(5) If there are no deviations from any emission or operating limitations that apply to you, a statement that there were no deviations from the emission or operating limitations during the reporting period.

(6) If there were no periods during which the continuous monitoring system (CMS), including CEMS and CPMS, was out-of-control, as specified in § 63.8(c)(7), a statement that there were no periods during which the CMS was out-of-control during the reporting period.

(d) For each deviation from an emission or operating limitation that occurs for a stationary RICE where you are not using a CMS to comply with the emission or operating limitations in this subpart, the Compliance report must contain the information in paragraphs (c)(1) through (4) of this section and the information in paragraphs (d)(1) and (2) of this section.

(1) The total operating time of the stationary RICE at which the deviation occurred during the reporting period.

(2) Information on the number, duration, and cause of deviations (including unknown cause, if applicable), as applicable, and the corrective action taken.

(e) For each deviation from an emission or operating limitation occurring for a stationary RICE where you are using a CMS to comply with the emission and operating limitations in this subpart, you must include information in paragraphs (c)(1) through (4) and (e)(1) through (12) of this section.

(1) The date and time that each malfunction started and stopped.

(2) The date, time, and duration that each CMS was inoperative, except for zero (low-level) and high-level checks.

(3) The date, time, and duration that each CMS was out-of-control, including the information in § 63.8(c)(8).

(4) The date and time that each deviation started and stopped, and whether each deviation occurred during a period of malfunction or during another period.

(5) A summary of the total duration of the deviation during the reporting period, and the total duration as a percent of the total source operating time during that reporting period.

(6) A breakdown of the total duration of the deviations during the reporting period into those that are due to control equipment problems, process problems, other known causes, and other unknown causes.

(7) A summary of the total duration of CMS downtime during the reporting period, and the total duration of CMS downtime as a percent of the total operating time of the stationary RICE at which the CMS downtime occurred during that reporting period.

(8) An identification of each parameter and pollutant (CO or formaldehyde) that was monitored at the stationary RICE.

(9) A brief description of the stationary RICE.

(10) A brief description of the CMS.

(11) The date of the latest CMS certification or audit.

(12) A description of any changes in CMS, processes, or controls since the last reporting period.

(f) Each affected source that has obtained a title V operating permit pursuant to 40 CFR part 70 or 71 must report all deviations as defined in this subpart in the semiannual monitoring report required by 40 CFR 70.6 (a)(3)(iii)(A) or 40 CFR 71.6(a)(3)(iii)(A). If an affected source submits a Compliance report pursuant to Table 7 of this subpart along with, or as part of, the semiannual monitoring report required by 40 CFR 70.6(a)(3)(iii)(A) or 40 CFR 71.6(a)(3)(iii)(A), and the Compliance report includes all required information concerning deviations from any emission or operating limitation in this subpart, submission of the Compliance report shall be deemed to satisfy any obligation to report the same deviations in the semiannual monitoring report. However, submission of a Compliance report shall not otherwise affect any obligation the affected source may have to report deviations from permit requirements to the permit authority.

(g) If you are operating as a new or reconstructed stationary RICE which fires landfill gas or digester gas equivalent to 10 percent or more of the gross heat input on an annual basis, you must submit an annual report according to Table 7 of this subpart by the date specified unless the Administrator has approved a different schedule, according to the information described in paragraphs (b)(1) through (b)(5) of this section. You must report the data specified in (g)(1) through (g)(3) of this section.

(1) Fuel flow rate of each fuel and the heating values that were used in your calculations. You must also demonstrate that the percentage of heat input provided by landfill gas or digester gas is equivalent to 10 percent or more of the total fuel consumption on an annual basis.

(2) The operating limits provided in your federally enforceable permit, and any deviations from these limits.

(3) Any problems or errors suspected with the meters.

(h) If you own or operate an emergency stationary RICE with a site rating of more than 100 brake HP that operates for the purpose specified in § 63.6640(f)(4)(ii), you must submit an annual report according to the requirements in paragraphs (h)(1) through (3) of this section.

(1) The report must contain the following information:

(i) Company name and address where the engine is located.

(ii) Date of the report and beginning and ending dates of the reporting period.

(iii) Engine site rating and model year.

(iv) Latitude and longitude of the engine in decimal degrees reported to the fifth decimal place.

(v)-(vi) {Reserved}

(vii) Hours spent for operation for the purpose specified in § 63.6640(f)(4)(ii), including the date, start time, and end time for engine operation for the purposes specified in § 63.6640(f)(4)(ii). The report must also identify the entity that dispatched the engine and the situation that necessitated the dispatch of the engine.

(viii) If there were no deviations from the fuel requirements in § 63.6604 that apply to the engine (if any), a statement that there were no deviations from the fuel requirements during the reporting period.

(ix) If there were deviations from the fuel requirements in § 63.6604 that apply to the engine (if any), information on the number, duration, and cause of deviations, and the corrective action taken.

(2) The first annual report must cover the calendar year 2015 and must be submitted no later than March 31, 2016. Subsequent annual reports for each calendar year must be submitted no later than March 31 of the following calendar year.

(3) The annual report must be submitted electronically using the subpart specific reporting form in the Compliance and Emissions Data Reporting Interface (CEDRI) that is accessed through EPA's Central Data

Exchange (CDX) ([www.epa.gov/cdx](http://www.epa.gov/cdx)). However, if the reporting form specific to this subpart is not available in CEDRI at the time that the report is due, the written report must be submitted to the Administrator at the appropriate address listed in § 63.13.

[69 FR 33506, June 15, 2004, as amended at 75 FR 9677, Mar. 3, 2010; 78 FR 6705, Jan. 30, 2013; 87 FR 48607, Aug. 10, 2022]

**§ 63.6655 What records must I keep?**

(a) If you must comply with the emission and operating limitations, you must keep the records described in paragraphs (a)(1) through (a)(5), (b)(1) through (b)(3) and (c) of this section.

(1) A copy of each notification and report that you submitted to comply with this subpart, including all documentation supporting any Initial Notification or Notification of Compliance Status that you submitted, according to the requirement in § 63.10(b)(2)(xiv).

(2) Records of the occurrence and duration of each malfunction of operation (*i.e.*, process equipment) or the air pollution control and monitoring equipment.

(3) Records of performance tests and performance evaluations as required in § 63.10(b)(2)(viii).

(4) Records of all required maintenance performed on the air pollution control and monitoring equipment.

(5) Records of actions taken during periods of malfunction to minimize emissions in accordance with § 63.6605(b), including corrective actions to restore malfunctioning process and air pollution control and monitoring equipment to its normal or usual manner of operation.

(b) For each CEMS or CPMS, you must keep the records listed in paragraphs (b)(1) through (3) of this section.

(1) Records described in § 63.10(b)(2)(vi) through (xi).

(2) Previous (*i.e.*, superseded) versions of the performance evaluation plan as required in § 63.8(d)(3).

(3) Requests for alternatives to the relative accuracy test for CEMS or CPMS as required in § 63.8(f)(6)(i), if applicable.

(c) If you are operating a new or reconstructed stationary RICE which fires landfill gas or digester gas equivalent to 10 percent or more of the gross heat input on an annual basis, you must keep the records of your daily fuel usage monitors.

(d) You must keep the records required in Table 6 of this subpart to show continuous compliance with each emission or operating limitation that applies to you.

(e) You must keep records of the maintenance conducted on the stationary RICE in order to demonstrate that you operated and maintained the stationary RICE and after-treatment control device (if any) according to your own maintenance plan if you own or operate any of the following stationary RICE;

(1) An existing stationary RICE with a site rating of less than 100 brake HP located at a major source of HAP emissions.

(2) An existing stationary emergency RICE.

(3) An existing stationary RICE located at an area source of HAP emissions subject to management practices as shown in Table 2d to this subpart.

(f) If you own or operate any of the stationary RICE in paragraphs (f)(1) through (2) of this section, you must keep records of the hours of operation of the engine that is recorded through the non-resettable hour meter. The owner or operator must document how many hours are spent for emergency operation, including what classified the operation as emergency and how many hours are spent for non-emergency operation. If the engine is used for the purpose specified in § 63.6640(f)(4)(ii), the owner or operator must keep records of the notification of the emergency situation, and the date, start time, and end time of engine operation for these purposes.

(1) An existing emergency stationary RICE with a site rating of less than or equal to 500 brake HP located at a major source of HAP emissions that does not meet the standards applicable to non-emergency engines.

(2) An existing emergency stationary RICE located at an area source of HAP emissions that does not meet the standards applicable to non-emergency engines.

[69 FR 33506, June 15, 2004, as amended at 75 FR 9678, Mar. 3, 2010; 75 FR 51592, Aug. 20, 2010; 78 FR 6706, Jan. 30, 2013; 87 FR 48607, Aug. 10, 2022]

**§ 63.6660 In what form and how long must I keep my records?**

(a) Your records must be in a form suitable and readily available for expeditious review according to § 63.10(b)(1).

(b) As specified in § 63.10(b)(1), you must keep each record for 5 years following the date of each occurrence, measurement, maintenance, corrective action, report, or record.

(c) You must keep each record readily accessible in hard copy or electronic form for at least 5 years after the date of each occurrence, measurement, maintenance, corrective action, report, or record, according to § 63.10(b)(1).

[69 FR 33506, June 15, 2004, as amended at 75 FR 9678, Mar. 3, 2010]

**Other Requirements and Information**

**§ 63.6665 What parts of the General Provisions apply to me?**

Table 8 to this subpart shows which parts of the General Provisions in §§ 63.1 through 63.15 apply to you. If you own or operate a new or reconstructed stationary RICE with a site rating of less than or equal to 500 brake HP located at a major source of HAP emissions (except new or reconstructed 4SLB engines greater than or equal to 250 and less than or equal to 500 brake HP), a new or reconstructed stationary RICE located at an area source of HAP emissions, or any of the following RICE with a site rating of more than 500 brake HP located at a major source of HAP emissions, you do not need to comply with any of the requirements of the General Provisions specified in Table 8: An existing 2SLB stationary RICE, an existing 4SLB stationary RICE, an existing stationary RICE that combusts landfill or digester gas equivalent to 10 percent or more of the gross heat input on an annual basis, an existing emergency stationary RICE, or an existing limited use stationary RICE. If you own or operate any of the following RICE with a site rating of more than 500 brake HP located at a major source of HAP emissions, you do not need to comply with the requirements in the General Provisions specified in Table 8 except for the initial notification requirements: A new stationary RICE that combusts landfill gas or digester gas equivalent to 10 percent or more of the gross heat input on an annual basis, a new emergency stationary RICE, or a new limited use stationary RICE.

[75 FR 9678, Mar. 3, 2010]

**§ 63.6670 Who implements and enforces this subpart?**

(a) This subpart is implemented and enforced by the U.S. EPA, or a delegated authority such as your State, local, or tribal agency. If the U.S. EPA Administrator has delegated authority to your State, local, or tribal agency, then that agency (as well as the U.S. EPA) has the authority to implement and enforce this subpart. You should contact your U.S. EPA Regional Office to find out whether this subpart is delegated to your State, local, or tribal agency.

(b) In delegating implementation and enforcement authority of this subpart to a State, local, or tribal agency under 40 CFR part 63, subpart E, the authorities contained in paragraph (c) of this section are retained by the Administrator of the U.S. EPA and are not transferred to the State, local, or tribal agency.

(c) The authorities that will not be delegated to State, local, or tribal agencies are:

- (1) Approval of alternatives to the non-opacity emission limitations and operating limitations in § 63.6600 under § 63.6(g).
- (2) Approval of major alternatives to test methods under § 63.7(e)(2)(ii) and (f) and as defined in § 63.90.
- (3) Approval of major alternatives to monitoring under § 63.8(f) and as defined in § 63.90.
- (4) Approval of major alternatives to recordkeeping and reporting under § 63.10(f) and as defined in § 63.90.
- (5) Approval of a performance test which was conducted prior to the effective date of the rule, as specified in § 63.6610(b).

**§ 63.6675 What definitions apply to this subpart?**

Terms used in this subpart are defined in the Clean Air Act (CAA); in 40 CFR 63.2, the General Provisions of this part; and in this section as follows:

*Alaska Railbelt Grid* means the service areas of the six regulated public utilities that extend from Fairbanks to Anchorage and the Kenai Peninsula. These utilities are Golden Valley Electric Association; Chugach Electric Association; Matanuska Electric Association; Homer Electric Association; Anchorage Municipal Light & Power; and the City of Seward Electric System.

*Area source* means any stationary source of HAP that is not a major source as defined in part 63.

*Associated equipment* as used in this subpart and as referred to in section 112(n)(4) of the CAA, means equipment associated with an oil or natural gas exploration or production well, and includes all equipment from the well bore to the point of custody transfer, except glycol dehydration units, storage vessels with potential for flash emissions, combustion turbines, and stationary RICE.

*Backup power for renewable energy* means an engine that provides backup power to a facility that generates electricity from renewable energy resources, as that term is defined in Alaska Statute 42.45.045(l)(5) (incorporated by reference, see § 63.14).

*Black start engine* means an engine whose only purpose is to start up a combustion turbine.

*CAA* means the Clean Air Act (42 U.S.C. 7401 *et seq.*, as amended by Public Law 101-549, 104 Stat. 2399).

*Commercial emergency stationary RICE* means an emergency stationary RICE used in commercial establishments such as office buildings, hotels, stores, telecommunications facilities, restaurants, financial institutions such as banks, doctor's offices, and sports and performing arts facilities.

*Compression ignition* means relating to a type of stationary internal combustion engine that is not a spark ignition engine.

*Custody transfer* means the transfer of hydrocarbon liquids or natural gas: After processing and/or treatment in the producing operations, or from storage vessels or automatic transfer facilities or other such equipment, including product loading racks, to pipelines or any other forms of transportation. For the purposes of this subpart, the point at which such liquids or natural gas enters a natural gas processing plant is a point of custody transfer.

*Deviation* means any instance in which an affected source subject to this subpart, or an owner or operator of such a source:

- (1) Fails to meet any requirement or obligation established by this subpart, including but not limited to any emission limitation or operating limitation;
- (2) Fails to meet any term or condition that is adopted to implement an applicable requirement in this subpart and that is included in the operating permit for any affected source required to obtain such a permit; or
- (3) Fails to meet any emission limitation or operating limitation in this subpart during malfunction, regardless or whether or not such failure is permitted by this subpart.
- (4) Fails to satisfy the general duty to minimize emissions established by § 63.6(e)(1)(i).

*Diesel engine* means any stationary RICE in which a high boiling point liquid fuel injected into the combustion chamber ignites when the air charge has been compressed to a temperature sufficiently high for auto-ignition. This process is also known as compression ignition.

*Diesel fuel* means any liquid obtained from the distillation of petroleum with a boiling point of approximately 150 to 360 degrees Celsius. One commonly used form is fuel oil number 2. Diesel fuel also includes any non-distillate fuel with comparable physical and chemical properties (e.g. biodiesel) that is suitable for use in compression ignition engines.

*Digester gas* means any gaseous by-product of wastewater treatment typically formed through the anaerobic decomposition of organic waste materials and composed principally of methane and CO<sub>2</sub>.

*Dual-fuel engine* means any stationary RICE in which a liquid fuel (typically diesel fuel) is used for compression ignition and gaseous fuel (typically natural gas) is used as the primary fuel.

*Emergency stationary RICE* means any stationary reciprocating internal combustion engine that meets all of the criteria in paragraphs (1) through (3) of this definition. All emergency stationary RICE must comply with the requirements specified in § 63.6640(f) in order to be considered emergency stationary RICE. If the engine does not comply with the requirements specified in § 63.6640(f), then it is not considered to be an emergency stationary RICE under this subpart.

- (1) The stationary RICE is operated to provide electrical power or mechanical work during an emergency situation. Examples include stationary RICE used to produce power for critical networks or equipment (including power supplied to portions of a facility) when electric power from the local utility (or the normal power source, if the facility runs on its own power production) is interrupted, or stationary RICE used to pump water in the case of fire or flood, etc.
- (2) The stationary RICE is operated under limited circumstances for situations not included in paragraph (1) of this definition, as specified in § 63.6640(f).
- (3) The stationary RICE operates as part of a financial arrangement with another entity in situations not included in paragraph (1) of this definition only as allowed in § 63.6640(f)(4)(i) or (ii).

*Engine startup* means the time from initial start until applied load and engine and associated equipment reaches steady state or normal operation. For stationary engine with catalytic controls, engine startup means the time from initial start until applied load and engine and associated equipment, including the catalyst, reaches steady state or normal operation.

*Four-stroke engine* means any type of engine which completes the power cycle in two crankshaft revolutions, with intake and compression strokes in the first revolution and power and exhaust strokes in the second revolution.

*Gaseous fuel* means a material used for combustion which is in the gaseous state at standard atmospheric temperature and pressure conditions.

*Gasoline* means any fuel sold in any State for use in motor vehicles and motor vehicle engines, or nonroad or stationary engines, and commonly or commercially known or sold as gasoline.

*Glycol dehydration unit* means a device in which a liquid glycol (including, but not limited to, ethylene glycol, diethylene glycol, or triethylene glycol) absorbent directly contacts a natural gas stream and absorbs water in a contact tower or absorption column (absorber). The glycol contacts and absorbs water vapor and other gas stream constituents from the natural gas and becomes "rich" glycol. This glycol is then regenerated in the glycol dehydration unit reboiler. The "lean" glycol is then recycled.

*Hazardous air pollutants (HAP)* means any air pollutants listed in or pursuant to section 112(b) of the CAA.

*Institutional emergency stationary RICE* means an emergency stationary RICE used in institutional establishments such as medical centers, nursing homes, research centers, institutions of higher education, correctional facilities, elementary and secondary schools, libraries, religious establishments, police stations, and fire stations.

*ISO standard day conditions* means 288 degrees Kelvin (15 degrees Celsius), 60 percent relative humidity and 101.3 kilopascals pressure.

*Landfill gas* means a gaseous by-product of the land application of municipal refuse typically formed through the anaerobic decomposition of waste materials and composed principally of methane and CO<sub>2</sub>.

*Lean burn engine* means any two-stroke or four-stroke spark ignited engine that does not meet the definition of a rich burn engine.

*Limited use stationary RICE* means any stationary RICE that operates less than 100 hours per year.

*Liquefied petroleum gas* means any liquefied hydrocarbon gas obtained as a by-product in petroleum refining of natural gas production.

*Liquid fuel* means any fuel in liquid form at standard temperature and pressure, including but not limited to diesel, residual/crude oil, kerosene/naphtha (jet fuel), and gasoline.

*Major Source*, as used in this subpart, shall have the same meaning as in § 63.2, except that:

- (1) Emissions from any oil or gas exploration or production well (with its associated equipment (as defined in this section)) and emissions from any pipeline compressor station or pump station shall not be aggregated with emissions from other similar units, to determine whether such emission points or stations are major sources, even when emission points are in a contiguous area or under common control;
- (2) For oil and gas production facilities, emissions from processes, operations, or equipment that are not part of the same oil and gas production facility, as defined in § 63.1271 of subpart HHH of this part, shall not be aggregated;
- (3) For production field facilities, only HAP emissions from glycol dehydration units, storage vessel with the potential for flash emissions, combustion turbines and reciprocating internal combustion engines shall be aggregated for a major source determination; and
- (4) Emissions from processes, operations, and equipment that are not part of the same natural gas transmission and storage facility, as defined in § 63.1271 of subpart HHH of this part, shall not be aggregated.

*Malfunction* means any sudden, infrequent, and not reasonably preventable failure of air pollution control equipment, process equipment, or a process to operate in a normal or usual manner which causes, or has the potential to cause, the emission limitations in an applicable standard to be exceeded. Failures that are caused in part by poor maintenance or careless operation are not malfunctions.

*Natural gas* means a naturally occurring mixture of hydrocarbon and non-hydrocarbon gases found in geologic formations beneath the Earth's surface, of which the principal constituent is methane. Natural gas may be field or pipeline quality.

*Non-selective catalytic reduction (NSCR)* means an add-on catalytic nitrogen oxides (NO<sub>x</sub>) control device for rich burn engines that, in a two-step reaction, promotes the conversion of excess oxygen, NO<sub>x</sub>, CO, and volatile organic compounds (VOC) into CO<sub>2</sub>, nitrogen, and water.

*Oil and gas production facility* as used in this subpart means any grouping of equipment where hydrocarbon liquids are processed, upgraded (*i.e.*, remove impurities or other constituents to meet contract specifications), or stored prior to the point of custody transfer; or where natural gas is processed, upgraded, or stored prior to entering the natural gas transmission and storage source category. For purposes of a major source determination, facility (including a building, structure, or installation) means oil and natural gas production and processing equipment that is located within the boundaries of an individual surface site as defined in this section. Equipment that is part of a facility will typically be located within close proximity to other equipment located at the same facility. Pieces of production equipment or groupings of equipment located on different oil and gas leases, mineral fee tracts, lease tracts, subsurface or surface unit areas, surface fee tracts, surface lease tracts, or separate surface sites, whether or not connected by a road, waterway, power line or pipeline, shall not be considered part of the same facility. Examples of facilities in the oil and natural gas production source category include, but are not limited to, well sites, satellite tank batteries, central tank batteries, a compressor station that transports natural gas to a natural gas processing plant, and natural gas processing plants.

*Oxidation catalyst* means an add-on catalytic control device that controls CO and VOC by oxidation.

*Peaking unit or engine* means any standby engine intended for use during periods of high demand that are not emergencies.

*Percent load* means the fractional power of an engine compared to its maximum manufacturer's design capacity at engine site conditions. Percent load may range between 0 percent to above 100 percent.

*Potential to emit* means the maximum capacity of a stationary source to emit a pollutant under its physical and operational design. Any physical or operational limitation on the capacity of the stationary source to emit a pollutant, including air pollution control equipment and restrictions on hours of operation or on the type or amount of material combusted, stored, or processed, shall be treated as part of its design if the limitation or the effect it would have on emissions is federally enforceable. For oil and natural gas production facilities subject to subpart HH of this part, the potential to emit provisions in § 63.760(a) may be used. For natural gas transmission and storage facilities subject to subpart HHH of this part, the maximum annual facility gas throughput for storage facilities may be determined according to § 63.1270(a)(1) and the maximum annual throughput for transmission facilities may be determined according to § 63.1270(a)(2).

*Production field facility* means those oil and gas production facilities located prior to the point of custody transfer.

*Production well* means any hole drilled in the earth from which crude oil, condensate, or field natural gas is extracted.

*Propane* means a colorless gas derived from petroleum and natural gas, with the molecular structure C<sub>3</sub>H<sub>8</sub>.

*Remote stationary RICE* means stationary RICE meeting any of the following criteria:

- (1) Stationary RICE located in an offshore area that is beyond the line of ordinary low water along that portion of the coast of the United States that is in direct contact with the open seas and beyond the line marking the seaward limit of inland waters.



(2) Stationary RICE located on a pipeline segment that meets both of the criteria in paragraphs (2)(i) and (ii) of this definition.

(i) A pipeline segment with 10 or fewer buildings intended for human occupancy and no buildings with four or more stories within 220 yards (200 meters) on either side of the centerline of any continuous 1-mile (1.6 kilometers) length of pipeline. Each separate dwelling unit in a multiple dwelling unit building is counted as a separate building intended for human occupancy.

(ii) The pipeline segment does not lie within 100 yards (91 meters) of either a building or a small, well-defined outside area (such as a playground, recreation area, outdoor theater, or other place of public assembly) that is occupied by 20 or more persons on at least 5 days a week for 10 weeks in any 12-month period. The days and weeks need not be consecutive. The building or area is considered occupied for a full day if it is occupied for any portion of the day.

(iii) For purposes of this paragraph (2), the term pipeline segment means all parts of those physical facilities through which gas moves in transportation, including but not limited to pipe, valves, and other appurtenance attached to pipe, compressor units, metering stations, regulator stations, delivery stations, holders, and fabricated assemblies. Stationary RICE located within 50 yards (46 meters) of the pipeline segment providing power for equipment on a pipeline segment are part of the pipeline segment. Transportation of gas means the gathering, transmission, or distribution of gas by pipeline, or the storage of gas. A building is intended for human occupancy if its primary use is for a purpose involving the presence of humans.

(3) Stationary RICE that are not located on gas pipelines and that have 5 or fewer buildings intended for human occupancy and no buildings with four or more stories within a 0.25 mile radius around the engine. A building is intended for human occupancy if its primary use is for a purpose involving the presence of humans.

*Residential emergency stationary RICE* means an emergency stationary RICE used in residential establishments such as homes or apartment buildings.

*Responsible official* means responsible official as defined in 40 CFR 70.2.

*Rich burn engine* means any four-stroke spark ignited engine where the manufacturer's recommended operating air/fuel ratio divided by the stoichiometric air/fuel ratio at full load conditions is less than or equal to 1.1. Engines originally manufactured as rich burn engines, but modified prior to December 19, 2002 with passive emission control technology for NO<sub>x</sub> (such as pre-combustion chambers) will be considered lean burn engines. Also, existing engines where there are no manufacturer's recommendations regarding air/fuel ratio will be considered a rich burn engine if the excess oxygen content of the exhaust at full load conditions is less than or equal to 2 percent.

*Site-rated HP* means the maximum manufacturer's design capacity at engine site conditions.

*Spark ignition* means relating to either: A gasoline-fueled engine; or any other type of engine with a spark plug (or other sparking device) and with operating characteristics significantly similar to the theoretical Otto combustion cycle. Spark ignition engines usually use a throttle to regulate intake air flow to control power during normal operation. Dual-fuel engines in which a liquid fuel (typically diesel fuel) is used for CI and gaseous fuel (typically natural gas) is used as the primary fuel at an annual average ratio of less than 2 parts diesel fuel to 100 parts total fuel on an energy equivalent basis are spark ignition engines.

*Stationary reciprocating internal combustion engine (RICE)* means any reciprocating internal combustion engine which uses reciprocating motion to convert heat energy into mechanical work and which is not mobile. Stationary RICE differ from mobile RICE in that a stationary RICE is not a non-road engine as defined at 40 CFR 1068.30, and is not used to propel a motor vehicle or a vehicle used solely for competition.

*Stationary RICE test cell/stand* means an engine test cell/stand, as defined in subpart P of this part, that tests stationary RICE.

*Stoichiometric* means the theoretical air-to-fuel ratio required for complete combustion.

*Storage vessel with the potential for flash emissions* means any storage vessel that contains a hydrocarbon liquid with a stock tank gas-to-oil ratio equal to or greater than 0.31 cubic meters per liter and an American Petroleum Institute gravity equal to or greater than 40 degrees and an actual annual average hydrocarbon liquid throughput equal to or greater than 79,500 liters per day. Flash emissions occur when dissolved hydrocarbons in the fluid evolve from solution when the fluid pressure is reduced.

*Subpart* means 40 CFR part 63, subpart ZZZZ.

*Surface site* means any combination of one or more graded pad sites, gravel pad sites, foundations, platforms, or the immediate physical location upon which equipment is physically affixed.

*Two-stroke engine* means a type of engine which completes the power cycle in single crankshaft revolution by combining the intake and compression operations into one stroke and the power and exhaust operations into a second stroke. This system requires auxiliary scavenging and inherently runs lean of stoichiometric.

[69 FR 33506, June 15, 2004, as amended at 71 FR 20467, Apr. 20, 2006; 73 FR 3607, Jan. 18, 2008; 75 FR 9679, Mar. 3, 2010; 75 FR 51592, Aug. 20, 2010; 76 FR 12867, Mar. 9, 2011; 78 FR 6706, Jan. 30, 2013; 87 FR 48608, Aug. 10, 2022]

**Table 1a to Subpart ZZZZ of Part 63—Emission Limitations for Existing, New, and Reconstructed Spark Ignition, 4SRB Stationary RICE >500 HP Located at a Major Source of HAP Emissions**

As stated in §§63.6600 and 63.6640, you must comply with the following emission limitations at 100 percent load plus or minus 10 percent for existing, new and reconstructed 4SRB stationary RICE >500 HP located at a major source of HAP emissions:

For each . . .	You must meet the following emission limitation, except during periods of startup . . .	During periods of startup you must . . .
1. 4SRB stationary RICE	a. Reduce formaldehyde emissions by 76 percent or more. If you commenced construction or reconstruction between December 19, 2002 and June 15, 2004, you may reduce formaldehyde emissions by 75 percent or more until June 15, 2007 or	Minimize the engine's time spent at idle and minimize the engine's startup time at startup to a period needed for appropriate and safe loading of the engine, not to exceed 30 minutes, after which time the non-startup emission limitations apply. <sup>1</sup>
	b. Limit the concentration of formaldehyde in the stationary RICE exhaust to 350 ppbvd or less at 15 percent O <sub>2</sub>	

<sup>1</sup> Sources can petition the Administrator pursuant to the requirements of 40 CFR 63.6(g) for alternative work practices.

[75 FR 9679, Mar. 3, 2010, as amended at 75 FR 51592, Aug. 20, 2010]

**Table 1b to Subpart ZZZZ of Part 63—Operating Limitations for Existing, New, and Reconstructed SI 4SRB Stationary RICE >500 HP Located at a Major Source of HAP Emissions**

As stated in §§63.6600, 63.6603, 63.6630 and 63.6640, you must comply with the following operating limitations for existing, new and reconstructed 4SRB stationary RICE >500 HP located at a major source of HAP emissions:

For each . . .	You must meet the following operating limitation, except during periods of startup . . .
1. existing, new and reconstructed 4SRB stationary RICE >500 HP located at a major source of HAP emissions complying with the requirement to reduce formaldehyde emissions by 76 percent or more (or by 75 percent or more, if applicable) and using NSCR; or existing, new and reconstructed 4SRB stationary RICE >500 HP located at a major source of HAP emissions complying with the requirement to limit the concentration of formaldehyde in the stationary RICE exhaust to 350 ppbvd or less at 15 percent O <sub>2</sub> and using NSCR;	a. maintain your catalyst so that the pressure drop across the catalyst does not change by more than 2 inches of water at 100 percent load plus or minus 10 percent from the pressure drop across the catalyst measured during the initial performance test; and b. maintain the temperature of your stationary RICE exhaust so that the catalyst inlet temperature is greater than or equal to 750 °F and less than or equal to 1250 °F. <sup>1</sup>
2. existing, new and reconstructed 4SRB stationary RICE >500 HP located at a major source of HAP emissions complying with the requirement to reduce formaldehyde emissions by 76 percent or more (or by 75 percent or more, if applicable) and not using NSCR; or	Comply with any operating limitations approved by the Administrator.
existing, new and reconstructed 4SRB stationary RICE >500 HP located at a major source of HAP emissions complying with the requirement to limit the concentration of formaldehyde in the stationary RICE exhaust to 350 ppbvd or less at 15 percent O <sub>2</sub> and not using NSCR.	

<sup>1</sup>Sources can petition the Administrator pursuant to the requirements of 40 CFR 63.8(f) for a different temperature range.

[78 FR 6706, Jan. 30, 2013]

**Table 2a to Subpart ZZZZ of Part 63—Emission Limitations for New and Reconstructed 2SLB and Compression Ignition Stationary RICE >500 HP and New and Reconstructed 4SLB Stationary RICE ≥250 HP Located at a Major Source of HAP Emissions**

As stated in §§63.6600 and 63.6640, you must comply with the following emission limitations for new and reconstructed lean burn and new and reconstructed compression ignition stationary RICE at 100 percent load plus or minus 10 percent:

For each . . .	You must meet the following emission limitation, except during periods of startup . . .	During periods of startup you must . . .
1. 2SLB stationary RICE	a. Reduce CO emissions by 58 percent or more; or b. Limit concentration of formaldehyde in the stationary RICE exhaust to 12 ppmvd or less at 15 percent O <sub>2</sub> . If you commenced construction or reconstruction between December 19, 2002 and June 15, 2004, you may limit concentration of formaldehyde to 17 ppmvd or less at 15 percent O <sub>2</sub> until June 15, 2007	Minimize the engine's time spent at idle and minimize the engine's startup time at startup to a period needed for appropriate and safe loading of the engine, not to exceed 30 minutes, after which time the non-startup emission limitations apply. <sup>1</sup>
2. 4SLB stationary RICE	a. Reduce CO emissions by 93 percent or more; or	

For each . . .	You must meet the following emission limitation, except during periods of startup . . .	During periods of startup you must . . .
	b. Limit concentration of formaldehyde in the stationary RICE exhaust to 14 ppmvd or less at 15 percent O <sub>2</sub>	
3. CI stationary RICE	a. Reduce CO emissions by 70 percent or more; or	
	b. Limit concentration of formaldehyde in the stationary RICE exhaust to 580 ppbvd or less at 15 percent O <sub>2</sub>	

<sup>1</sup>Sources can petition the Administrator pursuant to the requirements of 40 CFR 63.6(g) for alternative work practices.

[75 FR 9680, Mar. 3, 2010]

**Table 2b to Subpart ZZZZ of Part 63—Operating Limitations for New and Reconstructed 2SLB and CI Stationary RICE >500 HP Located at a Major Source of HAP Emissions, New and Reconstructed 4SLB Stationary RICE ≥250 HP Located at a Major Source of HAP Emissions, Existing CI Stationary RICE >500 HP**

As stated in §§63.6600, 63.6601, 63.6603, 63.6630, and 63.6640, you must comply with the following operating limitations for new and reconstructed 2SLB and CI stationary RICE >500 HP located at a major source of HAP emissions; new and reconstructed 4SLB stationary RICE ≥250 HP located at a major source of HAP emissions; and existing CI stationary RICE >500 HP:

For each . . .	You must meet the following operating limitation, except during periods of startup . . .
1. New and reconstructed 2SLB and CI stationary RICE >500 HP located at a major source of HAP emissions and new and reconstructed 4SLB stationary RICE ≥250 HP located at a major source of HAP emissions complying with the requirement to reduce CO emissions and using an oxidation catalyst; and New and reconstructed 2SLB and CI stationary RICE >500 HP located at a major source of HAP emissions and new and reconstructed 4SLB stationary RICE ≥250 HP located at a major source of HAP emissions complying with the requirement to limit the concentration of formaldehyde in the stationary RICE exhaust and using an oxidation catalyst.	a. maintain your catalyst so that the pressure drop across the catalyst does not change by more than 2 inches of water at 100 percent load plus or minus 10 percent from the pressure drop across the catalyst that was measured during the initial performance test; and b. maintain the temperature of your stationary RICE exhaust so that the catalyst inlet temperature is greater than or equal to 450 °F and less than or equal to 1350 °F. <sup>1</sup>
2. Existing CI stationary RICE >500 HP complying with the requirement to limit or reduce the concentration of CO in the stationary RICE exhaust and using an oxidation catalyst	a. maintain your catalyst so that the pressure drop across the catalyst does not change by more than 2 inches of water from the pressure drop across the catalyst that was measured during the initial performance test; and b. maintain the temperature of your stationary RICE exhaust so that the catalyst inlet temperature is greater than or equal to 450 °F and less than or equal to 1350 °F. <sup>1</sup>
3. New and reconstructed 2SLB and CI stationary RICE >500 HP located at a major source of HAP emissions and new and reconstructed 4SLB stationary RICE ≥250 HP located at a major source of HAP emissions complying with the requirement to reduce CO emissions and not using an oxidation catalyst; and	Comply with any operating limitations approved by the Administrator.

For each . . .	You must meet the following operating limitation, except during periods of startup . . .
New and reconstructed 2SLB and CI stationary RICE >500 HP located at a major source of HAP emissions and new and reconstructed 4SLB stationary RICE ≥250 HP located at a major source of HAP emissions complying with the requirement to limit the concentration of formaldehyde in the stationary RICE exhaust and not using an oxidation catalyst; and	
existing CI stationary RICE >500 HP complying with the requirement to limit or reduce the concentration of CO in the stationary RICE exhaust and not using an oxidation catalyst.	

<sup>1</sup>Sources can petition the Administrator pursuant to the requirements of 40 CFR 63.8(f) for a different temperature range.

[78 FR 6707, Jan. 30, 2013]

**Table 2c to Subpart ZZZZ of Part 63—Requirements for Existing Compression Ignition Stationary RICE Located at a Major Source of HAP Emissions and Existing Spark Ignition Stationary RICE ≤500 HP Located at a Major Source of HAP Emissions**

As stated in §§63.6600, 63.6602, and 63.6640, you must comply with the following requirements for existing compression ignition stationary RICE located at a major source of HAP emissions and existing spark ignition stationary RICE ≤500 HP located at a major source of HAP emissions:

For each . . .	You must meet the following requirement, except during periods of startup . . .	During periods of startup you must . . .
1. Emergency stationary CI RICE and black start stationary CI RICE <sup>1</sup>	a. Change oil and filter every 500 hours of operation or annually, whichever comes first. <sup>2</sup> b. Inspect air cleaner every 1,000 hours of operation or annually, whichever comes first, and replace as necessary; c. Inspect all hoses and belts every 500 hours of operation or annually, whichever comes first, and replace as necessary. <sup>3</sup>	Minimize the engine's time spent at idle and minimize the engine's startup time at startup to a period needed for appropriate and safe loading of the engine, not to exceed 30 minutes, after which time the non-startup emission limitations apply. <sup>3</sup>

For each . . .	You must meet the following requirement, except during periods of startup . . .	During periods of startup you must . . .
2. Non-Emergency, non-black start stationary CI RICE <100 HP	<p>a. Change oil and filter every 1,000 hours of operation or annually, whichever comes first.<sup>2</sup></p> <p>b. Inspect air cleaner every 1,000 hours of operation or annually, whichever comes first, and replace as necessary;</p> <p>c. Inspect all hoses and belts every 500 hours of operation or annually, whichever comes first, and replace as necessary.<sup>3</sup></p>	
3. Non-Emergency, non-black start CI stationary RICE 100≤HP≤300 HP	Limit concentration of CO in the stationary RICE exhaust to 230 ppmvd or less at 15 percent O <sub>2</sub> .	
4. Non-Emergency, non-black start CI stationary RICE 300<HP≤500	<p>a. Limit concentration of CO in the stationary RICE exhaust to 49 ppmvd or less at 15 percent O<sub>2</sub>; or</p> <p>b. Reduce CO emissions by 70 percent or more.</p>	
5. Non-Emergency, non-black start stationary CI RICE >500 HP	<p>a. Limit concentration of CO in the stationary RICE exhaust to 23 ppmvd or less at 15 percent O<sub>2</sub>; or</p> <p>b. Reduce CO emissions by 70 percent or more.</p>	
6. Emergency stationary SI RICE and black start stationary SI RICE. <sup>1</sup>	<p>a. Change oil and filter every 500 hours of operation or annually, whichever comes first;<sup>2</sup></p> <p>b. Inspect spark plugs every 1,000 hours of operation or annually, whichever comes first, and replace as necessary;</p> <p>c. Inspect all hoses and belts every 500 hours of operation or annually, whichever comes first, and replace as necessary.<sup>3</sup></p>	
7. Non-Emergency, non-black start stationary SI RICE <100 HP that are not 2SLB stationary RICE	<p>a. Change oil and filter every 1,440 hours of operation or annually, whichever comes first;<sup>2</sup></p> <p>b. Inspect spark plugs every 1,440 hours of operation or annually, whichever comes first, and replace as necessary;</p>	

For each . . .	You must meet the following requirement, except during periods of startup . . .	During periods of startup you must . . .
	c. Inspect all hoses and belts every 1,440 hours of operation or annually, whichever comes first, and replace as necessary. <sup>3</sup>	
8. Non-Emergency, non-black start 2SLB stationary SI RICE <100 HP	a. Change oil and filter every 4,320 hours of operation or annually, whichever comes first; <sup>2</sup> b. Inspect spark plugs every 4,320 hours of operation or annually, whichever comes first, and replace as necessary;	
	c. Inspect all hoses and belts every 4,320 hours of operation or annually, whichever comes first, and replace as necessary. <sup>3</sup>	
9. Non-emergency, non-black start 2SLB stationary RICE 100≤HP≤500	Limit concentration of CO in the stationary RICE exhaust to 225 ppmvd or less at 15 percent O <sub>2</sub> .	
10. Non-emergency, non-black start 4SLB stationary RICE 100≤HP≤500	Limit concentration of CO in the stationary RICE exhaust to 47 ppmvd or less at 15 percent O <sub>2</sub> .	
11. Non-emergency, non-black start 4SRB stationary RICE 100≤HP≤500	Limit concentration of formaldehyde in the stationary RICE exhaust to 10.3 ppmvd or less at 15 percent O <sub>2</sub> .	
12. Non-emergency, non-black start stationary RICE 100≤HP≤500 which combusts landfill or digester gas equivalent to 10 percent or more of the gross heat input on an annual basis	Limit concentration of CO in the stationary RICE exhaust to 177 ppmvd or less at 15 percent O <sub>2</sub> .	

<sup>1</sup>If an emergency engine is operating during an emergency and it is not possible to shut down the engine in order to perform the work practice requirements on the schedule required in Table 2c of this subpart, or if performing the work practice on the required schedule would otherwise pose an unacceptable risk under federal, state, or local law, the work practice can be delayed until the emergency is over or the unacceptable risk under federal, state, or local law has abated. The work practice should be performed as soon as practicable after the emergency has ended or the unacceptable risk under federal, state, or local law has abated. Sources must report any failure to perform the work practice on the schedule required and the federal, state or local law under which the risk was deemed unacceptable.

<sup>2</sup>Sources have the option to utilize an oil analysis program as described in §63.6625(i) or (j) in order to extend the specified oil change requirement in Table 2c of this subpart.

<sup>3</sup>Sources can petition the Administrator pursuant to the requirements of 40 CFR 63.6(g) for alternative work practices.

[78 FR 6708, Jan. 30, 2013, as amended at 78 FR 14457, Mar. 6, 2013]

**Table 2d to Subpart ZZZZ of Part 63—Requirements for Existing Stationary RICE Located at Area Sources of HAP Emissions**

As stated in §§63.6603 and 63.6640, you must comply with the following requirements for existing stationary RICE located at area sources of HAP emissions:

For each . . .	You must meet the following requirement, except during periods of startup . . .	During periods of startup you must . . .
1. Non-Emergency, non-black start CI stationary RICE ≤300 HP	a. Change oil and filter every 1,000 hours of operation or annually, whichever comes first; <sup>1</sup> b. Inspect air cleaner every 1,000 hours of operation or annually, whichever comes first, and replace as necessary; c. Inspect all hoses and belts every 500 hours of operation or annually, whichever comes first, and replace as necessary.	Minimize the engine's time spent at idle and minimize the engine's startup time at startup to a period needed for appropriate and safe loading of the engine, not to exceed 30 minutes, after which time the non-startup emission limitations apply.
2. Non-Emergency, non-black start CI stationary RICE 300<HP≤500	a. Limit concentration of CO in the stationary RICE exhaust to 49 ppmvd at 15 percent O <sub>2</sub> ; or	
	b. Reduce CO emissions by 70 percent or more.	
3. Non-Emergency, non-black start CI stationary RICE >500 HP	a. Limit concentration of CO in the stationary RICE exhaust to 23 ppmvd at 15 percent O <sub>2</sub> ; or	
	b. Reduce CO emissions by 70 percent or more.	
4. Emergency stationary CI RICE and black start stationary CI RICE. <sup>2</sup>	a. Change oil and filter every 500 hours of operation or annually, whichever comes first; <sup>1</sup>	
	b. Inspect air cleaner every 1,000 hours of operation or annually, whichever comes first, and replace as necessary; and	
	c. Inspect all hoses and belts every 500 hours of operation or annually, whichever comes first, and replace as necessary.	



For each . . .	You must meet the following requirement, except during periods of startup . . .	During periods of startup you must . . .
5. Emergency stationary SI RICE; black start stationary SI RICE; non-emergency, non-black start 4SLB stationary RICE >500 HP that operate 24 hours or less per calendar year; non-emergency, non-black start 4SRB stationary RICE >500 HP that operate 24 hours or less per calendar year. <sup>2</sup>	a. Change oil and filter every 500 hours of operation or annually, whichever comes first; <sup>1</sup> ; b. Inspect spark plugs every 1,000 hours of operation or annually, whichever comes first, and replace as necessary; and c. Inspect all hoses and belts every 500 hours of operation or annually, whichever comes first, and replace as necessary.	
6. Non-emergency, non-black start 2SLB stationary RICE	a. Change oil and filter every 4,320 hours of operation or annually, whichever comes first; <sup>1</sup>	
	b. Inspect spark plugs every 4,320 hours of operation or annually, whichever comes first, and replace as necessary; and	
	c. Inspect all hoses and belts every 4,320 hours of operation or annually, whichever comes first, and replace as necessary.	
7. Non-emergency, non-black start 4SLB stationary RICE ≤500 HP	a. Change oil and filter every 1,440 hours of operation or annually, whichever comes first; <sup>1</sup>	
	b. Inspect spark plugs every 1,440 hours of operation or annually, whichever comes first, and replace as necessary; and	
	c. Inspect all hoses and belts every 1,440 hours of operation or annually, whichever comes first, and replace as necessary.	
8. Non-emergency, non-black start 4SLB remote stationary RICE >500 HP	a. Change oil and filter every 2,160 hours of operation or annually, whichever comes first; <sup>1</sup>	
	b. Inspect spark plugs every 2,160 hours of operation or annually, whichever comes first, and replace as necessary; and	

For each . . .	You must meet the following requirement, except during periods of startup . . .	During periods of startup you must . . .
	c. Inspect all hoses and belts every 2,160 hours of operation or annually, whichever comes first, and replace as necessary.	
9. Non-emergency, non-black start 4SLB stationary RICE >500 HP that are not remote stationary RICE and that operate more than 24 hours per calendar year	Install an oxidation catalyst to reduce HAP emissions from the stationary RICE.	
10. Non-emergency, non-black start 4SRB stationary RICE ≤500 HP	a. Change oil and filter every 1,440 hours of operation or annually, whichever comes first; <sup>1</sup>	
	b. Inspect spark plugs every 1,440 hours of operation or annually, whichever comes first, and replace as necessary; and	
	c. Inspect all hoses and belts every 1,440 hours of operation or annually, whichever comes first, and replace as necessary.	
11. Non-emergency, non-black start 4SRB remote stationary RICE >500 HP	a. Change oil and filter every 2,160 hours of operation or annually, whichever comes first; <sup>1</sup>	
	b. Inspect spark plugs every 2,160 hours of operation or annually, whichever comes first, and replace as necessary; and	
	c. Inspect all hoses and belts every 2,160 hours of operation or annually, whichever comes first, and replace as necessary.	
12. Non-emergency, non-black start 4SRB stationary RICE >500 HP that are not remote stationary RICE and that operate more than 24 hours per calendar year	Install NSCR to reduce HAP emissions from the stationary RICE.	
13. Non-emergency, non-black start stationary RICE which combusts landfill or digester gas equivalent to 10 percent or more of the gross heat input on an annual basis	a. Change oil and filter every 1,440 hours of operation or annually, whichever comes first; <sup>1</sup> b. Inspect spark plugs every 1,440 hours of operation or annually, whichever comes first, and replace as necessary; and	

<b>For each . . .</b>	<b>You must meet the following requirement, except during periods of startup . . .</b>	<b>During periods of startup you must . . .</b>
	c. Inspect all hoses and belts every 1,440 hours of operation or annually, whichever comes first, and replace as necessary.	

<sup>1</sup>Sources have the option to utilize an oil analysis program as described in §63.6625(i) or (j) in order to extend the specified oil change requirement in Table 2d of this subpart.

<sup>2</sup>If an emergency engine is operating during an emergency and it is not possible to shut down the engine in order to perform the management practice requirements on the schedule required in Table 2d of this subpart, or if performing the management practice on the required schedule would otherwise pose an unacceptable risk under federal, state, or local law, the management practice can be delayed until the emergency is over or the unacceptable risk under federal, state, or local law has abated. The management practice should be performed as soon as practicable after the emergency has ended or the unacceptable risk under federal, state, or local law has abated. Sources must report any failure to perform the management practice on the schedule required and the federal, state or local law under which the risk was deemed unacceptable.

[78 FR 6709, Jan. 30, 2013]

**Table 3 to Subpart ZZZZ of Part 63—Subsequent Performance Tests**

As stated in §§63.6615 and 63.6620, you must comply with the following subsequent performance test requirements:

<b>For each . . .</b>	<b>Complying with the requirement to . . .</b>	<b>You must . . .</b>
1. New or reconstructed 2SLB stationary RICE >500 HP located at major sources; new or reconstructed 4SLB stationary RICE ≥250 HP located at major sources; and new or reconstructed CI stationary RICE >500 HP located at major sources	Reduce CO emissions and not using a CEMS	Conduct subsequent performance tests semiannually. <sup>1</sup>
2. 4SRB stationary RICE ≥5,000 HP located at major sources	Reduce formaldehyde emissions	Conduct subsequent performance tests semiannually. <sup>1</sup>
3. Stationary RICE >500 HP located at major sources and new or reconstructed 4SLB stationary RICE 250≤HP≤500 located at major sources	Limit the concentration of formaldehyde in the stationary RICE exhaust	Conduct subsequent performance tests semiannually. <sup>1</sup>
4. Existing non-emergency, non-black start CI stationary RICE >500 HP that are not limited use stationary RICE	Limit or reduce CO emissions and not using a CEMS	Conduct subsequent performance tests every 8,760 hours or 3 years, whichever comes first.
5. Existing non-emergency, non-black start CI stationary RICE >500 HP that are limited use stationary RICE	Limit or reduce CO emissions and not using a CEMS	Conduct subsequent performance tests every 8,760 hours or 5 years, whichever comes first.

<sup>1</sup>After you have demonstrated compliance for two consecutive tests, you may reduce the frequency of subsequent performance tests to annually. If the results of any subsequent annual performance test indicate the stationary RICE is not in compliance with the CO or formaldehyde emission limitation, or you deviate from any of your operating limitations, you must resume semiannual performance tests.

[78 FR 6711, Jan. 30, 2013]

**Table 4 to Subpart ZZZZ of Part 63—Requirements for Performance Tests**

As stated in §§ 63.6610, 63.6611, 63.6620, and 63.6640, you must comply with the following requirements for performance tests for stationary RICE:

For each . . .	Complying with the requirement to . . .	You must . . .	Using . . .	According to the following requirements . . .
1. 2SLB, 4SLB, and CI stationary RICE	a. Reduce CO emissions	i. Select the sampling port location and the number/location of traverse points at the inlet and outlet of the control device; and		(a) For CO, O <sub>2</sub> , and moisture measurement, ducts ≤6 inches in diameter may be sampled at a single point located at the duct centroid and ducts >6 and ≤12 inches in diameter may be sampled at 3 traverse points located at 16.7, 50.0, and 83.3% of the measurement line ('3-point long line'). If the duct is >12 inches in diameter <i>and</i> the sampling port location meets the two and half-diameter criterion of section 11.1.1 of method 1 of 40 CFR part 60, appendix A–1, the duct may be sampled at '3-point long line'; otherwise, conduct the stratification testing and select sampling points according to section 8.1.2 of method 7E of 40 CFR part 60, appendix A–4.
		ii. Measure the O <sub>2</sub> at the inlet and outlet of the control device; and	(1) Method 3 or 3A or 3B of 40 CFR part 60, appendix A–2, or ASTM D6522–00 (Reapproved 2005) <sup>13</sup> (heated probe not necessary)	(b) Measurements to determine O <sub>2</sub> must be made at the same time as the measurements for CO concentration.
		iii. Measure the CO at the inlet and the outlet of the control device; and	(2) ASTM D6522–00 (Reapproved 2005) <sup>123</sup> (heated probe not necessary) or method 10 of 40 CFR part 60, appendix A–4	(c) The CO concentration must be at 15 percent O <sub>2</sub> , dry basis.
		iv. Measure moisture content at the inlet and outlet of the control device as needed to determine CO and O <sub>2</sub> concentrations on a dry basis	(3) Method 4 of 40 CFR part 60, appendix A–3, or method 320 of 40 CFR part 63, appendix A, or ASTM D6348–03 <sup>13</sup>	(d) Measurements to determine moisture content must be made at the same time and location as the measurements for CO concentration.

For each . . .	Complying with the requirement to . . .	You must . . .	Using . . .	According to the following requirements . . .
2. 4SRB stationary RICE	a. Reduce formaldehyde or THC emissions	i. Select the sampling port location and the number/location of traverse points at the inlet and outlet of the control device; and		(a) For formaldehyde, THC, O <sub>2</sub> , and moisture measurement, ducts ≤6 inches in diameter may be sampled at a single point located at the duct centroid and ducts >6 and ≤12 inches in diameter may be sampled at 3 traverse points located at 16.7, 50.0, and 83.3% of the measurement line ('3-point long line'). If the duct is >12 inches in diameter <i>and</i> the sampling port location meets the two and half-diameter criterion of section 11.1.1 of method 1 of 40 CFR part 60, appendix A, the duct may be sampled at '3-point long line'; otherwise, conduct the stratification testing and select sampling points according to section 8.1.2 of method 7E of 40 CFR part 60, appendix A.
		ii. Measure O <sub>2</sub> at the inlet and outlet of the control device; and	(1) Method 3 or 3A or 3B of 40 CFR part 60, appendix A–2, or ASTM D6522–00 (Reapproved 2005) <sup>13</sup> (heated probe not necessary)	(b) Measurements to determine O <sub>2</sub> concentration must be made at the same time as the measurements for formaldehyde or THC concentration.
		iii. Measure moisture content at the inlet and outlet of the control device as needed to determine formaldehyde or THC and O <sub>2</sub> concentrations on a dry basis; and	(2) Method 4 of 40 CFR part 60, appendix A–3, or method 320 of 40 CFR part 63, appendix A, or ASTM D6348–03 <sup>13</sup>	(c) Measurements to determine moisture content must be made at the same time and location as the measurements for formaldehyde or THC concentration.
		iv. If demonstrating compliance with the formaldehyde percent reduction requirement, measure formaldehyde at the inlet and the outlet of the control device	(3) Method 320 or 323 of 40 CFR part 63, appendix A; or ASTM D6348–03, <sup>13</sup> provided in ASTM D6348–03 Annex A5 (Analyte Spiking Technique), the percent R must be greater than or equal to 70 and less than or equal to 130	(d) Formaldehyde concentration must be at 15 percent O <sub>2</sub> , dry basis. Results of this test consist of the average of the three 1-hour or longer runs.

For each . . .	Complying with the requirement to . . .	You must . . .	Using . . .	According to the following requirements . . .
		v. If demonstrating compliance with the THC percent reduction requirement, measure THC at the inlet and the outlet of the control device	(4) (1) Method 25A, reported as propane, of 40 CFR part 60, appendix A-7	(e) THC concentration must be at 15 percent O <sub>2</sub> , dry basis. Results of this test consist of the average of the three 1-hour or longer runs.
3. Stationary RICE	a. Limit the concentration of formaldehyde or CO in the stationary RICE exhaust	i. Select the sampling port location and the number/location of traverse points at the exhaust of the stationary RICE; and		(a) For formaldehyde, CO, O <sub>2</sub> , and moisture measurement, ducts ≤6 inches in diameter may be sampled at a single point located at the duct centroid and ducts >6 and ≤12 inches in diameter may be sampled at 3 traverse points located at 16.7, 50.0, and 83.3% of the measurement line ('3-point long line'). If the duct is >12 inches in diameter and the sampling port location meets the two and half-diameter criterion of section 11.1.1 of method 1 of 40 CFR part 60, appendix A, the duct may be sampled at '3-point long line'; otherwise, conduct the stratification testing and select sampling points according to section 8.1.2 of method 7E of 40 CFR part 60, appendix A. If using a control device, the sampling site must be located at the outlet of the control device.
		ii. Determine the O <sub>2</sub> concentration of the stationary RICE exhaust at the sampling port location; and	(1) Method 3 or 3A or 3B of 40 CFR part 60, appendix A-2, or ASTM D6522-00 (Reapproved 2005) <sup>13</sup> (heated probe not necessary)	(b) Measurements to determine O <sub>2</sub> concentration must be made at the same time and location as the measurements for formaldehyde or CO concentration.
		iii. Measure moisture content of the stationary RICE exhaust at the sampling port location as needed to determine formaldehyde or CO and O <sub>2</sub> concentrations on a dry basis; and	(2) Method 4 of 40 CFR part 60, appendix A-3, or method 320 of 40 CFR part 63, appendix A, or ASTM D6348-03 <sup>13</sup>	(c) Measurements to determine moisture content must be made at the same time and location as the measurements for formaldehyde or CO concentration.

For each . . .	Complying with the requirement to . . .	You must . . .	Using . . .	According to the following requirements . . .
		iv. Measure formaldehyde at the exhaust of the stationary RICE; or	(3) Method 320 or 323 of 40 CFR part 63, appendix A; or ASTM D6348–03, <sup>13</sup> provided in ASTM D6348–03 Annex A5 (Analyte Spiking Technique), the percent R must be greater than or equal to 70 and less than or equal to 130	(d) Formaldehyde concentration must be at 15 percent O <sub>2</sub> , dry basis. Results of this test consist of the average of the three 1-hour or longer runs.
		v. Measure CO at the exhaust of the stationary RICE	(4) Method 10 of 40 CFR part 60, appendix A–4, ASTM D6522–00 (2005), <sup>13</sup> method 320 of 40 CFR part 63, appendix A, or ASTM D6348–03 <sup>13</sup>	(e) CO concentration must be at 15 percent O <sub>2</sub> , dry basis. Results of this test consist of the average of the three 1-hour or longer runs.

<sup>1</sup> You may also use methods 3A and 10 as options to ASTM–D6522–00 (2005).

<sup>2</sup> You may obtain a copy of ASTM–D6348–03 from at least one of the following addresses: American Society for Testing and Materials, 100 Barr Harbor Drive, West Conshohocken, PA 19428–2959, or University Microfilms International, 300 North Zeeb Road, Ann Arbor, MI 48106.

<sup>3</sup> Incorporated by reference, see § 63.14.

[88 FR 18413, Mar. 29, 2023]

**Table 5 to Subpart ZZZZ of Part 63—Initial Compliance With Emission Limitations, Operating Limitations, and Other Requirements**

As stated in §§63.6612, 63.6625 and 63.6630, you must initially comply with the emission and operating limitations as required by the following:

For each . . .	Complying with the requirement to . . .	You have demonstrated initial compliance if . . .
1. New or reconstructed non-emergency 2SLB stationary RICE >500 HP located at a major source of HAP, new or reconstructed non-emergency 4SLB stationary RICE ≥250 HP located at a major source of HAP, non-emergency stationary CI RICE >500 HP located at a major source of HAP, and existing non-emergency stationary CI RICE >500 HP located at an area source of HAP	a. Reduce CO emissions and using oxidation catalyst, and using a CPMS	i. The average reduction of emissions of CO determined from the initial performance test achieves the required CO percent reduction; and ii. You have installed a CPMS to continuously monitor catalyst inlet temperature according to the requirements in §63.6625(b); and iii. You have recorded the catalyst pressure drop and catalyst inlet temperature during the initial performance test.

For each . . .	Complying with the requirement to . . .	You have demonstrated initial compliance if . . .
2. Non-emergency stationary CI RICE >500 HP located at a major source of HAP, and existing non-emergency stationary CI RICE >500 HP located at an area source of HAP	a. Limit the concentration of CO, using oxidation catalyst, and using a CPMS	i. The average CO concentration determined from the initial performance test is less than or equal to the CO emission limitation; and
		ii. You have installed a CPMS to continuously monitor catalyst inlet temperature according to the requirements in §63.6625(b); and
		iii. You have recorded the catalyst pressure drop and catalyst inlet temperature during the initial performance test.
3. New or reconstructed non-emergency 2SLB stationary RICE >500 HP located at a major source of HAP, new or reconstructed non-emergency 4SLB stationary RICE ≥250 HP located at a major source of HAP, non-emergency stationary CI RICE >500 HP located at a major source of HAP, and existing non-emergency stationary CI RICE >500 HP located at an area source of HAP	a. Reduce CO emissions and not using oxidation catalyst	i. The average reduction of emissions of CO determined from the initial performance test achieves the required CO percent reduction; and ii. You have installed a CPMS to continuously monitor operating parameters approved by the Administrator (if any) according to the requirements in §63.6625(b); and iii. You have recorded the approved operating parameters (if any) during the initial performance test.
4. Non-emergency stationary CI RICE >500 HP located at a major source of HAP, and existing non-emergency stationary CI RICE >500 HP located at an area source of HAP	a. Limit the concentration of CO, and not using oxidation catalyst	i. The average CO concentration determined from the initial performance test is less than or equal to the CO emission limitation; and ii. You have installed a CPMS to continuously monitor operating parameters approved by the Administrator (if any) according to the requirements in §63.6625(b); and
		iii. You have recorded the approved operating parameters (if any) during the initial performance test.
5. New or reconstructed non-emergency 2SLB stationary RICE >500 HP located at a major source of HAP, new or reconstructed non-emergency 4SLB stationary RICE ≥250 HP located at a major source of HAP, non-emergency stationary CI RICE >500 HP located at a major source of HAP, and existing non-emergency stationary CI RICE >500 HP located at an area source of HAP	a. Reduce CO emissions, and using a CEMS	i. You have installed a CEMS to continuously monitor CO and either O <sub>2</sub> or CO <sub>2</sub> at both the inlet and outlet of the oxidation catalyst according to the requirements in §63.6625(a); and ii. You have conducted a performance evaluation of your CEMS using PS 3 and 4A of 40 CFR part 60, appendix B; and
		iii. The average reduction of CO calculated using §63.6620 equals or exceeds the required percent reduction. The initial test comprises the first 4-hour period after successful validation of the CEMS. Compliance is based on the average percent reduction achieved during the 4-hour period.



For each . . .	Complying with the requirement to . . .	You have demonstrated initial compliance if . . .
6. Non-emergency stationary CI RICE >500 HP located at a major source of HAP, and existing non-emergency stationary CI RICE >500 HP located at an area source of HAP	a. Limit the concentration of CO, and using a CEMS	i. You have installed a CEMS to continuously monitor CO and either O <sub>2</sub> or CO <sub>2</sub> at the outlet of the oxidation catalyst according to the requirements in §63.6625(a); and
		ii. You have conducted a performance evaluation of your CEMS using PS 3 and 4A of 40 CFR part 60, appendix B; and
		iii. The average concentration of CO calculated using §63.6620 is less than or equal to the CO emission limitation. The initial test comprises the first 4-hour period after successful validation of the CEMS. Compliance is based on the average concentration measured during the 4-hour period.
7. Non-emergency 4SRB stationary RICE >500 HP located at a major source of HAP	a. Reduce formaldehyde emissions and using NSCR	i. The average reduction of emissions of formaldehyde determined from the initial performance test is equal to or greater than the required formaldehyde percent reduction, or the average reduction of emissions of THC determined from the initial performance test is equal to or greater than 30 percent; and
		ii. You have installed a CPMS to continuously monitor catalyst inlet temperature according to the requirements in §63.6625(b); and
		iii. You have recorded the catalyst pressure drop and catalyst inlet temperature during the initial performance test.
8. Non-emergency 4SRB stationary RICE >500 HP located at a major source of HAP	a. Reduce formaldehyde emissions and not using NSCR	i. The average reduction of emissions of formaldehyde determined from the initial performance test is equal to or greater than the required formaldehyde percent reduction or the average reduction of emissions of THC determined from the initial performance test is equal to or greater than 30 percent; and
		ii. You have installed a CPMS to continuously monitor operating parameters approved by the Administrator (if any) according to the requirements in §63.6625(b); and
		iii. You have recorded the approved operating parameters (if any) during the initial performance test.

For each . . .	Complying with the requirement to . . .	You have demonstrated initial compliance if . . .
<p>9. New or reconstructed non-emergency stationary RICE &gt;500 HP located at a major source of HAP, new or reconstructed non-emergency 4SLB stationary RICE 250≤HP≤500 located at a major source of HAP, and existing non-emergency 4SRB stationary RICE &gt;500 HP located at a major source of HAP</p>	<p>a. Limit the concentration of formaldehyde in the stationary RICE exhaust and using oxidation catalyst or NSCR</p>	<p>i. The average formaldehyde concentration, corrected to 15 percent O<sub>2</sub>, dry basis, from the three test runs is less than or equal to the formaldehyde emission limitation; and ii. You have installed a CPMS to continuously monitor catalyst inlet temperature according to the requirements in §63.6625(b); and</p>
		<p>iii. You have recorded the catalyst pressure drop and catalyst inlet temperature during the initial performance test.</p>
<p>10. New or reconstructed non-emergency stationary RICE &gt;500 HP located at a major source of HAP, new or reconstructed non-emergency 4SLB stationary RICE 250≤HP≤500 located at a major source of HAP, and existing non-emergency 4SRB stationary RICE &gt;500 HP located at a major source of HAP</p>	<p>a. Limit the concentration of formaldehyde in the stationary RICE exhaust and not using oxidation catalyst or NSCR</p>	<p>i. The average formaldehyde concentration, corrected to 15 percent O<sub>2</sub>, dry basis, from the three test runs is less than or equal to the formaldehyde emission limitation; and ii. You have installed a CPMS to continuously monitor operating parameters approved by the Administrator (if any) according to the requirements in §63.6625(b); and</p>
		<p>iii. You have recorded the approved operating parameters (if any) during the initial performance test.</p>
<p>11. Existing non-emergency stationary RICE 100≤HP≤500 located at a major source of HAP, and existing non-emergency stationary CI RICE 300&lt;HP≤500 located at an area source of HAP</p>	<p>a. Reduce CO emissions</p>	<p>i. The average reduction of emissions of CO or formaldehyde, as applicable determined from the initial performance test is equal to or greater than the required CO or formaldehyde, as applicable, percent reduction.</p>
<p>12. Existing non-emergency stationary RICE 100≤HP≤500 located at a major source of HAP, and existing non-emergency stationary CI RICE 300&lt;HP≤500 located at an area source of HAP</p>	<p>a. Limit the concentration of formaldehyde or CO in the stationary RICE exhaust</p>	<p>i. The average formaldehyde or CO concentration, as applicable, corrected to 15 percent O<sub>2</sub>, dry basis, from the three test runs is less than or equal to the formaldehyde or CO emission limitation, as applicable.</p>
<p>13. Existing non-emergency 4SLB stationary RICE &gt;500 HP located at an area source of HAP that are not remote stationary RICE and that are operated more than 24 hours per calendar year</p>	<p>a. Install an oxidation catalyst</p>	<p>i. You have conducted an initial compliance demonstration as specified in §63.6630(e) to show that the average reduction of emissions of CO is 93 percent or more, or the average CO concentration is less than or equal to 47 ppmvd at 15 percent O<sub>2</sub>;</p>
		<p>ii. You have installed a CPMS to continuously monitor catalyst inlet temperature according to the requirements in §63.6625(b), or you have installed equipment to automatically shut down the engine if the catalyst inlet temperature exceeds 1350 °F.</p>

For each . . .	Complying with the requirement to . . .	You have demonstrated initial compliance if . . .
14. Existing non-emergency 4SRB stationary RICE >500 HP located at an area source of HAP that are not remote stationary RICE and that are operated more than 24 hours per calendar year	a. Install NSCR	i. You have conducted an initial compliance demonstration as specified in §63.6630(e) to show that the average reduction of emissions of CO is 75 percent or more, the average CO concentration is less than or equal to 270 ppmvd at 15 percent O <sub>2</sub> , or the average reduction of emissions of THC is 30 percent or more;
		ii. You have installed a CPMS to continuously monitor catalyst inlet temperature according to the requirements in §63.6625(b), or you have installed equipment to automatically shut down the engine if the catalyst inlet temperature exceeds 1250 °F.

[78 FR 6712, Jan. 30, 2013]

**Table 6 to Subpart ZZZZ of Part 63—Continuous Compliance With Emission Limitations, and Other Requirements**

As stated in §63.6640, you must continuously comply with the emissions and operating limitations and work or management practices as required by the following:

For each . . .	Complying with the requirement to . . .	You must demonstrate continuous compliance by . . .
1. New or reconstructed non-emergency 2SLB stationary RICE >500 HP located at a major source of HAP, new or reconstructed non-emergency 4SLB stationary RICE ≥250 HP located at a major source of HAP, and new or reconstructed non-emergency CI stationary RICE >500 HP located at a major source of HAP	a. Reduce CO emissions and using an oxidation catalyst, and using a CPMS	i. Conducting semiannual performance tests for CO to demonstrate that the required CO percent reduction is achieved <sup>a</sup> ; and ii. Collecting the catalyst inlet temperature data according to §63.6625(b); and iii. Reducing these data to 4-hour rolling averages; and
		iv. Maintaining the 4-hour rolling averages within the operating limitations for the catalyst inlet temperature; and
		v. Measuring the pressure drop across the catalyst once per month and demonstrating that the pressure drop across the catalyst is within the operating limitation established during the performance test.
2. New or reconstructed non-emergency 2SLB stationary RICE >500 HP located at a major source of HAP, new or reconstructed non-emergency 4SLB stationary RICE ≥250 HP located at a major source of HAP, and new or reconstructed non-emergency CI stationary RICE >500 HP located at a major source of HAP	a. Reduce CO emissions and not using an oxidation catalyst, and using a CPMS	i. Conducting semiannual performance tests for CO to demonstrate that the required CO percent reduction is achieved <sup>a</sup> ; and ii. Collecting the approved operating parameter (if any) data according to §63.6625(b); and iii. Reducing these data to 4-hour rolling averages; and

For each . . .	Complying with the requirement to . . .	You must demonstrate continuous compliance by . . .
		iv. Maintaining the 4-hour rolling averages within the operating limitations for the operating parameters established during the performance test.
3. New or reconstructed non-emergency 2SLB stationary RICE >500 HP located at a major source of HAP, new or reconstructed non-emergency 4SLB stationary RICE ≥250 HP located at a major source of HAP, new or reconstructed non-emergency stationary CI RICE >500 HP located at a major source of HAP, and existing non-emergency stationary CI RICE >500 HP	a. Reduce CO emissions or limit the concentration of CO in the stationary RICE exhaust, and using a CEMS	i. Collecting the monitoring data according to §63.6625(a), reducing the measurements to 1-hour averages, calculating the percent reduction or concentration of CO emissions according to §63.6620; and ii. Demonstrating that the catalyst achieves the required percent reduction of CO emissions over the 4-hour averaging period, or that the emission remain at or below the CO concentration limit; and
		iii. Conducting an annual RATA of your CEMS using PS 3 and 4A of 40 CFR part 60, appendix B, as well as daily and periodic data quality checks in accordance with 40 CFR part 60, appendix F, procedure 1.
4. Non-emergency 4SRB stationary RICE >500 HP located at a major source of HAP	a. Reduce formaldehyde emissions and using NSCR	i. Collecting the catalyst inlet temperature data according to §63.6625(b); and
		ii. Reducing these data to 4-hour rolling averages; and
		iii. Maintaining the 4-hour rolling averages within the operating limitations for the catalyst inlet temperature; and
		iv. Measuring the pressure drop across the catalyst once per month and demonstrating that the pressure drop across the catalyst is within the operating limitation established during the performance test.
5. Non-emergency 4SRB stationary RICE >500 HP located at a major source of HAP	a. Reduce formaldehyde emissions and not using NSCR	i. Collecting the approved operating parameter (if any) data according to §63.6625(b); and
		ii. Reducing these data to 4-hour rolling averages; and
		iii. Maintaining the 4-hour rolling averages within the operating limitations for the operating parameters established during the performance test.

For each . . .	Complying with the requirement to . . .	You must demonstrate continuous compliance by . . .
6. Non-emergency 4SRB stationary RICE with a brake HP $\geq 5,000$ located at a major source of HAP	a. Reduce formaldehyde emissions	Conducting semiannual performance tests for formaldehyde to demonstrate that the required formaldehyde percent reduction is achieved, or to demonstrate that the average reduction of emissions of THC determined from the performance test is equal to or greater than 30 percent. <sup>a</sup>
7. New or reconstructed non-emergency stationary RICE $>500$ HP located at a major source of HAP and new or reconstructed non-emergency 4SLB stationary RICE $250 \leq \text{HP} \leq 500$ located at a major source of HAP	a. Limit the concentration of formaldehyde in the stationary RICE exhaust and using oxidation catalyst or NSCR	i. Conducting semiannual performance tests for formaldehyde to demonstrate that your emissions remain at or below the formaldehyde concentration limit <sup>a</sup> ; and ii. Collecting the catalyst inlet temperature data according to §63.6625(b); and
		iii. Reducing these data to 4-hour rolling averages; and
		iv. Maintaining the 4-hour rolling averages within the operating limitations for the catalyst inlet temperature; and
		v. Measuring the pressure drop across the catalyst once per month and demonstrating that the pressure drop across the catalyst is within the operating limitation established during the performance test.
8. New or reconstructed non-emergency stationary RICE $>500$ HP located at a major source of HAP and new or reconstructed non-emergency 4SLB stationary RICE $250 \leq \text{HP} \leq 500$ located at a major source of HAP	a. Limit the concentration of formaldehyde in the stationary RICE exhaust and not using oxidation catalyst or NSCR	i. Conducting semiannual performance tests for formaldehyde to demonstrate that your emissions remain at or below the formaldehyde concentration limit <sup>a</sup> ; and ii. Collecting the approved operating parameter (if any) data according to §63.6625(b); and
		iii. Reducing these data to 4-hour rolling averages; and
		iv. Maintaining the 4-hour rolling averages within the operating limitations for the operating parameters established during the performance test.

For each . . .	Complying with the requirement to . . .	You must demonstrate continuous compliance by . . .
<p>9. Existing emergency and black start stationary RICE ≤500 HP located at a major source of HAP, existing non-emergency stationary RICE &lt;100 HP located at a major source of HAP, existing emergency and black start stationary RICE located at an area source of HAP, existing non-emergency stationary CI RICE ≤300 HP located at an area source of HAP, existing non-emergency 2SLB stationary RICE located at an area source of HAP, existing non-emergency stationary SI RICE located at an area source of HAP which combusts landfill or digester gas equivalent to 10 percent or more of the gross heat input on an annual basis, existing non-emergency 4SLB and 4SRB stationary RICE ≤500 HP located at an area source of HAP, existing non-emergency 4SLB and 4SRB stationary RICE &gt;500 HP located at an area source of HAP that operate 24 hours or less per calendar year, and existing non-emergency 4SLB and 4SRB stationary RICE &gt;500 HP located at an area source of HAP that are remote stationary RICE</p>	<p>a. Work or Management practices</p>	<p>i. Operating and maintaining the stationary RICE according to the manufacturer's emission-related operation and maintenance instructions; or ii. Develop and follow your own maintenance plan which must provide to the extent practicable for the maintenance and operation of the engine in a manner consistent with good air pollution control practice for minimizing emissions.</p>
<p>10. Existing stationary CI RICE &gt;500 HP that are not limited use stationary RICE</p>	<p>a. Reduce CO emissions, or limit the concentration of CO in the stationary RICE exhaust, and using oxidation catalyst</p>	<p>i. Conducting performance tests every 8,760 hours or 3 years, whichever comes first, for CO or formaldehyde, as appropriate, to demonstrate that the required CO or formaldehyde, as appropriate, percent reduction is achieved or that your emissions remain at or below the CO or formaldehyde concentration limit; and</p>
		<p>ii. Collecting the catalyst inlet temperature data according to §63.6625(b); and</p>
		<p>iii. Reducing these data to 4-hour rolling averages; and</p>
		<p>iv. Maintaining the 4-hour rolling averages within the operating limitations for the catalyst inlet temperature; and</p>
		<p>v. Measuring the pressure drop across the catalyst once per month and demonstrating that the pressure drop across the catalyst is within the operating limitation established during the performance test.</p>
<p>11. Existing stationary CI RICE &gt;500 HP that are not limited use stationary RICE</p>	<p>a. Reduce CO emissions, or limit the concentration of CO in the stationary RICE exhaust, and not using oxidation catalyst</p>	<p>i. Conducting performance tests every 8,760 hours or 3 years, whichever comes first, for CO or formaldehyde, as appropriate, to demonstrate that the required CO or formaldehyde, as appropriate, percent reduction is achieved or that your emissions remain at or below the CO or formaldehyde concentration limit; and</p>

For each . . .	Complying with the requirement to . . .	You must demonstrate continuous compliance by . . .
		ii. Collecting the approved operating parameter (if any) data according to §63.6625(b); and
		iii. Reducing these data to 4-hour rolling averages; and
		iv. Maintaining the 4-hour rolling averages within the operating limitations for the operating parameters established during the performance test.
12. Existing limited use CI stationary RICE >500 HP	a. Reduce CO emissions or limit the concentration of CO in the stationary RICE exhaust, and using an oxidation catalyst	i. Conducting performance tests every 8,760 hours or 5 years, whichever comes first, for CO or formaldehyde, as appropriate, to demonstrate that the required CO or formaldehyde, as appropriate, percent reduction is achieved or that your emissions remain at or below the CO or formaldehyde concentration limit; and
		ii. Collecting the catalyst inlet temperature data according to §63.6625(b); and
		iii. Reducing these data to 4-hour rolling averages; and
		iv. Maintaining the 4-hour rolling averages within the operating limitations for the catalyst inlet temperature; and
		v. Measuring the pressure drop across the catalyst once per month and demonstrating that the pressure drop across the catalyst is within the operating limitation established during the performance test.
13. Existing limited use CI stationary RICE >500 HP	a. Reduce CO emissions or limit the concentration of CO in the stationary RICE exhaust, and not using an oxidation catalyst	i. Conducting performance tests every 8,760 hours or 5 years, whichever comes first, for CO or formaldehyde, as appropriate, to demonstrate that the required CO or formaldehyde, as appropriate, percent reduction is achieved or that your emissions remain at or below the CO or formaldehyde concentration limit; and
		ii. Collecting the approved operating parameter (if any) data according to §63.6625(b); and
		iii. Reducing these data to 4-hour rolling averages; and
		iv. Maintaining the 4-hour rolling averages within the operating limitations for the operating parameters established during the performance test.

For each . . .	Complying with the requirement to . . .	You must demonstrate continuous compliance by . . .
<p>14. Existing non-emergency 4SLB stationary RICE &gt;500 HP located at an area source of HAP that are not remote stationary RICE and that are operated more than 24 hours per calendar year</p>	<p>a. Install an oxidation catalyst</p>	<p>i. Conducting annual compliance demonstrations as specified in §63.6640(c) to show that the average reduction of emissions of CO is 93 percent or more, or the average CO concentration is less than or equal to 47 ppmvd at 15 percent O<sub>2</sub>; and either</p> <p>ii. Collecting the catalyst inlet temperature data according to §63.6625(b), reducing these data to 4-hour rolling averages; and maintaining the 4-hour rolling averages within the limitation of greater than 450 °F and less than or equal to 1350 °F for the catalyst inlet temperature; or</p> <p>iii. Immediately shutting down the engine if the catalyst inlet temperature exceeds 1350 °F.</p>
<p>15. Existing non-emergency 4SRB stationary RICE &gt;500 HP located at an area source of HAP that are not remote stationary RICE and that are operated more than 24 hours per calendar year</p>	<p>a. Install NSCR</p>	<p>i. Conducting annual compliance demonstrations as specified in §63.6640(c) to show that the average reduction of emissions of CO is 75 percent or more, the average CO concentration is less than or equal to 270 ppmvd at 15 percent O<sub>2</sub>, or the average reduction of emissions of THC is 30 percent or more; and either</p> <p>ii. Collecting the catalyst inlet temperature data according to §63.6625(b), reducing these data to 4-hour rolling averages; and maintaining the 4-hour rolling averages within the limitation of greater than or equal to 750 °F and less than or equal to 1250 °F for the catalyst inlet temperature; or</p> <p>iii. Immediately shutting down the engine if the catalyst inlet temperature exceeds 1250 °F.</p>

<sup>a</sup>After you have demonstrated compliance for two consecutive tests, you may reduce the frequency of subsequent performance tests to annually. If the results of any subsequent annual performance test indicate the stationary RICE is not in compliance with the CO or formaldehyde emission limitation, or you deviate from any of your operating limitations, you must resume semiannual performance tests.

[78 FR 6715, Jan. 30, 2013]



**Table 7 to Subpart ZZZZ of Part 63—Requirements for Reports**

As stated in §63.6650, you must comply with the following requirements for reports:

For each . . .	You must submit a . . .	The report must contain . . .	You must submit the report . . .
<p>1. Existing non-emergency, non-black start stationary RICE 100≤HP≤500 located at a major source of HAP; existing non-emergency, non-black start stationary CI RICE &gt;500 HP located at a major source of HAP; existing non-emergency 4SRB stationary RICE &gt;500 HP located at a major source of HAP; existing non-emergency, non-black start stationary CI RICE &gt;300 HP located at an area source of HAP; new or reconstructed non-emergency stationary RICE &gt;500 HP located at a major source of HAP; and new or reconstructed non-emergency 4SLB stationary RICE 250≤HP≤500 located at a major source of HAP</p>	<p>Compliance report</p>	<p>a. If there are no deviations from any emission limitations or operating limitations that apply to you, a statement that there were no deviations from the emission limitations or operating limitations during the reporting period. If there were no periods during which the CMS, including CEMS and CPMS, was out-of-control, as specified in §63.8(c)(7), a statement that there were not periods during which the CMS was out-of-control during the reporting period; or</p>	<p>i. Semiannually according to the requirements in §63.6650(b)(1)-(5) for engines that are not limited use stationary RICE subject to numerical emission limitations; and ii. Annually according to the requirements in §63.6650(b)(6)-(9) for engines that are limited use stationary RICE subject to numerical emission limitations.</p>
		<p>b. If you had a deviation from any emission limitation or operating limitation during the reporting period, the information in §63.6650(d). If there were periods during which the CMS, including CEMS and CPMS, was out-of-control, as specified in §63.8(c)(7), the information in §63.6650(e); or</p>	<p>i. Semiannually according to the requirements in §63.6650(b).</p>
		<p>c. If you had a malfunction during the reporting period, the information in §63.6650(c)(4).</p>	<p>i. Semiannually according to the requirements in §63.6650(b).</p>
<p>2. New or reconstructed non-emergency stationary RICE that combusts landfill gas or digester gas equivalent to 10 percent or more of the gross heat input on an annual basis</p>	<p>Report</p>	<p>a. The fuel flow rate of each fuel and the heating values that were used in your calculations, and you must demonstrate that the percentage of heat input provided by landfill gas or digester gas, is equivalent to 10 percent or more of the gross heat input on an annual basis; and</p>	<p>i. Annually, according to the requirements in §63.6650.</p>
		<p>b. The operating limits provided in your federally enforceable permit, and any deviations from these limits; and</p>	<p>i. See item 2.a.i.</p>
		<p>c. Any problems or errors suspected with the meters.</p>	<p>i. See item 2.a.i.</p>
<p>3. Existing non-emergency, non-black start 4SLB and 4SRB stationary RICE &gt;500 HP located at an area source of HAP that are not remote stationary RICE and that operate more than 24 hours per calendar year</p>	<p>Compliance report</p>	<p>a. The results of the annual compliance demonstration, if conducted during the reporting period.</p>	<p>i. Semiannually according to the requirements in §63.6650(b)(1)-(5).</p>

<b>For each . . .</b>	<b>You must submit a . . .</b>	<b>The report must contain . . .</b>	<b>You must submit the report . . .</b>
4. Emergency stationary RICE that operate for the purposes specified in § 63.6640(f)(4)(ii)	Report	a. The information in §63.6650(h)(1)	i. annually according to the requirements in §63.6650(h)(2)-(3).

[87 FR 48608, Aug. 10, 2022]

**Table 8 to Subpart ZZZZ of Part 63—Applicability of General Provisions to Subpart ZZZZ.**

As stated in §63.6665, you must comply with the following applicable general provisions.

<b>General provisions citation</b>	<b>Subject of citation</b>	<b>Applies to subpart</b>	<b>Explanation</b>
§63.1	General applicability of the General Provisions	Yes.	
§63.2	Definitions	Yes	Additional terms defined in §63.6675.
§63.3	Units and abbreviations	Yes.	
§63.4	Prohibited activities and circumvention	Yes.	
§63.5	Construction and reconstruction	Yes.	
§63.6(a)	Applicability	Yes.	
§63.6(b)(1)-(4)	Compliance dates for new and reconstructed sources	Yes.	
§63.6(b)(5)	Notification	Yes.	
§63.6(b)(6)	[Reserved]		
§63.6(b)(7)	Compliance dates for new and reconstructed area sources that become major sources	Yes.	
§63.6(c)(1)-(2)	Compliance dates for existing sources	Yes.	
§63.6(c)(3)-(4)	[Reserved]		
§63.6(c)(5)	Compliance dates for existing area sources that become major sources	Yes.	
§63.6(d)	[Reserved]		
§63.6(e)	Operation and maintenance	No.	
§63.6(f)(1)	Applicability of standards	No.	
§63.6(f)(2)	Methods for determining compliance	Yes.	
§63.6(f)(3)	Finding of compliance	Yes.	
§63.6(g)(1)-(3)	Use of alternate standard	Yes.	
§63.6(h)	Opacity and visible emission standards	No	Subpart ZZZZ does not contain opacity or visible emission standards.

<b>General provisions citation</b>	<b>Subject of citation</b>	<b>Applies to subpart</b>	<b>Explanation</b>
§63.6(i)	Compliance extension procedures and criteria	Yes.	
§63.6(j)	Presidential compliance exemption	Yes.	
§63.7(a)(1)-(2)	Performance test dates	Yes	Subpart ZZZZ contains performance test dates at §§63.6610, 63.6611, and 63.6612.
§63.7(a)(3)	CAA section 114 authority	Yes.	
§63.7(b)(1)	Notification of performance test	Yes	Except that §63.7(b)(1) only applies as specified in §63.6645.
§63.7(b)(2)	Notification of rescheduling	Yes	Except that §63.7(b)(2) only applies as specified in §63.6645.
§63.7(c)	Quality assurance/test plan	Yes	Except that §63.7(c) only applies as specified in §63.6645.
§63.7(d)	Testing facilities	Yes.	
§63.7(e)(1)	Conditions for conducting performance tests	No.	Subpart ZZZZ specifies conditions for conducting performance tests at §63.6620.
§63.7(e)(2)	Conduct of performance tests and reduction of data	Yes	Subpart ZZZZ specifies test methods at §63.6620.
§63.7(e)(3)	Test run duration	Yes.	
§63.7(e)(4)	Administrator may require other testing under section 114 of the CAA	Yes.	
§63.7(f)	Alternative test method provisions	Yes.	
§63.7(g)	Performance test data analysis, recordkeeping, and reporting	Yes.	
§63.7(h)	Waiver of tests	Yes.	
§63.8(a)(1)	Applicability of monitoring requirements	Yes	Subpart ZZZZ contains specific requirements for monitoring at §63.6625.
§63.8(a)(2)	Performance specifications	Yes.	
§63.8(a)(3)	[Reserved]		
§63.8(a)(4)	Monitoring for control devices	No.	
§63.8(b)(1)	Monitoring	Yes.	
§63.8(b)(2)-(3)	Multiple effluents and multiple monitoring systems	Yes.	
§63.8(c)(1)	Monitoring system operation and maintenance	Yes.	
§63.8(c)(1)(i)	Routine and predictable SSM	No	
§63.8(c)(1)(ii)	SSM not in Startup Shutdown Malfunction Plan	Yes.	

<b>General provisions citation</b>	<b>Subject of citation</b>	<b>Applies to subpart</b>	<b>Explanation</b>
§63.8(c)(1)(iii)	Compliance with operation and maintenance requirements	No	
§63.8(c)(2)-(3)	Monitoring system installation	Yes.	
§63.8(c)(4)	Continuous monitoring system (CMS) requirements	Yes	Except that subpart ZZZZ does not require Continuous Opacity Monitoring System (COMS).
§63.8(c)(5)	COMS minimum procedures	No	Subpart ZZZZ does not require COMS.
§63.8(c)(6)-(8)	CMS requirements	Yes	Except that subpart ZZZZ does not require COMS.
§63.8(d)	CMS quality control	Yes.	
§63.8(e)	CMS performance evaluation	Yes	Except for §63.8(e)(5)(ii), which applies to COMS.
		Except that §63.8(e) only applies as specified in §63.6645.	
§63.8(f)(1)-(5)	Alternative monitoring method	Yes	Except that §63.8(f)(4) only applies as specified in §63.6645.
§63.8(f)(6)	Alternative to relative accuracy test	Yes	Except that §63.8(f)(6) only applies as specified in §63.6645.
§63.8(g)	Data reduction	Yes	Except that provisions for COMS are not applicable. Averaging periods for demonstrating compliance are specified at §§63.6635 and 63.6640.
§63.9(a)	Applicability and State delegation of notification requirements	Yes.	
§63.9(b)(1)-(5)	Initial notifications	Yes	Except that §63.9(b)(3) is reserved.
		Except that §63.9(b) only applies as specified in §63.6645.	
§63.9(c)	Request for compliance extension	Yes	Except that §63.9(c) only applies as specified in §63.6645.
§63.9(d)	Notification of special compliance requirements for new sources	Yes	Except that §63.9(d) only applies as specified in §63.6645.
§63.9(e)	Notification of performance test	Yes	Except that §63.9(e) only applies as specified in §63.6645.
§63.9(f)	Notification of visible emission (VE)/opacity test	No	Subpart ZZZZ does not contain opacity or VE standards.
§63.9(g)(1)	Notification of performance evaluation	Yes	Except that §63.9(g) only applies as specified in §63.6645.
§63.9(g)(2)	Notification of use of COMS data	No	Subpart ZZZZ does not contain opacity or VE standards.

<b>General provisions citation</b>	<b>Subject of citation</b>	<b>Applies to subpart</b>	<b>Explanation</b>
§63.9(g)(3)	Notification that criterion for alternative to RATA is exceeded	Yes	If alternative is in use.
		Except that §63.9(g) only applies as specified in §63.6645.	
§63.9(h)(1)-(6)	Notification of compliance status	Yes	Except that notifications for sources using a CEMS are due 30 days after completion of performance evaluations. §63.9(h)(4) is reserved.
			Except that §63.9(h) only applies as specified in §63.6645.
§63.9(i)	Adjustment of submittal deadlines	Yes.	
§63.9(j)	Change in previous information	Yes.	
§63.9(k)	Electronic reporting procedures	Yes	Only as specified in §63.9(j).
§63.10(a)	Administrative provisions for recordkeeping/reporting	Yes.	
§63.10(b)(1)	Record retention	Yes	Except that the most recent 2 years of data do not have to be retained on site.
§63.10(b)(2)(i)-(v)	Records related to SSM	No.	
§63.10(b)(2)(vi)-(xi)	Records	Yes.	
§63.10(b)(2)(xii)	Record when under waiver	Yes.	
§63.10(b)(2)(xiii)	Records when using alternative to RATA	Yes	For CO standard if using RATA alternative.
§63.10(b)(2)(xiv)	Records of supporting documentation	Yes.	
§63.10(b)(3)	Records of applicability determination	Yes.	
§63.10(c)	Additional records for sources using CEMS	Yes	Except that §63.10(c)(2)-(4) and (9) are reserved.
§63.10(d)(1)	General reporting requirements	Yes.	
§63.10(d)(2)	Report of performance test results	Yes.	
§63.10(d)(3)	Reporting opacity or VE observations	No	Subpart ZZZZ does not contain opacity or VE standards.
§63.10(d)(4)	Progress reports	Yes.	
§63.10(d)(5)	Startup, shutdown, and malfunction reports	No.	
§63.10(e)(1) and (2)(i)	Additional CMS Reports	Yes.	
§63.10(e)(2)(ii)	COMS-related report	No	Subpart ZZZZ does not require COMS.

General provisions citation	Subject of citation	Applies to subpart	Explanation
§63.10(e)(3)	Excess emission and parameter exceedances reports	Yes.	Except that §63.10(e)(3)(i) (C) is reserved.
§63.10(e)(4)	Reporting COMS data	No	Subpart ZZZZ does not require COMS.
§63.10(f)	Waiver for recordkeeping/reporting	Yes.	
§63.11	Flares	No.	
§63.12	State authority and delegations	Yes.	
§63.13	Addresses	Yes.	
§63.14	Incorporation by reference	Yes.	
§63.15	Availability of information	Yes.	

[75 FR 9688, Mar. 3, 2010, as amended at 78 FR 6720, Jan. 30, 2013; 85 FR 73912, Nov. 19, 2020]

**Appendix A to Subpart ZZZZ of Part 63—Protocol for Using an Electrochemical Analyzer to Determine Oxygen and Carbon Monoxide Concentrations From Certain Engines**

1.0 SCOPE AND APPLICATION. WHAT IS THIS PROTOCOL?

This protocol is a procedure for using portable electrochemical (EC) cells for measuring carbon monoxide (CO) and oxygen (O<sub>2</sub>) concentrations in controlled and uncontrolled emissions from existing stationary 4-stroke lean burn and 4-stroke rich burn reciprocating internal combustion engines as specified in the applicable rule.

1.1 Analytes. What does this protocol determine?

This protocol measures the engine exhaust gas concentrations of carbon monoxide (CO) and oxygen (O<sub>2</sub>).

Analyte	CAS No.	Sensitivity
Carbon monoxide (CO)	630-08-0	Minimum detectable limit should be 2 percent of the nominal range or 1 ppm, whichever is less restrictive.
Oxygen (O <sub>2</sub> )	7782-44-7	

1.2 Applicability. When is this protocol acceptable?

This protocol is applicable to 40 CFR part 63, subpart ZZZZ. Because of inherent cross sensitivities of EC cells, you must not apply this protocol to other emissions sources without specific instruction to that effect.

1.3 Data Quality Objectives. How good must my collected data be?

Refer to Section 13 to verify and document acceptable analyzer performance.

1.4 Range. What is the targeted analytical range for this protocol?

The measurement system and EC cell design(s) conforming to this protocol will determine the analytical range for each gas component. The nominal ranges are defined by choosing up-scale calibration gas concentrations near the maximum anticipated flue gas concentrations for CO and O<sub>2</sub>, or no more than twice the permitted CO level.

*1.5 Sensitivity. What minimum detectable limit will this protocol yield for a particular gas component?*

The minimum detectable limit depends on the nominal range and resolution of the specific EC cell used, and the signal to noise ratio of the measurement system. The minimum detectable limit should be 2 percent of the nominal range or 1 ppm, whichever is less restrictive.

2.0 SUMMARY OF PROTOCOL

In this protocol, a gas sample is extracted from an engine exhaust system and then conveyed to a portable EC analyzer for measurement of CO and O<sub>2</sub> gas concentrations. This method provides measurement system performance specifications and sampling protocols to ensure reliable data. You may use additions to, or modifications of vendor supplied measurement systems (e.g., heated or unheated sample lines, thermocouples, flow meters, selective gas scrubbers, etc.) to meet the design specifications of this protocol. Do not make changes to the measurement system from the as-verified configuration (Section 3.12).

3.0 DEFINITIONS

*3.1 Measurement System.* The total equipment required for the measurement of CO and O<sub>2</sub> concentrations. The measurement system consists of the following major subsystems:

*3.1.1 Data Recorder.* A strip chart recorder, computer or digital recorder for logging measurement data from the analyzer output. You may record measurement data from the digital data display manually or electronically.

*3.1.2 Electrochemical (EC) Cell.* A device, similar to a fuel cell, used to sense the presence of a specific analyte and generate an electrical current output proportional to the analyte concentration.

*3.1.3 Interference Gas Scrubber.* A device used to remove or neutralize chemical compounds that may interfere with the selective operation of an EC cell.

*3.1.4 Moisture Removal System.* Any device used to reduce the concentration of moisture in the sample stream so as to protect the EC cells from the damaging effects of condensation and to minimize errors in measurements caused by the scrubbing of soluble gases.

*3.1.5 Sample Interface.* The portion of the system used for one or more of the following: sample acquisition; sample transport; sample conditioning or protection of the EC cell from any degrading effects of the engine exhaust effluent; removal of particulate matter and condensed moisture.

*3.2 Nominal Range.* The range of analyte concentrations over which each EC cell is operated (normally 25 percent to 150 percent of up-scale calibration gas value). Several nominal ranges can be used for any given cell so long as the calibration and repeatability checks for that range remain within specifications.

*3.3 Calibration Gas.* A vendor certified concentration of a specific analyte in an appropriate balance gas.

*3.4 Zero Calibration Error.* The analyte concentration output exhibited by the EC cell in response to zero-level calibration gas.

*3.5 Up-Scale Calibration Error.* The mean of the difference between the analyte concentration exhibited by the EC cell and the certified concentration of the up-scale calibration gas.

*3.6 Interference Check.* A procedure for quantifying analytical interference from components in the engine exhaust gas other than the targeted analytes.

*3.7 Repeatability Check.* A protocol for demonstrating that an EC cell operated over a given nominal analyte concentration range provides a stable and consistent response and is not significantly affected by repeated exposure to that gas.

**3.8 Sample Flow Rate.** The flow rate of the gas sample as it passes through the EC cell. In some situations, EC cells can experience drift with changes in flow rate. The flow rate must be monitored and documented during all phases of a sampling run.

**3.9 Sampling Run.** A timed three-phase event whereby an EC cell's response rises and plateaus in a sample conditioning phase, remains relatively constant during a measurement data phase, then declines during a refresh phase. The sample conditioning phase exposes the EC cell to the gas sample for a length of time sufficient to reach a constant response. The measurement data phase is the time interval during which gas sample measurements can be made that meet the acceptance criteria of this protocol. The refresh phase then purges the EC cells with CO-free air. The refresh phase replenishes requisite O<sub>2</sub> and moisture in the electrolyte reserve and provides a mechanism to de-gas or desorb any interference gas scrubbers or filters so as to enable a stable CO EC cell response. There are four primary types of sampling runs: pre-sampling calibrations; stack gas sampling; post-sampling calibration checks; and measurement system repeatability checks. Stack gas sampling runs can be chained together for extended evaluations, providing all other procedural specifications are met.

**3.10 Sampling Day.** A time not to exceed twelve hours from the time of the pre-sampling calibration to the post-sampling calibration check. During this time, stack gas sampling runs can be repeated without repeated recalibrations, providing all other sampling specifications have been met.

**3.11 Pre-Sampling Calibration/Post-Sampling Calibration Check.** The protocols executed at the beginning and end of each sampling day to bracket measurement readings with controlled performance checks.

**3.12 Performance-Established Configuration.** The EC cell and sampling system configuration that existed at the time that it initially met the performance requirements of this protocol.

#### 4.0 INTERFERENCES.

When present in sufficient concentrations, NO and NO<sub>2</sub> are two gas species that have been reported to interfere with CO concentration measurements. In the likelihood of this occurrence, it is the protocol user's responsibility to employ and properly maintain an appropriate CO EC cell filter or scrubber for removal of these gases, as described in Section 6.2.12.

#### 5.0 SAFETY. [RESERVED]

#### 6.0 EQUIPMENT AND SUPPLIES.

##### 6.1 What equipment do I need for the measurement system?

The system must maintain the gas sample at conditions that will prevent moisture condensation in the sample transport lines, both before and as the sample gas contacts the EC cells. The essential components of the measurement system are described below.

##### 6.2 Measurement System Components.

**6.2.1 Sample Probe.** A single extraction-point probe constructed of glass, stainless steel or other non-reactive material, and of length sufficient to reach any designated sampling point. The sample probe must be designed to prevent plugging due to condensation or particulate matter.

**6.2.2 Sample Line.** Non-reactive tubing to transport the effluent from the sample probe to the EC cell.

**6.2.3 Calibration Assembly (optional).** A three-way valve assembly or equivalent to introduce calibration gases at ambient pressure at the exit end of the sample probe during calibration checks. The assembly must be designed such that only stack gas or calibration gas flows in the sample line and all gases flow through any gas path filters.

**6.2.4 Particulate Filter (optional).** Filters before the inlet of the EC cell to prevent accumulation of particulate material in the measurement system and extend the useful life of the components. All filters must be fabricated of materials that are non-reactive to the gas mixtures being sampled.



**6.2.5 Sample Pump.** A leak-free pump to provide undiluted sample gas to the system at a flow rate sufficient to minimize the response time of the measurement system. If located upstream of the EC cells, the pump must be constructed of a material that is non-reactive to the gas mixtures being sampled.

**6.2.8 Sample Flow Rate Monitoring.** An adjustable rotameter or equivalent device used to adjust and maintain the sample flow rate through the analyzer as prescribed.

**6.2.9 Sample Gas Manifold (optional).** A manifold to divert a portion of the sample gas stream to the analyzer and the remainder to a by-pass discharge vent. The sample gas manifold may also include provisions for introducing calibration gases directly to the analyzer. The manifold must be constructed of a material that is non-reactive to the gas mixtures being sampled.

**6.2.10 EC cell.** A device containing one or more EC cells to determine the CO and O<sub>2</sub> concentrations in the sample gas stream. The EC cell(s) must meet the applicable performance specifications of Section 13 of this protocol.

**6.2.11 Data Recorder.** A strip chart recorder, computer or digital recorder to make a record of analyzer output data. The data recorder resolution (i.e., readability) must be no greater than 1 ppm for CO; 0.1 percent for O<sub>2</sub>; and one degree (either °C or °F) for temperature. Alternatively, you may use a digital or analog meter having the same resolution to observe and manually record the analyzer responses.

**6.2.12 Interference Gas Filter or Scrubber.** A device to remove interfering compounds upstream of the CO EC cell. Specific interference gas filters or scrubbers used in the performance-established configuration of the analyzer must continue to be used. Such a filter or scrubber must have a means to determine when the removal agent is exhausted. Periodically replace or replenish it in accordance with the manufacturer's recommendations.

## 7.0 REAGENTS AND STANDARDS. WHAT CALIBRATION GASES ARE NEEDED?

**7.1 Calibration Gases.** CO calibration gases for the EC cell must be CO in nitrogen or CO in a mixture of nitrogen and O<sub>2</sub>. Use CO calibration gases with labeled concentration values certified by the manufacturer to be within ±5 percent of the label value. Dry ambient air (20.9 percent O<sub>2</sub>) is acceptable for calibration of the O<sub>2</sub> cell. If needed, any lower percentage O<sub>2</sub> calibration gas must be a mixture of O<sub>2</sub> in nitrogen.

**7.1.1 Up-Scale CO Calibration Gas Concentration.** Choose one or more up-scale gas concentrations such that the average of the stack gas measurements for each stack gas sampling run are between 25 and 150 percent of those concentrations. Alternatively, choose an up-scale gas that does not exceed twice the concentration of the applicable outlet standard. If a measured gas value exceeds 150 percent of the up-scale CO calibration gas value at any time during the stack gas sampling run, the run must be discarded and repeated.

### 7.1.2 Up-Scale O<sub>2</sub> Calibration Gas Concentration.

Select an O<sub>2</sub> gas concentration such that the difference between the gas concentration and the average stack gas measurement or reading for each sample run is less than 15 percent O<sub>2</sub>. When the average exhaust gas O<sub>2</sub> readings are above 6 percent, you may use dry ambient air (20.9 percent O<sub>2</sub>) for the up-scale O<sub>2</sub> calibration gas.

**7.1.3 Zero Gas.** Use an inert gas that contains less than 0.25 percent of the up-scale CO calibration gas concentration. You may use dry air that is free from ambient CO and other combustion gas products (e.g., CO<sub>2</sub>).

## 8.0 SAMPLE COLLECTION AND ANALYSIS

### 8.1 Selection of Sampling Sites.

**8.1.1 Control Device Inlet.** Select a sampling site sufficiently downstream of the engine so that the combustion gases should be well mixed. Use a single sampling extraction point near the center of the duct (e.g., within the 10 percent centroidal area), unless instructed otherwise.

**8.1.2 Exhaust Gas Outlet.** Select a sampling site located at least two stack diameters downstream of any disturbance (e.g., turbocharger exhaust, crossover junction or recirculation take-off) and at least one-half stack diameter upstream of the gas discharge to the atmosphere. Use a single sampling extraction point near the center of the duct (e.g., within the 10 percent centroidal area), unless instructed otherwise.

**8.2 Stack Gas Collection and Analysis.** Prior to the first stack gas sampling run, conduct that the pre-sampling calibration in accordance with Section 10.1. Use Figure 1 to record all data. Zero the analyzer with zero gas. Confirm and record that the scrubber media color is correct and not exhausted. Then position the probe at the sampling point and begin the sampling run at the same flow rate used during the up-scale calibration. Record the start time. Record all EC cell output responses and the flow rate during the “sample conditioning phase” once per minute until constant readings are obtained. Then begin the “measurement data phase” and record readings every 15 seconds for at least two minutes (or eight readings), or as otherwise required to achieve two continuous minutes of data that meet the specification given in Section 13.1. Finally, perform the “refresh phase” by introducing dry air, free from CO and other combustion gases, until several minute-to-minute readings of consistent value have been obtained. For each run use the “measurement data phase” readings to calculate the average stack gas CO and O<sub>2</sub> concentrations.

**8.3 EC Cell Rate.** Maintain the EC cell sample flow rate so that it does not vary by more than ±10 percent throughout the pre-sampling calibration, stack gas sampling and post-sampling calibration check. Alternatively, the EC cell sample flow rate can be maintained within a tolerance range that does not affect the gas concentration readings by more than ±3 percent, as instructed by the EC cell manufacturer.

## 9.0 QUALITY CONTROL (RESERVED)

## 10.0 CALIBRATION AND STANDARDIZATION

**10.1 Pre-Sampling Calibration.** Conduct the following protocol once for each nominal range to be used on each EC cell before performing a stack gas sampling run on each field sampling day. Repeat the calibration if you replace an EC cell before completing all of the sampling runs. There is no prescribed order for calibration of the EC cells; however, each cell must complete the measurement data phase during calibration. Assemble the measurement system by following the manufacturer’s recommended protocols including for preparing and preconditioning the EC cell. Assure the measurement system has no leaks and verify the gas scrubbing agent is not depleted. Use Figure 1 to record all data.

**10.1.1 Zero Calibration.** For both the O<sub>2</sub> and CO cells, introduce zero gas to the measurement system (e.g., at the calibration assembly) and record the concentration reading every minute until readings are constant for at least two consecutive minutes. Include the time and sample flow rate. Repeat the steps in this section at least once to verify the zero calibration for each component gas.

**10.1.2 Zero Calibration Tolerance.** For each zero gas introduction, the zero level output must be less than or equal to ±3 percent of the up-scale gas value or ±1 ppm, whichever is less restrictive, for the CO channel and less than or equal to ±0.3 percent O<sub>2</sub> for the O<sub>2</sub> channel.

**10.1.3 Up-Scale Calibration.** Individually introduce each calibration gas to the measurement system (e.g., at the calibration assembly) and record the start time. Record all EC cell output responses and the flow rate during this “sample conditioning phase” once per minute until readings are constant for at least two minutes. Then begin the “measurement data phase” and record readings every 15 seconds for a total of two minutes, or as otherwise required. Finally, perform the “refresh phase” by introducing dry air, free from CO and other combustion gases, until readings are constant for at least two consecutive minutes. Then repeat the steps in this section at least once to verify the calibration for each component gas. Introduce all gases to flow through the entire sample handling system (i.e., at the exit end of the sampling probe or the calibration assembly).

**10.1.4 Up-Scale Calibration Error.** The mean of the difference of the “measurement data phase” readings from the reported standard gas value must be less than or equal to ±5 percent or ±1 ppm for CO or ±0.5 percent O<sub>2</sub>, whichever is less restrictive, respectively. The maximum allowable deviation from the mean measured value of any single “measurement data phase” reading must be less than or equal to ±2 percent or ±1 ppm for CO or ±0.5 percent O<sub>2</sub>, whichever is less restrictive, respectively.

**10.2 Post-Sampling Calibration Check.** Conduct a stack gas post-sampling calibration check after the stack gas sampling run or set of runs and within 12 hours of the initial calibration. Conduct up-scale and zero calibration checks

using the protocol in Section 10.1. Make no changes to the sampling system or EC cell calibration until all post-sampling calibration checks have been recorded. If either the zero or up-scale calibration error exceeds the respective specification in Sections 10.1.2 and 10.1.4 then all measurement data collected since the previous successful calibrations are invalid and re-calibration and re-sampling are required. If the sampling system is disassembled or the EC cell calibration is adjusted, repeat the calibration check before conducting the next analyzer sampling run.

#### 11.0 ANALYTICAL PROCEDURE

The analytical procedure is fully discussed in Section 8.

#### 12.0 CALCULATIONS AND DATA ANALYSIS

Determine the CO and O<sub>2</sub> concentrations for each stack gas sampling run by calculating the mean gas concentrations of the data recorded during the "measurement data phase".

#### 13.0 PROTOCOL PERFORMANCE

Use the following protocols to verify consistent analyzer performance during each field sampling day.

**13.1 Measurement Data Phase Performance Check.** Calculate the mean of the readings from the "measurement data phase". The maximum allowable deviation from the mean for each of the individual readings is  $\pm 2$  percent, or  $\pm 1$  ppm, whichever is less restrictive. Record the mean value and maximum deviation for each gas monitored. Data must conform to Section 10.1.4. The EC cell flow rate must conform to the specification in Section 8.3.

*Example:* A measurement data phase is invalid if the maximum deviation of any single reading comprising that mean is greater than  $\pm 2$  percent or  $\pm 1$  ppm (the default criteria). For example, if the mean = 30 ppm, single readings of below 29 ppm and above 31 ppm are disallowed).

**13.2 Interference Check.** Before the initial use of the EC cell and interference gas scrubber in the field, and semi-annually thereafter, challenge the interference gas scrubber with NO and NO<sub>2</sub> gas standards that are generally recognized as representative of diesel-fueled engine NO and NO<sub>2</sub> emission values. Record the responses displayed by the CO EC cell and other pertinent data on Figure 1 or a similar form.

**13.2.1 Interference Response.** The combined NO and NO<sub>2</sub> interference response should be less than or equal to  $\pm 5$  percent of the up-scale CO calibration gas concentration.

**13.3 Repeatability Check.** Conduct the following check once for each nominal range that is to be used on the CO EC cell within 5 days prior to each field sampling program. If a field sampling program lasts longer than 5 days, repeat this check every 5 days. Immediately repeat the check if the EC cell is replaced or if the EC cell is exposed to gas concentrations greater than 150 percent of the highest up-scale gas concentration.

**13.3.1 Repeatability Check Procedure.** Perform a complete EC cell sampling run (all three phases) by introducing the CO calibration gas to the measurement system and record the response. Follow Section 10.1.3. Use Figure 1 to record all data. Repeat the run three times for a total of four complete runs. During the four repeatability check runs, do not adjust the system except where necessary to achieve the correct calibration gas flow rate at the analyzer.

**13.3.2 Repeatability Check Calculations.** Determine the highest and lowest average "measurement data phase" CO concentrations from the four repeatability check runs and record the results on Figure 1 or a similar form. The absolute value of the difference between the maximum and minimum average values recorded must not vary more than  $\pm 3$  percent or  $\pm 1$  ppm of the up-scale gas value, whichever is less restrictive.

#### 14.0 POLLUTION PREVENTION (RESERVED)

#### 15.0 WASTE MANAGEMENT (RESERVED)



Facility	Engine I.D.					Date				
"										
"										
"										
Mean										
Refresh Phase										
"										
"										
"										
"										

[78 FR 6721, Jan. 30, 2013]

**Indiana Department of Environmental Management  
Office of Air Quality**

**Technical Support Document (TSD) for a Significant Permit Revision to a  
Federally Enforceable State Operating Permit (FESOP) Renewal**

**Source Description and Location**

<b>Source Name:</b>	<b>AstraZeneca Pharmaceuticals LP</b>
<b>Source Location:</b>	<b>4601 Hwy 62 East, Mt. Vernon, IN 47620</b>
<b>County:</b>	<b>Posey</b>
<b>SIC Code:</b>	<b>2834 (Pharmaceutical Preparations)</b>
<b>Operation Permit No.:</b>	<b>F 129-36688-00021</b>
<b>Operation Permit Issuance Date:</b>	<b>April 18, 2016</b>
<b>Significant Permit Revision No.:</b>	<b>129-47826-00021</b>
<b>Permit Reviewer:</b>	<b>Hind Mohamed</b>

**Existing Approvals**

The source was issued FESOP Renewal No. 129-36688-00021 on April 18, 2016. The source has since received the following approvals:

Permit Type	Permit Number	Issuance Date
Minor Permit Revision	129-37120-00021	June 14, 2016
Administrative Amendment	129-38325-00021	April 24, 2017
Administrative Amendment	129-40490-00021	November 19, 2018
Significant Permit Revision	129-43243-00021	April 23, 2021

**County Attainment Status**

The source is located in Posey County.

Pursuant to amendments to Indiana Code IC 13-17-3-14, effective July 1, 2023, a federal regulation that classifies or amends a designation of attainment, nonattainment, or unclassifiable for any area in Indiana under the federal Clean Air Act is effective and enforceable in Indiana on the effective date of the federal regulation.

Pollutant	Designation
SO <sub>2</sub>	Unclassifiable or attainment effective April 9, 2018, for the 2010 primary 1-hour SO <sub>2</sub> standard. Better than national secondary standards effective March 3, 1978.
CO	Unclassifiable or attainment effective November 15, 1990.
O <sub>3</sub>	Unclassifiable or attainment effective January 16, 2018, for the 2015 8-hour ozone standard.
PM <sub>2.5</sub>	Unclassifiable or attainment effective April 15, 2015, for the 2012 annual PM <sub>2.5</sub> standard.
PM <sub>2.5</sub>	Unclassifiable or attainment effective December 13, 2009, for the 2006 24-hour PM <sub>2.5</sub> standard.
PM <sub>10</sub>	Unclassifiable effective November 15, 1990.
NO <sub>2</sub>	Unclassifiable or attainment effective January 29, 2012, for the 2010 NO <sub>2</sub> standard.
Pb	Unclassifiable or attainment effective December 31, 2011, for the 2008 lead standard.

- (a) Ozone Standards  
Volatile organic compounds (VOC) and Nitrogen Oxides (NO<sub>x</sub>) are regulated under the Clean Air Act (CAA) for the purposes of attaining and maintaining the National Ambient Air Quality

Standards (NAAQS) for ozone. Therefore, VOC and NO<sub>x</sub> emissions are considered when evaluating the rule applicability relating to ozone. Posey County has been designated as attainment or unclassifiable for ozone. Therefore, VOC and NO<sub>x</sub> emissions were reviewed pursuant to the requirements of Prevention of Significant Deterioration (PSD), 326 IAC 2-2.

- (b) **PM<sub>2.5</sub>**  
 Posey County has been classified as attainment for PM<sub>2.5</sub>. Therefore, direct PM<sub>2.5</sub>, SO<sub>2</sub>, and NO<sub>x</sub> emissions were reviewed pursuant to the requirements of Prevention of Significant Deterioration (PSD), 326 IAC 2-2.
- (c) **Other Criteria Pollutants**  
 Posey County has been classified as attainment or unclassifiable in Indiana for all the other criteria pollutants. Therefore, these emissions were reviewed pursuant to the requirements for Prevention of Significant Deterioration (PSD), 326 IAC 2-2.

**Fugitive Emissions**

Since this type of operation is not one (1) of the twenty-eight (28) listed source categories under 326 IAC 2-2-1(ff)(1), 326 IAC 2-3-2(g), or 326 IAC 2-7-1(22)(B), and there is no applicable New Source Performance Standard or National Emission Standard for Hazardous Air Pollutants that was in effect on August 7, 1980, fugitive emissions are not counted toward the determination of PSD, Emission Offset, and Part 70 Permit applicability.

The fugitive emissions of hazardous air pollutants (HAP) are counted toward the determination of Part 70 Permit applicability and source status under Section 112 of the Clean Air Act (CAA).

**Greenhouse Gas (GHG) Emissions**

On June 23, 2014, in the case of *Utility Air Regulatory Group v. EPA*, cause no. 12-1146, (available at [http://www.supremecourt.gov/opinions/13pdf/12-1146\\_4g18.pdf](http://www.supremecourt.gov/opinions/13pdf/12-1146_4g18.pdf)) the United States Supreme Court ruled that the U.S. EPA does not have the authority to treat greenhouse gases (GHGs) as an air pollutant for the purpose of determining operating permit applicability or PSD Major source status. On July 24, 2014, the U.S. EPA issued a memorandum to the Regional Administrators outlining next steps in permitting decisions in light of the Supreme Court's decision. U.S. EPA's guidance states that U.S. EPA will no longer require PSD or Title V permits for sources "previously classified as 'Major' based solely on greenhouse gas emissions."

The Indiana Environmental Rules Board adopted the GHG regulations required by U.S. EPA at 326 IAC 2-2-1(zz), pursuant to Ind. Code § 13-14-9-8(h) (Section 8 rulemaking). A rule, or part of a rule, adopted under Section 8 is automatically invalidated when the corresponding federal rule, or part of the rule, is invalidated. Due to the United States Supreme Court Ruling, IDEM, OAQ cannot consider GHG emissions to determine operating permit applicability or PSD applicability to a source or modification.

**Source Status - Existing Source**

The table below summarizes the potential to emit of the entire source, prior to the proposed revision, after consideration of all enforceable limits established in the effective permits. If the control equipment has been determined to be integral, the table reflects the potential to emit (PTE) after consideration of the integral control device.

	Source-Wide Emissions Prior to Revision (ton/year)								
	PM <sup>1</sup>	PM <sub>10</sub> <sup>1</sup>	PM <sub>2.5</sub> <sup>1,2</sup>	SO <sub>2</sub>	NO <sub>x</sub>	VOC	CO	Single HAP <sup>3</sup>	Total HAPs
<b>Total PTE of Entire Source Excluding Fugitive Emissions*</b>	90.07	91.65	88.78	23.39	80.56	13.55	58.08	1.23	2.26

	Source-Wide Emissions Prior to Revision (ton/year)								
	PM <sup>1</sup>	PM <sub>10</sub> <sup>1</sup>	PM <sub>2.5</sub> <sup>1, 2</sup>	SO <sub>2</sub>	NO <sub>x</sub>	VOC	CO	Single HAP <sup>3</sup>	Total HAPs
Title V Major Source Thresholds	NA	100	100	100	100	100	100	10	25
PSD Major Source Thresholds	250	250	250	250	250	250	250	--	--
<sup>1</sup> Under the Part 70 Permit program (40 CFR 70), PM <sub>10</sub> and PM <sub>2.5</sub> , not particulate matter (PM), are each considered as a "regulated air pollutant." <sup>2</sup> PM <sub>2.5</sub> listed is direct PM <sub>2.5</sub> . <sup>3</sup> Single highest source-wide HAP is HCl *Fugitive HAP emissions are always included in the source-wide emissions.									

- (a) This existing source is not a major stationary source, under PSD (326 IAC 2-2), because no PSD regulated pollutant is emitted at a rate of two hundred fifty (250) tons per year or more and it is not one of the twenty-eight (28) listed source categories, as specified in 326 IAC 2-2-1(ff)(1).
- (b) This existing source is not a major source of HAP, as defined in 40 CFR 63.2, because HAP emissions are less than ten (10) tons per year for any single HAP and less than twenty-five (25) tons per year of a combination of HAPs.
- (c) These emissions are based on the TSD of SPR No. 129-43243-00021, issued on April 23, 2021.

**Description of Proposed Revision**

The Office of Air Quality (OAQ) has reviewed an application, submitted by AstraZeneca Pharmaceuticals LP on May 08, 2024, relating to addition of one (1) natural gas fired temporary boiler station, identified as (TB1), and removal of two (2) natural gas fired boilers installed in 1970, identified as Boiler #1 (S1) and Boiler #2 (S2).

The following is a list of the new emission units and pollution control device(s):

- (a) One (1) natural gas fired temporary boiler station, identified as (TB1), approved in 2024 for construction, with a maximum operating input rate of 60 MMBtu/hr, using No. 2 fuel oil as back up fuel, using no control, and exhausting to stacks S-1.

As part of this permitting action, the following emission units are being removed from the permit:

- (a) Two (2) natural gas fired boilers installed in 1970, identified as Boiler #1 (S1) and Boiler #2 (S2), each with a maximum heat input rate of 30.64 million (MM) British thermal units (Btu) per hour, and exhausting through stacks S-1 and S-2, respectively. Boilers #1 and #2 use No. 2 fuel oil as back-up fuel.

**Enforcement Issues**

There are no pending enforcement actions related to this revision.

**Emission Calculations**

See Appendix A of this Technical Support Document for detailed emission calculations.



**Permit Level Determination – FESOP Significant Permit Revision**

Pursuant to 326 IAC 2-1.1-1(12), Potential to Emit is defined as “the maximum capacity of a stationary source or emission unit to emit any air pollutant under its physical and operational design. Any physical or operational limitation on the capacity of a source to emit an air pollutant, including air pollution control equipment and restrictions on hours of operation or type or amount of material combusted, stored, or processed shall be treated as part of its design if the limitation is enforceable by the U. S. EPA, IDEM, or the appropriate local air pollution control agency.”

The following table is used to determine the appropriate permit level under 326 IAC 2-8-11.1 (Permit Revisions). This table reflects the PTE before controls of the proposed revision. If the control equipment has been determined to be integral, the table reflects the potential to emit (PTE) after consideration of the integral control device.

Process / Emission Unit	PTE Before Controls of the New Emission Units (ton/year)								
	PM	PM <sub>10</sub>	PM <sub>2.5</sub> <sup>1</sup>	SO <sub>2</sub>	NO <sub>x</sub>	VOC	CO	Single HAP <sup>2</sup>	Total HAPs
Temporary boiler (TBI)	3.75	4.32	4.32	79.97	37.54	1.42	21.64	0.464	0.486
<b>Total PTE Before Controls of the New Emission Unit:</b>	<b>3.75</b>	<b>4.32</b>	<b>4.32</b>	<b>79.97</b>	<b>37.54</b>	<b>1.42</b>	<b>21.64</b>	<b>0.464</b>	<b>0.486</b>

<sup>1</sup>PM<sub>2.5</sub> listed is direct PM<sub>2.5</sub>.  
<sup>2</sup>Single highest HAP (Hexane)

Appendix A of this TSD reflects the detailed potential emissions of the proposed revision.

Pursuant to 326 IAC 2-8-11.1(f)(1)(E), this FESOP is being revised through a FESOP Significant Permit Revision because the proposed revision is not an Administrative Amendment or Minor Permit revision and the proposed revision involves the construction of new emission units with potential to emit equal to or greater than twenty-five (25) tons per year of the following pollutants:

- (a) Sulfur dioxide (SO<sub>2</sub>).
- (b) Nitrogen oxides (NO<sub>x</sub>).

**PTE of the Entire Source After Issuance of the FESOP Revision**

The table below summarizes the after issuance source-wide potential to emit, reflecting all limits, of the emission units. Any control equipment is considered federally enforceable only after issuance of the revision, and only to the extent that the effect of the control equipment is made practically enforceable in the permit. If the control equipment has been determined to be integral, the table reflects the potential to emit (PTE) after consideration of the integral control device.

	Source-Wide Emissions After Issuance (ton/year)								
	PM <sup>1</sup>	PM <sub>10</sub> <sup>1</sup>	PM <sub>2.5</sub> <sup>1, 2</sup>	SO <sub>2</sub>	NO <sub>x</sub>	VOC	CO	Single HAP <sup>3</sup>	Total HAPs
<b>Total PTE of Entire Source Excluding Fugitives*</b>	89.99	91.55	88.72	23.39	80.01	13.52	57.61	1.23	2.25

	Source-Wide Emissions After Issuance (ton/year)								
	PM <sup>1</sup>	PM <sub>10</sub> <sup>1</sup>	PM <sub>2.5</sub> <sup>1, 2</sup>	SO <sub>2</sub>	NO <sub>x</sub>	VOC	CO	Single HAP <sup>3</sup>	Total HAPs
Title V Major Source Thresholds	NA	100	100	100	100	100	100	10	25
PSD Major Source Thresholds	250	250	250	250	250	250	250	--	--
<sup>1</sup> Under the Part 70 Permit program (40 CFR 70), PM <sub>10</sub> and PM <sub>2.5</sub> , not particulate matter (PM), are each considered as a "regulated air pollutant." <sup>2</sup> PM <sub>2.5</sub> listed is direct PM <sub>2.5</sub> . <sup>3</sup> Single highest source-wide HAP is HCl *Fugitive HAP emissions are always included in the source-wide emissions.									

Appendix A of this TSD reflects the detailed potential to emit the entire source after issuance.

The source opted to take SO<sub>2</sub> and NO<sub>x</sub> limit(s) in order to render the requirements of 326 IAC 2-7 (Part 70 Permits) not applicable to this source. See Technical Support Document (TSD) State Rule Applicability - Entire Source section, 326 IAC 2-2 (PSD), 326 IAC 2-8 (FESOP), for more information regarding the limit(s).

- (a) This existing Title V minor stationary source will continue to be minor under 326 IAC 2-7 because the potential to emit regulated air pollutants and HAPs from the entire source will continue to be less than or limited to less than the Title V major source threshold levels. Therefore, the source is subject to the provisions of 326 IAC 2-8 (FESOP) and is an area source under Section 112 of the Clean Air Act (CAA).
- (b) This existing minor PSD stationary source will continue to be minor under 326 IAC 2-2 because the potential to emit of all PSD regulated pollutants from the entire source will continue to be less than less than the PSD major source thresholds. Therefore, pursuant to 326 IAC 2-2, the PSD requirements do not apply.

**Federal Rule Applicability Determination**

Due to the proposed revision, federal rule applicability has been reviewed as follows:

**New Source Performance Standards (NSPS):**

- (a) The requirements of the New Source Performance Standard for Fossil-Fuel-Fired Steam Generators, 40 CFR 60, Subpart D and 326 IAC 12, are not included in the permit for the one (1) natural gas fired temporary boiler station, identified as (TB1), because it has less than 250 MMBtu/hr heat input capacity. which are exempt from this rule.
- (b) The requirements of the New Source Performance Standard for Electric Utility Steam Generating Units, 40 CFR 60, Subpart Da and 326 IAC 12, are not included in the permit for the one (1) natural gas fired temporary boiler station, identified as (TB1), because it has less than 250 MMBtu/hr heat input capacity, each, which are exempt from this rule.
- (c) The requirements of the New Source Performance Standard for Industrial-Commercial-Institutional Steam Generating Units, 40 CFR 60, Subpart Db and 326 IAC 12, are not included in the permit for the one (1) natural gas fired temporary boiler station, identified as (TB1), because it has less than 100 MMBtu/hr heat input capacity, which is exempt from this rule.
- (d) The one (1) natural gas fired temporary boiler station, identified as (TB1) is subject to the New Source Performance Standards for Small Industrial-Commercial-Institutional Steam Generating, 40 CFR 60, Subpart Dc and 326 IAC 12, because it meets the definition for a steam generating

unit, and it constructed in 2024, after the rule applicability date of June 9, 1989 and it has a heat input capacity greater than 10 MMBtu/hr and less than 100 MMBtu/hr.

The one (1) natural gas fired temporary boiler station, identified as (TB1) is subject to the following portions of Subpart Dc.

- (1) 40 CFR 60.40c(a) through (d), and (g)
- (2) 40 CFR 60.41c
- (3) 40 CFR 60.42c(d), (f), through (j)
- (4) 40 CFR 60.43c(c) and (d)
- (5) 40 CFR 60.44c(c), (g), and (h)
- (6) 40 CFR 60.45c(c)
- (7) 40 CFR 60.46c(e)
- (8) 40 CFR 60.47c(c)
- (9) 40 CFR 60.48c(a)(1) through (a)(4), (d), (e)(1) through (e)(3), (e)(11), and (f) through (j)

The requirements of 40 CFR Part 60, Subpart A – General Provisions, which are incorporated as 326 IAC 12-1, apply to the one (1) natural gas fired temporary boiler station, identified as (TB1) except as otherwise specified in 40 CFR 60, Subpart Dc.

- (e) There are no other New Source Performance Standards (40 CFR Part 60) and 326 IAC 12 included for this proposed revision.

**National Emission Standards for Hazardous Air Pollutants (NESHAP):**

- (f) The requirements of the National Emission Standards for Hazardous Air Pollutants (NESHAPs) for Major Sources: Industrial, Commercial, and Institutional Boilers and Process Heaters, 40 CFR 63, Subpart DDDDD are not included in the permit for the one (1) natural gas fired temporary boiler station, identified as (TB1), since the source is not a major source of HAPs and temporary boilers are exempt from the requirements of the subpart.
- (g) The requirements of the National Emission Standards for Hazardous Air Pollutants (NESHAPs) for Industrial, Commercial, and Institutional Boilers Area Sources, 40 CFR 63, Subpart JJJJJ are not included in the permit for the one (1) natural gas fired temporary boiler station, identified as (TB1), since the temporary boilers not subject to this subpart as defined in 40 CFR 63.11195(h).

**Compliance Assurance Monitoring (CAM):**

Pursuant to 40 CFR 64.2, Compliance Assurance Monitoring (CAM) is not included in the permit, because the unlimited potential to emit of the source is limited to less than the Title V major source thresholds and the source is not required to obtain a Part 70 or Part 71 permit.

<b>State Rule Applicability - Entire Source</b>
---

Due to this revision, state rule applicability has been reviewed as follows:

**326 IAC 2-2 (PSD) and 326 IAC 2-3 (Emission Offset)**

PSD and Emission Offset applicability is discussed under the PTE of the Entire Source After Issuance of the FESOP Revision section of this document.

**326 IAC 2-4.1 (Major Sources of Hazardous Air Pollutants (HAP))**

The new emission unit(s) will emit less than ten (10) tons per year for a single HAP and less than twenty-five (25) tons per year for a combination of HAPs. Therefore, 326 IAC 2-4.1 does not apply.

**326 IAC 2-6 (Emission Reporting)**

This source is not subject to 326 IAC 2-6 (Emission Reporting), because it is not required to have an operating permit pursuant to 326 IAC 2-7 (Part 70), it is not located in Lake or Porter County, and its

potential to emit lead is less than 5 tons per year. Therefore, this rule does not apply.

### **326 IAC 2-8-4 (FESOP)**

FESOP applicability is discussed under the PTE of the Entire Source After Issuance of the FESOP Revision section of this document.

#### FESOP SO<sub>2</sub>, NO<sub>x</sub> Limit(s)

Pursuant to 326 IAC 2-8-4 (FESOP), and in order to render the requirements of 326 IAC 2-7 (Part 70 Permits), not applicable, the Permittee shall comply with the following:

- (a) The total input of fuel oil No. 2 and fuel oil No. 2 equivalents to the one (1) 60.0 MMBtu/hr temporary boiler station, identified as (TB1) and one (1) 60.8 MMBtu/hr boiler identified as Boiler #3 (S27, shall be limited to less than 1,057,500 U.S. gallons per twelve (12) consecutive month period with compliance determined at the end of each month.
- (b) The sulfur content of distillate fuel oil No. 2 shall not exceed 0.3% by weight.
- (c) For purposes of determining compliance with paragraph (a) of this condition, the following shall apply:

Every one (1) million cubic feet of natural gas burned shall be equivalent to 14 gallons of No. 2 distillate fuel oil burned based on SO<sub>2</sub> emissions, such that the total usage of No. 2 distillate fuel oil with a maximum sulfur content of 0.3% and No. 2 oil equivalent input does not exceed the limit specified.

- (d) NO<sub>x</sub> emissions shall not exceed 20.0 lb/kgal of fuel oil.

Compliance with these limits, combined with the potential to emit SO<sub>2</sub> and NO<sub>x</sub> from all other emission units at this source, shall limit the source-wide total potential to emit of SO<sub>2</sub> and NO<sub>x</sub> to less than 100 tons per twelve (12) consecutive month period, each, and shall render the requirements of 326 IAC 2-7 (Part 70 Permits) not applicable.

### **326 IAC 5-1 (Opacity Limitations)**

Pursuant to 326 IAC 5-1-2 (Opacity Limitations), except as provided in 326 IAC 5-1-3 (Temporary Alternative Opacity Limitations), opacity shall meet the following, unless otherwise stated in this permit:

- (1) Opacity shall not exceed an average of forty percent (40%) in any one (1) six (6) minute averaging period as determined in 326 IAC 5-1-4.
- (2) Opacity shall not exceed sixty percent (60%) for more than a cumulative total of fifteen (15) minutes (sixty (60) readings as measured according to 40 CFR 60, Appendix A, Method 9 or fifteen (15) one (1) minute nonoverlapping integrated averages for a continuous opacity monitor) in a six (6) hour period.

### **326 IAC 6-4 (Fugitive Dust Emissions Limitations)**

Pursuant to 326 IAC 6-4 (Fugitive Dust Emissions Limitations), the source shall not allow fugitive dust to escape beyond the property line or boundaries of the property, right-of-way, or easement on which the source is located, in a manner that would violate 326 IAC 6-4.

### **326 IAC 6-5 (Fugitive Particulate Matter Emission Limitations)**

This source is not subject to the requirements of 326 IAC 6-5, because the source has potential fugitive particulate emissions of less than twenty-five (25) tons per year.

### **326 IAC 6.5 (Particulate Matter Limitations Except Lake County)**

Pursuant to 326 IAC 6.5-1-1(a), this source (located in Posey County) is not subject to the requirements of 326 IAC 6.5 because it is not located in one of the following counties: Clark, Dearborn, Dubois, Howard, Marion, St. Joseph, Vanderburgh, Vigo or Wayne.

**326 IAC 6.8 (Particulate Matter Limitations for Lake County)**

Pursuant to 326 IAC 6.8-1-1(a), this source (located in Posey County) is not subject to the requirements of 326 IAC 6.8 because it is not located in Lake County.

**326 IAC 6.8 (Lake County: Fugitive Particulate Matter)**

Pursuant to 326 IAC 6.8-10-1, this source (located in Posey County) is not subject to the requirements of 326 IAC 6.8-10 because it is not located in Lake County.

**State Rule Applicability – Individual Facilities**

Due to the proposed revision, state rule applicability has been reviewed as follows:

**Boilers (TB1)**

**326 IAC 6-2-4 (Particulate Matter Emission Limitations for Sources of Indirect Heating)**

Pursuant to 326 IAC 6-2-1(d), indirect heating facilities which received permit to construct after September 21, 1983 are subject to the requirements of 326 IAC 6-2-4.

The particulate matter emissions (Pt) shall be limited by the following equation:

$$Pt = \frac{1.09}{Q^{0.26}}$$

Where:

Pt = Pounds of particulate matter emitted per million British thermal units (lb/MMBtu).

Q = Total source maximum operating capacity rating in MMBtu/hr heat input. The maximum operating capacity rating is defined as the maximum capacity at which the facility is operated or the nameplate capacity, whichever is specified in the facility's permit application, except when some lower capacity is contained in the facility's operation permit; in which case, the capacity specified in the operation permit shall be used.

Indirect Heating Units Which Began Operation After September 21, 1983						
Facility	Construction Date (Removal Date)	Operating Capacity (MMBtu/hr)	Q (MMBtu/hr)	Calculated Pt (lb/MMBtu)	Particulate Limitation, (Pt) (lb/MMBtu)	PM PTE based on AP-42 (lb/MMBtu)
Boiler #1&2 @30.64MMBtu/h each	1970 (2024)	64.28	64.28	0.51	0.51	0.002
						0.14
Boiler #3 (S27)	2005	60.8	122.08	0.31	0.31	0.002
						0.014
Temporary boiler (TB1)	2024	60	120.8	0.31	0.31	0.002
						0.014

Indirect Heating Units Which Began Operation After September 21, 1983						
Facility	Construction Date (Removal Date)	Operating Capacity (MMBtu/hr)	Q (MMBtu/hr)	Calculated Pt (lb/MMBtu)	Particulate Limitation, (Pt) (lb/MMBtu)	PM PTE based on AP-42 (lb/MMBtu)
Where: Q = Includes the capacity (MMBtu/hr) of the new unit(s) and the capacities for those unit(s) which were in operation at the source at the time the new unit(s) was constructed.						
Note: Emission units shown in strikethrough were subsequently removed from the source. The effect of removing these units on "Q" is shown in the year the boiler was removed.						

**326 IAC 6-3-2 (Particulate Emission Limitations for Manufacturing Processes)**

Pursuant to 326 IAC 6-3-1.5, the one (1) natural gas fired temporary boiler station, identified as (TB1) is not subject to the requirements of 326 IAC 6-3, since burning gaseous fuels is not considered part of the process weight rate.

**326 IAC 7-1.1 Sulfur Dioxide Emission Limitations**

This emission unit is not subject to 326 IAC 326 IAC 7-1.1 because it has a potential to emit (or limited potential to emit) sulfur dioxide (SO<sub>2</sub>) of less than 25 tons per year or 10 pounds per hour.

**326 IAC 8-1-6 (VOC Rules: General Reduction Requirements for New Facilities)**

Even though, this unit was constructed after January 1, 1980, it is not subject to the requirements of 326 IAC 8-1-6 because its unlimited VOC potential emissions are less than twenty-five (25) tons per year.

**326 IAC 9-1 (Carbon Monoxide Emission Limits)**

The requirements of 326 IAC 9-1 do not apply to the one (1) natural gas fired temporary boiler station, identified as (TB1), because this source does not operate a catalyst regeneration petroleum cracking system or a petroleum fluid coker, grey iron cupola, blast furnace, basic oxygen steel furnace, or other ferrous metal smelting equipment.

**326 IAC 10-3 (Nitrogen Oxide Reduction Program for Specific Source Categories)**

The requirements of 326 IAC 10-3 do not apply to the one (1) natural gas fired temporary boiler station, identified as (TB1), since this unit is not a blast furnace gas-fired boiler, a Portland cement kiln, or a facility specifically listed under 326 IAC 10-3-1(a)(2).

**Compliance Determination and Monitoring Requirements**

- (a) The Compliance Determination Requirements applicable to this revision are as follows:
  - (1) IDEM OAQ has determined that testing of the one (1) natural gas fired temporary boiler station, identified as (TB1), and one (1) natural gas fired boiler, identified as Boiler #3 (S27) stacks are not required at this time to determine compliance with the SO<sub>2</sub>, NO<sub>x</sub> emission limits. IDEM has the authority to require testing at a later time if necessary to demonstrate compliance with any applicable requirement.
- (b) The Compliance Monitoring Requirements applicable to this proposed revision are as follows:

Control Device OR Emission Unit	Type of Monitoring	Frequency	Range or Specification
- Filters (pre-filters dust collector, HEPA filters, and fabric filter dust collector)	Filters inspections	Semi-annual	Verify that it is operated and maintained per manufacturer's specifications

Control Device OR Emission Unit	Type of Monitoring	Frequency	Range or Specification
Boiler (TB1), and Boiler #3 (when combusting Fuel Oil)	Visible emission notations	Daily	Verify whether emissions are normal or abnormal

These monitoring conditions are necessary because the one (1) natural gas fired temporary boiler station, identified as (TB1), one (1) natural gas fired boiler, and filters for the Tablet core press machines, GEA fluid-bed dryers, Tablet coating (Thomas Flex 500), and Central Vacuum System must operate properly to assure compliance with 326 IAC 2-8 (FESOP) and 326 IAC 6-3-2 (Particulate Emission Limitations)

**Proposed Changes**

The following changes listed below are due to the proposed revision. Deleted language appears as ~~strikethrough~~ text and new language appears as **bold** text:

- (1) The FESOP Annual Certification Form has been revised to include space for an email address and phone number.
- (2) The permit is revised to include the most recent version of (NSPS IIII, NESHAP ZZZZZ) as permit Attachments B and C, but this change is not shown in bold and strikethrough text in this TSD.
- (3) Section D.1.2 was modified to reflect the right Particulate Emissions Rule citation header for the one (1) natural gas fired boiler, identified as Boiler #3 (S27)
- (4) Section A.2, Section D.1, and Section E.1 have been updated to include the new emission units.
- (5) Section D.1.8 (Reporting Requirement) has been revised to reflect the correct state rule reference.

\*\*\*\*

A.2 Emission Units and Pollution Control Equipment Summary [326 IAC 2-8-3(c)(3)]

This stationary source consists of the following emission units and pollution control devices:

- ~~(a) Two (2) natural gas fired boilers installed in 1970, identified as Boiler #1 (S1) and Boiler #2 (S2), each with a maximum heat input rate of 30.64 million (MM) British thermal units (Btu) per hour, and exhausting through stacks S-1 and S-2, respectively. Boilers #1 and #2 use No. 2 fuel oil as back up fuel.~~
- (a) **One (1) natural gas fired temporary boiler station, identified as (TB1), approved in 2024 for construction, with a maximum operating input rate of 60 MMBtu/hr, uses No. 2 fuel oil as back up fuel, using no control, and exhausting to stacks S-1.**

**[Under 40 CFR 60, Subpart Dc, this is an affected source.]**

\*\*\*

A.4 Insignificant Activities [326 IAC 2-7-1(21)] [326 IAC 2-8-3(c)(3)(I)]

This stationary source also includes the following insignificant activities:

\*\*\*

- (h) The following diesel storage tanks:
  - (1) One (1) 20,000 gallon aboveground VOC storage tank containing diesel fuel oil,

installed in 1997, located at Building 104 and connected to ~~Boiler S1, Boiler S2,~~  
**temporary boiler (TB1)**, Boiler S27, emergency generator S3, emergency  
generator S32, and emergency generator S45.

\*\*\*

\*\*\*\*\*

SECTION D.1

EMISSIONS UNIT OPERATION CONDITIONS

Emissions Unit Description:

~~(a) Two (2) natural gas fired boilers installed in 1970, identified as Boiler #1 (S1) and Boiler #2 (S2), each with a maximum heat input rate of 30.64 million (MM) British thermal units (Btu) per hour, and exhausting through stacks S-1 and S-2, respectively. Boilers #1 and #2 use No. 2 fuel oil as back-up fuel.~~

(a) **One (1) natural gas fired temporary boiler station, identified as (TB1), approved in 2024 for construction, with a maximum operating input rate of 60 MMBtu/hr, uses No. 2 fuel oil as back up fuel, using no control, and exhausting to stacks S-1.**

**[Under 40 CFR 60, Subpart Dc, this is an affected source.]**

\*\*\*

Emission Limitations and Standards [326 IAC 2-8-4(1)]

D.1.1 FESOP Minor Limits [326 IAC 2-8-4]

Pursuant to 326 IAC 2-8-4 (FESOP) and in order to render the requirements of 326 IAC 2-7 (Part 70 Permits) not applicable, the Permittee shall comply with the following:

(a) The total input of fuel oil No. 2 and fuel oil No. 2 equivalents to the ~~two (2) 30.64 MMBtu/hr boilers #1 (S1) and #2 (S2),~~ **one (1) temporary boiler station identified as (TB1)**, and one (1) 60.8 MMBtu/hr boiler #3 (S27), shall be limited to less than 1,057,500 U.S. gallons per twelve (12) consecutive month period with compliance determined at the end of each month.

\*\*\*

~~D.1.2 Particulate Emission Limitations [326 IAC 6-2-3]~~

~~(a) Pursuant to 326 IAC 6-2-3 (b) (Particulate Emission Limitations for Sources of Indirect Heating), PM emissions from Boilers #1 (S1) and #2 (S2), which were existing and in operation on or before June 8, 1972, shall be limited to 0.51 lbs/MMBtu.~~

~~(b) Pursuant to 326 IAC 6-2-4(a) (Particulate Matter Emission Limitations for Sources of Indirect Heating), PM emissions from Boiler #3 (S27) shall be limited to 0.312 lbs/MMBtu.~~

**D.1.2 Particulate Emissions [326 IAC 6-2-4]**

**Pursuant to 326 IAC 6-2-4 (Particulate Emission Limitations for Sources of Indirect Heating), the PM emissions from the following units shall be limited to the PM emission limit (Pt) in pounds per MMBtu heat input as specified in the following table:**

Emission Unit	Unit ID	Pt (lb/MMBtu)
<b>Boiler #3 (S27)</b>	<b>(S27)</b>	<b>0.31</b>



<b>Temporary boiler (TB1)</b>	<b>(TB1)</b>	<b>0.31</b>
-------------------------------	--------------	-------------

D.1.3 Sulfur Dioxide (SO<sub>2</sub>) Limits [326 IAC 7-1.1-2]

Pursuant to 326 IAC 7-1.1-2(a)(3) (Sulfur dioxide emission limitations) the SO<sub>2</sub> emissions from the Boilers #1 (S1), #2 (S2) **Temporary Boiler station identified as (TB1)**, and #3 (S27), shall not exceed five tenths (0.5) pounds per MMBtu heat input for distillate oil combustion. SO<sub>2</sub> emissions will be determined based on monthly average.

\*\*\*

Compliance Determination Requirements [326 IAC 2-8-4(1)]

D.1.5 Sulfur Dioxide Emissions and Sulfur Content

\*\*\*

(b) Compliance shall be determined using one of the following options:

\*\*\*

(2) Pursuant to 326 IAC 7-2-1(h)(1), compliance may also be determined by conducting a stack test for sulfur dioxide emissions from the boilers ~~S-1, S-2~~ **TB1**, and S-27 using 40 CFR 60, Appendix A, Method 6 in accordance with the procedures in 326 IAC 3-6.

\*\*\*

Compliance Monitoring Requirements [326 IAC 2-8-4(1)][326 IAC 2-8-5(a)(1)]

D.1.6 Visible Emission Notations

(a) Visible emission notations of Boilers **(TB1)**, and #3 (S27) stack exhausts shall be performed once per day during normal daylight operations when combusting fuel oil. A trained employee shall record whether emissions are normal or abnormal.

\*\*\*

\*\*\*

D.1.8 Reporting Requirements

(a) If the Permittee is a member of IDEM's Environmental Stewardship Program (ESP) program, the Permittee may submit reports summarizing the information to document compliance with Condition D.1.1 according to the provisions of ~~paragraph (e)~~ **Condition C.16(e)** of Section C General Reporting Requirements.

(b) A ~~quarterly~~ **semi-annual** report of No. 2 fuel oil and No. 2 oil equivalent usage and a ~~quarterly~~ **semi-annual** summary of the information to document the compliance status with D.1.1(a) shall be submitted not later than thirty (30) days after the end of the quarter being reported. Section C - General Reporting contains the Permittee's obligation with regard to the reporting required by this condition.

**Otherwise, a quarterly summary of the information to document the compliance status with Condition D.1.1 shall be submitted not later than thirty (30) days after the end of the quarter being reported. Section C - General Reporting contains the Permittee's obligation with regard to the reporting required by this condition. The report submitted by the Permittee does require a certification that meets the requirements of 326 IAC 2-8-5(a)(1) by an authorized individual as defined by 326 IAC 2-1.1-1(1).**

~~The report does require a certification that meets the requirements of 326 IAC 2-8-5(a)(1) by an~~

~~"authorized individual" as defined by 326 IAC 2-1.1-1(1).~~

SECTION D.2 EMISSIONS UNIT OPERATION CONDITIONS

\*\*\*

Compliance Monitoring Requirements [326 IAC 2-8-4(1)][326 IAC 2-8-5(a)(1)]

D.2.4 Semi-Annual Filter Inspections

The Permittee shall perform semi-annual inspections of the filters listed in Condition D.3.2.3 controlling particulate emissions from the respective emission units to verify that they are being operated and maintained in accordance with the manufacturer's specifications. Inspections required by this condition shall not be performed in consecutive months. All defective bags and/or filters shall be replaced.

\*\*\*

\*\*\*\*\*

SECTION E.1 NSPS

Emissions Unit Description:

- (a) **One (1) natural gas fired temporary boiler station, identified as (TB1), approved in 2024 for construction, with a maximum operating input rate of 60 MMBtu/hr, uses No. 2 fuel oil as back up fuel, using no control, and exhausting to stacks S-1.**

**[Under 40 CFR 60, Subpart Dc, this is an affected source.]**

\*\*\*

(The information describing the process contained in this emissions unit description box is descriptive information and does not constitute enforceable conditions.)

New Source Performance Standards (NSPS) Requirements [326 IAC 2-8-4(1)]

\*\*\*

\*\*\*\*\*

INDIANA DEPARTMENT OF ENVIRONMENTAL MANAGEMENT  
OFFICE OF AIR QUALITY  
COMPLIANCE AND ENFORCEMENT BRANCH

FEDERALLY ENFORCEABLE STATE OPERATING PERMIT (FESOP)  
CERTIFICATION

Source Name: AstraZeneca Pharmaceuticals LP  
Source Address: 4601 Highway 62 East, Mt. Vernon, Indiana 47620  
FESOP Permit No.: F129-36688-00021

This certification shall be included when submitting monitoring, testing reports/results or other documents as required by this permit.

Please check what document is being certified:

<input type="checkbox"/> Annual Compliance Certification Letter <input type="checkbox"/> Test Result (specify) _____ <input type="checkbox"/> Report (specify) _____ <input type="checkbox"/> Notification (specify) _____ <input type="checkbox"/> Affidavit (specify) _____ <input type="checkbox"/> Other (specify) _____
---

I certify that, based on information and belief formed after reasonable inquiry, the statements and information in the document are true, accurate, and complete.	
Signature: _____	
Printed Name: _____	
Title/Position: _____	
Email Address: _____	Phone: _____
Date: _____	

\*\*\*\*\*

**INDIANA DEPARTMENT OF ENVIRONMENTAL MANAGEMENT  
 OFFICE OF AIR QUALITY  
 COMPLIANCE AND ENFORCEMENT BRANCH**

FESOP Usage Report

Source Name: AstraZeneca Pharmaceuticals LP  
 Source Address: 4601 Highway 62 East, Mt. Vernon, Indiana 47620  
 FESOP Permit No.: F129-36688-00021  
 Facility: ~~Two (2) 30.64 MMBtu/hr boilers #1 (S1) and #2 (S2),~~ **One (1) Temporary Boiler (TB1) and one (1) 60.8 MMBtu/hr Boiler #3 (S27)**  
 Parameter: Fuel oil no. 2 equivalent usage  
 Limit: Total input of distillate fuel oil no. 2 distillate fuel oil equivalents to ~~boilers #1 (S1), #2 (S2)~~ **one (1) Temporary Boiler (TB1),** and #3 (S27) shall be limited to 1,057,500 gallons per twelve (12) consecutive month period, with compliance determined at the end of each month.

Quarter: \_\_\_\_\_ YEAR: \_\_\_\_\_

Month	Column 1	Column 2	Column 1 + Column 2
	No. 2 Distillate Fuel Oil Equivalent Usage This Month (gallons)	No. 2 Distillate Fuel Oil Equivalent Usage Previous 11 Months (gallons)	12 Month Total No. 2 Distillate Fuel Oil Equivalent Usage (gallons)


No deviation occurred in this quarter.

Deviation/s occurred in this quarter.

Deviation has been reported on: \_\_\_\_\_

Submitted by: \_\_\_\_\_

Title / Position: \_\_\_\_\_

Signature: \_\_\_\_\_

Date: \_\_\_\_\_

Phone: \_\_\_\_\_

### Conclusion and Recommendation

Unless otherwise stated, information used in this review was derived from the application and additional information submitted by the applicant. An application for the purposes of this review was received on May 08, 2024.

The construction and operation of this proposed revision shall be subject to the conditions of the attached proposed FESOP Significant Permit Revision No. 129-47826-00021. The staff recommends to the Commissioner that the FESOP Significant Permit Revision be approved.

### IDEM Contact

- (a) If you have any questions regarding this permit, please contact Hind Mohamed, Indiana Department Environmental Management, Office of Air Quality, Permits Branch, 100 North Senate Avenue, MC 61-53 IGCN 1003, Indianapolis, Indiana 46204-2251, or by telephone at (317) 234-6543 or (800) 451-6027, and ask for Hind Mohamed or (317) 234-6543.
- (b) A copy of the findings is available on the Internet at: <http://www.in.gov/ai/appfiles/idem-caats/>
- (c) For additional information about air permits and how the public and interested parties can participate, refer to the IDEM Air Permits page on the Internet at: <https://www.in.gov/idem/airpermit/public-participation/>; and the Citizens' Guide to IDEM on the Internet at: <https://www.in.gov/idem/resources/citizens-guide-to-idem/>.



**Appendix A: Emission Calculations  
PTE Summary**

**Company Name:** AstraZeneca Pharmaceuticals LP  
**Address City IN Zip:** 4601 Highway 62 East, Mt. Vernon, IN 47620  
**Permit No:** SPR 129-47826-00021  
**Reviewer:** Hind Mohamed

PTE of New Emissions Unit (tons/yr)										
Emission Unit	PM	PM10	PM2.5	SO <sub>2</sub>	NOx	VOC	CO	Single HAPs	Total HAPs	
Temporary boiler (TBI) Natural Gas	0.49	1.96	1.96	0.15	25.76	1.42	21.64	0.464	0.486	Hexane
Temporary boiler (TBI) No. 2 Distillate Oil	3.75	4.32	4.32	79.97	37.54	0.64	0.64	0.004	0.013	Selenium
Worst Case Fuel Combustion Boilers TB1	3.75	4.32	4.32	79.97	37.54	1.42	21.64	0.464	0.486	Hexane
<b>Significant Permit Revision(tpy) Threshold</b>	≥ 25	≥ 25	≥ 25	≥ 25	≥ 25	≥ 25	≥ 100	≥ 10	≥ 25	

**Appendix A: Emission Calculations  
Boilers TB1&S27**

**No. 2 Fuel Oil Combustion Only  
MM BTU/HR <100**

**Company Name:** AstraZeneca Pharmaceuticals LP  
**Address City IN Zip:** 4601 Highway 62 East, Mt. Vernon, IN 47620  
**Permit No:** SPR 129-47826-00021  
**Reviewer:** Hind Mohamed

Emission Unit ID	Heat Input Capacity (MMBtu/hr)	Oil Sulfur Content (%)
TB1	60	0.3
S27	60.8	
<b>Total</b>	<b>120.8</b>	

Limited Throughput (kgal/yr)	Fuel Heat Value (MMBtu/kgal)	Limited Heat Input (MMBtu/year)
<b>1,057.500</b>	<b>140</b>	<b>148,050</b>

(kgal/yr)	(MMBtu/kgal)	(MMBtu/hr)	(hr/yr)	(Day/yr)
4230	140	120.8	4902.318	204.26
1057.50	140	120.8	1.226	51

Emission Factor (lb/kgal)								
Fuel Type	Fuel Heat Value (MMBtu/kgal)	PM	PM10	direct PM2.5	SO <sub>2</sub> (142S)	NOx	VOC	CO
No. 2 Distillate Oil	140	2.00	2.30	1.55	42.6	20.0	0.34	5.00

Emission factors from AP 42, Chapter 1.3, Tables 1.3-1, 1.3-2, 1.3-3, 1.3-6, 1.3-10, and 1.3-11. (9/98)

Potential to Emit (ton/yr)								
Emission Unit ID	Potential Throughput (kgal/yr)	PM	PM10	direct PM2.5	SO <sub>2</sub>	NOx	VOC	CO
TB1	3,754	3.75	4.32	2.91	79.97	37.54	0.64	9.39
S27	3,804	3.80	4.37	2.95	81.0	38.04	0.65	9.51
<b>Total</b>	<b>7,559</b>	<b>7.56</b>	<b>8.69</b>	<b>5.86</b>	<b>161.00</b>	<b>75.59</b>	<b>1.28</b>	<b>18.90</b>

Limited Potential to Emit (ton/yr)								
Emission Unit ID	Limited Throughput (kgal/yr)*	PM	PM10	direct PM2.5	SO <sub>2</sub>	NOx	VOC	CO
Boilers TB1 & S27	1,057.500	-	-	-	22.52	10.58	-	-
<b>Total</b>	<b>1,057.500</b>	-	-	-	<b>22.52</b>	<b>10.58</b>	-	-

\* The total input of fuel No2 for the two boilers (TB, S3) limited to 1/4 of the annual throughput of fuel oil (4320kgal/yr)

**Methodology**

Limited throughput kgal/yr = 0.25\*Total throughput(kgal/yr)

Potential Throughput (kgal/yr) = Heat Input Capacity (MMBtu/hr) x 8,760 hr/yr x 1/Fuel Heat Value (MMBtu/kgal)

Potential to Emit (ton/yr) = Throughput (kgal/yr) x Emission Factor (lb/kgal) x 1 ton/2,000 lb

Emission Factor (lbs/mmBtu)									
Fuel Type	Arsenic	Beryllium	Cadmium	Chromium	Lead	Mercury	Manganese	Nickel	Selenium
No. 2 Distillate Oil	4.0E-06	3.0E-06	3.0E-06	3.0E-06	9.0E-06	3.0E-06	6.0E-06	3.0E-06	1.5E-05

Emission factors from AP 42, Chapter 1.3, Tables 1.3-9 and 1.3-11. (9/98)

Potential To Emit (tons/yr)									
Emission Unit ID	Arsenic	Beryllium	Cadmium	Chromium	Lead	Mercury	Manganese	Nickel	Selenium
TB1	1.05E-03	7.88E-04	7.88E-04	7.88E-04	2.37E-03	7.88E-04	1.58E-03	7.88E-04	3.94E-03
S27	1.07E-03	7.99E-04	7.99E-04	7.99E-04	2.40E-03	7.99E-04	1.60E-03	7.99E-04	3.99E-03
<b>Total</b>	<b>2.12E-03</b>	<b>1.59E-03</b>	<b>1.59E-03</b>	<b>1.59E-03</b>	<b>4.76E-03</b>	<b>1.59E-03</b>	<b>3.17E-03</b>	<b>1.59E-03</b>	<b>7.94E-03</b>

**Methodology**

Potential To Emit (tons/year) = Throughput (kgal/yr) x Emission Factor (lbs/kgal) x 1 ton/2,000 lbs

<b>Total HAPs</b>	<b>0.03</b>	
<b>Worst Single HAP</b>	<b>7.94E-03</b>	Selenium
<b>Total HAPs ( TB1)</b>	<b>0.01</b>	
<b>Worst Single HAP ( TB1)</b>	<b>3.94E-03</b>	Selenium



**Appendix A: Emission Calculations  
Boilers TB1, and #3**

**Natural Gas Combustion Only  
MM BTU/HR <100**

**Company Name:** AstraZeneca Pharmaceuticals LP  
**Address City IN Zip:** 4601 Highway 62 East, Mt. Vernon, IN 47620  
**Permit No:** SPR 129-47826-00021  
**Reviewer:** Hind Mohamed

Emission Unit ID	Heat Input Capacity (MMBtu/hr)
TB1	60
S27	60.8
<b>Total</b>	<b>120.8</b>

Unlimited Heat Input Capacity @ 8760 hrs/yr (MMBtu/yr)
<b>525,600</b>
<b>1,058,208</b>

NOx Burner Type	Fuel Heat Value (MMBtu/MMCF)	Emission Factor (lbs/MMCF)						
		PM*	PM10*	direct PM2.5	SO <sub>2</sub>	NOx**	VOC	CO
Ordinary Burners	1,020	1.9	7.6	7.6	0.6	100	5.5	84.0
Low Nox Burners (Boiler S27)						32		

\* PM emission factor is for filterable PM only. PM10 emission factor is for condensable PM10 and filterable PM combined.  
 \*\* Emission factors for NOx: Uncontrolled = 100 lbs/MMCF, Low NOx Burners = 50 lbs/MMCF, Low Nox Burners + FGR = 32 lbs/MMCF  
 Emission factors are from AP 42, Chapter 1.4, Tables 1.4-1, and 1.4-2, SCC 1-01-006-02, 1-02-006-02, 1-03-006-02, 1-03-006-03. (7/98)

Emission Unit ID	Potential Throughput (MMCF/yr)	Potential To Emit (tons/yr)						
		PM	PM10	direct PM2.5	SO <sub>2</sub>	NOx	VOC	CO
TB1	515.3	0.49	1.96	1.96	0.15	25.76	1.42	21.64
S27	522.2	0.50	1.98	1.98	0.16	8.35	1.44	21.93
<b>Total</b>	<b>1037.5</b>	<b>0.99</b>	<b>3.94</b>	<b>3.94</b>	<b>0.31</b>	<b>34.12</b>	<b>2.85</b>	<b>43.57</b>

**Methodology**

Maximum Potential Throughput (MMCF/yr) = Heat Input Capacity (MMBtu/hr) x 8,760 (hrs/yr) x 1 MMCF/1,000 MMBtu  
 Potential To Emit (tons/year) = Throughput (MMCF/yr) x Emission Factor (lbs/MMCF) x 1 ton/2,000 lbs

Emission Factor (lbs/MMCF)										
Benzene	Dichlorobenzene	Formaldehyde	Hexane	Toluene	Cadmium	Chromium	Manganese	Mercury	Nickel	
2.1E-03	1.2E-03	7.5E-02	1.8E+00	3.4E-03	1.1E-03	1.4E-03	3.8E-04	2.6E-04	2.1E-03	

Emission Unit ID	Potential To Emit (tons/yr) - Scenario #1									
	Benzene	Dichlorobenzene	Formaldehyde	Hexane	Toluene	Cadmium	Chromium	Manganese	Mercury	Nickel
TB1	5.41E-04	3.09E-04	1.93E-02	4.64E-01	8.76E-04	2.83E-04	3.61E-04	9.79E-05	6.70E-05	5.41E-04
S27	5.48E-04	3.13E-04	1.96E-02	4.70E-01	8.88E-04	2.87E-04	3.66E-04	9.92E-05	6.79E-05	5.48E-04
<b>Total</b>	<b>1.09E-03</b>	<b>6.22E-04</b>	<b>3.89E-02</b>	<b>9.34E-01</b>	<b>1.76E-03</b>	<b>5.71E-04</b>	<b>7.26E-04</b>	<b>1.97E-04</b>	<b>1.35E-04</b>	<b>1.09E-03</b>

HAP emission factors are from AP 42, Chapter 1.4, Tables 1.4-3 and 1.4-4. (7/98)

<b>Total HAP</b>	<b>0.98</b>	
<b>Worst Single HAP</b>	<b>0.93</b>	Hexane
<b>Total HAPs ( TB1)</b>	<b>0.49</b>	
<b>Worst Single HAP ( TB1)</b>	<b>0.46</b>	Hexane

**Methodology**

Potential To Emit (tons/yr) = Throughput (MMCF/yr) x Emission Factor (lbs/MMCF) x 1 ton/2,000 lbs

**Appendix A: Emission Calculations  
Boilers TB1, and #3**

**Natural Gas Combustion Only - NG fired after Maximum Fuel Oil Fired  
MM BTU/HR <100**

**Company Name:** AstraZeneca Pharmaceuticals LP  
**Address City IN Zip:** 4601 Highway 62 East, Mt. Vernon, IN 47620  
**Permit No:** SPR 129-47826-00021  
**Reviewer:** Hind Mohamed

Emission Unit ID	Heat Input Capacity (MMBtu/hr)	Unlimited Heat Input Capacity (MMBtu/yr)	FO Limited Heat Input (MMBtu/year)	NG Heat Input (MMBtu/year)	NG Fuel use (MMCF/year)
TB1	60	525,600	148,050	910,158	892.3
S27	60.8	1,058,208			
<b>Total</b>	<b>120.8</b>				

NOx Burner Type	Fuel Heat Value (MMBtu/MMCF)	Emission Factor (lbs/MMCF)						
		PM*	PM10*	direct PM2.5	SO <sub>2</sub>	NOx**	VOC	CO
Ordinary Burners	1,020	1.9	7.6	7.6	0.6	100	5.5	84.0
Low Nox Burners (Boiler S27)						32		

\* PM emission factor is for filterable PM only. PM10 emission factor is for condensable PM10 and filterable PM combined.

\*\* Emission factors for NOx: Uncontrolled = 100 lbs/MMCF, Low NOx Burners = 50 lbs/MMCF, Low Nox Burners + FGR = 32 lbs/MMCF

Emission factors are from AP 42, Chapter 1.4, Tables 1.4-1, and 1.4-2, SCC 1-01-006-02, 1-02-006-02, 1-03-006-02, 1-03-006-03. (7/98)

Emission Unit ID	Limited Throughput (MMCF/yr)	Potential To Emit (tons/yr)						
		PM	PM10	direct PM2.5	SO <sub>2</sub>	NOx	VOC	CO
TB1	515.3	0.49	1.96	1.96	0.15	25.76	1.42	21.64
S27	377.0	0.36	1.43	1.43	0.11	6.03	1.04	15.83
<b>Total</b>	<b>892.3</b>	<b>0.85</b>	<b>3.39</b>	<b>3.39</b>	<b>0.27</b>	<b>31.80</b>	<b>2.45</b>	<b>37.48</b>

**Methodology**

Limited NG Throughput (MMCF/yr) = NG limited annual Heat Input Capacity (MMBtu/yr) x 1 MMCF/1,020 MMBtu

Limited NG Potential To Emit (tons/year) = Limited NG Throughput (MMCF/yr) x Emission Factor (lbs/MMCF) x 1 ton/2,000 lbs

Emission Factor (lbs/MMCF)									
Benzene	Dichlorobenzene	Formaldehyde	Hexane	Toluene	Cadmium	Chromium	Manganese	Mercury	Nickel
2.1E-03	1.2E-03	7.5E-02	1.8E+00	3.4E-03	1.1E-03	1.4E-03	3.8E-04	2.6E-04	2.1E-03

Emission Unit ID	Potential To Emit (tons/yr) - Scenario #1									
	Benzene	Dichlorobenzene	Formaldehyde	Hexane	Toluene	Cadmium	Chromium	Manganese	Mercury	Nickel
TB1	5.41E-04	3.09E-04	1.93E-02	4.64E-01	8.76E-04	2.83E-04	3.61E-04	9.79E-05	6.70E-05	5.41E-04
S27	3.96E-04	2.26E-04	1.41E-02	3.39E-01	6.41E-04	2.07E-04	2.64E-04	7.16E-05	4.90E-05	3.96E-04
<b>Total</b>	<b>9.37E-04</b>	<b>5.35E-04</b>	<b>3.35E-02</b>	<b>8.03E-01</b>	<b>1.52E-03</b>	<b>4.91E-04</b>	<b>6.25E-04</b>	<b>1.70E-04</b>	<b>1.16E-04</b>	<b>9.37E-04</b>
									<b>Total HAP</b>	<b>0.84</b>

HAP emission factors are from AP 42, Chapter 1.4, Tables 1.4-3 and 1.4-4. (7/98)

**Methodology**

NG Limited Potential To Emit (tons/yr) = Limited NG Throughput (MMCF/yr) x Emission Factor (lbs/MMCF) x 1 ton/2,000 lbs

**Appendix A: Emission Calculations  
Fuel Equivalency for Boilers TB1, and #3**

**Company Name:** AstraZeneca Pharmaceuticals LP  
**Address City IN Zip:** 4601 Highway 62 East, Mt. Vernon, IN 47620  
**Permit No:** SPR 129-47826-00021  
**Reviewer:** Hind Mohamed

Fuel equivalence limit for natural gas based on SO2 emissions from #2 distillate fuel oil:

$$\frac{0.31 \text{ n.g. potential emissions (ton/yr)}}{1037.46 \text{ n.g. potential usage (MMCF/yr)}} \div \frac{161.00 \text{ #2 fuel oil potential emissions (ton/yr)}}{7.56E+03 \text{ #2 fuel oil potential usage (kgal/yr)}}$$

$$= \frac{0.014 \text{ No. 2 distillate fuel oil (kgal)}}{\text{MMCF n.g. burned}}$$

**326 IAC 7 Compliance Calculations:**

The following calculations determine the maximum sulfur content of distillate fuel oil (No. 2 Oil) allowable by 326 IAC 7:

$$0.5 \text{ lb/MMBtu} \times 140,000 \text{ Btu/gal} = 70 \text{ lb/1000gal}$$

$$70 \text{ lb/1000gal} \div 144 \text{ lb/1000 gal} = 0.5 \%$$

Sulfur content must be less than or equal to 0.5% to comply with 326 IAC 7.

**Appendix A: Emission Calculations  
Pressing and Granulation Facilities  
Bld 122 Presses and Bld 123 Granulation**

**Company Name:** AstraZeneca Pharmaceuticals LP  
**Address City IN Zip:** 4601 Highway 62 East, Mt. Vernon, IN 47620  
**Permit No:** SPR 129-47826-00021  
**Reviewer:** Hind Mohamed

Particulate Matter Emissions from mixing, weighing, pressing, and coating facilities

Unit ID	Max. Process Weight Rate lb/hr	Emission Factor lb PM / 1000 lb solids	Source of Emission Factor *	Control Efficiency (%)	Potential Uncontrolled PM Emissions lbs/hr	Potential Uncontrolled PM Emissions tons/yr	Potential Controlled PM Emissions tons/yr
Tablet Core Presses (Building 122, Room 1109)	425.00	3.90	Emission factor developed from stack testing study conducted at Mead Johnson - Evansville (March 1993)	75%	<b>1.66</b>	7.26	1.81
Tablet Core Presses (Building 122, Room 1111)	425.00	3.90	Emission factor developed from stack testing study conducted at Mead Johnson - Evansville (March 1993)	75%	<b>1.66</b>	7.26	1.81
Granulator: Aqueous wet Granulations (Building 123, Room 1202)	290.00	2.10	Emission factor developed from stack testing study conducted at Mead Johnson - Evansville (March 1993)	99%	0.30	1.33	0.01
GEA fluid bed dryer: Aqueous wet Granulations (Building 123, Room 1202)	290.00	10.00	Worse case engineering estimate - amount lost to product recovery bag filter from materials	75%	<b>1.45</b>	6.35	1.59
Granulator: Aqueous wet Granulations (Building 123, Room 1229)	290.00	2.10	Emission factor developed from stack testing study conducted at Mead Johnson - Evansville (March 1993)	99%	0.30	1.33	0.01
GEA fluid bed dryer: Aqueous wet Granulations (Building 123, Room 1229)	290.00	10.00	Worse case engineering estimate - amount lost to product recovery bag filter from materials	75%	<b>1.45</b>	6.35	1.59

**Methodology**

Throughput (lb/hr) \* EF (lb PM / 1000 lb solids) \* 8760 hr/yr \* ton/2000 lb = throughput (ton/yr)

\* Emission factors are provided by the source; PM, PM10, PM2.5 presumed same.

**Appendix A: Emission Calculations  
Building 121 Granulation, Pressing, and Coating  
Particulate Matter Emissions**

**Company Name:** AstraZeneca Pharmaceuticals LP  
**Address City IN Zip:** 4601 Highway 62 East, Mt. Vernon, IN 47620  
**Permit No:** SPR 129-47826-00021  
**Reviewer:** Hind Mohamed

Unit ID	Max. Process Weight Rate	Emission Factor	Source of	Control Efficiency	Potential Uncontrolled	Potential Uncontrolled	Potential Controlled
	lb/hr	lb PM / 2000 lb solids	Emission Factor *	(%)	PM Emissions	PM Emissions	PM Emissions
					lbs/hr	tons/yr	tons/yr ***
Granulator: Aqueous Granulations (Building 121, Room 1119)	98.00	2.10	Emission factor developed from stack testing study conducted at Mead Johnson - Evansville (March 1993)	99%	0.10	0.45	0.005
Glatt 120 fluid bed dryer: Aqueous Granulations (Building 121, Room 1119)	98.00	10.00	Worse case engineering estimate - amount lost to product recovery bag filter from materials	99%	0.49	2.15	0.02
Tablet Core Press (Building 121, Room 116c)	80.00	7.80	Emission factor developed from stack testing study conducted at Mead Johnson - Evansville (March 1993)	99%	0.31	1.37	0.01
Tablet Coater (Building 121, Room 116c)	50.00	2.00	Emission factor developed from stack testing study conducted at Mead Johnson - Evansville (March 1993)	99%	0.05	0.22	0.00
Tablet Core Press (Building 121, Room 1014)	80.00	7.80	Emission factor developed from stack testing study conducted at Mead Johnson - Evansville (March 1993)	99%	0.31	1.37	0.01
Tablet Coater (Building 121, Room 1023)	50.00	2.00	Emission factor developed from stack testing study conducted at Mead Johnson - Evansville (March 1993)	99%	0.05	0.22	0.00

**Total Potential PM Emissions (tons/yr):**

**5.77**

**0.06**

**Methodology**

Throughput (lb/hr) \* EF (lb PM / 2000 lb solids) \* 8760 hr/yr \* ton/2000 lb = throughput (ton/yr)

\* Emission factors are provided by the source; PM, PM10, PM2.5 presumed same.

\*\* Evansville Stack Test, 3/93, approved by IDEM.

**Appendix A: Emission Calculations  
Building 122 Tablet Press and Encapsulate  
Particulate Matter Emissions**

**Company Name:** AstraZeneca Pharmaceuticals LP  
**Address City IN Zip:** 4601 Highway 62 East, Mt. Vernon, IN 47620  
**Permit No:** SPR 129-47826-00021  
**Reviewer:** Hind Mohamed

Particulate Matter Emissions from mixing, weighing, pressing, and coating facilities

Unit ID	Max. Process Weight Rate lb/hr	Emission Factor lb PM / 1000 lb solids	Source of Emission Factor *	Control Efficiency (%)	Potential Uncontrolled PM Emissions lbs/hr	Potential Uncontrolled PM Emissions tons/yr	Potential Controlled PM Emissions tons/yr ***
Tablet Core Press (Building 122, Room 1113)	165.00	3.90	Emission factor developed from stack testing study conducted at Mead Johnson - Evansville (March 1993)	99.00	<b>0.64</b>	2.82	0.0282
Encapsulator Machine (Building 122, Room 1123)	110.00	3.90	Emission factor developed from stack testing study conducted at Mead Johnson - Evansville (March 1993)	99.00	0.43	1.88	0.0188
Encapsulator Machine (Building 122, Room 1124)	185.00	3.90	Emission factor developed from stack testing study conducted at Mead Johnson - Evansville (March 1993)	99.00	<b>0.72</b>	3.16	0.0316
<b>Total Potential PM Emissions (tons/yr):</b>						<b>7.86</b>	<b>0.08</b>

**Methodology**

Throughput (lb/hr) \* EF (lb PM / 1000 lb solids) \* 8760 hr/yr \* ton/2000 lb = throughput (ton/yr)

\* Emission factors are provided by the source; PM, PM10, PM2.5 presumed same.

\*\* Evansville Stack Test, 3/93, approved by IDEM.

**Appendix A: Emission Calculations  
Building 123 Pressing and Coating Facilities**

**Company Name:** AstraZeneca Pharmaceuticals LP  
**Address City IN Zip:** 4601 Highway 62 East, Mt. Vernon, IN 47620  
**Permit No:** SPR 129-47826-00021  
**Reviewer:** Hind Mohamed

Unit ID	Max. Process Weight Rate lb/hr	Emission Factor lb PM / 2000 lb solids	Source of Emission Factor *	Control Efficiency(%)	Potential Uncontrolled (lbs/hr)	Potential Uncontrolled (tons/yr)	Potential Controlled (tons/yr)
Bin Charging System (Building 123)	800	0.2	Engineering Estimate. Total enclosure, dust generation is negligible	0.99	0.08	0.35	0.004
Tablet Coater (Thomas Flex) (Building 123, Room 1023)	106.00	20.00	Emission factor based on 20 pct. solids coating and 95 pct. transfer efficiency onto tablets.	0.99	<b>1.06</b>	4.64	0.05
<b>Total</b>						<b>4.99</b>	<b>0.05</b>

**Methodology**

Throughput (lb/hr) \* EF (lb PM / 1000 lb solids) \* 8760 hr/yr \* ton/2000 lb = throughput (ton/yr)

\* Emission factors are provided by the source; PM, PM10, PM2.5 presumed same.

**Appendix A: Emission Calculations**  
**VOC Emissions**  
**Tablet Printing, Building 123**

**Company Name:** AstraZeneca Pharmaceuticals LP  
**Address City IN Zip:** 4601 Highway 62 East, Mt. Vernon, IN 47620  
**Permit No:** SPR 129-47826-00021  
**Reviewer:** Hind Mohamed

**VOC Potential to Emit:**

Tablet Printing Ink

4 printers x 3000 lb throughput per printer per day x 365 day/yr x 4.5 kg ink per 3000 lb throughput = 6570 kg/yr ink

6,570 kg/yr ink x 63 wt% VOC x 2.20462 lb/kg = 9125 lb/yr VOC from ink  
9125 lb/yr x 1 ton/2000 lb = 4.56 ton/yr VOC from ink

IPA Usage

4 printers x 1.5 batches per day per printer x 365 day/yr x 1.5 kg IPA per batch = 3285 kg/yr IPA

3,285 kg/yr IPA x 100 wt% VOC x 2.20462 lb/kg = 7242 lb/yr VOC from IPA  
7242 lb/yr x 1 ton/2000 lb = 3.62 ton/yr VOC from IPA

**Total VOC Potential to Emit:**

16367 lbs/yr VOC ( Ink usage + IPA usage)  
**8.18 tons/yr VOC** = 16,367 lb/yr x 1 ton/2000 lbs



**Appendix A: Emission Calculations**  
**Particulate Matter Emissions**  
**Four Weighing and Dispensing Rooms, Building 123**

**Company Name:** AstraZeneca Pharmaceuticals LP  
**Address City IN Zip:** 4601 Highway 62 East, Mt. Vernon, IN 47620  
**Permit No:** SPR 129-47826-00021  
**Reviewer:** Hind Mohamed

Unit ID	Number of Units	Max. Process Weight Rate, each	Emission Factor	Source of Emission Factor *	Control Efficiency	Potential Uncontrolled	Potential Uncontrolled	Potential Controlled
		lb/hr	lb PM / 2000 lb solids		(%)	PM Emissions	PM Emissions	PM Emissions
						lbs/hr	tons/yr	tons/yr
Dry Material Weighing and Dispensing	4	1237	0.20	Engineering estimate. Closed Room, dust generation is negligible.	50%	0.49	2.17	1.084
							<b>2.17</b>	<b>1.08</b>

**Methodology**

Potential uncontrolled emissions are a conservative engineering estimate, based on mixing and blending operations.

Throughput (lb/hr) \* EF (lb PM / 2000 lb solids) \* 8760 hr/yr \* ton/2000 lb = throughput (ton/yr)

\*PM, PM10, PM2.5 presumed same.

**Emission Calculations**  
**Weigh Room - Building 123, Room 1228**  
**Particulate Matter Emissions**

**Company Name:** AstraZeneca Pharmaceuticals LP  
**Address City IN Zip:** 4601 Highway 62 East, Mt. Vernon, IN 47620  
**Permit No:** SPR 129-47826-00021  
**Reviewer:** Hind Mohamed

Particulate Matter Emissions from dry material

Unit ID	Max. Process Weight Rate <sup>1</sup> (lb/hr)	Emission Factor <sup>2</sup> (lb PM / 2000 lb solids)	Source of Emission Factor	Control Efficiency <sup>3</sup> (%)	Potential Uncontrolled PM Emissions (lbs/hr)	Potential Uncontrolled PM Emissions <sup>4</sup> (tons/yr)	Potential Controlled PM Emissions <sup>5</sup> (tons/yr)
Material Input into Vacuum Transfer System: Weigh Room 1228	1,323	0.20	Engineering estimate. Closed Room, dust generation is negligible.	99.99%	0.13	0.58	5.79E-05
Vacuum Transfer into Receiver: Weigh Room 1228	1,323	0.20	Engineering estimate. Closed Room, dust generation is negligible.	50%	0.13	0.58	0.29

**Total Potential PM Emissions (tons/yr):**

**1.16**

**0.29**

**Methodology and Notes:**

<sup>1</sup> The maximum throughput is 10 Kg/min when batching materials and 750 Kg per day.

<sup>2</sup> Emission factors are provided by the source; PM, PM10, PM2.5 presumed same.

Emission factor based on other similar sources (Small Weigh Room, bin charging system, etc.)

<sup>3</sup> Material input emissions are controlled by a prefilter and H14 HEPA filter prior to exhausting to atmosphere. The H14 HEPA filter has a 99.99% efficiency.

Transfer into receiver emissions are vented indoors. 50% control for venting indoors.

<sup>4</sup> Throughput (lb/hr) \* EF (lb PM / 2000 lb solids) \* 8760 hr/yr \* ton/2000 lb = potential uncontrolled emissions (ton/yr)

<sup>5</sup> Potential uncontrolled emissions (ton/yr) \* (1 - control efficiency) = potential controlled emissions (ton/yr)

**Appendix A: Emission Calculations  
Particulate Matter Emissions  
Building 124 Pharmaceutical Packaging Line**

**Company Name:** AstraZeneca Pharmaceuticals LP  
**Address City IN Zip:** 4601 Highway 62 East, Mt. Vernon, IN 47620  
**Permit No:** SPR 129-47826-00021  
**Reviewer:** Hind Mohamed

Unit ID	Max. Process Weight Rate lb/hr	Emission Factor lb PM / 2000 lb solids	Source of Emission Factor *	Control Efficiency (%)	Potential Uncontrolled PM Emissions lbs/hr	Potential Uncontrolled PM Emissions tons/yr	Potential Controlled PM Emissions tons/yr ***
Pharmaceutical packaging lines Packaging line 20 (Formerly line 3)	442.00	0.02	Engineering estimate. The materials handled are coated solid tablets; dust generation is negligible.	99%	0.004	0.019	0.0002
Pharmaceutical packaging lines Packaging lines 8, 9, 11, 12, and 10	3236.00	0.02	Engineering estimate. The materials handled are coated solid tablets; dust generation is negligible.	99%	0.032	0.142	0.0014
Pharmaceutical Packaging Line 15	200	0.02	Engineering estimate. The materials handled are coated solid tablets; dust generation is negligible.	99%	0.002	0.009	0.00009
Pharmaceutical Packaging Line 16	200	0.02	Engineering estimate. The materials handled are coated solid tablets; dust generation is negligible.	99%	0.002	0.009	0.0001
Pharmaceutical Packaging Line 17	200	0.02	Engineering estimate. The materials handled are coated solid tablets; dust generation is negligible.	99%	0.002	0.009	0.0001
<b>Total</b>						<b>0.187</b>	<b>1.87E-03</b>

**Methodology:**

Throughput (lb/hr) \* EF (lb PM/2,000 lbs solids) \* 8,760 hrs/yr \* ton/2,000 lbs = emissions (ton/yr)

\*PM, PM<sub>10</sub> and PM<sub>2.5</sub> are presumed to be the same

**Appendix A: Emission Calculations  
Bohle Tablet Coaters #1 through #9**

**Company Name:** AstraZeneca Pharmaceuticals LP  
**Address City IN Zip:** 4601 Highway 62 East, Mt. Vernon, IN 47620  
**Permit No:** SPR 129-47826-00021  
**Reviewer:** Hind Mohamed

Tablet Coating Process comprised of three coating suspension prep tanks (coating solids, water, hydrochloric acid mixed into solution) and a single pan tablet coating machine (coating suspension sprayed onto uncoated tablets). Exhausts from prep tanks and pan coater are combined in a vent header with a local exhaust over HCl storage drums, and vented to a packed-bed scrubber for HCl fume and particulate control.

Potential to Emit:				Uncontrolled			Controlled	
Emission Unit	Description	PM/PM10/PM2.5 Emission Rate from Site Test plus 25% Safety Factor <sup>1</sup>	HCl Emission Rate from Site Test plus 30% Safety Factor <sup>1</sup>	Uncontrolled PM/PM <sub>10</sub> PM <sub>2.5</sub>	Uncontrolled HCl	Dust Filter PM/PM10/PM2.5 Control Efficiency <sup>2</sup>	Controlled PM/PM <sub>10</sub> PM <sub>2.5</sub>	Controlled HCl
		lb/hr	lb/hr	ton/yr	ton/yr	%	ton/yr	ton/yr
Bohle Tablet Coater #1	S-30 - Building 121	0.46	0.03	2.03	0.14	99%	0.02	0.14
Bohle Tablet Coater #2	S-33	0.46	0.03	2.03	0.14	99%	0.02	0.14
Bohle Tablet Coater #3	S-36 - Building 122	0.46	0.03	2.03	0.14	99%	0.02	0.14
Bohle Tablet Coater #4	S-37 - Building 122	0.46	0.03	2.03	0.14	99%	0.02	0.14
Bohle Tablet Coater #5	S-38 - Building 122	0.46	0.03	2.03	0.14	99%	0.02	0.14
Bohle Tablet Coater #6	S-39 - Building 122	0.46	0.03	2.03	0.14	99%	0.02	0.14
Bohle Tablet Coater #7	S-40 - Building 122	0.46	0.03	2.03	0.14	99%	0.02	0.14
Bohle Tablet Coater #8	S-41 - Building 122	0.46	0.03	2.03	0.14	99%	0.02	0.14
Bohle Tablet Coater #9	S-42 - Building 122	0.46	0.03	2.03	0.14	99%	0.02	0.14
				<b>18.23</b>	<b>1.23</b>		<b>0.18</b>	<b>1.23</b>

<sup>1</sup> Data from Worst Case Site Test conducted on Bohle Coater #4 on January 6, 2021. Accepted by IDEM.

<sup>2</sup> Nominal equipment performance assumed (Manufacturer's guaranteed control efficiency is 99.97%)

Methodology

Uncontrolled PTE (ton/yr) = worst-case test result (lb/hr) x safety factor x (8760 hr/year) x (1 ton/2000lbs)

Controlled PTE (ton/yr) = Uncontrolled PTE (ton/yr) x (1-control efficiency%)

**Appendix A: Emission Calculations**  
**Fette 64, 65, and 66: Tablet Core Press Machine Building 123, Room 1142**

**Company Name:** AstraZeneca Pharmaceuticals LP  
**Address City IN Zip:** 4601 Highway 62 East, Mt. Vernon, IN 47620  
**Permit No:** SPR 129-47826-00021  
**Reviewer:** Hind Mohamed

Maximum Tablet Core Press Throughput =	844 lb/hr	<i>(design capacity)</i>
=	0.422 ton/hr	<i>( 844 lb/hr / 2,000 lbs per ton )</i>
Total Weight of Fette container (per Fette) =	15,503 lbs.	<i>(Container Weight study Jan '19 to July '20)*</i>
Total Number of Containers (per Fette) =	296 cont.	<i>(Container Weight study Jan '19 to July '20)*</i>
Average weight of container (per Fette) =	52.4 lbs./cont.	<i>( 15,503 lbs. / 296 cont.)</i>
Containers used during study (per Fette) =	1.0 cont. /wk	<i>(Container Weight study Jan '19 to July '20)*</i>
Capacity during Container Wt Study =	90 %	<i>(Container Weight study Jan '19 to July '20)*</i>
Safety Factor =	30 %	<i>(engineering judgement)</i>
Particulate Control Efficiency (CE) =	99 %	<i>engineering estimate for Camfil-Farr dust collectors</i>

**Particulate Emissions**

$$\begin{aligned}
 \text{Uncontrolled PM Emissions (per Fette)} &= \text{Wt of container} * \text{containers per week} / \text{hrs per week} * \text{scale up} * \text{safety factor} \\
 &= 52.4 \text{ lbs./cont.} * 1.0 \text{ cont. /wk} / 168 \text{ hrs/week} * 100/90 * \text{safety factor } 1.3 \\
 &= 0.450 \text{ lb/hr} \\
 &= 1.97 \text{ tons/yr} \\
 \text{Total Uncontrolled PM Emissions for Fette 64, Fette 65, \& Fette 66} &= \mathbf{5.92 \text{ tons/yr}}
 \end{aligned}$$

$$\begin{aligned}
 \text{Controlled PM Emissions (per Fette)} &= \text{Uncontrolled Emissions} * (1 - \text{CE}) \\
 &= 0.45 \text{ lb/hr} * (1 - 99/100) \\
 &= 0.0045 \text{ lb/hr} \\
 &= 0.020 \text{ tons/yr} \\
 \text{Total Controlled PM Emissions for Fette 64, Fette 65, \& Fette 66} &= \mathbf{0.059 \text{ tons/yr}}
 \end{aligned}$$

**Allowable Particulate Matter Emissions (326 IAC 6-3-2(e))**

$$\begin{aligned}
 \text{Allowable rate of emission (E)} &= 4.10(P)^{0.67} \\
 &= 4.10 * (0.422 \text{ ton/hr})^{0.67} \\
 &= 2.30 \text{ lb/hr}
 \end{aligned}$$

Where:

E = allowable rate of emissions (lb/hr)

P = process weight rate (tons/hr)

\*AstraZeneca conducted a Fette 64 and 66 tablet core press machines disposal container weight study from January 2019 through July 2020. The weights collected by the particulate controls represents uncontrolled particulate emissions. The weights recorded in the study are very conservative in that the weight not only is the dust collected, but the weight of the containers, pallets, controlled particulate collected in downstream HEPA filter, and the HEPA bags. Since the Fettes did not operate at capacity during the period of the weight study, emissions were scaled up to capacity.

### Appendix A: Emission Calculations Vacuum Systems

**Company Name:** AstraZeneca Pharmaceuticals LP  
**Address City IN Zip:** 4601 Highway 62 East, Mt. Vernon, IN 47620  
**Permit No:** SPR 129-47826-00021  
**Reviewer:** Hind Mohamed

#### Central Vacuum System, Building 123

Source info:

4 ports ties to central vacuum system =	1 kg/day =	2.2 lbs/day of dust is vacuum
1 port =	0.25 kg/day =	0.55 lbs/day of dust is vacuum
38 ports thru out blg 123		20.9 lbs/day of dust is vacuum
PM PTE (ton/yr)		<b>3.81 ton/yr</b>

PM PTE (ton/yr) = lbs/day of dust is vacuum \* 365 (day/yr) / 2000(lb/ton)

Max air flow rate =	2312 acfm	<b>2 blowers combined</b>
Hi-eff filter rating =	0.01 gr/ft3	
unit conversion=	7000 gr/lb	
	60 min/hr	
Control Coefficient =	99%	
PM/PM10/PM2.5 emissions =	0.20 lb/hr	
	0.87 ton/yr	

6-3-2
0.02 lb/hr < 0.551 lb/hr

Max. Process Weight Rate of less than 100 lbs/hr is limited to 0.551 lbs/hr

#### Central Vacuum Systems, Buildings 121, 122, and 124

The vacuum systems in Bldg 121, 122 and 124 are tied into the granulation and compression systems, so they function primarily as control equipment. Therefore, their emissions would already be included as a portion of the granulation and presses in those buildings. For secondary processes, a conservatitive engineering estimate of 0.5 tons has been added for each of these three units.

	ton/yr
Mac Central Vacuum System, Building 121	0.5
Spencer Central Vacuum System, Building 122	0.5
Central Vacuum System, Building 124	0.5

**Total for all vacuum systems (ton/yr) = 5.31**

**Appendix A: Emission Calculations  
Emergency Fire Pump Engine, S7**

**Reciprocating Internal Combustion Engines - Diesel Fuel  
Output Rating (<=600 HP)  
Maximum Input Rate (<=4.2 MMBtu/hr)**

**Company Name:** AstraZeneca Pharmaceuticals LP  
**Address City IN Zip:** 4601 Highway 62 East, Mt. Vernon, IN 47620  
**Permit No:** SPR 129-47826-00021  
**Reviewer:** Hind Mohamed

**Emissions calculated based on output rating (hp)**

Output Horsepower Rating (hp)	246
Maximum Hours Operated per Year	500
Potential Throughput (hp-hr/yr)	123,000

	Pollutant						
	PM*	PM10*	direct PM2.5*	SO2	NOx	VOC	CO
Emission Factor in lb/hp-hr	0.0022	0.0022	0.0022	0.0021	0.0310	0.0025	0.0067
Potential Emission in tons/yr	<b>0.14</b>	<b>0.14</b>	<b>0.14</b>	<b>0.13</b>	<b>1.91</b>	<b>0.15</b>	<b>0.41</b>

\*PM and PM2.5 emission factors are assumed to be equivalent to PM10 emission factors. No information was given regarding which method was used to determine the factor or the fraction of PM10 which is condensable.

**Hazardous Air Pollutants (HAPs)**

	Pollutant							
	Benzene	Toluene	Xylene	1,3-Butadiene	Formaldehyde	Acetaldehyde	Acrolein	Total PAH HAPs***
Emission Factor in lb/hp-hr****	6.53E-06	2.86E-06	2.00E-06	2.74E-07	8.26E-06	5.37E-06	6.48E-07	1.18E-06
Potential Emission in tons/yr	4.02E-04	1.76E-04	1.23E-04	1.68E-05	5.08E-04	3.30E-04	3.98E-05	7.23E-05

\*\*\*PAH = Polyaromatic Hydrocarbon (PAHs are considered HAPs, since they are considered Polycyclic Organic Matter)

\*\*\*\*Emission factors in lb/hp-hr were calculated using emission factors in lb/MMBtu and a brake specific fuel consumption of 7,000 Btu / hp-hr (AP-42 Table 3.3-1).

<b>Potential Emission of Total HAPs (tons/yr)</b>	<b>1.67E-03</b>
---	-----------------

**Methodology**

Emission Factors are from AP 42 (Supplement B 10/96) Tables 3.3-1 and 3.3-2.

Potential Throughput (hp-hr/yr) = [Output Horsepower Rating (hp)] \* [Maximum Hours Operated per Year]

Potential Emission (tons/yr) = [Potential Throughput (hp-hr/yr)] \* [Emission Factor (lb/hp-hr)] / [2,000 lb/ton]

**Appendix A: Emission Calculations  
Emergency Generator S-3**

**Large Reciprocating Internal Combustion Engines - Diesel Fuel  
Output Rating (>600 HP)  
Maximum Input Rate (>4.2 MMBtu/hr)**

**Company Name:** AstraZeneca Pharmaceuticals LP  
**Address City IN Zip:** 4601 Highway 62 East, Mt. Vernon, IN 47620  
**Permit No:** SPR 129-47826-00021  
**Reviewer:** Hind Mohamed

**Emissions calculated based on heat input capacity (MMBtu/hr)**

Emergency diesel generator (S-3)	4.4
Total Heat Input Capacity (MMBtu/hr)	4.4
Maximum Hours Operated per Year	500
Potential Throughput (MMBtu/yr)	2,200
Sulfur Content (S) of Fuel (% by weight)	0.0015

	Pollutant						
	PM*	PM10*	direct PM2.5*	SO2	NOx	VOC	CO
Emission Factor in lb/MMBtu	0.10	0.0573	0.0573	0.002 (1.01S)	3.2 **see below	0.09	0.85
Potential Emission in tons/yr	<b>0.11</b>	<b>0.06</b>	<b>0.06</b>	<b>0.0017</b>	<b>3.52</b>	<b>0.10</b>	<b>0.94</b>

\*No information was given regarding which method was used to determine the PM emission factor or whether condensable PM is included. The PM10 emission factor is filterable and condensable PM10 combined. The PM2.5 emissions were assumed to be equal to PM10.

\*\*NOx emissions: uncontrolled = 3.2 lb/MMBtu, controlled with ignition timing retard = 1.9 lb/MMBtu

**Hazardous Air Pollutants (HAPs)**

	Pollutant						
	Benzene	Toluene	Xylene	Formaldehyde	Acetaldehyde	Acrolein	Total PAH HAPs***
Emission Factor in lb/MMBtu	7.76E-04	2.81E-04	1.93E-04	7.89E-05	2.52E-05	7.88E-06	2.12E-04
Potential Emission in tons/yr	8.54E-04	3.09E-04	2.12E-04	8.68E-05	2.77E-05	8.67E-06	2.33E-04

\*\*\*PAH = Polyaromatic Hydrocarbon (PAHs are considered HAPs, since they are considered Polycyclic Organic Matter)

<b>Potential Emission of Total HAPs (tons/yr)</b>	<b>1.73E-03</b>
---	-----------------

**Methodology**

Potential Throughput (MMBtu/yr) = [Heat Input Capacity (MMBtu/hr)] \* [Maximum Hours Operated per Year]

Potential Emission (tons/yr) = [Potential Throughput (MMBtu/yr)] \* [Emission Factor (lb/MMBtu)] / [2,000 lb/ton]



**Appendix A: Emission Calculations  
Emergency Generator S32**

**Internal Combustion Engines - Diesel Fuel  
Reciprocating Ignition Internal Combustion Engines (> 4.2 MMBtu/hr)**

**Company Name:** AstraZeneca Pharmaceuticals LP  
**Address City IN Zip:** 4601 Highway 62 East, Mt. Vernon, IN 47620  
**Permit No:** SPR 129-47826-00021  
**Reviewer:** Hind Mohamed

Potential Emissions calculated based on 500 hours per year.

	Generator Capacity	
Emergency diesel generator of 1500kW (S32)	14.25	1,500.00
	MMBtu/hr	kW-hr
Total Heat Input Capacity	14.25	1,500.00
	MMBtu/hr	Total kW-hr
Maximum Hours Operated per Year	500	
Potential Throughput	7,125.00	
	MMBtu/yr	

	Pollutant						
	PM**	PM10**	PM2.5**	SO2*	NOx**	VOC**	CO**
Emission Factor in lb/MMBtu				0.0015			
Emission Factor in g/kW-hr	0.18	0.18	0.18		6.40	0.64	3.50
Potential Emissions (tons per year)	<b>0.15</b>	<b>0.15</b>	<b>0.15</b>	<b>0.005</b>	<b>5.29</b>	<b>0.53</b>	<b>2.89</b>

**Methodology**

\*Emission Factors are from AP42 (October 1996), Table 3.4-1 and 3.4-3

\*\*Emission Factors are provided by source based on Tier II FEL stds - NSPS Subpart IIII applicable to this source

Potential Emission (tons/yr) = [Generator Capacity (MMBtu/hr) x Emission Factor (lb/MMBtu)] \* 500 hr/yr / (2,000 lb/ton)

Potential Emission (tons/yr) = [Kilowatt per hour x Emission Factor (g/kW-hr)] \* 500 hr/yr \* (.0000011023)

Conversion factor is 1 gram=0.0000011023 short tons

**HAPs - Organics**

	Benzene	Acetaldehyde	Xylenes	Toluene	Napthalene	Formaldehyde	TOTAL
Emission Factor in lb/MMBtu	7.76E-04	2.52E-05	1.93E-04	2.81E-04	1.30E-04	7.89E-05	
Potential Emissions (tons per year)	2.76E-03	8.98E-05	6.88E-04	1.00E-03	4.63E-04	2.81E-04	<b>5.29E-03</b>

Methodology is the same as above.

The six highest organic HAPs emission factors are provided above.

HAPs emission factors are available in AP-42, Chapter 3.4-3 and 3.4-4.

**Appendix A: Emission Calculations  
Emergency Generator S34**

**Internal Combustion Engines - Diesel Fuel  
Reciprocating Ignition Internal Combustion Engines (> 4.2 MMBtu/hr)**

**Company Name:** AstraZeneca Pharmaceuticals LP  
**Address City IN Zip:** 4601 Highway 62 East, Mt. Vernon, IN 47620  
**Permit No:** SPR 129-47826-00021  
**Reviewer:** Hind Mohamed

Potential Emissions calculated based on 500 hours per year.

	Generator Capacity	
Emergency diesel generator of 350kW (S34)	3.89	MMBtu/hr
	350.00	kW-hr
Total Heat Input Capacity	3.89	MMBtu/hr
Maximum Hours Operated per Year	500	
Potential Throughput	1,945.00	MMBtu/yr
	350.00	Total kW-hr

	Pollutant						
	PM**	PM10**	PM2.5**	SO2*	NOx**	VOC**	CO**
Emission Factor in lb/MMBtu Emission Factor in g/kW-hr	0.18	0.18	0.18	0.0015	6.40	0.64	3.50
Potential Emissions (tons per year)	0.03	0.03	0.03	0.0015	1.23	0.12	0.68

**Methodology**

\*Emission Factors are from AP42 (October 1996), Table 3.4-1 and 3.4-3

\*\*Emission Factors are provided by source based on Tier II FEL stds - NSPS Subpart IIII applicable to this source

Potential Emission (tons/yr) = [Generator Capacity (MMBtu/hr) x Emission Factor (lb/MMBtu)] \* 500 hr/yr / (2,000 lb/ton)

Potential Emission (tons/yr) = [Kilowatt per hour x Emission Factor (g/kW-hr)] \* 500 hr/yr \*(.0000011023)

Conversion factor is 1 gram=0.0000011023 short tons

	HAPs - Organics						TOTAL
	Benzene	Acetaldehyde	Xylenes	Toluene	Napthalene	Formaldehyde	
Emission Factor in lb/MMBtu	7.76E-04	2.52E-05	1.93E-04	2.81E-04	1.30E-04	7.89E-05	
Potential Emissions (tons per year)	7.55E-04	2.45E-05	1.88E-04	2.73E-04	1.26E-04	7.67E-05	1.44E-03

Methodology is the same as above.

The six highest organic HAPs emission factors are provided above.

HAPs emission factors are available in AP-42, Chapter 3.4-3 and 3.4-4.

**Appendix A: Emission Calculations  
Emergency Generator S35**

**Internal Combustion Engines - Diesel Fuel  
Reciprocating Ignition Internal Combustion Engines (> 10 MMBtu/hr)**

**Company Name:** AstraZeneca Pharmaceuticals LP  
**Address City IN Zip:** 4601 Highway 62 East, Mt. Vernon, IN 47620  
**Permit No:** SPR 129-47826-00021  
**Reviewer:** Hind Mohamed

Emergency diesel generator (S35)

Output Horsepower Rating (hp)	4423.0
Maximum Hours Operated per Year	500
Potential Throughput (hp-hr/yr)	2,211,500
Sulfur Content (S) of Fuel (% by weight)	0.0015

	Pollutant						
	PM*	PM10*	PM2.5*	SO2	NOx*	VOC*	CO*
Emission Factor in lb/hp-hr	7.50E-05	7.50E-05	7.50E-05	1.21E-05 (.00809S)	0.011	0.0002	0.0014
Potential Emissions (tons per year)	0.08	0.08	0.08	0.01	12.65	0.24	1.54

**Methodology**

\*Emission Factors from generator manufacturer. The generator manufacturer has certified that the emergency generator is in compliance with the emission standards in NSPS Subpart IIII and 40 CFR 89. All other emission factors are from AP 42 (Supplement B 10/96) Tables 3.4-1 , 3.4-2, 3.4-3, and 3.4-4.

Potential Throughput (hp-hr/yr) = [Output Horsepower Rating (hp)] \* [Maximum Hours Operated per Year]

Potential Emission (tons/yr) = [Potential Throughput (hp-hr/yr)] \* [Emission Factor (lb/hp-hr)] / [2,000 lb/ton]

**Hazardous Air Pollutants (HAPs)**

	Pollutant						
	Benzene	Toluene	Xylene	Formaldehyde	Acetaldehyde	Acrolein	Total PAH HAPs**
Emission Factor in lb/hp-hr***	5.43E-06	1.97E-06	1.35E-06	5.52E-07	1.76E-07	5.52E-08	1.48E-06
Potential Emission in tons/yr	6.01E-03	2.18E-03	1.49E-03	6.11E-04	1.95E-04	6.10E-05	1.64E-03

\*\*PAH = Polyaromatic Hydrocarbon (PAHs are considered HAPs, since they are considered Polycyclic Organic Matter)

\*\*\*Emission factors in lb/hp-hr were calculated using emission factors in lb/MMBtu and a brake specific fuel consumption of 7,000 Btu / hp-hr (AP-42 Table 3.3-1).

<b>Potential Emission of Total HAPs (tons/yr)</b>	<b>1.22E-02</b>
---	-----------------

**Appendix A: Emission Calculations  
Emergency Generator, S44**

**Reciprocating Internal Combustion Engines - Diesel Fuel  
Output Rating (<=600 HP)  
Maximum Input Rate (<=4.2 MMBtu/hr)**

**Company Name:** AstraZeneca Pharmaceuticals LP  
**Address City IN Zip:** 4601 Highway 62 East, Mt. Vernon, IN 47620  
**Permit No:** SPR 129-47826-00021  
**Reviewer:** Hind Mohamed

**Emissions calculated based on output rating (hp)**

Output Horsepower Rating (hp)	315
Output Rating (kW)	235
Maximum Hours Operated per Year	500
Potential Throughput (hp-hr/yr)	157,500
Potential Throughput (kW-hr/yr)	117,448

	Pollutant						
	PM*	PM10**	direct PM2.5**	SO2	NOx*	VOC	CO*
Emission Factor in lb/hp-hr		0.0022	0.0022	0.0021		0.0025	
Emission Factor in g/kW-hr	0.2				4.0		3.5
Potential Emission in tons/yr	<b>0.03</b>	<b>0.17</b>	<b>0.17</b>	<b>0.16</b>	<b>0.52</b>	<b>0.20</b>	<b>0.45</b>

\*Emission factors from 40 CFR 89.112, Table 1. Engine is EPA certified to Tier 3 (225≤kW<450), Certificate Number FPKXL07.0PW1-007.

\*\*PM2.5 emission factor is assumed to be equivalent to PM10 emission factor. No information was given regarding which method was used to determine the factor or the fraction of PM10 which is condensable.

**Hazardous Air Pollutants (HAPs)**

	Pollutant							
	Benzene	Toluene	Xylene	1,3-Butadiene	Formaldehyde	Acetaldehyde	Acrolein	Total PAH HAPs***
Emission Factor in lb/hp-hr****	6.53E-06	2.86E-06	2.00E-06	2.74E-07	8.26E-06	5.37E-06	6.48E-07	1.18E-06
Potential Emission in tons/yr	<b>5.14E-04</b>	<b>2.25E-04</b>	<b>1.57E-04</b>	<b>2.16E-05</b>	<b>6.50E-04</b>	<b>4.23E-04</b>	<b>5.10E-05</b>	<b>9.26E-05</b>

\*\*\*PAH = Polycyclic Aromatic Hydrocarbon (PAHs are considered HAPs, since they are considered Polycyclic Organic Matter)

\*\*\*\*Emission factors in lb/hp-hr were calculated using emission factors in lb/MMBtu and a brake specific fuel consumption of 7,000 Btu / hp-hr (AP-42 Table 3.3-1).

<b>Potential Emission of Total HAPs (tons/yr)</b>	<b>2.14E-03</b>
---	-----------------

**Methodology**

Emission Factors are from AP 42 (Supplement B 10/96) Tables 3.3-1 and 3.3-2.

Potential Throughput (hp-hr/yr) = [Output Horsepower Rating (hp)] \* [Maximum Hours Operated per Year]

Potential Emission (tons/yr) = [Potential Throughput (hp-hr/yr)] \* [Emission Factor (lb/hp-hr)] / [2,000 lb/ton]

**Appendix A: Emission Calculations  
Emergency Generator, S45**

**Large Reciprocating Internal Combustion Engines - Diesel Fuel  
Output Rating (>600 HP)  
Maximum Input Rate (>4.2 MMBtu/hr)**

**Company Name:** AstraZeneca Pharmaceuticals LP  
**Address City IN Zip:** 4601 Highway 62 East, Mt. Vernon, IN 47620  
**Permit No:** SPR 129-47826-00021  
**Reviewer:** Hind Mohamed

**Emissions calculated based on output rating (hp)**

Output Horsepower Rating (hp)	4423
Output Rating (kW)	3298
Maximum Hours Operated per Year	500
Potential Throughput (hp-hr/yr)	2,211,500
Potential Throughput (kW-hr/yr)	1,649,115
Sulfur Content (S) of Fuel (% by weight)	0.0015

	Pollutant						
	PM*	PM10**	direct PM2.5**	SO2	NOx*	VOC	CO*
Emission Factor in lb/hp-hr		4.01E-04	4.01E-04	1.21E-05 (.00809S)		7.05E-04	
Emission Factor in g/kW-hr	0.20				6.4		3.5
Potential Emission in tons/yr	0.36	0.44	0.44	0.01	11.63	0.78	6.36

\*Emission factors from 40 CFR 89.112, Table 1. Engine is EPA certified to Tier 2 (560<kW≤2237), Certificate Number FCPXL106.NZS-004.

\*\*PM10 emission factor in lb/hp-hr was calculated using the emission factor in lb/MMBtu and a brake specific fuel consumption of 7,000 Btu / hp-hr (AP-42 Table 3.3-1).

**Hazardous Air Pollutants (HAPs)**

	Pollutant						
	Benzene	Toluene	Xylene	Formaldehyde	Acetaldehyde	Acrolein	Total PAH HAPs***
Emission Factor in lb/hp-hr****	5.43E-06	1.97E-06	1.35E-06	5.52E-07	1.76E-07	5.52E-08	1.48E-06
Potential Emission in tons/yr	6.01E-03	2.18E-03	1.49E-03	6.11E-04	1.95E-04	6.10E-05	1.64E-03

\*\*\*PAH = Polyaromatic Hydrocarbon (PAHs are considered HAPs, since they are considered Polycyclic Organic Matter)

\*\*\*\*Emission factors in lb/hp-hr were calculated using emission factors in lb/MMBtu and a brake specific fuel consumption of 7,000 Btu / hp-hr (AP-42 Table 3.3-1).

**Methodology**

Emission Factors are from AP 42 (Supplement B 10/96) Tables 3.4-1 , 3.4-2, 3.4-3, and 3.4-4.

Potential Throughput (hp-hr/yr) = [Output Horsepower Rating (hp)] \* [Maximum Hours Operated per Year]

Potential Emission (tons/yr) = [Potential Throughput (hp-hr/yr)] \* [Emission Factor (lb/hp-hr)] / [2,000 lb/ton]

<b>Potential Emission of Total HAPs (tons/yr)</b>	<b>1.22E-02</b>
---	-----------------

**Appendix A: Emission Calculations  
Emergency Generator, S46**

**Reciprocating Internal Combustion Engines - Diesel Fuel  
Output Rating (<=600 HP)  
Maximum Input Rate (<=4.2 MMBtu/hr)**

**Company Name:** AstraZeneca Pharmaceuticals LP  
**Address City IN Zip:** 4601 Highway 62 East, Mt. Vernon, IN 47620  
**Permit No:** SPR 129-47826-00021  
**Reviewer:** Hind Mohamed

**Emissions calculated based on output rating (hp)**

Output Horsepower Rating (hp)	539
Output Rating (kW)	402
Maximum Hours Operated per Year	500
Potential Throughput (hp-hr/yr)	269,500
Potential Throughput (kW-hr/yr)	200,966

	Pollutant						
	PM*	PM10**	direct PM2.5**	SO2	NOx*	VOC	CO*
Emission Factor in lb/hp-hr		0.0022	0.0022	0.0021		0.0025	
Emission Factor in g/kW-hr	0.2				4.0		3.5
Potential Emission in tons/yr	<b>0.04</b>	<b>0.30</b>	<b>0.30</b>	<b>0.28</b>	<b>0.89</b>	<b>0.34</b>	<b>0.78</b>

\*Emission factors from 40 CFR 89.112, Table 1. Engine is EPA certified to Tier 3 (225≤kW<450), Certificate Number FPKXL07.0PW1-007.

\*\*PM2.5 emission factor is assumed to be equivalent to PM10 emission factor. No information was given regarding which method was used to determine the factor or the fraction of PM10 which is condensable.

**Hazardous Air Pollutants (HAPs)**

	Pollutant							
	Benzene	Toluene	Xylene	1,3-Butadiene	Formaldehyde	Acetaldehyde	Acrolein	Total PAH HAPs***
Emission Factor in lb/hp-hr****	6.53E-06	2.86E-06	2.00E-06	2.74E-07	8.26E-06	5.37E-06	6.48E-07	1.18E-06
Potential Emission in tons/yr	<b>8.80E-04</b>	<b>3.86E-04</b>	<b>2.69E-04</b>	<b>3.69E-05</b>	<b>1.11E-03</b>	<b>7.23E-04</b>	<b>8.73E-05</b>	<b>1.58E-04</b>

\*\*\*PAH = Polycyclic Aromatic Hydrocarbon (PAHs are considered HAPs, since they are considered Polycyclic Organic Matter)

\*\*\*\*Emission factors in lb/hp-hr were calculated using emission factors in lb/MMBtu and a brake specific fuel consumption of 7,000 Btu / hp-hr (AP-42 Table 3.3-1).

<b>Potential Emission of Total HAPs (tons/yr)</b>	<b>3.65E-03</b>
---	-----------------

**Methodology**

Emission Factors are from AP 42 (Supplement B 10/96) Tables 3.3-1 and 3.3-2.

Potential Throughput (hp-hr/yr) = [Output Horsepower Rating (hp)] \* [Maximum Hours Operated per Year]

Potential Emission (tons/yr) = [Potential Throughput (hp-hr/yr)] \* [Emission Factor (lb/hp-hr)] / [2,000 lb/ton]

**Appendix A: Emission Calculations**  
**VOC**  
**From Cold Cleaning Operation**

**Company Name:** AstraZeneca Pharmaceuticals LP  
**Address City IN Zip:** 4601 Highway 62 East, Mt. Vernon, IN 47620  
**Permit No:** SPR 129-47826-00021  
**Reviewer:** Hind Mohamed

**Insignificant Activity: One (1) cold cleaner/degreaser**

Potential Emissions:											
Material (as applied)	Process	Density (lb/gal)	Weight % Volatile (H2O & Organics)	Weight % Water	Weight % Organics	Volume % Water	Volume % Non-Vol (solids)	Gal of Mat. Lost (gal/day)*	Potential VOC Pounds per hour	Potential VOC pounds per day	Potential VOC tons per year
Safety-Kleen Premium Gold Solvent	Cold Cleaners (Building 122)	6.80	100.00%	0.00%	100.00%	0.00%	0.00%	0.016	0.0045	0.11	0.02

**Total Potential Emissions:** **0.11**      **0.020**

Note: \* Gallons of material lost is based on actual material usage in 2015. According to records, in 2015 a total of 32 gallons of clean solvent was supplied and 26 gallons (of solvent after adjusting for the volume of sludge, dirt, etc.) was returned or is still in inventory.  
HAP content of the solvent is negligible.

**Methodology:**

Potential VOC Pounds per Hour = Density (lb/gal) \* Gal of Material (gal/day) / 24 hrs/day

Potential VOC Pounds per Day = Density (lb/gal) \* Gal of Material (gal/day)

Potential VOC Tons per Year = Density (lb/gal) \* Gal of Material (gal/day) \* (365 days/yr) \* (1 ton/2000 lbs)

**Appendix A: Emission Calculations**  
**VOC and HAP Emissions**  
**Fuel Storage Tanks**

**Company Name:** AstraZeneca Pharmaceuticals LP  
**Address City IN Zip:** 4601 Highway 62 East, Mt. Vernon, IN 47620  
**Permit No:** SPR 129-47826-00021  
**Reviewer:** Hind Mohamed

**Volatile Organic Compound (VOC) Emissions From Storage Tanks (Working and Breathing Losses) Using US EPA TANKS Version 4.09 program**

Storage Tank ID	Product Stored	Tank Type	Tank Color/Shade	Tank Dimensions (nominal)	Maximum Liquid Volume (gallons)	Turnovers per year	Product Throughput (gallons/yr)	VOC Working Losses (lbs/yr)	VOC Breathing Losses (lbs/yr)	Total VOC Losses (lbs/yr)	VOC Working Losses (tons/yr)	VOC Breathing Losses (tons/yr)	Total VOC Losses (tons/yr)
Building 104, S32	No. 2 Fuel Oil	horizontal fixed roof	dull gray	2.0 ft. dia., 4.25 ft. long	100	516	51,630	0.27	0.11	0.38	1.4E-04	5.5E-05	1.9E-04
Building 113, S44	No. 2 Fuel Oil	horizontal fixed roof	dull gray	3.5 ft. dia., 5.75 ft. long	395	19	7,750	0.18	0.17	0.35	9.0E-05	8.5E-05	1.8E-04
Building 104, S45	No. 2 Fuel Oil	horizontal fixed roof	dull gray	2.5 ft. dia., 5.5 ft. long	200	533	106,520	0.56	0.12	0.68	2.8E-04	6.0E-05	3.4E-04
<b>Totals</b>										1.41			<b>7.1E-04</b>

**Hazardous Air Pollutant (HAP) Emissions**

Storage Tank ID	Product Stored	Total PTE of VOC (tons/yr)	Total HAP Content (weight %)*	PTE of Total HAPs (tons/yr)	Worst Single HAP Content (weight %)*		PTE of Worst Single HAP (tons/yr)
Building 104, S32	No. 2 Fuel Oil	1.9E-04	1.2%	2.3E-06	0.5%	Xylenes	9.5E-07
Building 113, S44	No. 2 Fuel Oil	1.8E-04	1.2%	2.1E-06	0.5%	Xylenes	8.8E-07
Building 104, S45	No. 2 Fuel Oil	3.4E-04	1.2%	4.1E-06	0.5%	Xylenes	1.7E-06
<b>Total</b>				<b>8.5E-06</b>			<b>3.5E-06</b>

\*Source: Petroleum Liquids. Potter, T.L. and K.E. Simmons. 1998. Total Petroleum Hydrocarbon Criteria Working Group Series, Volume 2. Composition of Petroleum Mixtures. The Association for Environmental Health and Science.

**Methodology**

PTE of Total HAPs (tons/yr) = [Total HAP Content (% by weight)] \* [PTE of VOC (tons/yr)]

PTE of Worst Single HAP (tons/yr) = [Worst Single HAP Content (% by weight)] \* [PTE of VOC (tons/yr)]

**Abbreviations**

PTE = Potential to Emit



**Appendix A: Emission Calculations**  
**Fugitive Dust Emissions - Paved Roads**

**Company Name:** AstraZeneca Pharmaceuticals LP  
**Source Address:** 4601 Highway 62 East, Mt. Vernon, IN 47620  
**Permit No:** SPR 129-47826-00021  
**Reviewer:** Hind Mohamed

**Paved Roads at Industrial Site**

The following calculations determine the amount of emissions created by paved roads, based on 8,760 hours of use and AP-42, Ch 13.2.1 (1/2011).

Vehicle Information (provided by source)

Type	Maximum number of vehicles per day	Number of one-way trips per day per vehicle	Maximum trips per day (trip/day)	Maximum Weight of Loaded Vehicle (tons/trip)	Total Weight driven per day (ton/day)	Maximum one-way distance (feet/trip)	Maximum one-way distance (mi/trip)	Maximum one-way miles (miles/day)	Maximum one-way miles (miles/yr)
Box or Semi Trucks - product out	14.0	2.0	28.0	7.0	196.0	2640.0	0.500	14.0	5110.0
Box or Semi Trucks - deliveries	2.0	2.0	4.0	15.0	60.0	2640.0	0.500	2.0	730.0
Maintenance traffic	10.0	3.0	30.0	2.0	60.0	2640.0	0.500	15.0	5475.0
Cars	20.0	2.0	40.0	2.0	80.0	2640.0	0.500	20.0	7300.0
<b>Totals</b>			<b>102.0</b>		<b>396.0</b>			<b>51.0</b>	<b>18615.0</b>

Average Vehicle Weight Per Trip =  $\frac{3.9}{0.50}$  tons/trip  
Average Miles Per Trip =  $\frac{3.9}{0.50}$  miles/trip

Unmitigated Emission Factor, Ef =  $[k * (sL)^{0.91} * (W)^{1.02}]$  (Equation 1 from AP-42 13.2.1)

	PM	PM10	PM2.5	
where k =	0.011	0.0022	0.00054	lb/VMT = particle size multiplier (AP-42 Table 13.2.1-1)
W =	3.9	3.9	3.9	tons = average vehicle weight
sL =	9.7	9.7	9.7	g/m <sup>2</sup> = silt loading value for paved roads at iron and steel production facilities - Table 13.2.1-3)

Taking natural mitigation due to precipitation into consideration, Mitigated Emission Factor, Eext =  $E * [1 - (p/4N)]$  (Equation 2 from AP-42 13.2.1)

Mitigated Emission Factor, Eext =  $Ef * [1 - (p/4N)]$   
where p =  $\frac{125}{365}$  days of rain greater than or equal to 0.01 inches (see Fig. 13.2.1-2)  
N = 365 days per year

	PM	PM10	PM2.5	
Unmitigated Emission Factor, Ef =	0.347	0.069	0.0170	lb/mile
Mitigated Emission Factor, Eext =	0.317	0.063	0.0156	lb/mile

Process	Mitigated PTE of PM (Before Control) (tons/yr)	Mitigated PTE of PM10 (Before Control) (tons/yr)	Mitigated PTE of PM2.5 (Before Control) (tons/yr)
Box or Semi Trucks - product out	0.81	0.16	0.04
Box or Semi Trucks - deliveries	0.12	0.02	0.01
Maintenance traffic	0.87	0.17	0.04
Cars	1.16	0.23	0.06
<b>Totals</b>	<b>2.95</b>	<b>0.59</b>	<b>0.14</b>

**Methodology**

Total Weight driven per day (ton/day) = [Maximum Weight of Loaded Vehicle (tons/trip)] \* [Maximum trips per day (trip/day)]  
Maximum one-way distance (mi/trip) = [Maximum one-way distance (feet/trip)] / [5280 ft/mile]  
Maximum one-way miles (miles/day) = [Maximum trips per year (trip/day)] \* [Maximum one-way distance (mi/trip)]  
Average Vehicle Weight Per Trip (ton/trip) = SUM[Total Weight driven per day (ton/day)] / SUM[Maximum trips per day (trip/day)]  
Average Miles Per Trip (miles/trip) = SUM[Maximum one-way miles (miles/day)] / SUM[Maximum trips per day (trip/day)]  
Unmitigated PTE (tons/yr) = [Maximum one-way miles (miles/yr)] \* [Unmitigated Emission Factor (lb/mile)] \* (ton/2000 lbs)  
Mitigated PTE (Before Control) (tons/yr) = [Maximum one-way miles (miles/yr)] \* [Mitigated Emission Factor (lb/mile)] \* (ton/2000 lbs)  
Mitigated PTE (After Control) (tons/yr) = [Mitigated PTE (Before Control) (tons/yr)] \* [1 - Dust Control Efficiency]

**Abbreviations**

PM = Particulate Matter  
PM10 = Particulate Matter (<10 um)  
PM2.5 = Particulate Matter (<2.5 um)  
PTE = Potential to Emit

**Appendix A: Emission Calculations**  
**Fugitive Dust Emissions - Unpaved Roads**

**Company Name:** AstraZeneca Pharmaceuticals LP  
**Source Address:** 4601 Highway 62 East, Mt. Vernon, IN 47620  
**Permit No:** SPR 129-47826-00021  
**Reviewer:** Hind Mohamed

**Unpaved Roads at Industrial Site**

The following calculations determine the amount of emissions created by unpaved roads, based on 8,760 hours of use and AP-42, Ch 13.2.2 (11/2006).

Vehicle Information (provided by source)

Type	Maximum number of vehicles	Number of one-way trips per day per vehicle	Maximum trips per day (trip/day)	Maximum Weight of Loaded Vehicle (tons/trip)	Total Weight driven per day (ton/day)	Maximum one-way distance (feet/trip)	Maximum one-way distance (mi/trip)	Maximum one-way miles (miles/day)	Maximum one-way miles (miles/yr)
Contractor Cars	10.0	4.0	40.0	2.0	80.0	528	0.100	4.0	1460.0
<b>Totals</b>			<b>40.0</b>		<b>80.0</b>			<b>4.0</b>	<b>1460.0</b>

Average Vehicle Weight Per Trip =  tons/trip  
 Average Miles Per Trip =  miles/trip

Unmitigated Emission Factor, Ef =  $k[(s/12)^a][W^3]^b$  (Equation 1a from AP-42 13.2.2)

	PM	PM10	PM2.5	
where k =	4.9	1.5	0.15	lb/mi = particle size multiplier (AP-42 Table 13.2.2-2 for Industrial Roads)
s =	6.0	6.0	6.0	% = mean % silt content of unpaved roads (AP-42 Table 13.2.2-1 Iron and Steel Production)
a =	0.7	0.9	0.9	= constant (AP-42 Table 13.2.2-2 for Industrial Roads)
W =	2.0	2.0	2.0	tons = average vehicle weight
b =	0.45	0.45	0.45	= constant (AP-42 Table 13.2.2-2 for Industrial Roads)

Taking natural mitigation due to precipitation into consideration, Mitigated Emission Factor, Eext =  $E * [(365 - P)/365]$  (Equation 2 from AP-42 13.2.2)

Mitigated Emission Factor, Eext =  $E * [(365 - P)/365]$   
 where P =  days of rain greater than or equal to 0.01 inches (see Fig. 13.2.2-1)

	PM	PM10	PM2.5	
Unmitigated Emission Factor, Ef =	2.51	0.67	0.07	lb/mile
Mitigated Emission Factor, Eext =	1.65	0.44	0.04	lb/mile

Process	Mitigated PTE of PM (Before Control) (tons/yr)	Mitigated PTE of PM10 (Before Control) (tons/yr)	Mitigated PTE of PM2.5 (Before Control) (tons/yr)
Contractor Cars	1.21	0.32	0.03
<b>Totals</b>	<b>1.21</b>	<b>0.32</b>	<b>0.03</b>

**Methodology**

Total Weight driven per day (ton/day) = [Maximum Weight of Loaded Vehicle (tons/trip)] \* [Maximum trips per day (trip/day)]  
 Maximum one-way distance (mi/trip) = [Maximum one-way distance (feet/trip)] / [5280 ft/mile]  
 Maximum one-way miles (miles/day) = [Maximum trips per year (trip/day)] \* [Maximum one-way distance (mi/trip)]  
 Average Vehicle Weight Per Trip (ton/trip) = SUM[Total Weight driven per day (ton/day)] / SUM[Maximum trips per day (trip/day)]  
 Average Miles Per Trip (miles/trip) = SUM[Maximum one-way miles (miles/day)] / SUM[Maximum trips per year (trip/day)]  
 Mitigated PTE (Before Control) (tons/yr) = (Maximum one-way miles (miles/yr)) \* (Mitigated Emission Factor (lb/mile)) \* (ton/2000 lbs)  
 Mitigated PTE (After Control) (tons/yr) = (Mitigated PTE (Before Control) (tons/yr)) \* (1 - Dust Control Efficiency)

**Abbreviations**

PM = Particulate Matter  
 PM10 = Particulate Matter (<10 um)  
 PM2.5 = Particulate Matter (<2.5 um)  
 PTE = Potential to Emit

**Appendix A: Emission Calculations  
326 IAC 6-3-2, Particulate Emission Limitations**

Company Name: AstraZeneca Pharmaceuticals LP  
Address City IN Zip: 4601 Highway 62 East, Mt. Vernon, IN 47620  
Permit No: SPR 129-47826-00021  
Reviewer: Hind Mohamed

Process Description	Process Weight Rate (ton/hr)	Process Weight Rate (lb/hr)	326 IAC 6-3-2 Limit (lb/hr)	Uncontrolled PM Emissions (lb/hr)	Controlled PM Emissions (lb/hr)	Capable of Compliance with 326 IAC 6-3-2
<b>Bld 122-123 Gran-Press</b>						
Granulator: Aqueous wet Granulations (Building 123, Room 1202)	0.15	290.00	1.12	0.30	0.003	exempt
GEA fluid bed dryer: Aqueous wet Granulations (Building 123, Room 1202)	0.15	290.00	1.12	1.45	0.36	Yes, with Control
Granulator: Aqueous wet Granulations (Building 123, Room 1229)	0.15	290.00	1.12	0.30	0.003	exempt
GEA fluid bed dryer: Aqueous wet Granulations (Building 123, Room 1229)	0.15	290.00	1.12	1.45	0.36	Yes, with Control
Tablet Core Presses (Building 122, Room 1109)	0.21	425.00	1.45	1.66	0.41	Yes, with Control
Tablet Core Presses (Building 122, Room 1111)	0.21	425.00	1.45	1.66	0.41	Yes, with Control
<b>Bld 121 Gran-Press-Coat</b>						
Granulator: Aqueous Granulations (Building 121, Room 1119)	0.05	98.00	0.55	0.10	0.001	exempt
Glatt 120 fluid bed dryer: Aqueous Granulations (Building 121, Room 1119)	0.05	98.00	0.55	0.49	0.005	exempt
Tablet Core Press (Building 121, Room 116c)	0.04	80.00	0.55	0.31	0.003	exempt
Tablet Core Press (Building 121, Room 1014)	0.04	80.00	0.55	0.31	0.003	exempt
Tablet Coater (Building 121, Room 116c)	0.03	50.00	0.55	0.05	0.001	exempt
Tablet Coater (Building 121, Room 1023)	0.03	50.00	0.55	0.05	0.001	exempt
<b>Bld 122 Press-Encap</b>						
Tablet Core Press (Building 122, Room 1113)	0.08	165.00	0.77	0.64	0.006	Yes
Encapsulator Machine (Building 122, Room 1123)	0.06	110.00	0.59	0.43	0.004	exempt
Encapsulator Machine (Building 122, Room 1124)	0.09	185.00	0.83	0.72	0.007	Yes
<b>Bld 123 Coat</b>						
Bin Charging System (Building 123)	0.40	800.00	2.22	0.08	0.001	exempt
Tablet Coater (Thomas Flex) (Building 123, Room 1023)	0.05	106.00	0.57	1.06	0.011	Yes, with Control
<b>Bld 123 Weigh-Dispense</b>						
Four Weighing and Dispensing Rooms, Building 123	0.62	1237.00	2.97	0.12	0.062	exempt
<b>Weigh Room - Building 123, Room 1228</b>						
Material Input into Vacuum Transfer System: Weigh Room 1228	0.66	1322.76	3.11	0.13	0.00001	exempt
Vacuum Transfer into Receiver: Weigh Room 1228	0.66	1322.76	3.11	0.13	0.066	exempt
<b>Bld 124 Packaging</b>						
Pharmaceutical packaging lines Packaging line 20 (Formerly line 3)	0.22	442.00	1.49	0.004	0.00004	exempt
Pharmaceutical packaging lines Packaging lines 8, 9, 11, 12, and 10	1.62	3236.00	5.66	0.032	0.00032	exempt
Pharmaceutical Packaging Line 15	0.10	200.00	0.88	0.002	0.00002	exempt
Pharmaceutical Packaging Line 16	0.10	200.00	0.88	0.002	0.00002	exempt
<b>Fette 64, 65, and 66</b>						
Fette 64, 65, and 66: Tablet Core Press Machine Building 123, Room 1142	0.42	844	2.30	0.45	0.005	exempt
<b>Vacuum Systems</b>						
Central Vacuum System, Building 123	0.0004	0.87	0.551	0.87	0.20	Yes, with Control
Mac Central Vacuum System, Building 121				0.11		exempt
Spencer Central Vacuum System, Building 122				0.11		exempt
Central Vacuum System, Building 124				0.11		exempt

**Emission Limit Calculation Notes:**

Pursuant to 326 IAC 6-3-1(b), manufacturing processes with potential emissions less than 0.551 lbs/hour are exempt.

When the process weight rate is less than one hundred (100) pounds per hour, the allowable rate of emission is five hundred fifty-one thousandths (0.551) pound per hour.

Emission limitations for process weight rates up to sixty thousand pounds per hour shall be calculated with the following equation:

$$E \text{ (lb/hr)} = 4.10 P^{0.67}$$

Where: E = Rate of emission in pounds per hour  
P = Process Weight Rate in tons per hour



# INDIANA DEPARTMENT OF ENVIRONMENTAL MANAGEMENT

*We Protect Hoosiers and Our Environment.*

100 N. Senate Avenue • Indianapolis, IN 46204  
(800) 451-6027 • (317) 232-8603 • [www.idem.IN.gov](http://www.idem.IN.gov)

**Eric J. Holcomb**  
*Governor*

**Brian C. Rockensuess**  
*Commissioner*

July 3, 2024

Kevin Conkright  
AstraZeneca Pharmaceuticals LP  
4601 US Hwy 62 E  
Mount Vernon, IN 47620

Re: Public Notice  
AstraZeneca Pharmaceuticals LP  
Permit Level: FESOP Significant Permit Revision  
(Minor PSD/EO)  
Permit Number: 129-47826-00021

Dear Kevin Conkright:

Enclosed is the Notice of 30-Day Period for Public Comment for your draft air permit.

Our records indicate that you are the contact person for this application. However, if you are not the appropriate person within your company to receive this document, please forward it to the correct person. The Notice of 30-Day Period for Public Comment has also been sent to the OAQ Permits Branch Interested Parties List and, if applicable, your Consultant/Agent and/or Responsible Official/Authorized Individual.

The preliminary findings, including the draft permit, technical support document, emission calculations, and other supporting documents, **are available electronically at:**

**IDEM's online searchable database:** <http://www.in.gov/apps/idem/caats/> . Choose Search Option by **Permit Number**, then enter permit 47826

and

**IDEM's Virtual File Cabinet (VFC):** <https://www.IN.gov/idem>. Enter VFC in the search box, then search for permit documents using a variety of criteria, such as Program area, date range, permit #, Agency Interest Number, or Source ID.

The Public Notice period will begin the date the Notice is published on the IDEM Official Public Notice website. Publication has been requested and is expected within 2-3 business days. You may check the exact Public Notice begins and ends date here: <https://www.in.gov/idem/public-notices/>

Please note that as of April 17, 2019, IDEM is no longer required to publish the notice in a newspaper.

OAQ has submitted the draft permit package to the Alexandrian Public Library, 115 W 5th St in Mount Vernon, IN 47620. As a reminder, you are obligated by 326 IAC 2-1.1-6(c) to place a copy of the complete permit application at this library no later than ten (10) days after submittal of the application or additional information to our department. We highly recommend that even if you have already placed these materials at the library, that you confirm with the library that these materials are available for review and request that the library keep the materials available for review during the entire permitting process.

Please review the draft permit documents carefully. This is your opportunity to comment on the draft permit and notify the OAQ of any corrections that are needed before the final decision. Questions or comments about the enclosed documents should be directed to Hind Mohamed, Indiana Department of Environmental Management, Office of Air Quality, 100 N. Senate Avenue, Indianapolis, Indiana, 46204 or call (800) 451-6027, and ask for extension 6543 or dial (317) 234-6543.

Sincerely,

*Jennifer Scott*

Jennifer Scott  
Permits Branch  
Office of Air Quality

Enclosures

PN Applicant Cover Letter access via website 8/10/2020



# INDIANA DEPARTMENT OF ENVIRONMENTAL MANAGEMENT

*We Protect Hoosiers and Our Environment.*

100 N. Senate Avenue • Indianapolis, IN 46204  
(800) 451-6027 • (317) 232-8603 • www.idem.IN.gov

**Eric J. Holcomb**  
*Governor*

**Brian C. Rockensuess**  
*Commissioner*

July 3, 2024

To: Alexandrian Public Library

From: Jenny Acker, Branch Chief  
Permits Branch  
Office of Air Quality

Subject: **Important Information to Display Regarding a Public Notice for an Air Permit**

**Applicant Name: AstraZeneca Pharmaceuticals LP**  
**Permit Number: 129-47826-00021**

Enclosed is a copy of important information to make available to the public. This proposed project is regarding a source that may have the potential to significantly impact air quality. Librarians are encouraged to educate the public to make them aware of the availability of this information. The following information is enclosed for public reference at your library:

- Notice of a 30-day Period for Public Comment
- Draft Permit and Technical Support Document

You will not be responsible for collecting any comments from the citizens. Please refer all questions and request for the copies of any pertinent information to the person named below.

Members of your community could be very concerned in how these projects might affect them and their families. **Please make this information readily available until you receive a copy of the final package.**

If you have any questions concerning this public review process, please contact Joanne Smiddie-Brush, OAQ Permits Administration Section at 1-800-451-6027, extension 3-0185. Questions pertaining to the permit itself should be directed to the contact listed on the notice.

Enclosures  
PN Library updated 4/2019



# INDIANA DEPARTMENT OF ENVIRONMENTAL MANAGEMENT

*We Protect Hoosiers and Our Environment.*

100 N. Senate Avenue • Indianapolis, IN 46204  
(800) 451-6027 • (317) 232-8603 • [www.idem.IN.gov](http://www.idem.IN.gov)

**Eric J. Holcomb**  
Governor

**Brian C. Rockensuess**  
Commissioner

## Notice of Public Comment

**July 3, 2024**  
**AstraZeneca Pharmaceuticals LP**  
**129-47826-00021**

To: Interested Parties:

You are receiving this notice because you asked to be on IDEM's notification list for this company and/or county; or because your property is nearby the company being permitted; or because you represent a local/regional government entity. The Indiana Department of Environmental Management, Office of Air Quality, invites your comments on the draft air permit.

Enclosed is a Notice of Public Comment, which has posted on IDEM's Public Notice website at <https://www.in.gov/idem/public-notices/>.


The application and supporting documentation for this proposed permit have been placed at the library indicated in the Notice. These documents more fully describe the project, the applicable air pollution control requirements and how the applicant will comply with these requirements.

If you would like to comment on this draft permit, please contact the person named in the enclosed Public Notice. Thank you for your interest in the Indiana's Air Permitting Program.

**Please Note:** *If you would like to be removed from the Air Permits mailing list, please contact Joanne Smiddie-Brush with the Air Permits Administration Section at 1-800-451-6027, ext. 3-0185 or via e-mail at [JBRUSH@IDEM.IN.GOV](mailto:JBRUSH@IDEM.IN.GOV). If you have recently moved and this Notice has been forwarded to you, please notify us of your new address and if you wish to remain on the mailing list. Mail that is returned to IDEM by the Post Office with a forwarding address in a different county will be removed from our list unless otherwise requested.*

Enclosure  
PN Interested Parties Cover Letter 10/13/2023

# Mail Code 61-53

IDEM Staff	JLSCOTT 7/3/2024 AstraZeneca Pharmaceutical LP 129-47826-00021 Draft		Type of Mail:  <b>CERTIFICATE OF MAILING ONLY</b>	AFFIX STAMP HERE IF USED AS CERTIFICATE OF MAILING
Name and address of Sender		Indiana Department of Environmental Management Office of Air Quality – Permits Branch 100 N. Senate Indianapolis, IN 46204		

Line	Article Number	Name, Address, Street and Post Office Address	Postage	Handing Charges	Act. Value (If Registered)	Insured Value	Due Send if COD	R.R. Fee	S.D. Fee	S.H. Fee	Rest. Del. Fee
											Remarks
1		Kevin Conkright AstraZeneca Pharmaceuticals LP 4601 US Hwy 62 E Mount Vernon IN 47620 (Source CAATS)									
2		Femi D-Etti Vice President AstraZeneca Pharmaceutical LP 4601 Hwy 62 E Mount Vernon IN 47620 (RO CAATS)									
3		Posey County Commissioners County Courthouse, 126 E 3rd St Mount Vernon IN 47620 (Local Official)									
4		Posey County Health Department 100 Vista Dr Mount Vernon IN 47620 (Health Department)									
5		Mount Vernon City Council and Mayors Office 520 Main St Mount Vernon IN 47620 (Local Official)									
6		Alexandrian Public Library 115 W 5th St Mount Vernon IN 47620 (Library)									
7		Mr. Mark Wilson Evansville Courier & Press PO Box 268 Evansville IN 47702-0268 (Affected Party)									
8		Mrs. Connie Parkinson 510 Western Hills Dr Mount Vernon IN 47620 (Affected Party)									
9		David Boggs 216 Western Hills Dr Mount Vernon IN 47620 (Affected Party)									
10											
11											
12											
13											
14											
15											

Total number of pieces Listed by Sender	Total number of Pieces Received at Post Office	Postmaster, Per (Name of Receiving employee)	The full declaration of value is required on all domestic and international registered mail. The maximum indemnity payable for the reconstruction of nonnegotiable documents under Express Mail document reconstructing insurance is \$50,000 per piece subject to a limit of \$50, 000 per occurrence. The maximum indemnity payable on Express mil merchandise insurance is \$500. The maximum indemnity payable is \$25,000 for registered mail, sent with optional postal insurance. See <b>Domestic Mail Manual R900, S913, and S921</b> for limitations of coverage on inured and COD mail. See <b>International Mail Manual</b> for limitations o coverage on international mail. Special handling charges apply only to Standard Mail (A) and Standard Mail (B) parcels.
---	--	--	--