

## Monthly Report of Operation of Water Treatment Plant


System Name: Benton Central School Corp.

PWSID Number: IN 2040802

Month: June--2024

IDEM Field Rep: Sarah Benkert

Signed:



Title: Operator

I certify, under penalty of law, by this signature that this document was prepared by me, or under my direction, and the information submitted is to the best of my knowledge and belief, true, accurate, and complete. I'm also aware that there are significant penalties for submitting false information.

Certification No.: WT2--WT110090

DSM--DS110089

Date	Water Treated 1000 gal	Chemicals used in Gals. calcium hypochlorite	Chlorine Residual						Remarks
			Benton Central		Well House		Prairie Crossing		
June			Free	Total	Free	Total	Free	Total	
1	21.00		0.55	0.72	0.81	0.94	0.42	0.48	Weekend
2	6.30		0.51	0.59	0.80	0.91	0.51	0.55	
3	20.16		0.53	0.60	0.85	0.95	0.54	0.62	
4	20.16		0.41	0.48	0.70	0.76	0.48	0.61	
5	16.38		0.38	0.45	0.62	0.79	0.49	0.55	
6	42.84		1.53	1.66	1.90	2.05	1.69	1.74	
7	102.06		1.33	1.41	1.99	2.11	1.58	1.64	
8	31.50		1.06	1.13	1.21	1.38	1.62	1.75	Weekend
9	0.00		0.90	1.01	0.87	0.99	1.31	1.39	
10	26.04		0.86	1.01	1.10	1.48	1.19	1.25	
11	49.98		0.54	0.75	0.41	0.50	0.52	0.66	
12	54.60		0.47	0.58	0.61	0.78	0.58	0.67	
13	63.00		0.43	0.61	0.32	0.55	0.42	0.70	
14	137.34		0.45	0.53	0.53	0.65	0.40	0.51	
15	32.34		0.55	0.66	0.55	0.69	0.35	0.48	Weekend
16	0.00		0.59	0.71	0.59	0.72	0.54	0.67	
17	36.96		0.57	0.82	0.62	0.91	0.53	0.77	
18	67.62		0.53	0.81	0.58	0.84	0.44	0.71	
19	70.98		0.33	0.62	0.60	0.90	0.50	0.75	
20	32.34		0.49	0.76	0.56	0.74	0.63	0.65	
21	50.82		0.49	0.75	0.61	0.96	0.39	0.43	
22	0.00		0.54	0.62	0.64	0.75	0.44	0.51	Weekend
23	31.50		0.37	0.45	0.35	0.42	0.45	0.54	Plugged Chlorine Line
24	16.38		0.23	0.28	0.26	0.27	0.29	0.37	
25	36.12		1.16	1.56	1.03	1.44	0.31	0.37	
26	26.88		0.86	1.32	0.71	1.02	0.22	0.29	
27	32.76		0.88	1.13	0.93	2.25	0.77	0.87	
28	0.00		0.77	0.83	0.71	0.88	0.52	0.66	
29	42.84		0.61	0.69	0.69	0.77	0.49	0.54	Weekend
30	10.50		0.52	0.64	0.35	0.41	0.44	0.51	
1079.40							Total Gallons		1,079,400
							Max Day		137,340
							Min Day		0
							Ave Day		35,980