

Table 1

Date	Water Treated	Chlorine Residuals		Residuals	Remarks
		Plant	D.S.		
		FREE/TOTAL	Free/Total		
1	433	1.37/1.55			
2	528	1.33/1.56			
3	680	1.42/1.65	1.25/1.33		
4	555	1.22/1.31	1.01/1.24		FKWC purchased
5	626	1.36/1.54	1.03/1.13		19,101,000 gallons from
6	564	1.50/1.68	.71/.82		Ramsey Water Co and
7	531	1.27/1.53	1.01/1.12		204,111 gallons from
8	637	1.28/1.55			Borden Tri-County Water
9	962	1.33/1.66			
10	664	1.50/1.70	.83/.84		
11	444	1.42/1.59	1.09/1.12		
12	852	1.50/1.72	1.22/1.32		
13	1009	1.44/1.67	.83/.97		
14	935	1.33/1.55	1.13/1.15		
15	939	1.34/1.54			
16	938	1.36/1.58			
17	922	1.37/1.59	.88/1.18		I certify under penalty of law by this signature that this document was prepared by me or under my direction and the information submitted is to the best of my knowledge and believe to be true, accurate, and complete.
18	776	1.54/1.71	1.35/1.73		I am also aware that there are significant penalties for submitting false information
19	790	1.31/1.56	1.10/1.17		
20	1167	1.35/1.51	.85/.93		
21	1073	1.31/1.44	1.41/1.43		
22	1000	1.33/1.47			
23	572	1.28/1.41			
24	1147	1.25/1.44	1.03/1.07		
25	650	1.38/1.46	1.01/1.12		
26	590	1.43/1.58	1.26/1.41		
27	679	1.27/1.43	1.04/1.11		Total Gallons (MGD) 23,265
28	722	1.32/1.44	.87/1.03		Max Day 1,167
29	1035	1.38/1.47			Min. Day 433
30	845	1.37/1.44			Avg. Daily 775.4
31					

Danny Standiford
7/3/24