



MONTHLY REPORT OF OPERATION WATER TREATMENT PLANT

State Form 34609 (R11 / 1-17)

INDIANA DEPARTMENT OF
ENVIRONMENTAL MANAGEMENT

System Name Park One Water PWSID Number IN2180926

For the Month of June Year 2024 IDEM Field Rep. Thomas Wiseman

Signed [Signature] Title Water superintendent

I certify under penalty of law, by this signature that this document was prepared by me, or under my direction, and the information submitted is to the best of my knowledge and belief, true, accurate, and complete. I am also aware that there are significant penalties for submitting false information.

Certification Number DS 190140 WT 200066

PHYSICAL AND CHEMICAL DATA *

Date	Turbidity		Alkalinity		pH		Hardness		Iron		Manganese		Phosphate	Fluoride
	Raw	Finished	Raw	Finished	Raw	Finished	Raw	Finished	Raw	Finished	Raw	Finished	Finished	Finished
1														
2														
3														
4														
5														
6														
7														
8														
9														
10														
11														
12														
13														
14														
15														
16														
17														
18														
19														
20														
21														
22														
23														
24														
25														
26														
27														
28														
29														
30														
31														

* All parameters are to be expressed in mg/l except pH and turbidity.

DUE BY THE 10TH OF THE MONTH FOLLOWING THE REPORTING PERIOD.

Date	Water Treated 1000 gallons	Chemicals Used - Pounds GALLONS								Filters		Chlorine Residual				Remarks
		Salt	Alum	Lime	Soda Ash	Carbon	Chlorine	Fluoride	Phos- phate	Filter Run (hours)	Gallons per wash x 1000	Plant Tap		D. S.		
												Free	Total	Free	Total	
1	0						0					1.32	1.46	1.21	1.39	
2	79.5						0					1.30	1.26	1.40	1.47	
3	39.5						.50					1.00	1.06	1.30	1.33	
4	3.5						0					1.07	1.11	1.07	1.20	
5	0						.50					.68	1.10	1.18	1.31	
6	41.3						0					1.20	1.21	1.26	1.30	
7	29.5						0					1.06	1.16	1.10	1.12	
8	31						1.00					.91	.97	1.06	1.10	
9	0						0					.77	.57	.82	.90	
10	39.6						1.50					.77	.57	.81	.91	
11	3.7						.50					1.14	1.18	.77	.84	
12	32.8						1.75					1.47	1.91	.49	.81	
13	0						0					1.90	1.96	1.15	1.26	
14	32.8						1.00					1.88	2.00	.93	.92	
15	6.3						.50					2.13	2.16	1.38	1.61	Elevated cl2 was due to Fire
16	41.4						.25					1.89	2.10	1.01	1.14	suppression testing resulting in
17	0						0					1.85	1.81	1.59	1.60	the excess chemical use.
18	0						0					1.66	1.71	1.46	1.46	
19	42.9						.25					1.72	1.87	1.48	1.48	
20	0						0					1.19	1.21	1.43	1.43	
21	0						0					.81	1.03	1.14	1.14	Monthly Water Treatment
22	0						0					.69	.74	.92	.92	Total Gallons 652,500
23	91.9						.50					.65	.71	.94	.94	Max. Day 91,900
24	32.2						0					.75	.80	.90	.90	Min. Day 0
25	0						0					1.00	1.18	.80	.80	Avg. Daily 21,750
26	41.6						.50					.70	.76	1.10	1.10	E-Mail To: DWBmro@idem.in.gov
27	0						0					.80	.86	.91	.91	
28	0						.75					1.07	1.11	.86	.86	Mail To: Indiana Department of Environmental Management
29	60.3						0					.96	1.00	1.00	1.00	Drinking Water Branch
30	0						0					.74	.80	.92	.92	100 N. Senate Ave. Room N1201 Indianapolis, IN 46204-2237
31																