

NIPSCO Rollin M. Schahfer Generating Station

PWS ID IN 2370016

Monthly Report of Operations Operator Certification: Mark Hein, 72092,72376

Mark Hein

Monthly Water Treatment	
Total Gallons	258,482
Max. Day	11,694
Min. Day	5,093
Avg. Daily	8,616

I certify *under penalty by law*, by this signature that this document was prepared by me, or under my direction and the information submitted is to the best of my knowledge and belief, true, accurate, and complete. *I am also aware that there are significant penalties for submitting false information.*

June-24	Water Treated	Hypochlorite Used (1. Inchs=4.32 gal)	Distribution System Chlorine Residual			Remarks
			Total	Free	Sample Point	
1	6867	0.43	0.68	0.51	Loi sink	
2	8102	0.54	0.52	0.41	PPS	
3	5093	1.08	0.60	0.45	fgd lab	
4	7581	2.16	0.30	0.23	Lab sink	leak fixed at domestic pump house
5	10450	0.54	0.33	0.25	loi sink	
6	5687	0.13	0.55	0.45	mens lkr	
7	8108	1.08	0.68	0.55	blr sink	
8	7723	1.08	0.61	0.48	lab sink	
9	8940	1.51	0.53	0.44	loi sin k	
10	7370	0.86	0.77	0.64	14 1st aid room	
11	6802	0.86	0.51	0.37	ecology lab	
12	6468	2.16	0.37	0.29	17 womens locker room	
13	7102	1.08	0.33	0.26	BLR Sink	
14	9711	1.08	0.54	0.43	FGD Mens lckr	
15	7916	1.08	0.53	0.42	Eco Lab	
16	7628	1.62	0.56	0.36	17 Mens LCKR	
17	10851	1.62	0.48	0.37	eco lab	
18	8985	5.40	0.51	0.36	14 womens lckr	
19	10074	6.05	0.31	0.20	loi sink	
20	9669	0.43	0.52	0.47	14 first aid room	
21	10795	1.08	0.46	0.36	FGD LCKR	
22	11694	1.08	0.37	0.27	17 Men's Lckr	
23	10849	1.08	0.46	0.31	LOI Sink	
24	7685	2.16	0.48	0.32	14 First Aid Room	
25	11657	1.08	0.42	0.27	LOI Sink	
26	8622	1.62	0.54	0.26	LOI Sink	
27	11017	0.54	0.73	0.45	14 Ladies	
28	7624	3.24	0.47	0.30	Kitchen	
29	10690	1.62	0.46	0.24	LOI Sink	
30	6722	1.08	0.45	0.28	14/15 Women's LR	
Average	8616	1.51	0.50	0.37		
Total	258482	45.38				