

MONTHLY REPORT OF OPERATION

WATER TREATMENT PLANT #2

Report for: Morristown Water Plant # #2
I.D.E.M. Field Rep.: CAROLYN CHAPPELL

For the month of: June


Operator: Gary L. Rogers

Public Water Supply I.D. No.: 5273003

Certification Number: DS110079 & WT130060

| Day | WATER TREATED 1000 gallons | CHEMICAL USED Chlorine | IRON | | FILTERS | | | | Chlorine Residual | | | | Remarks | |
|-----|-------------------------------|---------------------------|------|----------|------------|------------------|------|--------|-------------------|-----------------|-----------|------------|---------------|-------------------------|
| | | | Raw | Finished | Filter Run | Gallons per wash | | | Plant Tap Free | Plant Tap Total | D.S. Free | D.S. Total | | |
| 1 | 279 | 2.9 | 2.29 | 0.00 | 9.6 | 0 | 0 | 0 | 0.97 | 1.02 | 0.76 | 0.82 | | |
| 2 | 270 | 2.8 | 3.78 | 0.03 | 9.1 | 0 | 0 | 0 | 1.02 | 1.09 | 0.65 | 0.66 | | |
| 3 | 319 | 3 | 1.42 | 0.04 | 10.4 | 60 | AUTO | 30,000 | 1.09 | 1.18 | 0.68 | 0.75 | | |
| 4 | 280 | 2.9 | 1.48 | 0.04 | 9.3 | 0 | 0 | 0 | 1.11 | 1.14 | 0.86 | 0.90 | | |
| 5 | 216 | 2.2 | 1.43 | 0.00 | 7.3 | 0 | 0 | 0 | 1.06 | 1.11 | 0.76 | 0.80 | | |
| 6 | 262 | 2.7 | 3.26 | 0.04 | 8.5 | 0 | 0 | 0 | 1.08 | 1.18 | 0.77 | 0.82 | | |
| 7 | 167 | 1.5 | 2.98 | 0.04 | 5.5 | 40 | AUTO | 20,000 | 1.01 | 1.05 | 0.70 | 0.73 | | |
| 8 | 147 | 1.5 | 3.18 | 0.00 | 4.8 | 0 | 0 | 0 | 1.16 | 1.16 | 0.71 | 0.77 | | |
| 9 | 149 | 1.5 | 2.27 | 0.00 | 4.9 | 0 | 0 | 0 | 1.11 | 1.14 | 0.72 | 0.72 | | |
| 10 | 189 | 2.2 | 1.35 | 0.00 | 6.2 | 40 | AUTO | 20,000 | 1.08 | 1.11 | 0.70 | 0.77 | | |
| 11 | 204 | 2.1 | 1.22 | 0.00 | 6.7 | 0 | 0 | 0 | 1.15 | 1.19 | 0.70 | 0.77 | | |
| 12 | 244 | 2.6 | 3.18 | 0.00 | 8.0 | 0 | 0 | 0 | 1.14 | 1.20 | 0.75 | 0.78 | | |
| 13 | 210 | 2 | 2.68 | 0.00 | 7.2 | 0 | 0 | 0 | 1.13 | 1.18 | 0.70 | 0.80 | | |
| 14 | 8 | 0 | 3.08 | 0.00 | 0.2 | 40 | AUTO | 20,000 | 1.13 | 1.23 | 0.72 | 0.80 | | |
| 15 | 274 | 2.8 | 1.95 | 0.00 | 9.0 | 0 | 0 | 0 | 0.96 | 0.99 | 0.75 | 0.84 | | |
| 16 | 329 | 4 | 1.41 | 0.02 | 10.8 | 0 | 0 | 0 | 1.11 | 1.16 | 0.71 | 0.77 | | |
| 17 | 307 | 3.1 | 1.41 | 0.00 | 10.0 | 40 | AUTO | 20,000 | 1.15 | 1.19 | 0.78 | 0.82 | | |
| 18 | 196 | 1.7 | 3.84 | 0.00 | 6.4 | 0 | 0 | 0 | 1.14 | 1.19 | 0.74 | 0.80 | | |
| 19 | 347 | 3.9 | 1.45 | 0.00 | 11.4 | 0 | 0 | 0 | 1.02 | 1.11 | 0.73 | 0.80 | | |
| 20 | 96 | 1.1 | 2.39 | 0.00 | 3.1 | 0 | 0 | 0 | 1.09 | 1.11 | 0.80 | 0.87 | | |
| 21 | 280 | 2.8 | 2.99 | 0.00 | 9.2 | 40 | AUTO | 20,000 | 1.10 | 1.13 | 0.74 | 0.81 | | |
| 22 | 300 | 2.9 | 2.30 | 0.00 | 9.9 | 0 | 0 | 0 | 1.11 | 1.14 | 0.73 | 0.82 | | |
| 23 | 297 | 3.6 | 1.34 | 0.00 | 9.8 | 0 | 0 | 0 | 1.07 | 1.14 | 0.78 | 0.86 | | |
| 24 | 321 | 3.1 | 1.41 | 0.00 | 10.5 | 40 | AUTO | 20,000 | 1.47 | 1.49 | 0.64 | 0.71 | | |
| 25 | 271 | 3.2 | 3.16 | 0.00 | 8.9 | 0 | 0 | 0 | 1.14 | 1.13 | 0.73 | 0.80 | | |
| 26 | 283 | 2.7 | 2.88 | 0.03 | 9.2 | 0 | 0 | 0 | 1.07 | 1.09 | 0.73 | 0.79 | | |
| 27 | 266 | 2.8 | 1.34 | 0.00 | 8.9 | 0 | 0 | 0 | 0.95 | 1.03 | 0.68 | 0.78 | | Monthly Water Treatment |
| 28 | 284 | 3 | 2.62 | 0.00 | 9.3 | 40 | AUTO | 20,000 | 1.10 | 1.12 | 0.65 | 0.73 | Total Gallons | 7,333,000 |
| 29 | 281 | 3.3 | 1.39 | 0.02 | 9.3 | 0 | 0 | 0 | 1.14 | 1.15 | 0.56 | 0.64 | Max. Day | 347,000 |
| 30 | 257 | 3.7 | 1.41 | 0.00 | 8.6 | 0 | 0 | 0 | 1.12 | 1.14 | 0.54 | 0.65 | Min. Day | 8,000 |
| 31 | | | | | | | | | | | | | Avg. Daily | 244,433 |

I certify, under penalty of law, by this signature that this document was prepared by me, or under my direction, and the information submitted is to the best of my knowledge and belief, true, accurate, and complete. I am also aware that there are significant penalties for submitting false information.

Signed: 

Mail To:
Indiana Dept. of Environmental Management
Drinking Water Branch 66-34
100 N. Senate Avenue
Indianapolis, Indiana 46204-2251