

MONTHLY REPORT OF OPERATION

WATER TREATMENT PLANT #3

Report for: Morristown Water Plant # #3
I.D.E.M. Field Rep.: CAROLYN CHAPPELL

For the month of: June

Operator: Gary L. Rogers

Public Water Supply I.D. No.: 5273003

Certification Number: DS110079 & WT130060

Day	WATER TREATED 1000 gallons	CHEMICAL USED Chlorine	IRON		FILTERS				Chlorine Residual				Remarks
			Raw	Finished	Filter Run	Gallons per wash			Plant Tap Free	Plant Tap Total	D.S. Free	D.S. Total	
1	662	6.4	2.23	0.00	22.8	0.0	0.0	0.0	1.11	1.20	0.76	0.82	
2	527	6.2	2.69	0.00	18.0	0.0	0.0	0.0	1.02	1.10	0.65	0.61	
3	623	7	2.03	0.00	23.0	48.0	AUTO	57600.0	1.00	1.04	0.68	0.75	
4	596	6.4	2.22	0.00	19.0	0.0	0.0	0.0	1.19	1.24	0.86	0.90	
5	488	5	2.46	0.00	16.6	0.0	0.0	0.0	1.00	1.04	0.76	0.80	
6	545	5.2	1.75	0.00	17.5	0.0	0.0	0.0	1.00	1.06	0.77	0.82	
7	416	4	2.25	0.00	14.1	0.0	0.0	0.0	1.03	1.08	0.70	0.73	
8	301	3.7	1.57	0.00	10.9	0.0	0.0	0.0	1.05	1.06	0.71	0.77	
9	317	3.2	1.41	0.00	10.1	0.0	0.0	0.0	0.92	1.01	0.72	0.72	
10	392	3.4	2.43	0.00	14.3	48.0	AUTO	57600.0	1.03	1.10	0.70	0.77	
11	366	3.6	2.23	0.00	11.9	0.0	0.0	0.0	0.93	1.02	0.70	0.77	
12	486	5.2	1.82	0.00	18.0	0.0	0.0	0.0	1.05	1.07	0.75	0.78	
13	485	4.8	2.07	0.00	15.6	0.0	0.0	0.0	0.92	1.01	0.70	0.80	
14	696	6.8	1.68	0.00	25.1	0.0	0.0	0.0	1.00	1.06	0.72	0.80	
15	453	4.4	2.08	0.00	14.4	0.0	0.0	0.0	1.04	1.11	0.75	0.84	
16	546	5.6	2.09	0.00	19.3	0.0	0.0	0.0	1.01	1.11	0.71	0.77	
17	724	7.4	2.36	0.00	26.9	48.0	AUTO	57600.0	1.01	1.06	0.78	0.82	
18	641	6.4	2.58	0.00	22.0	0.0	0.0	0.0	1.04	1.06	0.74	0.80	
19	773	7.8	2.31	0.00	28.0	0.0	0.0	0.0	1.19	1.20	0.73	0.80	
20	879	9.2	2.15	0.00	31.0	0.0	0.0	0.0	1.15	1.22	0.80	0.87	
21	699	7	1.88	0.00	23.3	0.0	0.0	0.0	0.94	1.02	0.74	0.81	
22	678	7	1.90	0.00	23.2	0.0	0.0	0.0	1.11	1.15	0.73	0.82	
23	604	5.2	2.25	0.00	20.3	0.0	0.0	0.0	0.89	0.95	0.78	0.86	
24	677	6.4	2.05	0.00	31.3	48.0	AUTO	57600.0	1.07	1.19	0.64	0.71	
25	649	6	2.94	0.00	23.0	0.0	0.0	0.0	0.90	0.96	0.73	0.80	
26	584	5.6	2.30	0.00	19.4	0.0	0.0	0.0	1.11	1.14	0.73	0.79	
27	661	6	2.04	0.03	21.5	0.0	0.0	0.0	0.93	1.00	0.68	0.78	Monthly Water Treatment
28	709	7.8	2.39	0.00	23.6	0.0	0.0	0.0	0.75	0.81	0.65	0.73	Total Gallons 17,144,000
29	452	5.2	2.22	0.00	17.0	0.0	0.0	0.0	1.05	1.15	0.56	0.64	Max. Day 879,000
30	515	6.2	1.81	0.00	16.5	0.0	0.0	0.0	0.66	0.74	0.54	0.65	Min. Day 301,000
31													Avg. Daily 571,467

I certify, under penalty of law, by this signature that this document was prepared by me, or under my direction, and the information submitted is to the best of my knowledge and belief, true, accurate, and complete. I am also aware that there are significant penalties for submitting false information.

Signed: Gary L. Rogers

Mail To:
Indiana Dept. of Environmental Management
Drinking Water Branch 66-34
100 N. Senate Avenue
Indianapolis, Indiana 46204-2251